

DISTRIBUTION REQUESTS TO

BULLETIN, 79-01 B

50-293

E. Jordan 21 copies

IE FILES 1 copy

NRR(Zoltan Rosztoczy) 1 copy

CENTRAL FILES 1 copy

PDR 1 copy

LPDR 2 copies

NSIC 1 copy

TIC 1 copy

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

Q

8011170 408

BOSTON EDISON COMPANY
GENERAL OFFICES 800 BOYLETON STREET
BOSTON, MASSACHUSETTS 02199

A. V. MORISI
MANAGER
NUCLEAR OPERATIONS SUPPORT DEPARTMENT

1980 NOV 14 PM 12:05

US NRC
REGULATORY SERVICES
BRANCH

October 29, 1980

BECo. Ltr. #80-272

Mr. Boyce H. Grier, Director
Office of Inspection and Enforcement
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA. 19406

License No. DPR-35
Docket No. 50-293

- Reference (1) BECo. Ltr. #80-50 to NRC: March 12, 1980
(2) BECo. Ltr. #80-75 to NRC: April 18, 1980
(3) BECo. Ltr. #80-77 to NRC: April 22, 1980
(4) BECo. Ltr. #80-151 to NRC: July 22, 1980

Attachment 1) Pilgrim Unit #1 - IE Bulletin #79-01B-
Final Response

Dear Sir:

By letter dated January 17, 1980, Boston Edison Co. (BECo.) was required by the NRC to address IE Bulletin #79-01B. References (1), (3) and (4) and their attachments provided the requested 45 day response, and our initial and revised 90 day responses. Reference (2) provided our anticipated schedule for subsequent submittals.

In Attachment 1) to this letter Boston Edison Co. provides its final response to IE Bulletin #79-01B for Pilgrim Station as required by your letter dated September 12, 1980. This letter modified the Operating License of Pilgrim Station to make continued operation contingent upon receipt of a full and complete response to Bulletin 79-01B. Since then, the submittal requirements have been modified.

Supplement 2 to Bulletin 79-01B, issued September 30, 1980, expanded the scope and modified the qualification evaluation acceptance criteria. Most significantly, it required that (a) TMI equipment be included in the submittal; (b) TMI radiation source terms (NUREG 0578) be used instead of NUREG-0588/water borne to determine radiation doses applicable to equipment qualification; and (c) equipment designed to function within a short time into an event be qualified to all environmental conditions for at least 1 hour in excess of the time assumed in the accident analysis. Supplement 3 to Bulletin 79-01B, issued October 24, 1980 modified the submittal requirements of the TMI equipment requiring qualification information

BOSTON EDISON COMPANY

Mr. Boyce H. Grier, Director
October 29, 1980
Page 2

for installed items to be submitted by February 1, 1981 and providing required submittal times for future equipment. Boston Edison has considered Supplement 2 in preparing its response to Bulletin 79-01B. Specifically,

- (a) TMI equipment installed to date has been addressed in this submittal. Some future TMI equipment is still in test as installation has been rescheduled for January 1, 1982. Although these items have been listed, evaluation is deferred pending completion of qualification. For those items scheduled for installation, January 1, 1981, qualification evaluations will be completed and results will be submitted by February 1, 1981. Items scheduled for installation by January 1, 1982, will be evaluated during 1981 and information will be submitted in accordance with Supplement 3 (i.e. with pre-implementation review data or by the implementation date).
- (b) Radiation analyses using the NUREG-0578 source terms required by Supplement 2 have not been performed for Pilgrim Station. Gamma radiation exposure due to the DBE-LOCA were tabulated in Pilgrim's FSAR Section 14. Table 14.0.19 using the assumptions given in TID-14844. These source terms are in general agreement with the requirements of NUREG-0588. For equipment located outside containment, in areas containing post - LOCA recirculation flow, conservatism was introduced by using the integrated contact dose on the surface of a 24 inch Schedule 80 pipe for all evaluations.

In response to NUREG-0578, Boston Edison is re-evaluating LOCA radiation levels outside containment. If the results of this work indicate the need for additional conservatism, evaluations under 79-01B will be conducted to the revised levels.

- (c) With respect to the modification to the required operating times, BECo. considers that it has already incorporated this requirement in its evaluations.

We consider the content of our responses to date reflect our commitment to equipment qualification; and, although our effort to date has been significant, it will not cease with the submittal of this response. Boston Edison recognizes the progressive nature of the qualification effort and will continue to meet reporting requirements of 79-01B until the effort is completed.

Very truly yours,

A. Morisi

Commonwealth of Massachusetts)
County of Suffolk)

Then personally appeared before me A. Victor Morisi, who, being duly sworn, did state that he is Manager, Nuclear Operations Support Department, of Boston Edison Company, the applicant herein, and that he is duly authorized to execute and file the submittal contained herein in the name and on behalf of Boston Edison Company and that the statements in said submittal are true to the best of his knowledge and belief.

My Commission expires: 1/17/86

Hanson R. B. Dan

BOSTON EDISON COMPANY

Mr. Boyce H. Grier, Director
October 29, 1980
Page 3

cc: Director
Office of Inspection and Enforcement
Division of Safeguards Inspection
Washington, D. C. 20555

Attachment
to BECo letter 80-272

PILGRIM UNIT #1 - IE BULLETIN 79-01B

FINAL RESPONSE

TABLE OF CONTENTS

SUMMARY AND CONCLUSIONS

BACKGROUND

STATUS

ACTIVITIES TO DATE

OUTSTANDING ITEMS

JUSTIFICATION FOR CONTINUED OPERATION

SCOPE

MASTER LIST

HOSTILE ENVIRONMENTS

ENVIRONMENTAL PROFILE CURVES

EVALUATIONS

QUALIFICATION TEST CURVES

QUALIFICATION SUMMARY REPORTS

- IN CONTAINMENT COMPONENTS

- OUTSIDE CONTAINMENT COMPONENTS

REFERENCES

SUMMARY AND CONCLUSIONS

This document represents Boston Edison's final response to Bulletin 79-01B for Pilgrim Unit #1. As required by the Bulletin, we are providing herein, the final results of qualification evaluations of safety-related electrical equipment exposed to harsh environments. The harsh environments considered are those resulting from LOCA inside containment and HELB outside containment. The included components are those required to help bring the plant to cold shutdown or mitigate the accident. Harsh environments are defined as the pressure, temperature, steam and radiation environments directly resulting from these DBE's and the radiation environment associated with long-term recirculation of fluids outside containment.

Each component was subjected to a systematic review process directed at the NRC mandated criteria (DOR Guidelines and NUREG-0588) ascertaining its qualification. Although the qualification of many items was found to meet the DOR guidelines, some items were found to require additional effort before their qualification could be established. Continued operation of these items has been justified on a generic and individual basis pending completion of their qualification.

Boston Edison has reviewed, as required by 79-01B, Pilgrim Unit 1's equipment against the NRC mandated criteria. Neither the Guidelines nor the NUREG have direct applicability to all Pilgrim's licensing requirements or equipment. As a screen device the Guidelines have considerable

merit. As the design basis to which components must be qualified it is flawed.

Boston Edison believes that Pilgrim's components and systems have been designed, procured, installed, maintained and operated consistent with insuring adequate protection to the health and safety of the public.

BACKGROUND

The NRC issued IE Circular 78-08 dated May 31, 1978 and IE Bulletin 79-01 dated January 17, 1980. Boston Edison, under the direction given by the NRC in its Circular and Bulletin, initiated qualification documentation searches for all safety-related electrical equipment. References (1) thru (6) provided information on work performed under Bulletin 79-01. By letter received January 17, 1980 Boston Edison was required by the NRC to address Bulletin 79-01B. Supplement 1 to 79-01B was issued February 19, 1980 clarifying the requirements of 79-01B. Bulletin 79-01B requested two responses, a 45 day and a 90 day, with information as requested by Enclosure 1 of the Bulletin. Boston Edison provided its response via references (7), (8) and (9).

The NRC, in its September 12, 1980 letter, amended Pilgrim's Station's Operating License to include the following provisions:

"Information which fully and completely responds to the staff's request as specified in I&E Bulletin 79-01B, shall be submitted to the Director, Region I, Office of Inspection and Enforcement, by the Licensee not later than November 1, 1980."

The NRC issued Supplement 2 to 79-01B on September 30, 1980 clarifying the previous submittal and modifying the requirements to incorporate information discussed at regional meetings. The NRC issued Supplement 3 to 79-01B on October 24, 1980 modifying the information provided in Supplement 2.

STATUS

Activities To Date

Boston Edison has invested significant time and money to confirm the qualification of safety-related equipment at Pilgrim Station.

To supplement its own efforts, BECo. has funded the original Pilgrim Station prime contractors, General Electric Company (NSSS Supplier) and Bechtel Power Corporation (Architect Engineer/Constructor) to build a qualification data base. As discussed in Reference (1), this effort was complicated by the elapsed time since Pilgrim's construction. Vendors were required to search their own plus subvendor records of 10 years ago and BECo. was usually required to fund these searches.

In an attempt to expand the data base and enhance the quality of industry submittals, BECo. participated in an EPRI/BWR Owner Group, jointly funding Wyle Laboratories and its subcontractor, NUTECH, to exhaustively search the industry for qualification data and distribute its findings.

BECo. has accumulated significant documentation on the qualification of safety-related equipment installed in Pilgrim and has used this documentation to perform specific evaluations.

These efforts were especially difficult for a plant of Pilgrim's vintage. For example, in addition to those problems previously identified in Reference (1-9), the following additional problems were identified by the BWR Owners Group consultants, Wyle Laboratories and NUTECH:

- 1) Proprietary data - vendors possess data but won't release it or let it be reviewed and summarized. Some will sell info or let NRC view it.

- 2) Vendors have qualified replacement items or newer models. Original equipment is not unqualified but vendor himself never qualified it.
- 3) Vendors shipped records/data to original equipment purchaser and have since lost or retired their own records (Many vendors do not keep records on a permanent basis - 3 years is a common time for record retention).
- 4) Some vendors are uncooperative - eg. Nuclear business is small or they've gotten out of it and they can't be bothered with the trouble and expense required to comply with the nuclear "paper trail."
- 5) Some vendors have disappeared. (Gone out of business or lost their identity during corporate reorganizations).

In spite of these difficulties, Boston Edison and its consultants have been able to retrieve much qualification documentation and determine the qualification status of safety-related components subject to 79-01B. The status of each device has been indicated in the computerized print-outs provided in Section III.

To ensure an independent review of all environmental qualifications evaluations, BECo. has contracted Wyle Laboratories to perform a final independent review and provide summary and evaluation reports to be kept on file at BECo. as part of its qualification records. These reports are listed under supporting documents for the in containment items and can be identified by their Wyle RPT No. 17446 -

Outstanding Items

Radiation -

The NRC, in response to Question 9 of Supplement 1 to 79-01B, advised that it considered NUREG-0578 and NUPEG-0588 to be consistent in their requirements for radiation evaluations. Based on this guidance, BECo used the TID-14844 source terms and distribution methodology presented in Section 14 of Pilgrim's FSAR. This approach is considered to be consistent with the requirements of NUREG-0588, Section 1.4 (1) and Appendix D, for DBA-LOCA. Supplement 2, Question 18 requested new evaluations assuming all source term inventories remain in the coolant. Boston Edison has initiated radiation analyses but has not yet incorporated this requirement into its equipment qualification evaluations. If revised radiation dose values result from the analyses, equipment qualification evaluations will be conducted to the revised values. Our conclusions are not expected to change as a result of this work because of the conservatism already included in our evaluations. For example, we have used the contact dose for a 24 inch pipe containing post-loca fluid for radiation evaluations outside containment.

Generic Evaluations -

Boston Edison has developed, for equipment located outside containment, technical papers addressing the ability of electrical equipment to function in spite of aging, radiation and short-term thermal transients. These papers, discussed in detail in the following section, have been used in the performance of generic qualification evaluations. In some cases, Boston Edison determined

that before a final equipment qualification evaluation could be made, verification of the applicability of these generic evaluations was required. For each item, this determination was reflected in the computer print-outs for evaluations. The component was classified as being justified for continued operation (JCO) or as meeting DOR guidelines except for aging (DOR-A). The outstanding verification effort (eg-Radiation Analysis (RA) and/or Aging Analysis (AA)) was listed under the Qualification Plan section along with its forecast completion date.

Justification for Continued Operation

As the attached computerized summary reports reflects, the qualification of many items has been found to meet the DOR guidelines. For those items requiring additional effort, discrete tasks and target completion dates have been established and reflected in the qualification plan for each item. In the interim, generic qualification evaluations support continued operation for many items. Boston Edison has prepared technical papers addressing the ability of electrical equipment to function in spite of aging, radiation, and short-term thermal transients.

P&CS memo 80-257 entitled "Simplified Methodology for Determining Significance of In-Service Aging and its Effects on Equipment Performance," presents a method to determine if thermal aging is a significant failure mechanism for safety related electrical equipment. Primarily, it uses Arrhenius methodology to infer increased life factors from manufacturer's information on expected life at some temperature, when, the maximum continuous operating temperature is lower.

P&CS Memo 80-186 dated August 18, 1980 entitled "Effects of PBOC Short-term Elevative Ambient Temperatures on the Operating Temperatures of Various Electrical Equipment," justified the use of device specific heat transfer analyses to demonstrate the ability of electrical components to function under the subject thermal effects. Analytical and empirical data were used to demonstrate that a component's thermal capacitance precluded it from experiencing the compartment maximum ambient temperatures. Based on this, specific heat transfer analyses will be performed on those components whose test environment temperature profile does not envelope the compartment ambient temperature profile.

P&CS Memo 80-238 entitled "Radiation Effects on Organic Compounds used in Safety Related Electrical Equipment Located Outside a BWR Primary Containment," establishes the conclusion that for outside containment equipment most of the organic materials, with a few exceptions will perform adequately at integrated doses of 1.0 Megarads gamma and lower. Radiation effects on material properties are identified and discussed. Empirical results from a variety of tests and studies supporting the conclusion are provided as attachments.

From the above discussion it is apparent that although verification of the applicability of the generic evaluations continues to be an outstanding item for some components, each component has been carefully reviewed and it is our judgement that the components will ultimately be found to be qualified. With respect to the outstanding radiation analyses dictated by Supplement 2, it has been demonstrated both in the preceding section and in the Hostile Environment section, that the evaluation conclusions should not be affected by this effort.

Throughout the reporting process Boston Edison has made a firm commitment to the equipment qualification effort and has maintained an approach consistent with other priority activities and available resources. To ensure optimal utilization of resources the following priority levels for equipment in hostile areas were established.

I - Equipment Inside Containment

II - Equipment Outside Containment located in compartments where pipe breaks occur.

III - Equipment Outside Containment located in adjacent compartments which experience reduced effects of these pipe breaks.

This prioritization insured that components were received in an order that recognizing the potential for failure due to environmental hazards.

Open items were relegated to components of lesser importance whenever possible. Edison's review process was supplied to each component within the scope of Bulletin 79-01B.

SCOPE

Please reference Appendix G - Station Nuclear Safety Operational Analysis of Pilgrim Unit #1 FSAR. Appendix G identifies various events (accidents) and the safety systems essential to achieving the required safety actions.

For the purposes of this submittal Event 39 - Pipe Breaks Inside Primary Containment and Event 41 - Pipe Breaks Outside Primary Containment were considered as exposing the required equipment to the most hostile environments. The BWR operating States during which this event was considered are States C, D, E and F.

PIPE BREAK INSIDE CONTAINMENT

In Appendix G for Event 39 - Pipe Break Inside Primary Containment up to and including a DBE-LOCA the following systems are identified as being required:

<u>Appendix G Description</u>	<u>79-01B System Name</u>
- Main Steam Line Isolation Valves	CNTM ISOLATION
- Control Rod Drive System	*
- RHRS (LPCI mode)	RHR
- RHRS (Torus cooling mode)	RHR
- HPCIS	HPCI
- Automatic Depressurization System	ADS
- Core Spray System	CORE SPRAY
- Reactor Protection System	RPS
- Primary Containment and Reactor Vessel Isolaiton	CNTM ISOLATION
- Standy AC Power System	*
- DC Power System	*
- Standby Gas Treatment System	STANDBY GAS TREATMENT
- Incident Detection Circuitry	(Items included in associated systems)
- Reactor Building Closed Cooling	RBCCW
Water	
- Salt Service Water	*
- Main Control Room Environmental	*
Control	
- Reactor Building Isolation Control	1.) SEC. CNTM ISOLATION 2.) STANDBY GAS TREATMENT Post-accident Monitoring
- Torus Water Temperature and Level Indication	SAFETY RELATED DISPLAY
- Equipment Area Cooling System	HVAC ECCS UNIT COOLERS

NOTE: * No components located in containment or in areas outside containment exposed to radiation due to long term core cooling.

PIPE BREAK OUTSIDE CONTAINMENT

In appendix G for Event 41 - Pipe Break outside Primary Containment following systems are identified as being required:

<u>Appendix G Description</u>	<u>79-01B System</u>
- Main Steam Line Isolation Valves	CNTM Isolation
- Control Rod Drive System	CRD Scram System
- RHR (LPCI mode)	RHR
- RHR (Torus cooling mode)	RHR
- HPCIS	HPCI
- Automatic Depressurization System	ADS
- Core Spray System	Core Spray
- Reactor Protection System	RPS
- Primary Containment and Reactor Vessel Isolation	CNTM Isolation
- Standby AC Power System	*
- DC Power System	*
- Incident Detection Circuitry	(Items included in associated systems)
- Reactor Building Closed Cooling	RBCCW
Water	
- Salt Service Water	*
- Main Control Room Environmental	*
Control	
- Torus Water Temperature and Level Indications	Safety Related Display
- Equipment Area Cooling System	HVAC ECCS Unit Coolers

NOTE: * No components located in areas in which pipe breaks occur or in adjacent compartments.

79-01B Item 7.1,a

Safety System Equipment Lists

Enclosed printout #1 provides a listing of components, by system, reviewed under 79-01B. As required, location information is provided using a coded plant symbol. Refer to attached list "Plant Location Code Designations" for description of the codes. (code 1.30 is inside containment all others are outside containment). Several components have been listed in more than one system. In most cases these components have requirements associated with each of these systems. These components will be listed only once on the Component Evaluation List.

II.

Plant Location Code Designations

The following codes are used in the Bulletin 79-01B computer printout to define plant locations.

<u>Code</u>	<u>Building</u>	<u>Elev.</u>	<u>Space Designation</u>
** 1.1	Reactor	(-) 17.6	RHR and Core Spray Pumps Room "A"
** 1.2	Reactor	(-) 17.6	RHR and Core Spray Pumps Room "B"
** 1.3	Reactor	(-) 17.6	HPCI Pump Room
** 1.4	Reactor	(-) 17.6	HPCI Pump Panel and Valve Room
** 1.5	Reactor	(-) 17.6	RCIC Pump Room
** 1.7	Reactor	2-9	RCIC Pump Room Mezzanine
** 1.8	Reactor	2-9	CRD Pump Room Mezzanine
** 1.9	Reactor	23-0	CRD Modules Area - East
** 1.9A	Reactor	23-0	RHR Piping Room
** 1.9C	Reactor	23-0	Drywell Access Room
** 1.10	Reactor	23-0	CRD Modules Area - West
** 1.10A	Reactor	23-0	RCIC Piping Room
** 1.10B	Reactor	23-0	RHR/HPCI Piping Room
** 1.11	Reactor	51.0	Open Area - East Half
** 1.11A	Reactor	51.0	RWCU Hx Ex. & Pump Room
** 1.12	Reactor	51.0	Open Area - West Half
** 1.13 1.13A 1.13B	Reactor	74-3	Fuel Pool Heat Exchanger Area: Reactor Building Closed Cooling Water System
** 1.14	Reactor	74-3	Open Area - North Half
** 1.15	Reactor	91-3	Standby Liquid Control Area
** 1.16 1.16A	Reactor	91-3	Open Area - North Half
** 1.17	Reactor	91-3	Clothing Change and Storage Area

<u>Code</u>	<u>Building</u>	<u>Elev.</u>	<u>Space Designation</u>
** 1.23 1.23A 1.23B	Reactor	51-0	Standby Gas Treatment Filter Rooms
** Steam Tunnel	Reactor	23-0	Steam Tunnel between Turbine Building and Drywell
** Torus Area	Reactor	(-) 17-6	Compartment surrounding Torus
** Various	Reactor	all	Indicates use in numerous areas.
* 1.30	Reactor		Drywell Interior

NOTES:

* Location for Level I equipment (inside containment)

** Location for Level II equipment (outside containment)

PRINTOUT

1

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/180) *** ADS SYSTEM COMPONENTS *** PAGE 1

System	Equipment No	PS1001-104A	PRESSURE SWITCH	M241
Description				
Plant Location		1.1 LOCAL MNTD		
System	Equipment No	PS1001-104B	PRESSURE SWITCH	M241
Description				
Plant Location		1.2 LOCAL MNTD		
System	Equipment No	PS1001-104C	PRESSURE SWITCH	M241
Description				
Plant Location		1.1 LOCAL MNTD		
System	Equipment No	PS1001-104D	PRESSURE SWITCH	M241
Description				
Plant Location		1.2 LOCAL MNTD		
System	Equipment No	PS1001-89A	PRESSURE SWITCH	M241
Description				
Plant Location		1.14 C129B		
System	Equipment No	PS1001-89B	PRESSURE SWITCH	M241
Description				
Plant Location		1.12 C2206		
System	Equipment No	PS1001-89C	PRESSURE SWITCH	M241
Description				
Plant Location		1.14 C129A		
System	Equipment No	PS1001-89D	PRESSURE SWITCH	M241
Description				
Plant Location		1.12 C2206		
System	Equipment No	PS1001-93A	PRESSURE SWITCH	M241
Description				
Plant Location		1.1 LOCAL MNTD		
System	Equipment No	PS1001-93B	PRESSURE SWITCH	M241
Description				
Plant Location		1.2 LOCAL MNTD		
System	Equipment No	PS1001-93C	PRESSURE SWITCH	M241
Description				
Plant Location		1.1 LOCAL MNTD		

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ADS SYSTEM COMPONENTS *** PAGE 2

System ADS
Equipment No PS1001-93D
Description PRESSURE SWITCH M241
Plant Location 1 2 LOCAL MNTD

System ADS
Equipment No PS1451A
Description PRESSURE SWITCH M242
Plant Location 1 1 C2201

System ADS
Equipment No PS1451B
Description PRESSURE SWITCH M242
Plant Location 1 2 C2260

System ADS
Equipment No PS1464A
Description PRESSURE SWITCH M242
Plant Location 1 1 C2201

System ADS
Equipment No PS1464B
Description PRESSURE SWITCH M242
Plant Location 1 2 C2260

System ADS
Equipment No SV203-3A
Description RELIEF VALVE SOLENOID VALVE M252
Plant Location 1 30

System ADS
Equipment No SV203-3B
Description RELIEF VALVE SOLENOID VALVE M252
Plant Location 1 30

System ADS
Equipment No SV203-3C
Description RELIEF VALVE SOLENOID VALVE M252
Plant Location 1 30

System ADS
Equipment No SV203-3D
Description RELIEF VALVE SOLENOID VALVE M252
Plant Location 1 30

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ADS via CORE SPRAY SYSTEM COMPONENTS *** PAGE 3

System ADS via CORE SPRAY
Equipment No LIS263-72A
Description LEVEL INDICATING SWITCH M253
Plant Location 1.11 C2205

System ADS via CORE SPRAY
Equipment No LIS263-72B
Description LEVEL INDICATING SWITCH M253
Plant Location 1.12 C2206

System ADS via CORE SPRAY
Equipment No LIS263-72C
Description LEVEL INDICATING SWITCH M253
Plant Location 1.11 C2205

System ADS via CORE SPRAY
Equipment No LIS263-72D
Description LEVEL INDICATING SWITCH M253
Plant Location 1.12 C2206

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNIM ATMOS CONTROL SYSTEM COMPONENTS *** PAGE 4

System	CNIM ATMOS CONTROL		
Equipment No	P1901b	Description	PRESSURE TRANSMITTER
Description	1.14	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	PT9017	Description	PRESSURE TRANSMITTER
Description	1.12	Plant Location	M-227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	PT9046	Description	PRESSURE TRANSMITTER
Description	1.14	Plant Location	
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5033A	Description	AIR OPERATOR SOLENOID VALVE
Description	1.9C	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5033B	Description	SOLENOID VV FOR AD5033B
Description	1.9	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5033C	Description	AIR OPERATOR SOLENOID VALVE
Description	1.9C	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5035A	Description	AIR OPERATOR SOLENOID VALVE
Description	1.9C	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5035B	Description	AIR OPERATOR SOLENOID VALVE
Description	1.9C	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5036A	Description	AIR OPERATOR SOLENOID VALVE
Description	1.9C	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5036B	Description	AIR OPERATOR SOLENOID VALVE
Description	1.9C	Plant Location	M227
Plant Location			
System	CNIM ATMOS CONTROL		
Equipment No	SV5040A	Description	AIR OPERATOR SOLENOID VALVE
Description	1.10A	Plant Location	M227
Plant Location			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNIM ATMOS CONTROL SYSTEM COMPONENTS *** PAGE 5

System	CNIM ATMOS CONTROL
Equipment No	SV5040B
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5041A
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5041B
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5042A
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5042B
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5043A
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5043B
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5044A
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5044B
Description	AIR OPERATOR SOLENOID VALVE
Plant Location	1 10A
System	CNIM ATMOS CONTROL
Equipment No	SV5065-10
Description	SOLENOID VALVE FOR CONTROL VALVE
Plant Location	1 13B
System	CNIM ATMOS CONTROL
Equipment No	SV5065-11
Description	SOLENOID VALVE FOR CONTROL VALVE
Plant Location	1 10
System	CNIM ATMOS CONTROL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ATMOS CONTROL SYSTEM COMPONENTS *** PAGE 6

Equipment No	SV5065-11A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ATMOS CONTROL
Equipment No	SV5065-12
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5065-13
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5065-13B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ATMOS CONTROL
Equipment No	SV5065-14
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5065-15
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5065-15B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ATMOS CONTROL
Equipment No	SV5065-16
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10A
System	CNTM ATMOS CONTROL
Equipment No	SV5065-17
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.13B
System	CNTM ATMOS CONTROL
Equipment No	SV5065-18
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5065-18A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ATMOS CONTROL
Equipment No	SV5065-19

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ATMOS CONTROL SYSTEM COMPONENTS *** PAGE 7

Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10	1 12
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-20	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-20B	
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER	
Plant Location	TORUS	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-21	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-22	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-22B	
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER	
Plant Location	TORUS	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-23	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10A	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-24	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-25	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-25B	
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER	
Plant Location	TORUS	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-26	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227
Plant Location	1 10	
System	CNTM ATMOS CONTROL	
Equipment No	SV5065-27	
Description	SOLENOID VALVE FOR CONTROL VALVE	M227

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ATMOS CONTROL SYSTEM COMPONENTS *** PAGE 8

Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5065-27B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ATMOS CONTROL
Equipment No	SV5081A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.14
System	CNTM ATMOS CONTROL
Equipment No	SV5081B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.14
System	CNTM ATMOS CONTROL
Equipment No	SV5082A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.14
System	CNTM ATMOS CONTROL
Equipment No	SV5082B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.14
System	CNTM ATMOS CONTROL
Equipment No	SV5083A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5083B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5084A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5084B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.10
System	CNTM ATMOS CONTROL
Equipment No	SV5085A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25
System	CNTM ATMOS CONTROL
Equipment No	SV5085B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ATMOS CONTROL SYSTEM COMPONENTS *** PAGE 9

System	CNTM ATMOS CONTROL
Equipment No	SV5086A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25

System	CNTM ATMOS CONTROL
Equipment No	SV5086B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25

System	CNTM ATMOS CONTROL
Equipment No	SV5087A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25

System	CNTM ATMOS CONTROL
Equipment No	SV5087B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25

System	CNTM ATMOS CONTROL
Equipment No	SV5088A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25

System	CNTM ATMOS CONTROL
Equipment No	SV5088B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
Plant Location	1.25

System	CNTM ATMOS CONTROL
Equipment No	TE5047
Description	TEMPERATURE ELEMENT (RTD) M227
Plant Location	TORUS AREA

System	CNTM ATMOS CONTROL
Equipment No	TE5048
Description	TEMPERATURE ELEMENT M227
Plant Location	TORUS AREA

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM INTEGRITY SYSTEM COMPONENTS *** PAGE 10

System	CNTM INTEGRITY
Equipment No	DPI55040A
Description	DIFFERENTIAL PRESSURE SWITCH M227
Plant Location	1.9 LOCAL MNTD

System	CNTM INTEGRITY
Equipment No	DPI55040B
Description	DIFFERENTIAL PRESSURE SWITCH M227
Plant Location	1.9 LOCAL MNTD

System	CNTM INTEGRITY
Equipment No	G100A
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
Plant Location	1.30 1.9

System	CNTM INTEGRITY
Equipment No	G100B
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
Plant Location	1.30 1.9

System	CNTM INTEGRITY
Equipment No	G100C
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
Plant Location	1.30 1.10

System	CNTM INTEGRITY
Equipment No	G100D
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
Plant Location	1.30 1.10

System	CNTM INTEGRITY
Equipment No	G100E
Description	CONTAINMENT ELECTRICAL PENETRATION LOW VOLTAGE SIGNAL & THERMOCUPLE
Plant Location	1.30 1.9

System	CNTM INTEGRITY
Equipment No	G101A
Description	CONTAINMENT ELECTRICAL PENETRATION 5 KV POWER
Plant Location	1.30 1.9

System	CNTM INTEGRITY
Equipment No	G101B
Description	CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
Plant Location	1.30 1.9

System	CNTM INTEGRITY
Equipment No	G101C
Description	CONTAINMENT ELECTRICAL PENETRATION 5 KV POWER
Plant Location	1.30 1.10

System	CNTM INTEGRITY
Equipment No	G102A
Description	CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
Plant Location	1.30 1.10

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM INTEGRITY SYSTEM COMPONENTS *** PAGE 11

System	CNTM INTEGRITY
Equipment No	G1023
Description	CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G103A
Description	CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
Plant Location	1 30 1 10
System	CNTM INTEGRITY
Equipment No	G103B
Description	CONTAINMENT ELECTRICAL PENETRATION LOW VOLTAGE SIGNAL & THERMOCOUPLE
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G104A
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G104B
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G104C
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G104D
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G104E
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G104F
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
Plant Location	1 30 1 9
System	CNTM INTEGRITY
Equipment No	G104G
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION & TIP SYS
Plant Location	1 30 1 10
System	CNTM INTEGRITY
Equipment No	G104H
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
Plant Location	1 30 1 10
System	CNTM INTEGRITY

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM INTEGRITY SYSTEM COMPONENTS *** PAGE 12

Equipment No	Q104J		
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION & TIP SYS		
Plant Location	1.30	1.10	
System	CNTM INTEGRITY		
Equipment No	Q105A		
Description	CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL		
Plant Location	1.30	1.9	
System	CNTM INTEGRITY		
Equipment No	Q105B		
Description	CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL		
Plant Location	1.30	1.10	
System	CNTM INTEGRITY		
Equipment No	Q106B		
Description	CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL		
Plant Location	1.30	1.9	
System	CNTM INTEGRITY		
Equipment No	Q202A		
Description	CONTAINMENT ELECTRICAL PENETRATION TORUS		
Plant Location	1.30	TORUS AREA	
System	CNTM INTEGRITY		
Equipment No	Q202B		
Description	CONTAINMENT ELECTRICAL PENETRATION TORUS		
Plant Location	1.30	TORUS AREA	
System	CNTM INTEGRITY		
Equipment No	SV5040A		
Description	AIR OPERATOR SOLENOID VALVE M227		
Plant Location	1.10A		
System	CNTM INTEGRITY		
Equipment No	SV5040B		
Description	AIR OPERATOR SOLENOID VALVE M227		
Plant Location	1.10A		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (111/80) *** CNIM ISOLATION SYSTEM COMPONENTS *** PAGE 13

System	CNIM ISOLATION
Equipment No	A0203-1A
Description	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM
Plant Location	1.30
System	CNIM ISOLATION
Equipment No	A0203-1B
Description	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM
Plant Location	1.30
System	CNIM ISOLATION
Equipment No	A0203-1C
Description	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM
Plant Location	1.30
System	CNIM ISOLATION
Equipment No	A0203-1D
Description	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM
Plant Location	1.30
System	CNIM ISOLATION
Equipment No	A0203-2A
Description	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM
Plant Location	STEAM TUNNEL
System	CNIM ISOLATION
Equipment No	A0203-2B
Description	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM
Plant Location	STEAM TUNNEL
System	CNIM ISOLATION
Equipment No	A0203-2C
Description	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM
Plant Location	STEAM TUNNEL
System	CNIM ISOLATION
Equipment No	DPI11243
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH
Plant Location	1.10 LOCAL MNID

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 14

System	CNTM ISOLATION
Equipment No	DPIS1244
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M247
Plant Location	1.10 LOCAL MNTD
System	CNTM ISOLATION
Equipment No	DPIS1360-1A
Description	DIFF PRESSURE IND SWITCH M245
Plant Location	1.7 C2257B
System	CNTM ISOLATION
Equipment No	DPIS1360-1B
Description	DIFF PRESSURE IND SWITCH M245
Plant Location	1.7 C2257B
System	CNTM ISOLATION
Equipment No	DPIS2301-2352
Description	DIFF PRESSURE IND SWITCH M243
Plant Location	1.2 C2257A
System	CNTM ISOLATION
Equipment No	DPIS2301-2353
Description	DIFF PRESSURE IND SWITCH M243
Plant Location	1.2 C2257A
System	CNTM ISOLATION
Equipment No	DPIS261-2A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2B
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2C
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2D
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2E
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2F
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 15

Equipment No	DPIS261-2G
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2H
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2J
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2K
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2L
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2M
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2N
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2P
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2R
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPIS261-2S
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
Plant Location	1.7 C2256
System	CNTM ISOLATION
Equipment No	DPISS040A
Description	DIFFERENTIAL PRESSURE SWITCH M227
Plant Location	1.9 LOCAL MNTD
System	CNTM ISOLATION
Equipment No	DPISS040B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 16

Description		DIFFERENTIAL PRESSURE SWITCH	M227
Plant Location	1.9 LOCAL MNTO		
System	CNTM ISOLATION		
Equipment No	J208		
Description	A0203-1A LIMIT SWITCH JUNCTION BOX		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J209		
Description	A0203-1B LIMIT SWITCH JUNCTION BOX		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J210		
Description	A0203-1C LIMIT SWITCH JUNCTION BOX		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J211		
Description	A0203-1D LIMIT SWITCH JUNCTION BOX		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J216		
Description	JUNCTION BOX AND TERMINAL BLOCKS		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J43		
Description	JUNCTION BOX AND TERMINAL BLOCK		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J44		
Description	JUNCTION BOX AND TERMINAL BLOCK		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J45		
Description	JUNCTION BOX AND TERMINAL BLOCKS		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	J55		
Description	JUNCTION BOX AND TERMINAL BLOCKS		
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	L15263-57A		
Description	LEVEL INDICATING SWITCH		M253
Plant Location	1.11 C2205		
System	CNTM ISOLATION		
Equipment No	L15263-57B		
Description	LEVEL INDICATING SWITCH		M253
Plant Location			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 17

Plant Location	1.11 C2205
System	CNTM ISOLATION
Equipment No	LIS263-58A
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.12 C2206
System	CNTM ISOLATION
Equipment No	LIS263-58B
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.12 C2206
System	CNTM ISOLATION
Equipment No	MO1001-18A
Description	MOTOR OPERATOR 3-N26M4 VALVE M241
Plant Location	1.1
System	CNTM ISOLATION
Equipment No	MO1001-18B
Description	MOTOR OPERATOR 3-N26M4 VALVE M241
Plant Location	1.2
System	CNTM ISOLATION
Equipment No	MO1001-21
Description	MOTOR OPERATOR 4-N26 VALVE M241
Plant Location	1.8
System	CNTM ISOLATION
Equipment No	MO1001-23A
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1.11A
System	CNTM ISOLATION
Equipment No	MO1001-23B
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1.10A
System	CNTM ISOLATION
Equipment No	MO1001-26A
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1.11A
System	CNTM ISOLATION
Equipment No	MO1001-26B
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1.10A
System	CNTM ISOLATION
Equipment No	MO1001-28A
Description	MOTOR OPERATOR 18-N136SP66 VALVE M241
Plant Location	1.9A
System	CNTM ISOLATION
Equipment No	MO1001-28B
Description	MOTOR OPERATOR 18-N136SP66 VALVE M241
Plant Location	1.10B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 18

System	CNTM ISOLATION
Equipment No	MD1001-29A
Description	MOTOR OPERATOR 18-N14SP66M3 VALVE M241
Plant Location	1.9A
System	CNTM ISOLATION
Equipment No	MD1001-29B
Description	MOTOR OPERATOR 18-N14SP66M3 VALVE M241
Plant Location	1.10B
System	CNTM ISOLATION
Equipment No	MD1001-32
Description	MOTOR OPERATOR 4-N26 VALVE M241
Plant Location	1.8
System	CNTM ISOLATION
Equipment No	MD1001-34A
Description	MOTOR OPERATOR 12-N26 VALVE M241
Plant Location	1.1
System	CNTM ISOLATION
Equipment No	MD1001-34B
Description	MOTOR OPERATOR 12-N26 VALVE M241
Plant Location	1.2
System	CNTM ISOLATION
Equipment No	MD1001-36A
Description	MOTOR OPERATOR 12-N139M4 VALVE M241
Plant Location	1.1
System	CNTM ISOLATION
Equipment No	MD1001-36B
Description	MOTOR OPERATOR 12-N139M4 VALVE M241
Plant Location	1.2
System	CNTM ISOLATION
Equipment No	MD1001-37A
Description	MOTOR OPERATOR 6-N139M4 VALVE M241
Plant Location	1.1
System	CNTM ISOLATION
Equipment No	MD1001-37B
Description	MOTOR OPERATOR 6-N139M4 VALVE M241
Plant Location	1.2
System	CNTM ISOLATION
Equipment No	MD1001-47
Description	MOTOR OPERATOR 20-N14M4 VALVE M241
Plant Location	1.9A
System	CNTM ISOLATION
Equipment No	MD1001-50
Description	MOTOR OPERATOR 20-N14M3 VALVE M241
Plant Location	1.30

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 19

System CNTM ISOLATION
Equipment No MO1001-60
Description MOTOR OPERATOR 4-N14M4 VALVE M241
Plant Location 1 13

System CNTM ISOLATION
Equipment No MO1001-63
Description MOTOR OPERATOR 4-N14M3 VALVE M241
Plant Location 1 30

System CNTM ISOLATION
Equipment No MO1001-7A
Description MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location 1 1

System CNTM ISOLATION
Equipment No MO1001-7B
Description MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location 1 2

System CNTM ISOLATION
Equipment No MO1001-7C
Description MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location 1 1

System CNTM ISOLATION
Equipment No MO1001-7D
Description MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location 1 2

System CNTM ISOLATION
Equipment No MO1201-2
Description MOTOR OPERATOR 6-N14M3 VALVE M247
Plant Location 1 30

System CNTM ISOLATION
Equipment No MO1201-5
Description MOTOR OPERATOR 6-N14M3 VALVE M247
Plant Location 1 11A

System CNTM ISOLATION
Equipment No MO1201-80
Description MOTOR OPERATOR 4-N116M3 VALVE M247
Plant Location 1 11A

System CNTM ISOLATION
Equipment No MO1301-16
Description MOTOR OPERATOR N14 VALVES RCIC M245
Plant Location 1 30

System CNTM ISOLATION
Equipment No MO1301-17
Description MOTOR OPERATOR N14 VALVES RCIC M245
Plant Location 1 10A

System CNTM ISOLATION

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 20

Equipment No MO1301-25
Description MOTOR OPERATOR GATE VALVE N29MA M245
Plant Location 1 5

System CNTM ISOLATION
Equipment No MO1301-26
Description MOTOR OPERATOR GATE VALVE 5-29 M245
Plant Location 1 5

System CNTM ISOLATION
Equipment No MO1301-60
Description MOTOR OPERATOR 2-129 VALVES RCIC M245
Plant Location 1 5

System CNTM ISOLATION
Equipment No MO1400-24A
Description MOTOR OPERATOR 1Q - N14SP66 VALVE M242
Plant Location 1 11A

System CNTM ISOLATION
Equipment No MO1400-24B
Description MOTOR OPERATOR 1Q-N14SP66 VALVE M242
Plant Location 1 12

System CNTM ISOLATION
Equipment No MO1400-25A
Description MOTOR OPERATOR 1Q-N14SP66M3 VALVE M242
Plant Location 1 11A

System CNTM ISOLATION
Equipment No MO1400-25B
Description MOTOR OPERATOR 1Q-N14SP66M3 VALVE M242
Plant Location 1 12

System CNTM ISOLATION
Equipment No MO1400-3A
Description MOTOR OPERATOR 18-N29M4 VALVE M242
Plant Location 1 1

System CNTM ISOLATION
Equipment No MO1400-3B
Description MOTOR OPERATOR 18-N29M4 VALVE M242
Plant Location 1 2

System CNTM ISOLATION
Equipment No MO1400-4A
Description MOTOR OPERATOR 6-N26M3 VALVE M242
Plant Location 1 1

System CNTM ISOLATION
Equipment No MO1400-4B
Description MOTOR OPERATOR 6-N26M3 VALVE M242
Plant Location 1 2

System CNTM ISOLATION
Equipment No MO2301-14

79-01B PILGRIM UNIT 1 FINAL RESPONSE (111/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 21

System	Description	Plant Location	MOTOR OPERATOR 4 GLOBE VALVE	H243
System	Equipment No.	Plant Location	CNTM ISOLATION MO2301-35	
System	Equipment No.	Plant Location	MOTOR OPERATOR SUPPRESSION POOL	
System	Description	Plant Location	SUCTION LINE VALVE HPC1	H243
System	Equipment No.	Plant Location	CNTM ISOLATION MO2301-36	
System	Description	Plant Location	MOTOR OPERATOR SUPPRESSION POOL	
System	Equipment No.	Plant Location	SUCTION LINE VALVE HPC1	H243
System	Description	Plant Location	CNTM ISOLATION MO2301-4	
System	Equipment No.	Plant Location	MOTOR OPERATOR N14 VALVES HPC1	H243
System	Description	Plant Location	1 30	
System	Equipment No.	Plant Location	CNTM ISOLATION MO2301-5	
System	Description	Plant Location	MOTOR OPERATOR N14 VALVES HPC1	H243
System	Equipment No.	Plant Location	1 30B	
System	Description	Plant Location	CNTM ISOLATION MO261-1	
System	Equipment No.	Plant Location	MOTOR OPERATOR 3-N14H4 VALVE	H252
System	Description	Plant Location	1 30	
System	Equipment No.	Plant Location	CNTM ISOLATION MO261-2	
System	Description	Plant Location	MOTOR OPERATOR 3-N14H4 VALVE	H252
System	Equipment No.	Plant Location	STEAM TUNNEL	
System	Description	Plant Location	CNTM ISOLATION MO4002	
System	Equipment No.	Plant Location	MOTOR OPERATOR 6-29 GATE VALVE	H215
System	Description	Plant Location	TORUS AREA	
System	Equipment No.	Plant Location	CNTM ISOLATION PS1360-9A	
System	Description	Plant Location	PRESSURE SWITCH	H245
System	Equipment No.	Plant Location	1 7 C2257B	
System	Description	Plant Location	CNTM ISOLATION PS1360-9B	
System	Equipment No.	Plant Location	PRESSURE SWITCH	H245
System	Description	Plant Location	1 7 C2257B	
System	Equipment No.	Plant Location	CNTM ISOLATION PS1360-9D	
System	Description	Plant Location	PRESSURE SWITCH	H245

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 22

Plant Location	1.7	C2257B
System	CNTM ISOLATION	
Equipment No	PS261-23A	
Description	PRESSURE SWITCH	M252
Plant Location	1.8	C2207
System	CNTM ISOLATION	
Equipment No	PS261-23B	
Description	PRESSURE SWITCH	M252
Plant Location	1.8	C2207
System	CNTM ISOLATION	
Equipment No	SV1001-95A	
Description	SOLENOID VALVE FOR AD 1001-95A	M241
Plant Location	1.30	
System	CNTM ISOLATION	
Equipment No	SV1001-95B	
Description	SOLENOID VALVE FOR AD 1001-95B	M241
Plant Location	1.30	
System	CNTM ISOLATION	
Equipment No	SV1301-12	
Description	SOLENOID VALVE FOR AD1301-12	M246
Plant Location	1.5	
System	CNTM ISOLATION	
Equipment No	SV1301-13	
Description	SOV FOR AD1301-13	M246
Plant Location	1.5	
System	CNTM ISOLATION	
Equipment No	SV1301-34	
Description	SOLENOID VALVE FOR AD1301-34	M245
Plant Location	1.5	
System	CNTM ISOLATION	
Equipment No	SV1301-35	
Description	SOV FOR AD1301-35	M245
Plant Location	1.5	
System	CNTM ISOLATION	
Equipment No	SV1400-51A	
Description	SOLENOID VALVE FOR AD1400-51A	M242
Plant Location	1.30	
System	CNTM ISOLATION	
Equipment No	SV1400-51B	
Description	SOLENOID VALVE FOR AD1400-51B	M242
Plant Location	1.30	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 23

System	CNTM ISOLATION		
Equipment No	SV220-44		
Description	SOLENOID VALVE FOR AO 220-44	M252	
Plant Location	1.30		
System	CNTM ISOLATION		
Equipment No	SV220-45		
Description	SOLENOID VALVE FOR AO 220-45	M252	
Plant Location	1.11A		
System	CNTM ISOLATION		
Equipment No	SV2301-29		
Description	SOLENOID VALVE	M243	
Plant Location	1.3		
System	CNTM ISOLATION		
Equipment No	SV2301-30		
Description	SOV FOR AO2301-30	M243	
Plant Location	1.3		
System	CNTM ISOLATION		
Equipment No	SV2301-64		
Description	SOLENOID VALVE	M244	
Plant Location	1.3		
System	CNTM ISOLATION		
Equipment No	SV2301-65		
Description	SOV FOR AO2301-65	M244	
Plant Location	1.3		
System	CNTM ISOLATION		
Equipment No	SV2301-9312		
Description	SOLENOID VALVE FOR AO 9312	M243	
Plant Location	1.3		
System	CNTM ISOLATION		
Equipment No	SV2301-9313		
Description	SOLENOID VALVE FOR AO 9313	M243	
Plant Location	1.3		
System	CNTM ISOLATION		
Equipment No	SV302-20A		
Description	SOLENOID VALVE	M250	
Plant Location	1.8		
System	CNTM ISOLATION		
Equipment No	SV302-20B		
Description	SOLENOID VALVE	M250	
Plant Location	1.8		

74-018 PILGRIM UNIT 1 FINAL RESPONSE (11/8/81) *** CNIM ISOLATION SYSTEM COMPLETENESS *** PAGE 24

System	Equipment No	Description	Plant Location	CNIM ISOLATION
System	Equipment No	Description	Plant Location	SYS033A AIR OPERATOR SOLENOID VALVE 1.9C
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS033B SOLENOID UV FOR AD5033B 1.9
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS033C AIR OPERATOR SOLENOID VALVE 1.9C
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS033A AIR OPERATOR SOLENOID VALVE 1.9C
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS035B AIR OPERATOR SOLENOID VALVE 1.9C
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS036A AIR OPERATOR SOLENOID VALVE 1.9C
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS036B AIR OPERATOR SOLENOID VALVE 1.9C
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS040A AIR OPERATOR SOLENOID VALVE 1.10A
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS040B AIR OPERATOR SOLENOID VALVE 1.10A
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS041A AIR OPERATOR SOLENOID VALVE 1.36A
System	Equipment No	Description	Plant Location	CNIM ISOLATION SYS041B AIR OPERATOR SOLENOID VALVE 1.10A
System				CNIM ISOLATION

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 25

Equipment No SV5042A
 Description AIR OPERATOR SOLENOID VALVE M227
 Plant Location 1 10A

System CNTM ISOLATION

Equipment No SV5042B
 Description AIR OPERATOR SOLENOID VALVE M227
 Plant Location 1 10A

System CNTM ISOLATION

Equipment No SV5043A
 Description AIR OPERATOR SOLENOID VALVE M227
 Plant Location 1 13A

System CNTM ISOLATION

Equipment No SV5043B
 Description AIR OPERATOR SOLENOID VALVE M227
 Plant Location 1 13A

System CNTM ISOLATION

Equipment No SV5044A
 Description AIR OPERATOR SOLENOID VALVE M227
 Plant Location 1 13A

System CNTM ISOLATION

Equipment No SV5044B
 Description AIR OPERATOR SOLENOID VALVE M227
 Plant Location 1 13A

System CNTM ISOLATION

Equipment No SV5065-10
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 Plant Location 1 13B

System CNTM ISOLATION

Equipment No SV5065-11
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 Plant Location 1 10

System CNTM ISOLATION

Equipment No SV5065-11A
 Description CONTROL VALVE FOR H₂/O₂ ANALYZER
 Plant Location TORUS

System CNTM ISOLATION

Equipment No SV5065-12
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 Plant Location 1 10

System CNTM ISOLATION

Equipment No SV5065-13
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 Plant Location 1 10

System CNTM ISOLATION

Equipment No SV5065-13B

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 26

Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ISOLATION
Equipment No	SV5065-14
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ISOLATION
Equipment No	SV5065-15
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ISOLATION
Equipment No	SV5065-15B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ISOLATION
Equipment No	SV5065-16
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10A
System	CNTM ISOLATION
Equipment No	SV5065-17
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.13B
System	CNTM ISOLATION
Equipment No	SV5065-18
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ISOLATION
Equipment No	SV5065-18A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ISOLATION
Equipment No	SV5065-19
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10 1.12
System	CNTM ISOLATION
Equipment No	SV5065-20
Description	SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location	1.10
System	CNTM ISOLATION
Equipment No	SV5065-20B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	TORUS
System	CNTM ISOLATION
Equipment No	SV5065-21
Description	SOLENOID VALVE FOR CONTROL VALVE M227

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 27

Plant Location 1.10

System CNTM ISOLATION
Equipment No SV5065-22
Description SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location 1.10

System CNTM ISOLATION
Equipment No SV5065-22B
Description CONTROL VALVE FOR H2/D2 ANALYZER
Plant Location TORUS

System CNTM ISOLATION
Equipment No SV5065-23
Description SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location 1.10A

System CNTM ISOLATION
Equipment No SV5065-24
Description SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location 1.10

System CNTM ISOLATION
Equipment No SV5065-25
Description SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location 1.10

System CNTM ISOLATION
Equipment No SV5065-25B
Description CONTROL VALVE FOR H2/D2 ANALYZER
Plant Location TORUS

System CNTM ISOLATION
Equipment No SV5065-26
Description SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location 1.10

System CNTM ISOLATION
Equipment No SV5065-27
Description SOLENOID VALVE FOR CONTROL VALVE M227
Plant Location 1.10

System CNTM ISOLATION
Equipment No SV5065-27B
Description CONTROL VALVE FOR H2/D2 ANALYZER
Plant Location TORUS

System CNTM ISOLATION
Equipment No SV7011A
Description AIR OPERATOR SOLENOID VALVE M232
Plant Location TORUS AREA

System CNTM ISOLATION
Equipment No SV7011B
Description AIR OPERATOR SOLENOID VALVE M232
Plant Location TORUS AREA

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 28

System	CNTM ISOLATION
Equipment No	SV7017A
Description	AIR OPERATOR SOLENOID VALVE M232
Plant Location	TORUS AREA
System	CNTM ISOLATION
Equipment No	SV7017B
Description	AIR OPERATOR SOLENOID VALVE M232
Plant Location	TORUS AREA
System	CNTM ISOLATION
Equipment No	TS1291-14C
Description	TEMPERATURE SWITCH M247
Plant Location	1.11 IN HV DUCT FROM BACKWASH RCVR TK ROOM
System	CNTM ISOLATION
Equipment No	TS1291-14D
Description	TEMPERATURE SWITCH M247
Plant Location	1.11 IN HV DUCT FROM BACKWASH RCVR TK ROOM
System	CNTM ISOLATION
Equipment No	TS1291-14E
Description	TEMPERATURE SWITCH M247
Plant Location	1.11 IN HV DUCT FROM RWCU HX ROOM
System	CNTM ISOLATION
Equipment No	TS1291-14F
Description	TEMPERATURE SWITCH M247
Plant Location	1.11 IN HV DUCT FROM RWCU HX ROOM
System	CNTM ISOLATION
Equipment No	TS1291-14G
Description	TEMPERATURE SWITCH M247
Plant Location	1.9A WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1291-14H
Description	TEMPERATURE SWITCH M247
Plant Location	1.9A WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1291-14J
Description	TEMPERATURE SWITCH M247
Plant Location	1.9 IN HV DUCT FROM RHR A VV ROOM
System	CNTM ISOLATION
Equipment No	TS1291-14K
Description	TEMPERATURE SWITCH M247
Plant Location	1.9 IN HV DUCT FROM RHR A VV ROOM
System	CNTM ISOLATION
Equipment No	TS1360-14G
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A WALL MOUNTED

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 29

System	CNTM ISOLATION
Equipment No	TS1360-14D
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1360-15A
Description	TEMPERATURE SWITCH M245
Plant Location	1.5 WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1360-15B
Description	TEMPERATURE SWITCH M245
Plant Location	1.5 WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1360-15C
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION
Equipment No	TS1360-15D
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION
Equipment No	TS1360-16C
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1360-16D
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1360-17A
Description	TEMPERATURE SWITCH M245
Plant Location	1.5 WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1360-17B
Description	TEMPERATURE SWITCH M245
Plant Location	1.5 WALL MOUNTED
System	CNTM ISOLATION
Equipment No	TS1360-17C
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION
Equipment No	TS1360-17D
Description	TEMPERATURE SWITCH M245
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 30

Equipment No	TS2370C
Description	TEMPERATURE SWITCH M243
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM
System	CNTM ISOLATION
Equipment No	TS2370D
Description	TEMPERATURE SWITCH M243
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM
System	CNTM ISOLATION
Equipment No	TS2371A
Description	TEMPERATURE SWITCH M243
Plant Location	1.2 IN HV DUCT FROM HPCI PP ROOM
System	CNTM ISOLATION
Equipment No	TS2371B
Description	TEMPERATURE SWITCH M243
Plant Location	1.2 IN HV DUCT FROM HPCI PP ROOM
System	CNTM ISOLATION
Equipment No	TS2371C
Description	TEMPERATURE SWITCH M243
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION
Equipment No	TS2371D
Description	TEMPERATURE SWITCH M243
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION
Equipment No	TS2372C
Description	TEMPERATURE SWITCH M243
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM
System	CNTM ISOLATION
Equipment No	TS2372D
Description	TEMPERATURE SWITCH M243
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM
System	CNTM ISOLATION
Equipment No	TS2373A
Description	TEMPERATURE SWITCH M243
Plant Location	1.2 IN HV DUCT FROM HPCI PP ROOM
System	CNTM ISOLATION
Equipment No	TS2373B
Description	TEMPERATURE SWITCH M243
Plant Location	1.2 IN DUCT FROM HPCI PP ROOM
System	CNTM ISOLATION
Equipment No	TS2373C
Description	TEMPERATURE SWITCH M243
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION
Equipment No	TS2373D

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 31

Description	TEMPERATURE SWITCH M243
Plant Location	1 10A IN HV DUCT FROM TORUS AREA
System	CNTM ISOLATION
Equipment No	TS261-15A
Description	TEMPERATURE SWITCH M252
Plant Location	1 10A IN HV DUCT FROM STEAM TUNNEL
System	CNTM ISOLATION
Equipment No	TS261-15B
Description	TEMPERATURE SWITCH M252
Plant Location	1 10A IN HV DUCT FROM STEAM TUNNEL
System	CNTM ISOLATION
Equipment No	TS261-15C
Description	TEMPERATURE SWITCH M252
Plant Location	1 10A IN HV DUCT FROM STEAM TUNNEL
System	CNTM ISOLATION
Equipment No	TS261-15D
Description	TEMPERATURE SWITCH M252
Plant Location	1 10A IN HV DUCT FROM STEAM TUNNEL
System	CNTM ISOLATION
Equipment No	TS261-16A
Description	TEMPERATURE SWITCH M252
Plant Location	2 11 IN TURB BLDG HV EXH DUCT
System	CNTM ISOLATION
Equipment No	TS261-16B
Description	TEMPERATURE SWITCH M252
Plant Location	2 11 IN TURB BLDG HV EXH DUCT
System	CNTM ISOLATION
Equipment No	TS261-16C
Description	TEMPERATURE SWITCH M252
Plant Location	2 11 IN TURB BLDG HV EXH DUCT
System	CNTM ISOLATION
Equipment No	TS261-16D
Description	TEMPERATURE SWITCH M252
Plant Location	2 11 IN TURB BLDG HV EXH DUCT

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CORE SPRAY SYSTEM COMPONENTS *** PAGE 32

System	CORE SPRAY
Equipment No	DP1S1459A
Description	DIFFERENTIAL PRESSURE SWITCH M242
Plant Location	1.B LOCAL MNID

System	CORE SPRAY
Equipment No	DP1S1459B
Description	DIFFERENTIAL PRESSURE SWITCH M242
Plant Location	1.B LOCAL MNID

System	CORE SPRAY
Equipment No	FT1461A
Description	FLOW TRANSMITTER
Plant Location	1.L C2201

System	CORE SPRAY
Equipment No	FT1461B
Description	FLOW TRANSMITTER
Plant Location	1.2 C2269

System	CORE SPRAY
Equipment No	LIS263-72A
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.11 C2205

System	CORE SPRAY
Equipment No	LIS263-72B
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.12 C2206

System	CORE SPRAY
Equipment No	LIS263-72C
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.11 C2205

System	CORE SPRAY
Equipment No	LIS263-72D
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.12 C2206

System	CORE SPRAY
Equipment No	M01400-24A
Description	MOTOR OPERATOR 10 - N14SP66 VALVE M242
Plant Location	1.11A

System	CORE SPRAY
Equipment No	M01400-24B
Description	MOTOR OPERATOR 10-N14SP66 VALVE M242
Plant Location	1.12

System	CORE SPRAY
Equipment No	M01400-25A
Description	MOTOR OPERATOR 10-N14SP66M3 VALVE M242
Plant Location	1.11A

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CORE SPRAY SYSTEM COMPONENTS *** PAGE 33

System	CORE SPRAY
Equipment No	MO1400-25B
Description	MOTOR OPERATOR 10-N14SP66M3 VALVE M242
Plant Location	1 12
System	CORE SPRAY
Equipment No	MO1400-3A
Description	MOTOR OPERATOR 18-N29M4 VALVE M242
Plant Location	1 1
System	CORE SPRAY
Equipment No	MO1400-3B
Description	MOTOR OPERATOR 18-N29M4 VALVE M242
Plant Location	1 2
System	CORE SPRAY
Equipment No	MO1400-4A
Description	MOTOR OPERATOR 6-N26M3 VALVE M242
Plant Location	1 1
System	CORE SPRAY
Equipment No	MO1400-4B
Description	MOTOR OPERATOR 6-N26M3 VALVE M242
Plant Location	1 2
System	CORE SPRAY
Equipment No	P215A
Description	CORE SPRAY PUMP M242
Plant Location	1 1
System	CORE SPRAY
Equipment No	P215B
Description	CORE SPRAY PUMP M242
Plant Location	1 2
System	CORE SPRAY
Equipment No	PS1001-90A
Description	PRESSURE SWITCH M241
Plant Location	1 14 C129B
System	CORE SPRAY
Equipment No	PS1001-90B
Description	PRESSURE SWITCH M241
Plant Location	1 12 C2206
System	CORE SPRAY
Equipment No	PS1001-90C
Description	PRESSURE SWITCH M241
Plant Location	1 14 C129A
System	CORE SPRAY
Equipment No	PS1001-90D
Description	PRESSURE SWITCH M241
Plant Location	1 12 C2206
System	CORE SPRAY

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CORE SPRAY SYSTEM COMPONENTS *** PAGE 34

Equipment No PS1451A
Description PRESSURE SWITCH M242
Plant Location 1.1 C2201

System CORE SPRAY
Equipment No PS1451B
Description PRESSURE SWITCH M242
Plant Location 1.2 C2260

System CORE SPRAY
Equipment No PS1464A
Description PRESSURE SWITCH M242
Plant Location 1.1 C2201

System CORE SPRAY
Equipment No PS1464B
Description PRESSURE SWITCH M242
Plant Location 1.2 C2260

System CORE SPRAY
Equipment No PS263-52A
Description PRESSURE SWITCH M253
Plant Location 1.11 C2205

System CORE SPRAY
Equipment No PS263-52B
Description PRESSURE SWITCH M253
Plant Location 1.12 C2206

System CORE SPRAY
Equipment No PS263-53A
Description PRESSURE SWITCH M253
Plant Location 1.11 C2205

System CORE SPRAY
Equipment No PS263-53B
Description PRESSURE SWITCH M253
Plant Location 1.12 C2206

System CORE SPRAY
Equipment No SV1400-51A
Description SOLENOID VALVE FOR AD140051A M242
Plant Location 1.30

System CORE SPRAY
Equipment No SV1400-51B
Description SOLENOID VALVE FOR AD1400-51B M242
Plant Location 1.30

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** CRD SCRAM SYSTEM SYSTEM COMPONENTS *** PAGE 35

System	CRD SCRAM SYSTEM		
Equipment No	LS302-82A	LEVEL SWITCH	M250
Description			
Plant Location	1.9.	LOCAL MNTD	
System	CRD SCRAM SYSTEM		
Equipment No	LS302-82B	LEVEL SWITCH	M250
Description			
Plant Location	1.9	LOCAL MNTD	
System	CRD SCRAM SYSTEM		
Equipment No	LS302-82C	LEVEL SWITCH	M250
Description			
Plant Location	1.9	LOCAL MNTD	
System	CRD SCRAM SYSTEM		
Equipment No	LS302-82D	LEVEL SWITCH	M250
Description			
Plant Location	1.9	LOCAL MNTD	
System	CRD SCRAM SYSTEM		
Equipment No	SO117	SOLENOID VALVE (TYP OF 145)	M250 (919D615)
Description			
Plant Location	1.9	1.10	
System	CRD SCRAM SYSTEM		
Equipment No	SO118	SOLENOID VALVE (TYP OF 145)	M250 (919D615)
Description			
Plant Location	1.9	1.10	
System	CRD SCRAM SYSTEM		
Equipment No	SV302-19A		
Description			
Plant Location	1.8		
System	CRD SCRAM SYSTEM		
Equipment No	SV302-19B		
Description			
Plant Location	1.8		
System	CRD SCRAM SYSTEM		
Equipment No	SV302-20A	SOLENOID VALVE	M250
Description			
Plant Location	1.8		
System	CRD SCRAM SYSTEM		
Equipment No	SV302-20B	SOLENOID VALVE	M250
Description			
Plant Location	1.8		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ELECTRICAL DISTRIBUTION SYSTEM COMPONENTS *** PAGE 36

ELECTRICAL DISTRIBUTION			
System	Equipment No	112 KERITE	600V POWER & CONTROL CABLE
	Description	1/C STRANDED #12	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	112 OKONITE	600V POWER & CONTROL CABLE
	Description	1/C STRANDED #12	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	210 KERITE	600V POWER & CONTROL CABLE
	Description	2/C STRANDED #10	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	212 KERITE	600V POWER & CONTROL CABLE
	Description	2/C STRANDED #12	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	212 OKONITE	600V POWER & CONTROL CABLE
	Description	2/C STRANDED #12	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	312 KERITE	600V POWER & CONTROL CABLE
	Description	3/C STRANDED #12	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	312 OKONITE	600V POWER & CONTROL CABLE
	Description	3/C STRANDED #12	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	410 KERITE	600V POWER & CONTROL CABLE
	Description	4/C STRANDED #10	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	412 KERITE	600V POWER & CONTROL CABLE
	Description	4/C STRANDED #12	
	Plant Location	1.30	VARIOUS
ELECTRICAL DISTRIBUTION			
System	Equipment No	512 KERITE	600V POWER & CONTROL CABLE
	Description	5/C STRANDED #12	
	Plant Location	1.30	VARIOUS

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ELECTRICAL DISTRIBUTION SYSTEM COMPONENTS *** PAGE 37

ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	512 OKONITE 5/C STRANDED #12	B9 OKONITE 600V POWER & CONTROL CABLE
	Description		1. 30 VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	712 KERITE 7/C STRANDED #12	600V POWER & CONTROL CABLE
	Description		1. 30 VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	912 MERITE 9/C STRANDED #12	600V POWER & CONTROL CABLE
	Description		1. 30 VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	A1 OKONITE 1/C STRANDED #000	5KV CABLE
	Description		VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	A1 MERITE 1/C STRANDED #0000	5KV CABLE
	Description		VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	A2 KERITE 1/C STRANDED 350 MCM	5KV CABLE
	Description		VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	A2 OKONITE 1/C STRANDED 350MCM	5KV CABLE
	Description		VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	A3 MERITE 1/C STRANDED 500MCM	5KV CABLE
	Description		VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	A4 MERITE 1/C STRANDED 1250MCM	5KV CABLE
	Description		VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	B1 KERITE 1/C STRANDED 350MCM	600V POWER CABLE
	Description		VARIOUS
Plant Location			
ELECTRICAL DISTRIBUTION			
System	Equipment No	Description	Plant Location
System	Equipment No	B1 MERITE 1/C STRANDED 350MCM	600V POWER CABLE
	Description		VARIOUS
Plant Location			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ELECTRICAL DISTRIBUTION SYSTEM COMPONENTS *** PAGE 38

System	Equipment No	B17	Description	AC MOTOR CONTROL CENTER	Plant Location	E10 1.9
ELECTRICAL DISTRIBUTION						
System	Equipment No	B18	Description	AC MOTOR CONTROL CENTER	Plant Location	E10 1.10
System	Equipment No	B2	Description	ELECTRICAL DISTRIBUTION	Plant Location	
ELECTRICAL DISTRIBUTION						
System	Equipment No	B2	Description	KERITE	Plant Location	
System	Equipment No	B20	Description	1/C STRANDED #0000	Plant Location	600V POWER CABLE VARIOUS
System	Equipment No	B20	Description	AC MOTOR CONTROL CENTER	Plant Location	E10 1.9
System	Equipment No	B2	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	B2	Description	KERITE	Plant Location	
System	Equipment No	B2	Description	1/C STRANDED #00	Plant Location	600V POWER CABLE VARIOUS
System	Equipment No	B3	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	B3	Description	KERITE	Plant Location	
System	Equipment No	B3	Description	1/C STRANDED #0	Plant Location	600V POWER CABLE VARIOUS
System	Equipment No	B4	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	B4	Description	KERITE	Plant Location	
System	Equipment No	B4	Description	1/C STRANDED #0	Plant Location	600V POWER CABLE VARIOUS
System	Equipment No	B5	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	B5	Description	KERITE	Plant Location	
System	Equipment No	B5	Description	1/C STRANDED #4	Plant Location	600V POWER CABLE VARIOUS
System	Equipment No	B6	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	B6	Description	KERITE	Plant Location	
System	Equipment No	B6	Description	3/C STRANDED #6	Plant Location	600V POWER & CONTROL CABLE 1.30 VARIOUS
System	Equipment No	B65	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	B65	Description	OMONLINE	Plant Location	
System	Equipment No	B65	Description	1/C STRANDED #6	Plant Location	600V POWER & CONTROL VARIOUS
System	Equipment No	B7	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	B7	Description	KERITE	Plant Location	
System	Equipment No	B7	Description	3/C STRANDED #10	Plant Location	300V POWER & CONTROL CABLE VARIOUS
System	Equipment No	C12	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	C12	Description	KERITE	Plant Location	
System	Equipment No	C12	Description	1/C STRANDED #12	Plant Location	600V POWER & CONTROL VARIOUS
System	Equipment No	C129A	Description	ELECTRICAL DISTRIBUTION	Plant Location	
System	Equipment No	C129A	Description	OMONLINE	Plant Location	
System	Equipment No	C129A	Description	1/C STRANDED #140	Plant Location	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ELECTRICAL DISTRIBUTION SYSTEM COMPONENTS *** PAGE 39

Description	INSTRUMENT RACK
Plant Location	1.14
System	ELECTRICAL DISTRIBUTION
Equipment No	C1298
Description	INSTRUMENT RACK
Plant Location	1.14
System	ELECTRICAL DISTRIBUTION
Equipment No	C152
Description	SHUTDOWN PANEL
Plant Location	1.9
System	ELECTRICAL DISTRIBUTION
Equipment No	C153
Description	SHUTDOWN PANEL
Plant Location	1.10
System	ELECTRICAL DISTRIBUTION
Equipment No	C154
Description	SHUTDOWN PANEL
Plant Location	1.10
System	ELECTRICAL DISTRIBUTION
Equipment No	C155
Description	SHUTDOWN PANEL
Plant Location	1.10
System	ELECTRICAL DISTRIBUTION
Equipment No	C156
Description	SHUTDOWN PANEL
Plant Location	1.9
System	ELECTRICAL DISTRIBUTION
Equipment No	C157
Description	SHUTDOWN PANEL
Plant Location	1.10
System	ELECTRICAL DISTRIBUTION
Equipment No	C158
Description	SHUTDOWN PANEL
Plant Location	1.10
System	ELECTRICAL DISTRIBUTION
Equipment No	C159
Description	SHUTDOWN PANEL
Plant Location	1.10
System	ELECTRICAL DISTRIBUTION
Equipment No	C163
Description	SHUTDOWN PANEL
Plant Location	1.9
System	ELECTRICAL DISTRIBUTION
Equipment No	C2201
Description	INSTRUMENT RACK

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ELECTRICAL DISTRIBUTION SYSTEM COMPONENTS *** PAGE 40

Plant Location 1.1

System ELECTRICAL DISTRIBUTION
Equipment No C2205
Description INSTRUMENT RACK
Plant Location 1.11

System ELECTRICAL DISTRIBUTION
Equipment No C2206
Description INSTRUMENT RACK
Plant Location 1.12

System ELECTRICAL DISTRIBUTION
Equipment No C2207
Description INSTRUMENT RACK
Plant Location 1.8

System ELECTRICAL DISTRIBUTION
Equipment No C2250
Description INSTRUMENT RACK
Plant Location 1.4

System ELECTRICAL DISTRIBUTION
Equipment No C2251
Description INSTRUMENT RACK
Plant Location 1.9

System ELECTRICAL DISTRIBUTION
Equipment No C2256
Description INSTRUMENT RACK
Plant Location 1.7

System ELECTRICAL DISTRIBUTION
Equipment No C2257A
Description INSTRUMENT RACK
Plant Location 1.2

System ELECTRICAL DISTRIBUTION
Equipment No C2257B
Description INSTRUMENT RACK
Plant Location 1.7

System ELECTRICAL DISTRIBUTION
Equipment No C2260
Description INSTRUMENT RACK
Plant Location 1.2

System ELECTRICAL DISTRIBUTION
Equipment No D7
Description DC MOTOR CONTROL CENTER E13
Plant Location 1.10

System ELECTRICAL DISTRIBUTION
Equipment No D9
Description DC MOTOR CONTROL CENTER E13
Plant Location 1.10

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ELECTRICAL DISTRIBUTION SYSTEM COMPONENTS *** PAGE 41

System	ELECTRICAL DISTRIBUTION		
Equipment No	D9	DC MOTOR CONTROL CENTER	E13
Description			
Plant Location	1.10		
System	ELECTRICAL DISTRIBUTION		
Equipment No	J216	JUNCTION BOX AND TERMINAL BLOCKS	
Description			
Plant Location	1.30		
System	ELECTRICAL DISTRIBUTION		
Equipment No	J43	JUNCTION BOX AND TERMINAL BLOCK	
Description			
Plant Location	1.30		
System	ELECTRICAL DISTRIBUTION		
Equipment No	J44	JUNCTION BOX AND TERMINAL BLOCK	
Description			
Plant Location	1.30		
System	ELECTRICAL DISTRIBUTION		
Equipment No	J55	JUNCTION BOX AND TERMINAL BLOCKS	
Description			
Plant Location	1.30		
System	ELECTRICAL DISTRIBUTION		
Equipment No	J56	JUNCTION BOX AND TERMINAL BLOCKS	
Description			
Plant Location	1.30		
System	ELECTRICAL DISTRIBUTION		
Equipment No	N550	SHUTDOWN PANEL	
Description			
Plant Location	1.10		
System	ELECTRICAL DISTRIBUTION		
Equipment No	O101B	CONTAINMENT ELECTRICAL PENETRATION	
Description		600 VOLT POWER & CONTROL	
Plant Location	1.30	1.9	
System	ELECTRICAL DISTRIBUTION		
Equipment No	O102A	CONTAINMENT ELECTRICAL PENETRATION	
Description		600 VOLT POWER & CONTROL	
Plant Location	1.30	1.10	
System	ELECTRICAL DISTRIBUTION		
Equipment No	O1023	CONTAINMENT ELECTRICAL PENETRATION	
Description		600 VOLT POWER & CONTROL	
Plant Location	1.30	1.9	
System	ELECTRICAL DISTRIBUTION		
Equipment No	O103A	CONTAINMENT ELECTRICAL PENETRATION	
Description		600 VOLT POWER & CONTROL	
Plant Location	1.30	1.10	

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** ELECTRICAL DISTRIBUTION SYSTEM COMPONENTS *** PAGE 42

System	ELECTRICAL DISTRIBUTION		
Equipment No	Q105A	CONTAINMENT ELECTRICAL PENETRATION	600 VOLT POWER & CONTROL
Description	1.30	1.9	
Plant Location			
System	ELECTRICAL DISTRIBUTION		
Equipment No	Q105B	CONTAINMENT ELECTRICAL PENETRATION	600 VOLT POWER & CONTROL
Description	1.30	1.10	
Plant Location			
System	ELECTRICAL DISTRIBUTION		
Equipment No	Q106B	CONTAINMENT ELECTRICAL PENETRATION	600 VOLT POWER & CONTROL
Description	1.30	1.9	
Plant Location			
System	ELECTRICAL DISTRIBUTION		
Equipment No	S1	2/C #16 TWISTED SHIELDED PAIR	
Description		VARIOUS	
Plant Location			
System	ELECTRICAL DISTRIBUTION		
Equipment No	S3	3/C #16 SHIELDED	
Description		VARIOUS	
Plant Location			
System	ELECTRICAL DISTRIBUTION		
Equipment No	S157275	TYPE SIS SWITCHBOARD WIRE	N/A
Description	1.30	VARIOUS	
Plant Location			
System	ELECTRICAL DISTRIBUTION		
Equipment No	S157279	TYPE SIS SWITCHBOARD WIRE	
Description	1.30	VARIOUS	
Plant Location			
System	ELECTRICAL DISTRIBUTION		
Equipment No		SPLICE (600V PENETRATION)	
Description		PENETRATION 600V POWER & CONTROL CABLE SPLICES	
Plant Location	1.30		
System	ELECTRICAL DISTRIBUTION		
Equipment No		SPLICE (SOV)	
Description		SOV 600V CABLE SPLICES	
Plant Location	1.30	VARIOUS	
System	ELECTRICAL DISTRIBUTION		
Equipment No		TERMINATIONS (4 Kv)	
Description		4 KV CABLE SPLICES & MOTOR TERMINATIONS	
Plant Location		VARIOUS	
System	ELECTRICAL DISTRIBUTION		
Equipment No		TERMINATIONS (LESS THAN 4 Kv)	
Description		STANDARD INDUSTRIAL COMPRESSION TYPE TERMINATIONS	
Plant Location	1.30	VARIOUS	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** H₂/O₂ ANALYZER SYSTEM COMPONENTS *** PAGE 43

System	H ₂ /O ₂ ANALYZER
Equipment No	C118
Description	HYDROGEN ANALYZER A M239
Plant Location	1.12
System	H ₂ /O ₂ ANALYZER
Equipment No	C119
Description	HYDROGEN ANALYZER B M239
Plant Location	1.11
System	H ₂ /O ₂ ANALYZER
Equipment No	C172
Description	H2O ₂ ANALYZER
Plant Location	1.14
System	H ₂ /O ₂ ANALYZER
Equipment No	C173
Description	H2O ₂ ANALYZER
Plant Location	1.14
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-14A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.10
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-21A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.10
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-24A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.12
System	H ₂ O ₂ ANALYZER
Equipment No	SV5065-26A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.12
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-31
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.11
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-31B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.14
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-32
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.11

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** H₂/O₂ ANALYZER SYSTEM COMPONENTS *** PAGE 44

System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-33
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.12
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-33A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.13
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-34
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.12
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-35
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.11
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-35B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.14
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-36
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.11
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-37
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.12
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-37A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
Plant Location	1.13
System	H ₂ /O ₂ ANALYZER
Equipment No	SV5065-38
Description	SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location	1.12

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI SYSTEM COMPONENTS *** PAGE 45

System	HPCI
Equipment No	C2303
Description	ENCLOSURES & TERM BLOCKS FOR HPCI TURB CNTRLS
Plant Location	1.3
System	HPCI
Equipment No	CV2301-32
Description	CONTROL VALVE M244
Plant Location	1.3
System	HPCI
Equipment No	CV9068A
Description	SOLENOID VALVE M243
Plant Location	1.3
System	HPCI
Equipment No	CV9068B
Description	SOLENOID VALVE M243
Plant Location	1.3
System	HPCI
Equipment No	DP152301-2352
Description	DIFF PRESSURE IND SWITCH M243
Plant Location	1.2 C2257A
System	HPCI
Equipment No	DP152301-2353
Description	DIFF PRESSURE IND SWITCH M243
Plant Location	1.2 C2257A
System	HPCI
Equipment No	FS2301-2354
Description	FLOW SWITCH M243
Plant Location	1.4 C2250
System	HPCI
Equipment No	FT2358
Description	FLOW TRANSMITTER M243
Plant Location	1.4 C2250
System	HPCI
Equipment No	HPCI TURB CONTROL
Description	EGM CONTROL BOX M244
Plant Location	1.3 C2303
System	HPCI
Equipment No	HPCI TURB CONTROL 1
Description	EGR ACTUATOR ASSEMBLY M244
Plant Location	1.3 C2303
System	HPCI
Equipment No	HPCI TURB CONTROL 2
Description	DROPPING RESISTOR ASSEMBLY M244
Plant Location	1.3 C2303

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI SYSTEM COMPONENTS *** PAGE 46

1	System		HPCI	TURB CONTROL 3				
1	Equipment No			LOW SPEED POTENTIOMETER	M244			
1	Description			1.3	C2303			
1	Plant Location							
1	System		HPCI	TURB CONTROL 4				
1	Equipment No			SPEED SIGNAL CONVERTER	M244			
1	Description			1.3	C2303			
1	Plant Location							
1	System		HPCI	TURB CONTROL 5				
1	Equipment No			MAGNETIC PICK-UP	M244			
1	Description			1.3	TURB SKID			
1	Plant Location							
1	System		HPCI	TURB CONTROL 6				
1	Equipment No			EGR % MAG PK-UP CABLE ASSEMBLIES	M244			
1	Description			1.3	C2303			
1	Plant Location							
1	System		HPCI	TURB CONTROL 7				
1	Equipment No			PRESSURE SWITCH	AUX OIL PMP START	M244		
1	Description			1.3	TURB SKID			
1	Plant Location							
1	System		HPCI	TURB CONTROL 8				
1	Equipment No			REMOTE TRIP SOV	M244			
1	Description			1.3	TURB SKID			
1	Plant Location							
1	System		HPCI	TURB CONTROL 9				
1	Equipment No			STOP VV LIMIT SW	M244			
1	Description			1.3	TURB SKID			
1	Plant Location							
1	System		HPCI	TURB CONTROL 10				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB SKID			
1	Plant Location							
1	System		HPCI	TURB CONTROL 11				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							
1	System		HPCI	TURB CONTROL 12				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							
1	System		HPCI	TURB CONTROL 13				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							
1	System		HPCI	TURB CONTROL 14				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							
1	System		HPCI	TURB CONTROL 15				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							
1	System		HPCI	TURB CONTROL 16				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							
1	System		HPCI	TURB CONTROL 17				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							
1	System		HPCI	TURB CONTROL 18				
1	Equipment No			LEVEL SWITCH	M243			
1	Description			1.3	TURB AREA LOCAL MNTD			
1	Plant Location							

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI SYSTEM COMPONENTS *** PAGE 46

System HPCI
Equipment No HPCI TURB CONTROL 3
Description LOW SPEED POTENTIOMETER M244
Plant Location 1 3 C2303

System HPCI
Equipment No HPCI TURB CONTROL 4
Description SPEED SIGNAL CONVERTER M244
Plant Location 1 3 C2303

System HPCI
Equipment No HPCI TURB CONTROL 5
Description MAGNETIC PICK-UP M244
Plant Location 1 3 TURB SKID

System HPCI
Equipment No HPCI TURB CONTROL 6
Description EGR & MAG PK-UP CABLE ASSEMBLIES M244
Plant Location 1 3 C2303

System HPCI
Equipment No HPCI TURB CONTROL 7
Description REMOTE TRIP SOV M244
Plant Location 1 3 TURB SKID

System HPCI
Equipment No HPCI TURB CONTROL 8
Description PRESSURE SWITCH AUX OIL PMP START M244
Plant Location 1 3 TURB SKID

System HPCI
Equipment No HPCI TURB CONTROL 9
Description STOP VV LIMIT SW M244
Plant Location 1 3 TURB SKID

System HPCI
Equipment No LS2301-2351A
Description LEVEL SWITCH M243
Plant Location TORUS AREA LOCAL MNTD

System HPCI
Equipment No LS2301-2351B
Description LEVEL SWITCH M243
Plant Location TORUS AREA LOCAL MNTD

System HPCI
Equipment No LS2301-2365
Description LEVEL SWITCH M243
Plant Location 1 3 LOCAL MNTD

System HPCI
Equipment No LS2301-2369
Description LEVEL SWITCH M244
Plant Location 1 3 LOCAL MNTD

System HPCI

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI SYSTEM COMPONENTS *** PAGE 47

System	Equipment No	LSB020	LEVEL SWITCH	H244
	Description	1.3	LOCAL MNTR	
	Plant Location			
System	Equipment No	LSP021	LEVEL SWITCH	H244
	Description	1.3	LOCAL MNTR	
	Plant Location			
System	Equipment No	LSP068	LEVEL SWITCH	H243
	Description	1.3	LOCAL MNTR	
	Plant Location			
System	Equipment No	MD2301-10		
	Description	MOTOR OPERATOR	N116 VALVE	HPCI
	Plant Location	1.4		
System	Equipment No	MD2301-14		
	Description	MOTOR OPERATOR	4 GLOBE VALVE	H243
	Plant Location	1.3		
System	Equipment No	MD2301-3		
	Description	MOTOR OPERATOR	N14 VALVES	HPCI
	Plant Location	1.3		
System	Equipment No	MD2301-35		
	Description	MOTOR OPERATOR	SUPPRESSION POOL SUCTION LINE	VALVE
	Plant Location	1.3		
System	Equipment No	MD2301-36		
	Description	MOTOR OPERATOR	SUPPRESSION POOL SUCTION LINE	VALVE
	Plant Location	1.3		
System	Equipment No	MD2301-4		
	Description	MOTOR OPERATOR	N14 VALVES	HPCI
	Plant Location	1.30		
System	Equipment No	MD2301-5		
	Description	MOTOR OPERATOR	N10 VALVES	HPCI
	Plant Location	1.10B		
System	Equipment No	MD2301-8		
	Description	MOTOR OPERATOR	N10 VALVES	HPCI
	Plant Location	1.10A		
System	Equipment No	HPCI		
	Description	MD2301-9		
	Plant Location			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI SYSTEM COMPONENTS *** PAGE 48

Description		MOTOR OPERATOR NO VALVES HPCI	H243
Plant Location	1. 3		
System	HPCI		
Equipment No	PS2301-2368A		
Description	PRESS SWITCH	H244	
Plant Location	1. 4 C2250		
System	HPCI		
Equipment No	PS2301-2368B		
Description	PRESS SWITCH	H244	
Plant Location	1. 4 C2250		
System	HPCI		
Equipment No	PS2301-2389A		
Description	PRESSURE SWITCH	H243	
Plant Location	1. 2 C2257A		
System	HPCI		
Equipment No	PS2301-2389B		
Description	PRESSURE SWITCH	H243	
Plant Location	1. 2 C2257A		
System	HPCI		
Equipment No	PS2301-2389C		
Description	PRESSURE SWITCH	H243	
Plant Location	1. 2 C2257A		
System	HPCI		
Equipment No	PS2301-2389D		
Description	PRESSURE SWITCH	H243	
Plant Location	1. 2 C2257A		
System	HPCI		
Equipment No	PS2360-1		
Description	PRESS SWITCH	H244	
Plant Location	1. 4 C2250		
System	HPCI		
Equipment No	SV2301-29		
Description	SOLENOID VALVE	H243	
Plant Location	1. 3		
System	HPCI		
Equipment No	SV2301-30		
Description	SOV FOR AD2301-30	H243	
Plant Location	1. 3		
System	HPCI		
Equipment No	SV2301-31		
Description	SOV FOR AD2301-31	H243	
Plant Location	1. 3		
System	HPCI		
Equipment No	SV2301-32		
Description			
Plant Location	1. 3		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI SYSTEM COMPONENTS *** PAGE 49

System	HPCI			
Equipment No.	SV2301-64			
Description	SOLENOID VALVE	M244		
Plant Location	1.0			
System	HPCI			
Equipment No.	SV2301-65			
Description	SOV FOR AO2301-65	M244		
Plant Location	1.3			
System	HPCI			
Equipment No.	SV2301-9312			
Description	SOLENOID VALVE FOR AO 9312	M243		
Plant Location	1.3			
System	HPCI			
Equipment No.	SV2301-9313			
Description	SOLENOID VALVE FOR AO 9313	M243		
Plant Location	1.3			
System	HPCI			
Equipment No.	SV2301-94			
Description	SOLENOID VALVE	M243		
Plant Location	STEAM TUNNEL			
System	HPCI			
Equipment No.	TS2370C			
Description	TEMPERATURE SWITCH	M243		
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM			
System	HPCI			
Equipment No.	TS2370D			
Description	TEMPERATURE SWITCH	M243		
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM			
System	HPEI			
Equipment No.	TS2371A			
Description	TEMPERATURE SWITCH	M243		
Plant Location	1.2 IN HV DUCT FROM HPCI PP ROOM			
System	HPCI			
Equipment No.	TS2371B			
Description	TEMPERATURE SWITCH	M243		
Plant Location	1.2 IN HV DUCT FROM HPCI PP ROOM			
System	HPCI			
Equipment No.	TS2371C			
Description	TEMPERATURE SWITCH	M243		
Plant Location	1.10A IN HV DUCT FROM TORUS AREA			
System	HPCI			
Equipment No.	TS2371D			
Description	TEMPERATURE SWITCH	M243		
Plant Location	1.10A IN HV DUCT FROM TORUS AREA			

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI SYSTEM COMPONENTS *** PAGE 50

System	HPCI
Equipment No	TS2372C
Description	TEMPERATURE SWITCH M243
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM
System	HT-1
Equipment No	TS2372D
Description	TEMPERATURE SWITCH M243
Plant Location	1.10 IN HV DUCT FROM HPCI VV ROOM
System	HPCI
Equipment No	TS2373A
Description	TEMPERATURE SWITCH M243
Plant Location	1.2 IN HV DUCT FROM HPCI PP ROOM
System	HPCI
Equipment No	TS2373B
Description	TEMPERATURE SWITCH M243
Plant Location	1.2 IN DUCT FROM HPCI PP ROOM
System	HPCI
Equipment No	TS2373C
Description	TEMPERATURE SWITCH M243
Plant Location	1.10A IN HV DUCT FROM TORUS AREA
System	HPCI
Equipment No	TS2373D
Description	TEMPERATURE SWITCH M243
Plant Location	1.10A IN HV DUCT FROM TORUS AREA

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI via CORE SPRAY SYSTEM COMPONENTS *** PAGE 51

System HPCI via CORE SPRAY
Equipment No PS1001-90A
Description PRESSURE SWITCH M241
Plant Location 1.14 C129B

System HPCI via CORE SPRAY
Equipment No PS1001-90B
Description PRESSURE SWITCH M241
Plant Location 1.12 C2206

System HPCI via CORE SPRAY
Equipment No PS1001-90C
Description PRESSURE SWITCH M241
Plant Location 1.14 C129A

System HPCI via CORE SPRAY
Equipment No PS1001-90D
Description PRESSURE SWITCH M241
Plant Location 1.12 C2206

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HPCI via RHR SYSTEM COMPONENTS *** PAGE 52

System HPCI via RHR
Equipment No LIS263-72A
Description LEVEL INDICATING SWITCH M253
Plant Location 1.11 C2205

System HPCI via RHR
Equipment No LIS263-72B
Description LEVEL INDICATING SWITCH M253
Plant Location 1.12 C2206

System HPCI via RHR
Equipment No LIS263-72C
Description LEVEL INDICATING SWITCH M253
Plant Location 1.11 C2205

System HPCI via RHR
Equipment No LIS263-72D
Description LEVEL INDICATING SWITCH M253
Plant Location 1.12 C2206

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HVAC ECCS UNIT COOLERS SYSTEM COMPONENTS *** PAGE 53

System	HVAC ECCS UNIT COOLERS
Equipment No	C61A
Description	REACTOR BLDG H&V CONTROL PANEL
Plant Location	1.9
System	HVAC ECCS UNIT COOLERS
Equipment No	C61B
Description	REACTOR BUILDING H&V CONTROL PANEL
Plant Location	1.9
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-41
Description	THERMOSTAT M282
Plant Location	1.5
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-42
Description	THERMOSTAT M282
Plant Location	1.5
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-43
Description	THERMOSTAT M282
Plant Location	1.3
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-44
Description	THERMOSTAT M282
Plant Location	1.3
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-45
Description	THERMOSTAT M282
Plant Location	1.1
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-46
Description	THERMOSTAT M282
Plant Location	1.1
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-47
Description	THERMOSTAT M282
Plant Location	1.2
System	HVAC ECCS UNIT COOLERS
Equipment No	TSD-48
Description	THERMOSTAT M282
Plant Location	1.2
System	HVAC ECCS UNIT COOLERS
Equipment No	HAC201A
Description	HPCI UNIT COOLER M215
Plant Location	1.3

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** HVAC ECCS UNIT COOLERS SYSTEM COMPONENTS *** PAGE 54

System HVAC ECCS UNIT COOLERS
Equipment No VAC201B
Description HPIC UNIT COOLER M215
Plant Location 1.3

System HVAC ECCS UNIT COOLERS
Equipment No VAC204A
Description RHR UNIT COOLER M215
Plant Location 1.1

System HVAC ECCS UNIT COOLERS
Equipment No VAC204B
Description RHR UNIT COOLER M215
Plant Location 1.1

System HVAC ECCS UNIT COOLERS
Equipment No VAC204C
Description RHR UNIT COOLER M215
Plant Location 1.2

System HVAC ECCS UNIT COOLERS
Equipment No VAC204D
Description RHR UNIT COOLER M215
Plant Location 1.2

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** POST ACCIDENT SAMPLING SYSTEM COMPONENTS *** PAGE 55

System	POST ACCIDENT SAMPLING
Equipment No	SV5065-63
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1 10
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-64
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1 10
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-65
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-66
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-67
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1 11
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-68
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1 11
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-69
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-70
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-71
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-72
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-73
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1 12

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** POST ACCIDENT SAMPLING SYSTEM COMPONENTS *** PAGE 56

System	POST ACCIDENT SAMPLING
Equipment No	SV5065-74
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1 12
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-75
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-76
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-77
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-78
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-79
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-80
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-81
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-82
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-83
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-84
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	TORUS
System	POST ACCIDENT SAMPLING

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** POST ACCIDENT SAMPLING SYSTEM COMPONENTS *** PAGE 57

Equipment No	SV5065-B5
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1.9
System	POST ACCIDENT SAMPLING
Equipment No	SV5065-B6
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
Plant Location	1.9
System	POST ACCIDENT SAMPLING
Equipment No	T1
Description	HEAT TRACING FOR BWR CNTM GAS MONITORING & POST ACCIDENT SAMPLING SAMPLE LINES
Plant Location	VARIOUS

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RBCCW SYSTEM COMPONENTS *** PAGE 58

System RBCCW
Equipment No M04002
Description MOTOR OPERATOR 6-29 GATE VALVE M215
Plant Location TORUS AREA

System RBCCW
Equipment No M04010A
Description MOTOR OPERATOR 12-29 GATE VALVE M215
Plant Location 1 2

System RBC
Equipment No MC
Description M ? GATE VALVE M215
Plant Location 1

System P
Equipment No MU4000A
Description MOTOR OPERATOR 12-29 GATE VALVE M215
Plant Location 1 1

System RBCCW
Equipment No M04060B
Description MOTOR OPERATOR 12-29 GATE VALVE M215
Plant Location 1.1

System RBCCW
Equipment No SV4044A
Description AIR OPERATOR SOLENOID VALVE M215
Plant Location 1 3

System RBCCW
Equipment No SV4044B
Description AIR OPERATOR SOLENOID VALVE M215
Plant Location 1.3

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 59

System	RHR
Equipment No	DPIS1001-79A
Description	DIFFERENTIAL PRESSURE SWITCH M241
Plant Location	1.1 LOCAL MNTD
System	RHR
Equipment No	DPIS1001-79B
Description	DIFFERENTIAL PRESSURE SWITCH M241
Plant Location	1.2 LOCAL MNTD
System	RHR
Equipment No	DPIS261-12A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.9 C2251
System	RHR
Equipment No	DPIS261-12B
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.9 C2251
System	RHR
Equipment No	DPIS261-12C
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.2 LOCAL MNTD
System	RHR
Equipment No	DPIS261-12D
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.8 LOCAL MNTD
System	RHR
Equipment No	DPIS261-36A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.8 C2207
System	RHR.
Equipment No	DPIS261-36B
Description	DIFF. PRESSURE INDICATOR SWITCH M252
Plant Location	1.8 C2207
System	RHR
Equipment No	DPIS261-37A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.8 C2207
System	RHR
Equipment No	DPIS261-37B
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.8 C2207
System	RHR
Equipment No	DPIS261-38A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
Plant Location	1.8 C2207

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 60

System	RHR			
Equipment No	DP16261-388	DIFFERENTIAL PRESSURE INDICATOR SWITCH	M252	
Description				
Plant Location	1. 8 C2207			
System	RHR			
Equipment No	DP16261-39A	DIFFERENTIAL PRESSURE INDICATOR SWITCH	M252	
Description				
Plant Location	1. 8 C2207			
System	RHR			
Equipment No	DP16261-39B	DIFFERENTIAL PRESSURE INDICATOR SWITCH	M252	
Description				
Plant Location	1. 8 C2207			
System	RHR			
Equipment No	LIS263-72A	LEVEL INDICATING SWITCH	M253	
Description				
Plant Location	1. 11 C2205			
System	RHR			
Equipment No	LIS263-72B	LEVEL INDICATING SWITCH	M253	
Description				
Plant Location	1. 11 C2205			
System	RHR			
Equipment No	LIS263-72C	LEVEL INDICATING SWITCH	M253	
Description				
Plant Location	1. 12 C2206			
System	RHR			
Equipment No	LIS263-72D	LEVEL INDICATING SWITCH	M253	
Description				
Plant Location	1. 12 C2206			
System	RHR			
Equipment No	LJT8263-73A	LEVEL INDICATING TRANS SWITCH	M253	
Description				
Plant Location	1. 9 C2231			
System	RHR			
Equipment No	LIT8263-73B	LEVEL INDICATING TRANS SWITCH	M253	
Description				
Plant Location	1. 10 C2252			
System	RHR			
Equipment No	M01001-16A	MOTOR OPERATOR 18-M139 VALVE	M241	
Description				
Plant Location	1. 1			
System	RHR			
Equipment No	M01001-16B	MOTOR OPERATOR 18-N139 VALVE	M241	
Description				
Plant Location	1. 2			
System	RHR			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 61

Equipment No	M01001-18A
Description	MOTOR OPERATOR 3-N26M4 VALVE M241
Plant Location	1 1
System	RHR
Equipment No	M01001-18B
Description	MOTOR OPERATOR 3-N26M4 VALVE M241
Plant Location	1 2
System	RHR
Equipment No	M01001-21
Description	MOTOR OPERATOR 4-N26 VALVE M241
Plant Location	1 8
System	RHR
Equipment No	M01001-23A
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1 11A
System	RHR
Equipment No	M01001-23B
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1 10A
System	RHR
Equipment No	M01001-26A
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1 11A
System	RHR
Equipment No	M01001-26B
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
Plant Location	1 10A
System	RHR
Equipment No	M01001-28A
Description	MOTOR OPERATOR 18-N136SP66 VALVE M241
Plant Location	1 9A
System	RHR
Equipment No	M01001-28B
Description	MOTOR OPERATOR 18-N136SP66 VALVE M241
Plant Location	1 10B
System	RHR
Equipment No	M01001-29A
Description	MOTOR OPERATOR 18-N14SP66M3 VALVE M241
Plant Location	1 9A
System	RHR
Equipment No	M01001-29B
Description	MOTOR OPERATOR 18-N14SP66M3 VALVE M241
Plant Location	1 10B
System	RHR
Equipment No	M01001-32

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 62

	Description	MOTOR OPERATOR 4-N26 VALVE	H241
	Plant Location	1 8	
System	Equipment No	RHR	
	Description	H01001-34A	
	Plant Location	MOTOR OPERATOR 12-N26 VALVE 1.1	M241
System	Equipment No	RHR	
	Description	MO1001-34B	
	Plant Location	MOTOR OPERATOR 12-N26 VALVE 1.2	M241
System	Equipment No	RHR	
	Description	MO1001-36A	
	Plant Location	MOTOR OPERATOR 12-N139H4 VALVE 1.1	H241
System	Equipment No	RHR	
	Description	MO1001-36B	
	Plant Location	MOTOR OPERATOR 12-N139H4 VALVE 1.2	H241
System	Equipment No	RHR	
	Description	MO1001-37A	
	Plant Location	MOTOR OPERATOR 6-N139H4 VALVE 1.1	H241
System	Equipment No	RHR	
	Description	MO1001-37B	
	Plant Location	MOTOR OPERATOR 6-N139H4 VALVE 1.2	H241
System	Equipment No	RHR	
	Description	MO1001-42A	
	Plant Location	MOTOR OPERATOR 18-N29 VALVE 1.1	M241
System	Equipment No	RHR	
	Description	MO1001-42B	
	Plant Location	MOTOR OPERATOR 18-N29 VALVE 1.2	M241
System	Equipment No	RHR	
	Description	MO1001-43D	
	Plant Location	MOTOR OPERATOR 18-N29 VALVE 1.2	M241
System	Equipment No	RHR	
	Description	MO1001-47	
	Plant Location	MOTOR OPERATOR 20-N14H4 VALVE	H241

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 63

Plant Location	1 9A
System	RHR
Equipment No	MO1001-50
Description	MOTOR OPERATOR 20-N14M3 VALVE M241
Plant Location	1 30
System	RHR
Equipment No	MO1001-60
Description	MOTOR OPERATOR 4-N14M4 VALVE M241
Plant Location	1 13
System	RHR
Equipment No	MO1001-63
Description	MOTOR OPERATOR 4-N14M3 VALVE M241
Plant Location	1 30
System	RHR
Equipment No	MO1001-7A
Description	MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location	1 1
System	RHR
Equipment No	MO1001-7B
Description	MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location	1 2
System	RHR
Equipment No	MO1001-7C
Description	MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location	1 1
System	RHR
Equipment No	MO1001-7D
Description	MOTOR OPERATOR 18-N29M4 VALVE M241
Plant Location	1 2
System	RHR
Equipment No	MO202-5A
Description	MOTOR OPERATOR 28 GATE VALVE M252
Plant Location	1 30
System	RHR
Equipment No	MO202-5B
Description	MOTOR OPERATOR 28 GATE VALVE
Plant Location	1 30
System	RHR
Equipment No	P203A
Description	RHR PUMP M241
Plant Location	1 1
System	RHR
Equipment No	P203B
Description	PUS M24
Plant Location	1 2

POOR ORIGINAL

79-018 P11 GRM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 64

System	RHR	P203C
Equipment No	RHR PUMP	M241
Description		
Plant Location	1.1.	
System	RHR	P203D
Equipment No	RHR PUMP	M241
Description		
Plant Location	1.2	
System	RHR	PS1001-104A
Equipment No	PS1001-104B	
Description	PRESSURE SWITCH	M241
Plant Location	1.1 LOCAL MN1D	
System	RHR	PS1001-104B
Equipment No	PS1001-104C	
Description	PRESSURE SWITCH	M241
Plant Location	1.2 LOCAL MN1D	
System	RHR	PS1001-104C
Equipment No	PS1001-104D	
Description	PRESSURE SWITCH	M241
Plant Location	1.1 LOCAL MN1D	
System	RHR	PS1001-B3A
Equipment No	PS1001-B3B	
Description	PRESSURE SWITCH	M241
Plant Location	1.14 C129A	
System	RHR	PS1001-B3B
Equipment No	PS1001-B3C	
Description	PRESSURE SWITCH	M241
Plant Location	1.14 C129A	
System	RHR	PS1001-B3D
Equipment No	PS1001-B3D	
Description	PRESSURE SWITCH	M241
Plant Location	1.12 C2206	
System	RHR	PS1001-B9A
Equipment No	PS1001-B9A	
Description	PRESSURE SWITCH	M241
Plant Location	1.14 C129B	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 65

System	RHR
Equipment No	PS1001-89B
Description	PRESSURE SWITCH M241
Plant Location	1 12 C2206

System	RHR
Equipment No	PS1001-89C
Description	PRESSURE SWITCH M241
Plant Location	1 14 C129A

System	RHR
Equipment No	PS1001-89D
Description	PRESSURE SWITCH M241
Plant Location	1 12 C2206

System	RHR
Equipment No	PS1001-90A
Description	PRESSURE SWITCH M241
Plant Location	1 14 C129B

System	RHR
Equipment No	PS1001-90B
Description	PRESSURE SWITCH M241
Plant Location	1 12 C2206

System	RHR
Equipment No	PS1001-90C
Description	PRESSURE SWITCH M241
Plant Location	1 14 C129A

System	RHR
Equipment No	PS1001-90D
Description	PRESSURE SWITCH M241
Plant Location	1 12 C2206

System	RHR
Equipment No	PS1001-93A
Description	PRESSURE SWITCH M241
Plant Location	1 1 LOCAL MNTD

System	RHR
Equipment No	PS1001-93B
Description	PRESSURE SWITCH M241
Plant Location	1 2 LOCAL MNTD

System	RHR
Equipment No	PS1001-93C
Description	PRESSURE SWITCH M241
Plant Location	1 1 LOCAL MNTD

System	RHP
Equipment No	PS1001-93B
Description	PRESSURE SWITCH M241
Plant Location	1 2 LOCAL MNTD

System	RHR
--------	-----

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 66

Equipment No	PS261-23A
Description	PRESSURE SWITCH M252
Plant Location	1.8 C2207
System	RHR
Equipment No	PS261-23B
Description	PRESSURE SWITCH M252
Plant Location	1.8 C2207
System	RHR
Equipment No	PS263-49A
Description	PRESSURE SWITCH M253
Plant Location	1.11 C2205
System	RHR
Equipment No	PS263-49B
Description	PRESSURE SWITCH M253
Plant Location	1.12 C2206
System	RHR
Equipment No	PS263-50A
Description	PRESSURE SWITCH M253
Plant Location	1.11 C2205
System	RHR
Equipment No	PS263-50B
Description	PRESSURE SWITCH M253
Plant Location	1.12 C2206
System	RHR
Equipment No	PS263-52A
Description	PRESSURE SWITCH M253
Plant Location	1.11 C2205
System	RHR
Equipment No	PS263-52B
Description	PRESSURE SWITCH M253
Plant Location	1.12 C2206
System	RHR
Equipment No	PS263-53A
Description	PRESSURE SWITCH M253
Plant Location	1.11 C2205
System	RHR
Equipment No	PS263-53B
Description	PRESSURE SWITCH M253
Plant Location	1.12 C2206
System	RHP
Equipment No	SV1001-95A
Description	SOLENOID VALVE FOR AD 1001-95A M241
Plant Location	1.30
System	RHP
Equipment No	SV1001-95B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RHR SYSTEM COMPONENTS *** PAGE 67

Description	Plant Location	SOLENOID VALVE FOR AO 1001-95B M241
	1 30	

79-011B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RPS SYSTEM COMPONENTS *** PAGE 68

System	RPS					
Equipment No	AQ203-1A	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252	(730E 583)		
Description	FIRST ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	1.30					
System	RPS					
Equipment No	AQ203-1B	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252	(730E 583)		
Description	FIRST ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	1.30					
System	RPS					
Equipment No	AQ203-1C	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252	(730E 583)		
Description	FIRST ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	1.30					
System	RPS					
Equipment No	AQ203-1D	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252			
Description	FIRST ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	1.30					
System	RPS					
Equipment No	AQ203-2A	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252			
Description	SECOND ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	STEAM TUNNEL					
System	RPS					
Equipment No	AQ203-2B	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252	(730E 583)		
Description	SECOND ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	STEAM TUNNEL					
System	RPS					
Equipment No	AQ203-2C	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252	(730E 583)		
Description	SECOND ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	STEAM TUNNEL					
System	RPS					
Equipment No	AQ203-2D	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM	M252	(730E 583)		
Description	SECOND ISOLATION VALVE	AIR OPERATOR & VALVE CONTROL SYSTEM				
Plant Location	STEAM TUNNEL					
System	RPS					
Equipment No	C510AH	SCRAM SOL FUSE PANEL				
Description	SCRAM SOL FUSE PANEL					
Plant Location	1.9	1.10				
System	RPS					
Equipment No	J212	J212 LIMIT SWITCH JUNCTION BOX				
Description	J212 LIMIT SWITCH JUNCTION BOX					
Plant Location	1.20					
System	RPS					
Equipment No	J212	J212 LIMIT SWITCH JUNCTION BOX				
Description	J212 LIMIT SWITCH JUNCTION BOX					
Plant Location	1.20					

79-01B PILGRIM UNIT 1 FINL RESPONSE (11/80) *** RPS SYSTEM COMPONENTS *** PAGE 69

System	RPS
Equipment No	J214
Description	A0203-1C LIMIT SWITCH JUNCTION BOX
Plant Location	1 30
System	RPS
Equipment No	J215
Description	A0203-1D LIMIT SWITCH JUNCTION BOX
Plant Location	1 30
System	RPS
Equipment No	LIS263-57A
Description	LEVEL INDICATING SWITCH M253
Plant Location	1 11 C2205
System	RPS
Equipment No	LIS263-57B
Description	LEVEL INDICATING SWITCH M253
Plant Location	1 11 C2205
System	RPS
Equipment No	LIS263-58A
Description	LEVEL INDICATING SWITCH M253
Plant Location	1 12 C2206
System	RPS
Equipment No	LIS263-58B
Description	LEVEL INDICATING SWITCH M253
Plant Location	1 12 C2206
System	RPS
Equipment No	PS263-51A
Description	PRESSURE SWITCH M253
Plant Location	1 11 C2205
System	RPS
Equipment No	PS263-51B
Description	PRESSURE SWITCH M253
Plant Location	1 11 LOCAL MNTD
System	RPS
Equipment No	PS263-51C
Description	PRESSURE SWITCH M253
Plant Location	1 12 C2206
System	RPS
Equipment No	PS263-51D
Description	PRESSURE SWITCH M253
Plant Location	1 12 C2206
System	RPS
Equipment No	PS263-57A
Description	PRESSURE SWITCH M253
Plant Location	1 11 C2205
System	RPS

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RPS SYSTEM COMPONENTS *** PAGE 70

Equipment No	PS263-55B
Description	PRESSURE SWITCH M253
Plant Location	1.11 C2205
System	RPS
Equipment No	PS263-55C
Description	PRESSURE SWITCH M253
Plant Location	1.12 C2206
System	RPS
Equipment No	PS263-55D
Description	PRESSURE SWITCH M253
Plant Location	1.12 C2206
System	RPS
Equipment No	PS503A
Description	PRESSURE SWITCH M207
Plant Location	2.11A LOCAL MNTD
System	RPS
Equipment No	PS503B
Description	PRESSURE SWITCH M207
Plant Location	2.11A LOCAL MNTD
System	RPS
Equipment No	PS503C
Description	PRESSURE SWITCH M207
Plant Location	2.12A LOCAL MNTD
System	RPS
Equipment No	PS503D
Description	PRESSURE SWITCH M207
Plant Location	2.12A LOCAL MNTD
System	RPS
Equipment No	PS504A
Description	PRESSURE SWITCH M203
Plant Location	2.11 LOCAL MNTD
System	RPS
Equipment No	PS504B
Description	PRESSURE SWITCH M203
Plant Location	2.11 LOCAL MNTD
System	RPS
Equipment No	PS504C
Description	PRESSURE SWITCH M203
Plant Location	2.11 LOCAL MNTD
System	RPS
Equipment No	PS504D
Description	PRESSURE SWITCH M203
Plant Location	2.12 LOCAL MNTD
System	RPS
Equipment No	PS512A

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** RPS SYSTEM COMPONENTS *** PAGE 71

Description	PRESSURE SWITCH M241
Plant Location	I 14 C129A
System	RPS
Equipment No	PSS12B
Description	PRESSURE SWITCH M241
Plant Location	I 14 C129B
System	RPS
Equipment No	PSS12C
Description	PRESSURE SWITCH M241
Plant Location	I 12 C2208
System	RPS
Equipment No	PSS12D
Description	PRESSURE SWITCH M241
Plant Location	I 12 C2206

POOR ORIGINAL

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/1/80) *** SAFETY RELATED DISPLAY SYSTEM COMPONENTS *** PAGE 72

System	SAFETY RELATED DISPLAY		
Equipment No	Description	Plant Location	
	GLOBE VALVE AIR OPERATOR	LIMIT SWITCHES	H252
	1.30		
System	SAFETY RELATED DISPLAY		
Equipment No	C118		
Description	HYDROGEN ANALYZER A	M239	
Plant Location	1.12		
System	SAFETY RELATED DISPLAY		
Equipment No	C119		
Description	HYDROGEN ANALYZER B	M239	
Plant Location	1.11		
System	SAFETY RELATED DISPLAY		
Equipment No	C172		
Description	H202 ANALYZER		
Plant Location	1.14		
System	SAFETY RELATED DISPLAY		
Equipment No	C173		
Description	H202 ANALYZER		
Plant Location	1.14		
System	SAFETY RELATED DISPLAY		
Equipment No	DPIB1459A		
Description	DIFFERENTIAL PRESSURE SWITCH	M242	
Plant Location	1.8 LOCAL MNTD		
System	SAFETY RELATED DISPLAY		
Equipment No	DPIB1459B		
Description	DIFFERENTIAL PRESSURE SWITCH	M242	
Plant Location	1.8 LOCAL MNTD		
System	SAFETY RELATED DISPLAY		
Equipment No	DPT1001-604A		
Description	LEVEL TRANSMITTER		
Plant Location	TORUS AREA		
System	SAFETY RELATED DISPLAY		
Equipment No	FT1461A		
Description	FLOW TRANSMITTER		
Plant Location	1.1 C2201		
System	SAFETY RELATED DISPLAY		
Equipment No	FT1461B		
Description	FLOW TRANSMITTER		
Plant Location	1.2 C2269		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** SAFETY RELATED DISPLAY SYSTEM COMPONENTS *** PAGE 73

SAFETY RELATED DISPLAY			
System	Equipment No	FT2358	FLOW TRANSMITTER M243
	Description	1 4	C2250
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	J208	A0203-1A LIMIT SWITCH JUNCTION BOX
	Description	1 30	
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	J209	A0203-1C LIMIT SWITCH JUNCTION BOX
	Description	1 30	
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	J210	A0203-1C LIMIT SWITCH JUNCTION BOX
	Description	1 30	
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	J211	A0203-1D LIMIT SWITCH JUNCTION BOX
	Description	1 30	
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	LITS263-59A	LEVEL TRANSMITTING SWITCH
	Description	1 11	C2205
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	LITS263-59B	LEVEL TRANSMITTING SWITCH
	Description	1 12	C2206
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	LITS263-73A	LEVEL INDICATING TRANS SWITCH M253
	Description	1 9	C2251
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	LITS263-73B	LEVEL INDICATING TRANS SWITCH M253
	Description	1 10	C2252
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	LTS038	LEVEL TRANSMITTER M241
	Description	TURUS AREA LOCAL MNID	
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No	LTS049	LEVEL XMTR M227
	Description	TURUS AREA LOCAL MNID	
	Plant Location		
SAFETY RELATED DISPLAY			
System	Equipment No		
	Description		
	Plant Location		
System			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** SAFETY RELATED DISPLAY SYSTEM COMPONENTS *** PAGE 74

Equipment No	LTE45A
Description	LEVEL TRANSMITTER
Plant Location	1.11 C2205
System	SAFETY RELATED DISPLAY
Equipment No	LT646B
Description	LEVEL TRANSMITTER
Plant Location	1.12 C2206
System	SAFETY RELATED DISPLAY
Equipment No	PT1001-600A
Description	PRESSURE TRANSMITTER
Plant Location	1.13
System	SAFETY RELATED DISPLAY
Equipment No	PT1001-600B
Description	PRESSURE TRANSMITTER
Plant Location	1.14
System	SAFETY RELATED DISPLAY
Equipment No	PT1001-601A
Description	PRESSURE TRANSMITTER
Plant Location	1.14
System	SAFETY RELATED DISPLAY
Equipment No	PT1001-601B
Description	PRESSURE TRANSMITTER
Plant Location	1.14
System	SAFETY RELATED DISPLAY
Equipment No	PT647A
Description	PRESSURE XMTR
Plant Location	1.11 C2205
System	SAFETY RELATED DISPLAY
Equipment No	PT647B
Description	PRESSURE XMTR
Plant Location	1.12 C2206
System	SAFETY RELATED DISPLAY
Equipment No	PT9016
Description	PRESSURE TRANSMITTER M227
Plant Location	1.14
System	SAFETY RELATED DISPLAY
Equipment No	PT9017
Description	PRESSURE TRANSMITTER M227
Plant Location	1.12
System	SAFETY RELATED DISPLAY
Equipment No	PT9045
Description	PRESSURE TRANSMITTER
Plant Location	1.14
System	SAFETY RELATED DISPLAY
Equipment No	PT1001-600A

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** SAFETY RELATED DISPLAY SYSTEM COMPONENTS *** PAGE 75

RADIATION DETECTOR			
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 10	SAFETY RELATED DISPLAY	RE1001-606B
Plant Location		RADIATION DETECTOR	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 10	SAFETY RELATED DISPLAY	RE1001-607A
Plant Location		RADIATION DETECTOR	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	TORUS AREA	SAFETY RELATED DISPLAY	RE1001-607B
Plant Location		RADIATION DETECTOR	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	TORUS AREA	SAFETY RELATED DISPLAY	SV5065-14A
Plant Location		CONTROL VALVE FOR H2/O2 ANALYZER	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	TORUS AREA	SAFETY RELATED DISPLAY	SV5065-14A
Plant Location		CONTROL VALVE FOR H2/O2 ANALYZER	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 10	SAFETY RELATED DISPLAY	SV5065-21A
Plant Location		CONTROL VALVE FOR H2/O2 ANALYZER	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 10	SAFETY RELATED DISPLAY	SV5065-21A
Plant Location		CONTROL VALVE FOR H2/O2 ANALYZER	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 12	SAFETY RELATED DISPLAY	SV5065-24A
Plant Location		CONTROL VALVE FOR H2/O2 ANALYZER	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 12	SAFETY RELATED DISPLAY	SV5065-26A
Plant Location		CONTROL VALVE FOR H2/O2 ANALYZER	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 12	SAFETY RELATED DISPLAY	SV5065-31
Plant Location		SOLENOID VALVE FOR CONTROL VALVE	H239
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 11	SAFETY RELATED DISPLAY	SV5065-31B
Plant Location		CONTROL VALVE FOR H2/O2 ANALYZER	
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 14	SAFETY RELATED DISPLAY	SV5065-32
Plant Location		SOLENOID VALVE FOR CONTROL VALVE	H239
Description	Plant Location	System	Equipment No
RADIATION DETECTOR	1. 11	SAFETY RELATED DISPLAY	SV5065-32
Plant Location		SOLENOID VALVE FOR CONTROL VALVE	H239

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** SAFETY RELATED DISPLAY SYSTEM COMPONENTS *** PAGE 76

Plant Location 1.12

System SAFETY RELATED DISPLAY
Equipment No SV5065-33A
Description CONTROL VALVE FOR H₂/O₂ ANALYZER
Plant Location 1.13

System SAFETY RELATED DISPLAY
Equipment No SV5065-34
Description SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location 1.12

System SAFETY RELATED DISPLAY
Equipment No SV5065-35
Description SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location 1.11

System SAFETY RELATED DISPLAY
Equipment No SV5065-35B
Description CONTROL VALVE FOR H₂/O₂ ANALYZER
Plant Location 1.14

System SAFETY RELATED DISPLAY
Equipment No SV5065-36
Description SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location 1.11

System SAFETY RELATED DISPLAY
Equipment No SV5065-37
Description SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location 1.12

System SAFETY RELATED DISPLAY
Equipment No SV5065-37A
Description CONTROL VALVE FOR H₂/O₂ ANALYZER
Plant Location 1.13

System SAFETY RELATED DISPLAY
Equipment No SV5065-38
Description SOLENOID VALVE FOR CONTROL VALVE M239
Plant Location 1.12

System SAFETY RELATED DISPLAY
Equipment No TE5047
Description TEMPERATURE ELEMENT (RTD) M227
Plant Location TORUS AREA

System SAFETY RELATED DISPLAY
Equipment No TE5048
Description TEMPERATURE ELEMENT M227
Plant Location TORUS AREA

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** SEC CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 77

System	SEC CNTM ISOLATION
Equipment No	LIS263-57A
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.11 C2205
System	SEC CNTM ISOLATION
Equipment No	LIS263-57B
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.11 C2205
System	SEC CNTM ISOLATION
Equipment No	LIS263-58A
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.12 C2206
System	SEC CNTM ISOLATION
Equipment No	LIS263-58B
Description	LEVEL INDICATING SWITCH M253
Plant Location	1.12 C2206
System	SEC CNTM ISOLATION
Equipment No	PS512A
Description	PRESSURE SWITCH M241
Plant Location	1.14 C129A
System	SEC CNTM ISOLATION
Equipment No	PS512B
Description	PRESSURE SWITCH M241
Plant Location	1.14 C129B
System	SEC CNTM ISOLATION
Equipment No	PS512C
Description	PRESSURE SWITCH M241
Plant Location	1.12 C2206
System	SEC CNTM ISOLATION
Equipment No	PS512D
Description	PRESSURE SWITCH M241
Plant Location	1.12 C2206
System	SEC CNTM ISOLATION
Equipment No	SVL43
Description	SOLENOID VALVE FOR AON78A&B M283
Plant Location	1.14A
System	SEC CNTM ISOLATION
Equipment No	SVL44
Description	SOLENOID VALVE FOR AON 79A&B M283
Plant Location	1.14A
System	SEC CNTM ISOLATION
Equipment No	SVL45
Description	SOLENOID VALVE FOR AON 80A&B M283
Plant Location	1.14B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** SEC CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 78

System	SEC CNTM ISOLATION		
Equipment No	SVL46	Description	SOLENOID VALVE FOR AON 81A1B
Plant Location	1-14B		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL47	Description	SOLENOID VALVE FOR AD N82A1B
Plant Location	1-16A		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL48	Description	SOLENOID VALVE FOR AD N83A1B
Plant Location	1-16A		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL49	Description	SOLENOID VALVE FOR AD N90ABCD
Plant Location	1-12		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL51	Description	SOLENOID VALVE FOR AON92A1B
Plant Location	1-23B		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL52	Description	SOLENOID VALVE FOR AON 93A1B
Plant Location	1-23B		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL53	Description	SOLENOID VALVE FOR AON95A1B
Plant Location	1-23A		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL54	Description	SOLENOID VALVE FOR AON 94A1B
Plant Location	1-23A		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL55	Description	SOLENOID VALVE FOR AON96
Plant Location	1-12		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL56	Description	SOLENOID VALVE FOR AON97
Plant Location	1-12		M283
System	SEC CNTM ISOLATION		
Equipment No	SVL71	Description	SOLENOID VALVE FOR AON114
Plant Location	1-10		M283
System	SEC CNTM ISOLATION		

7Q-018 PILGRIM UNIT 1: FVAC RESPONSE (11/80) *** SEC CNTM ISOLATION SYSTEM COMPONENTS *** PAGE 79

System	Equipment No	Description	Plant Location	SEC. CNTM ISOLATION
	SVL72	SOLENOID VALVE FOR AON115	H283	
		1 10		
System	Equipment No	Description	Plant Location	SEC. CNTM ISOLATION
	SVL73	SOLENOID VALVE FOR AON116	H283	
		1 10		
System	Equipment No	Description	Plant Location	SEC. CNTM ISOLATION
	SVL74	SOLENOID VALVE FOR AON117	H2d3	
		1 10		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** STANDBY GAS TREATMENT SYSTEM COMPONENTS *** PAGE 80

System	STANDBY GAS TREATMENT		
Equipment No	C68	STANDBY GAS TREATMENT FILTER UNIT A PANEL A	PANEL A1
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	C68A	STANDBY GAS TREATMENT FILTER UNIT A PANEL A	PANEL A1
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	C68B	STANDBY GAS TREATMENT FILTER UNIT A PANEL A	PANEL A2
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	C69	STANDBY GAS TREATMENT FILTER UNIT B PANEL B	PANEL B1
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	C69A	STANDBY GAS TREATMENT FILTER UNIT B PANEL B	PANEL B1
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	C69B	STANDBY GAS TREATMENT FILTER UNIT B PANEL B	PANEL B2
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	MON109	OUTLET DAMPER FOR VEX210A	M294
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	MON113	OUTLET DAMPER FOR VEX210B	M294
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	PS8135	PRESSURE SWITCH FAN CONTROL Ckt	M294
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	PS8136	PRESSURE SWITCH FAN CONTROL Ckt	M294
Description	1.23		
Plant Location			
System	STANDBY GAS TREATMENT		
Equipment No	S79007	SOLENOID VALVE SPRINKLER SOV (S.G.T.S.)	M294
Description	1.23		
Plant Location			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/1/80) *** STANDBY GAS TREATMENT SYSTEM COMPONENTS *** PAGE 81

STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SV9008	SOLENOID VALVE SPRINKLER SOV (S.Q.T.S.)	M294
Equipment No		SOLENOID VALVE	
Description		SPRINKLER SOV (S.Q.T.S.)	
Plant Location	1.23		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL43	SOLENOID VALVE FOR ADN78A/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR ADN78A/B	
Plant Location	1.14A		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL44	SOLENOID VALVE FOR ADN79A/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR ADN79A/B	
Plant Location	1.14A		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL45	SOLENOID VALVE FOR ADN BOA/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR ADN BOA/B	
Plant Location	1.14B		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL46	SOLENOID VALVE FOR ADN BOA/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR ADN BOA/B	
Plant Location	1.14B		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL47	SOLENOID VALVE FOR AD NB2A/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR AD NB2A/B	
Plant Location	1.16A		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL48	SOLENOID VALVE FOR AD NB3A/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR AD NB3A/B	
Plant Location	1.16A		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL49	SOLENOID VALVE FOR AD N90ABCD	M283
Equipment No		SOLENOID VALVE	
Description		FOR AD N90ABCD	
Plant Location	1.12		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL50	SOLENOID VALVE FOR AD N91ABCD	M283
Equipment No		SOLENOID VALVE	
Description		FOR AD N91ABCD	
Plant Location	1.12		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL51	SOLENOID VALVE FOR ADN92A/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR ADN92A/B	
Plant Location	1.23B		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location
System	SVL52	SOLENOID VALVE FOR ADN 93A/B	M283
Equipment No		SOLENOID VALVE	
Description		FOR ADN 93A/B	
Plant Location	1.23B		
STANDBY GAS TREATMENT			
System	Equipment No	Description	Plant Location

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** STANDBY GAS TREATMENT SYSTEM COMPONENTS *** PAGE 82

System	Equipment No	SVL53
Plant Location	Description	SOLENOID VALVE FOR AON7SA/B
	Plant Location	1. 23A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL54
Plant Location	Description	SOLENOID VALVE FOR AON 94A/B
	Plant Location	1. 23A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL55
Plant Location	Description	SOLENOID VALVE FOR AON96
	Plant Location	1. 12
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL56
Plant Location	Description	SOLENOID VALVE FOR AON97
	Plant Location	1. 12
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL57
Plant Location	Description	SOLENOID VALVE FOR AON98
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL58
Plant Location	Description	SOLENOID VALVE FOR AON99
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL59
Plant Location	Description	SOLENOID VALVE FOR AON101
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL60
Plant Location	Description	SOLENOID VALVE FOR AON102
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL61
Plant Location	Description	SOLENOID VALVE FOR AON103
	Plant Location	1. 23
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL62
Plant Location	Description	SOLENOID VALVE FOR AON104
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL63
Plant Location	Description	SOLENOID VALVE FOR AON105
	Plant Location	1. 23
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL64
Plant Location	Description	SOLENOID VALVE FOR AON106
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL65
Plant Location	Description	SOLENOID VALVE FOR AON107
	Plant Location	1. 23
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL66
Plant Location	Description	SOLENOID VALVE FOR AON108
	Plant Location	1. 23
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL67
Plant Location	Description	SOLENOID VALVE FOR AON109
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL68
Plant Location	Description	SOLENOID VALVE FOR AON110
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL69
Plant Location	Description	SOLENOID VALVE FOR AON111
	Plant Location	1. 10A
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL70
Plant Location	Description	SOLENOID VALVE FOR AON112
	Plant Location	1. 23
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL71
Plant Location	Description	SOLENOID VALVE FOR AON114
	Plant Location	1. 10
System	Equipment No	M2B3
Plant Location	Description	STANDBY GAS TREATMENT
System	Equipment No	SVL72
Plant Location	Description	SOLENOID VALVE FOR AON115
	Plant Location	1. 10

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) *** STANDBY GAS TREATMENT SYSTEM COMPONENTS *** PAGE 83

Description	SOLENOID VALVE FOR AON115 M283
Plant Location	1.10
System	STANDBY GAS TREATMENT
Equipment No	SVL73
Description	SOLENOID VALVE FOR AON116 M283
Plant Location	1.10
System	STANDBY GAS TREATMENT
Equipment No	SVL74
Description	SOLENOID VALVE FOR AON117 M283
Plant Location	1.10
System	STANDBY GAS TREATMENT
Equipment No	SVL77
Description	SOLENOID VALVE FOR AON 135
Plant Location	1.23
System	STANDBY GAS TREATMENT
Equipment No	SVL78
Description	SOLENOID VALVE FOR AON136
Plant Location	1.23
System	STANDBY GAS TREATMENT
Equipment No	SVL79
Description	SOLENOID VALVE FOR AON 100
Plant Location	1.10A
System	STANDBY GAS TREATMENT
Equipment No	VEX210A
Description	EXHAUST FAN
Plant Location	1.23
System	STANDBY GAS TREATMENT
Equipment No	VEX210B
Description	EXHAUST FAN
Plant Location	1.23
System	STANDBY GAS TREATMENT
Equipment No	VGTF201A
Description	STANDBY GAS TREATMENT FILTER UNIT A
Plant Location	1.23
System	STANDBY GAS TREATMENT
Equipment No	VGTF201B
Description	STANDBY GAS TREATMENT FILTER UNIT B
Plant Location	1.23

HOSTILE ENVIRONMENTS - EVENT 39

For Event 39 the inside containment environmental profiles developed in the FSAR considered 2 limiting cases. 1) Environment due to DBE-LOCA and 2) Environments due to the envelope of smaller size breaks. The Drywell Pressure, Temperature, time curves for both cases are shown as Service Profiles (enclosed) 1a) (Reference FSAR Figures 14.0-31 & 32) and 1b) (Reference FSAR Amendment 20 Response to comment 5.2.1 Figures 5.2.1.2 thru 5.2.1.4). Gamma radiation exposure due to the DBE-LOCA using the assumptions given in TID-14844 were developed and are presented as FSAR Table 14.0.19 - enclosed. The fission product source terms postulated in TID-14844 are conservative considering that the core standby cooling systems are designed to protect against such gross fission product releases. Equipment capabilities were reviewed using these TID-14844 gamma dose levels. For cable, wire, and splices not contained within protective enclosures evaluations were conducted assuming a total integrated dose (beta and gamma) of 2×10^8 Rads.

No hostile environments (temperature, pressure, humidity) due to DBE-LOCA inside containment are experienced by safety related electrical equipment outside primary containment. Radiation levels due to LOCA at electrical equipment locations in the Reactor Building are significantly below the threshold values for most plastics, elastomers and insulating compounds. The integrated TID-14844 doses for a compartment containing a core spray pump and associated piping are given in Table 14.0.19 as 7.1×10^3 Rads. Based on these considerations, Reactor Building areas would not experience hostile environment due to Event 39. For the purposes of this evaluation equipment located in Reactor Building areas containing post-LOCA recirculation flow have been reviewed using the integrated contact dose for the surface of a 24 inch Schedule 80 pipe (Service Profile 2a). Unless otherwise indicated, the considered "Required" dose included radiation received during normal operation.

In response to NUREG-0578 Boston Edison is re-evaluating LOCA Radiation levels outside containment. If the results of this work indicate that the Table 14.0.19 levels are inappropriate, evaluations under 79-01B will be conducted to the revised levels.

HOSTILE ENVIRONMENTS - EVENT 41

The environmental effects of PBOC are considerably less severe than those generated by DBE-LOCA. The principal effects involve high humidity and short-term elevated temperatures. Radiation effects to electrical equipment are insignificant as are the effects of the short-term pressurizations.

For Event 41, no abnormal environments are experienced inside containment or in the Control Room areas. Effects on other plant areas were formally investigated and presented as Amendment 34 to Pilgrim#1 FSAR. The analysis as developed in that section was primarily concerned with structural and piping system capabilities and the effects of compartment pressurization, jet impingement and pipe whip. The temperature profiles developed by the analysis were extremely conservative particularly for areas removed from the actual breaks.

Those pipe breaks outside containment which create hostile environments are breaks in the Main Steam lines, HPCI Turbine Steam Lines, RCIC Turbine Steam Lines and RWCU System Piping. Closure of the MSIV's due to a steam line break will generate a reactor trip.

For breaks in the main steam system termination of blowdown will occur within 5.5 seconds. The maximum duration of blowdown for all other PBOC cases considered is less than 26 seconds. The arrangement of electrical equipment is such that, in general, only electrical equipment associated with the system within which the break occurs is located in break compartments. Because the affected system is disabled due to the hypothesized pipe break this equipment need not function.

For the other plant areas affected by these breaks the abnormal environments are of shorter duration and substantially lower temperatures. The short term abnormal environments experienced in these less affected areas are considered no more severe than those found in many areas of conventional power plants and industrial plants where similar devices have satisfactorily performed.

The inherent ability of these devices to tolerate short term transients can be established by recognizing that their active intervals are insulated from such short term effects by their enclosures and the conduit systems which interface with them. The capability of enclosures to provide such a level of protection has been well known. The NRC in NUREG-0458, "Short Term Assessment of the Environmental Qualification of Safety Related Electrical Equipment of SEP Operating Reactors", and in various licensing submittals has recognized this capability and acceptably reviewed equipment qualifications based on models which predicted the devices response to such short time events.

As the nuclear industry's experience in equipment qualifications has progressed, the emphasis on the demonstration of qualification has further shifted to type testing. Since that time, a significant amount of testing has been conducted on devices generically similar to those used at Pilgrim #1. The successful completion of these tests demonstrated the inherent ability of such devices to function during short term elevated temperatures and substantiates the engineering analysis previously conducted which predicted their acceptability.

The use of equipment at Pilgrim #1 identical to the type supplied to other BWR's by GE and the specification of generically similar equipment to that used throughout the industry for Balance of Plant equipment insures a capability consistent with other plants.

Boston Edison is proceeding with searches and evaluations of recent qualification testing applicable to Pilgrim #1 equipment exposed to PBOC environments. When documentation cannot be found which is applicable to the equipment at Pilgrim, scheduled replacement with type tested units will occur. In addition we have completed developing realistic environmental profiles for all plant areas affected by PBOC. The profiles are attached. These PBOC environmental profiles were developed using Bechtel Corporation's latest version of "FLUD". FLUD is one-dimensional computer code designed to handle problems dealing with gas flows between interconnected compartments. Basic equations of mass and energy conservation are used along with quasi-steady state flow equations to calculate the transfer of mass and energy among the various compartments that comprise the system. Long term compartment cooling is achieved by considering heat-transfer into compartment walls using appropriate heat-transfer mechanisms.

POOR ORIGINAL

Table 14.0.19
DOSE RATES FOR VARIOUS EQUIPMENT OR LOCATIONS BASED ON
TID-14844 FISSION PRODUCT RELEASE ASSUMPTIONS

Location or Equipment	Max Dose Rate (R/Hr)	12 Hours	Integrated Dose (Rad) For		
			3 Days	30 Days	180 Days
Surface 24 in. in 80-pipe	1.1×10^4	5.9×10^4	2.0×10^5	4.4×10^5	6.2×10^5
Interior Surface wall	7.8×10^3	2.8×10^4	9.4×10^4	1.8×10^5	2.6×10^5
Floor of Corner Comp. Containing Spray Pump Seals	2.6×10^4	1.0×10^5	1.0×10^5	3.0×10^5	7.1×10^5
Pump Seals	1.1×10^4	5.9×10^4	2.0×10^5	4.4×10^5	6.2×10^5
Secondary Contain- ment Grd.	1.0×10^3	4.2×10^3	3.8×10^3	1.1×10^4	2.6×10^4
Refueling Floor	4.2×10^2	1.7×10^3	1.6×10^4	4.5×10^4	1.1×10^5

I. SERVICE CONDITIONS


The attached curves provide the requested information for the following service condition:


<u>SERVICE PROFILE</u>	<u>CONDITION</u>
1a)	LOCA: In-containment Pressure and Temperature (Reference FSAR Fig. 14.0-31 & 32)
1b)	MSLB: In-containment Pressure and Temperature (Reference FSAR Amendment 20 Response to Comment 5.2.1 Fig. 5.2.1 through 5.2.1.4)
1c)	LOCA: In-containment Integrated Radiation (Reference FSAR Table 14.9.19)
2a)	LOCA: Surface 24 in. Sch. 80 pipe (Typical for outside containment line mounted components - MOV's; SOV's) Integrated Radiation. (Reference FSAR Table 14.0.19)
2b)	LOCA: Floor of corner compartment (Typical for other outside containment components with post-LOCA recir- culation flow) Integrated Radiation (Reference FSAR Table 14.0.19)
PBOC-1	HPCI Line Break in HPCI Valve Station (Area - 1.10B): a) Pressure vs time (sec) b) Temperature vs time (min)
PBOC-2	RWCU Line Break in RWCU Compartment (Area - 1.11A): a) Pressure vs time (sec) b) Temperature vs time (min)
PBOC-3	HPCI Line Break in HPCI Pump Room (Area - 1.3): a) Pressure vs time (sec) b) Temperature vs time (min)
PBOC-4	RCIC Line Break in RCIC Valve Station (Area - 1.10A): a) Pressure vs time (sec) b) Temperature vs time (min)
PBOC-5A	HPCI Line Break in Torus Compartment - Case A (Area - Torus Area): a) Pressure vs time (sec) b) Temperature vs time (min)

<u>SERVICE PROFILE</u>	<u>CONDITION</u>
PBOC-5B	HPCI Line Break in Torus Compartment - Case B (Area - Torus Area): a) Pressure vs time (sec) b) Temperature vs time (min)
PBOC-6	RCIC Line Break in RCIC Pump Room (Area - 1.5): a) Pressure vs time (sec) b) Temperature vs time (min)
PBOC-7	Main Steam Line Break in Condenser Compartment (Area - 2.11 & 2.12) a) Pressure vs time (sec) b) Temperature vs time (min)
PBOC-8	Main Steam Line Break in Main Steam Tunnel (Area - Steam Tunnel): a) Pressure vs time (sec) b) Temperature vs time (min)

The PBOC effects are presented as a family of curves representing those areas considered as affected by the pipe breaks.


The curves have been prepared on a room by room basis. The environmental profile applicable to each component, can be found by finding the room number listed under plant location (e.g. 1.7) and consulting the Pressure and Temperature profile curves applicable to that room.





SE QUICE PROFILE 16)


NOV. 1964
(from RA. 4. - 19)



TIME
INTERIOR SURFACE DRYWELL

SERVICE PROFILE 1c


LOCAL INTEGRATED DOSE
(from TABLE 14.0.19)



SURFACE PROFILE 2a)
SCH 80 - PIPE

SERVICE PROFILE 2a)

LOCAL INTEGRATED DOSE
(from TABLE 14.0.19)




FLOOR OF CORNER COMPARTMENT CONTAINING
CORE SPRAY PUMP SEALS.

SERVICE PROFILE 2.

TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - RHR AND CORE SPRAY PUMPS ROOM "A" (1.1)
RHR AND CORE SPRAY PUMPS ROOM "B" (1.2)


REACTOR BUILDING
EL. (-17'-6")



TEMPERATURE ENVIRONMENT - PIPE BREK OUTSIDE CONTAINMENT

AREA - HPCI PUMP ROOM (1.3)
HPCI PANEL AND VALVE ROOM (1.4)
REACTOR BUILDING AUX BAY EL. 23'-0"


REACTOR BUILDING
(AUXILIARY BAY)



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - RCIC PUMP ROOM (1.5)
RCIC PUMP ROOM MEZZANINE (1.7)


REACTOR BUILDING
EL. (-17'-6")



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT


AREA - CRD PUMP ROOM (1.6)
CRD PUMP ROOM MEZZANINE (1.8)

REACTOR BUILDING
EL. (-17¹-6")



TEMPERATURE ENVIRONMENT - PIPE LINE AK OUTSIDE CONTAINMENT


AREA - CRD MODULES AREA - EAST (1.9)
CRD MODULES AREA - WEST (1.10)



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT


AREA - RHR PIPING ROOM (1.9A)

REACTOR BUILDING
EL. 23'-0"




TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - RCIC PIPING ROOM (1,10A)

REACTOR BUILDING
EL. 23'-0"



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - RHR/HPCI PIPING ROOM (1.10B)


REACTOR BUILDING
EL. 23'-0"



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - OPEN AREA EAST HALF (1.11)
OPEN AREA WEST HALF (1.12)


REACTOR BUILDING
EL. 51'-0"



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - RWCU HX EX & PUMP ROOM (1.11A)


REACTOR BUILDING
EL. 51'-0"



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - FUEL POOL HEAT EXCHANGER AREA:
REACTOR BUILDING CLOSED COOLING
WATER SYSTEM (1.13, 1.13A, 1.13B)
OPEN AREA - NORTH HALF (1.14)


REACTOR BUILDING
EL. 74'-3"




TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - STANDBY LIQUID CONTROL AREA (1.15)
OPEN AREA - NORTH HALF (1.16) (1.16A)
CLOTHING CHANGE AND STORAGE AREA (1.17)


REACTOR BUILDING
EL. 91'-3"



TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - TORUS COMPARTMENT




TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - STEAM TUNNEL




TEMPERATURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - TURBINE BUILDING EL. 51'-0" (2.11, 2.12)




PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - (1.1) (1.2) (1.5) (1.6) (1.7) (1.8) (1.11) (1.12)
(1.13) (1.14) (1.15) (1.16) (1.17)

REACTOR BUILDING



PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - HPCI PUMP ROOM (1.3)
HPCI PANEL AND VALVE ROOM (1.4)




PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT

AREA - CRD MODULES AREA - EAST (1.9)

CRD MODULES AREA - WEST (1.10)


REACTOR BUILDING
EL. 23'-0"



PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - RHR PIPING ROOM (1.9A)

REACTOR BUILDING


EL. 23'-0"



PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - RCIC PIPING ROOM (1.10A)

REACTOR BUILDING


EL. 23'-0"



PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - RHR/HPCT PIPING ROOM (1.10B)

REACTOR BUILDING


EL. 23'-0"




PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - RWCU HX EX & PUMP ROOM (1.11A)

REACTOR BUILDING


EL. 51'-0"




PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - STEAM TUNNEL



PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - TORUS COMPARTMENT



PRESSURE ENVIRONMENT - PIPE BREAK OUTSIDE CONTAINMENT
AREA - TURBINE BUILDING EL. 51'-0" (2.11, 2.12)



EVALUATIONS

Attached are qualification test curves and evaluation computer printouts
for 79-01B.

Test Curves, 1 through 41

Printout #2 - Component Evaluation List

2I - In containment

2II - Outside containment

In order to properly utilize the computerized information the following field
description and code interpretations preceed the printouts:


I. Description of 79-01B Computer Fields

II. Plant Location Codes

III. Equipment Safety Function Codes

Notes:

- 1) Rise time not specified
- 2) Preaged 100 hrs at 150 C
- 3) Preirradiated to 200 Megarads
- 4) Boric Acid spray during total 100 days




Temperature/Pressure Profile For KERITE
5 KV HTK/HTNS Power Cable: from test summary -
Attachment to Kerite letter 7/21/80

TEST CURVE
#1 (new)

Notes:


- 1) Rise & decay times not specified
- 2) Preaged 100 hrs. at 150 C
- 3) Pre-irradiated to 50 Megarads
- 4) Simultaneous irradiation to total dose of 200 Megarads during first 23 hours
- 5) Boric acid spray during total 100 days



Temperature/Pressure Profile For KERITE
1000 VOLT HTK/FR Control Cable: from test
summary - Attachment to Kerite letter 7/21/80

TEST CURVE
#2 (new)

- TESTS:**
- 1) Rise & decay times not specified
 - 2) Preaged 100 hours at 150 C
 - 3) Pre-irradiated to 50 Megarads
 - 4) Simultaneous irradiation to total dose of 200 Megarads during first 23 hours
 - 5) Boric acid spray during total 50 days



Temperature/Pressure Profile DERITE
 1000 VOLT FR/FR Control Cable: from test
 summary - Attachment to Kerite Letter 7/21/80

TEST CURVE
 #3 (new)

0 0 0 0 0 0 4 7 9

b3 PAN 3/5/80





Figure 1. Test Profile — OKONITE ENGINEERING REPORT No. 127 9/24/71
TEST CURVE # 4

NOTE: D, P&N 515/8

- 1) 1900 PPM Boric Acid continuous during test
- 2) Rise times & decay times unspecified
- 3) - - - curve represents autoclave test conducted prior to irradiation to 1×10^8 RADS

POOR ORIGINAL




Temperature/Pressure Profile for Conax Penetrations from
Test Report IPS-42; Rev. A

TEST CURVE
5

Re: b; D&N 115/80

- i) Rise and Decay times
unspecified




Temperature/Pressure Profile For Physical Science 5 KV
Penetration From SPSD - QC - 206

TEST CURVE
#6

note: 1/8 Pt. in 31..

- 1) Rise and Decay times
unspecified
- 2) — EPAQ-055
--- EPAQ-007




Temperature/Pressure Profile For GE 600 V Power & Control
Penetrations from EPAQ-055, EPAQ-007

TEST CURVE
7

Note: by PMH 3/5/80


1) Rise and decay times
unspecified

2) — EPAQ-060
- - - EPAQ-009 & -010



Temperature/Pressure Profile for GE Shielded Signal
Penetrations from EPAQ-060, EPAQ-009, EPAQ-010

TEST CURVE
8



Temperature/Pressure Profile For GE SIS WIRE SI-57275
FROM EPAQ -015 & - 016

TEST CURVE
9

POOR ORIGINAL




FIGURE 3

SCHEDULE OF TEST ENVIRONMENTS

Saturated Steam Pressure Cycle
and
Limitorque Operation Cycle

by P.A.N. 3/15/80
Notes:
1) Boric acid spray
pH 7.67

from FIRL test F-C2232-01 : TEST OF A LIMITORQUE VALVE OPERATOR UNDER A SIMULATED REACTOR CONTAINMENT POST ACCIDENT STEAM AND CHEMICAL ENVIRONMENT

part of Limitorque test : TEST OF LIMITORQUE VALVE OPERATOR TO MEET GENERAL REQUIREMENTS OF AN ELECTRIC VALVE ACTUATOR IN NUCLEAR REACTOR CONTAINMENT ENVIRONMENT.

TEST REPORT for ORDER # 600198

TEST CURVE
#10

Poor Original





Figure 3. Actual Steam Exposure Profile

TEST CURVE
11



FROM PHILADELPHIA ELECTRIC TEST: QUALIFICATION TESTS OF TERMINAL BLOCKS and SPLICE-INSULATING ASSEMBLIES In a SIMULATED LOSS-OF-COOLANT ACCIDENT ENVIRONMENT-PHASE B


Figure 16. Specified Temperature/Pressure Profile for the Steam/Demineralized-Water-Spray Exposure

TEST CURVE
12

by PHW 3/5/80

NOTE:
 1) Pre-irradiated 2×10^6 Rads
 2) 3000 ppm Boric Acid spray:
 $P_n = 10$; from +10 sec to end
 of test

Temperature/Pressure (°F/psi)




4-21

FIGURE 2
 ACTUAL LOCA SIMULATION BY ENVIRONMENTAL
 EXPOSURE (STEAM/CHEMICAL)

Temperature/Pressure Profile for simulation of loss-of-coolant accident (LOCA) design basis event (DBE) by steam/chemical-spray environmental exposure. TEST CURVE # 13

Notes: 1, Oct 13/1980

- 1) Combined total temperature exposure for both tests as follows:
- a) above 250°F: 9.3 Hours
 - b) above 310°F: 5.5 Hours
 - c) above 340°F: 3.3 Hours




Temperature/Pressure Profile For MSIV SOV's From Rockwell RPT
2792 - 03 -02, Exhibit 10.

TEST CURVE
14

Note: vj p1 in 3/11/60

- 1) Rise & Decay times unspecified
- 2) Preirradiated to 3×10^7 RADs
- 3) Profile repeated 4 times

POOR ORIGINAL



Temperature/Pressure Profile For Various SOVS From Test #7 GE Plant
Equipment Design Engineering Memorandum No. 126-62

TEST CURVE
15

Chamber temperature and pressure were monitored continuously on strip-chart recorders. The locations of the thermocouple junctions were as shown in Figure 5.

A list of the data acquisition instruments used in the test program is included as Appendix A.

Radiation Dosimetry data are included as Appendix B.

3.5 COMBINED RADIATION AND THERMAL AGING EXPOSURE

The specimens were electrically energized as stated in Section 3.3, while simultaneously thermally aged at 150°C (302°F) and irradiated to an air-equivalent dose of 5×10^5 rads. The vessel was electrically heated. During this exposure air was circulated through the test vessel by an external blower. Insulation resistance measurements were made during and after this exposure.

Note: An air-equivalent dose means that the volume occupied by the specimens receives an isotropic flux of gamma radiation equivalent to the radiation dose that would result if the volume contained only air.

Following the combined radiation-thermal aging exposure, the specimens were simultaneously exposed to steam, chemical-spray and gamma radiation (S/C/R) as illustrated in Figure 8.

A chemical spray consisting of 3000 ppm boron as boric acid, 0.064 molar sodium thiosulfate and adjusted with sodium hydroxide to a pH of 10.5 at room temperature, was applied at the rate of 0.15 gpm per square foot (100 ml per second per square meter) of spray area (See Section 3.2). Fresh heated spray solution was used for the first hour of the profile. Thereafter, the spray solution was recirculated from the reservoir at the bottom of the chamber. The pH was monitored periodically, and was maintained within the range of 9.5 to 11.0 by addition of fresh solution.

During the S/C/R exposure, the specimens were energized as indicated in Section 3.3.

3.7 MANDREL WRAP AND HIGH-POTENTIAL WITHSTAND TESTS

After the S/C/R exposure, before the test vessel was removed from the radiation hot cell, it was filled with tap water and insulation resistance measurements and preliminary




Figure 8. Temperature/pressure profile for simulation of Loss-Of-Coolant Accident environment.

TEST CURVE
16


from FIRL Report: F-C4033-3 ; TESTS OF RAYCHEM THERMOFIT INSULATION SYSTEMS UNDER SIMULTANEOUS EXPOSURE TO HEAT, GAMMA RADIATION, STEAM AND CHEMICAL SPRAY WHILE ELECTRICALLY ENERGIZED

7/24/72

by PMAH 3/5/80

NOTES:

- 1) Indicates Insulation Resistance measurement Required.



TIME - NOT TO SCALE

Accident (LOCA) test on two electrical cable splice assemblies for Boston Edison Co.

FIGURE 2
TEMPERATURE-PRESSURE PROFILE

TEST CURVE
17

3/29/78




Fig 1
 Test Chamber Temperature Profile for Accident Environment Simulation
(taken from IEEE Standard 382-1972)

from test report: QUALIFICATION OF NAMCO CONTROLS LIMIT SWITCH MODEL EA-740 2/20/78

TEST CURVE
 #18





Figure 4. Postulated Steam Impingement Environment Profile
from WYLE Test Report 43854-1: a test of Fenwal # 17002-40 temperature switch
and AMPHENOL Connector

TEST CURVE # 19



Temperature/Pressure Profile from GE file DV145C3004; Fenwal RPT.
6350 test #5 on a Fenwal #17322-0 temperature switch.

TEST CURVE #20

Qualification Type Test Report

Limitorque Valve Actuators

For Class 1E Service

Outside Primary Containment


Notes:

1) preirradiated to 2×10^7 rads

PH 3/11/80

REPORT NO. B0003

TEMPERATURE PROFILE



POOR ORIGINAL

QUALIFICATION TYPE TEST REPORT
LIMITORQUE DC VALVE ACTUATORS
FOR NUCLEAR POWER STATION

SERVICE CONDITIONS





FIGURE 1

MHN 3/20/80

- NOTE: 1. Rise time and dwell unspecified
2. SETPOINT DRIFT for 80°F-
212°F less than -10% and
then returning




Temperature/Pressure Profile for YARWAY #4418Ec: from:
Lockheed Test
RPT #3232-3155, part of G. E. RPT 145C3031

TEST CURVE
** 23*

PCH 3/20/80

- NOTE: 1. Rise and decay time unspecified
2. SETPOINT DRIFT for 75°F-
212°F: 288A - less than
+ 7.5%, 289A - less than
+ 10% and then returning




Temperature/Pressure Profile from:
Qualification Test Procedure for Barton 288A & 289A
Indicating Switches #9999.1217.2, part of G. E. RPT 145C3008 and 145C3009

TEST
CURVE
24

P&H 3/20/80

- NOTE: 1. Rise and decay times unspecified
2. Dwell times not specified, but must have been greater than 35 minutes to insure stability.
3. Setpoint drift for 75°F-212°F less than $\pm 5\%$ of setpoint, then returning




Temperature/Pressure Profile For Barton 288A Switch from:
Barton Engineering RPT
R1 - 288A - 16, part of G. E. RPT 145C3009

TEST
CURVE
25

Plan 3/10/80

- NOTE: 1. This is last portion of a test which initially tested switches from +70°F to -65°F and then back to +70°F.
2. Rise time unspecified, dwell times - 10 minutes
3. Setpoint drift from 70°F - 200°F/ - Diaphragm styles: less than 20% and returning - Bourdon tube styles: less than 4% and returning




Temperature/Pressure Profile from Wyle Test Report for Job #1085;
"Temperature Calibration Test on Seven Barksdale Switches"
Part of G. E. RPT 145C3010, 134C3046, 145C3028

TEST CURVE
#26

1/2

- NOTE: 1. Decay times not specified
2. dashed portion depicts temperature excursions during test chamber malfunctions and repairs
3. SETPOINT DRIFT for 74°F-212°F less than -10% and then returning
4. STATIC-O-RING Model 5N-AA3-SST-10-Viton Diaphragm & O-RING



TIME (hrs) (NOT TO SCALE)


Total Test Time 5 days

Temperature/Pressure Profile For STATIC-O-RING Model 5N Switch From:
Viking Lab Environmental
Test Report #30203-1, part of GE RPT. 145C3011

TEST CURVE
#27

MM 1/20/

- NOTE: 1. Decay Time Not Specified
2. SETPOINT DRIFT for 70°F-
212°F less than -10% and
then returning
3. STATIC-O-RING Model
12N-AA4-TTX10 - BuNA-N
Diaphragm and O-RING




TIME (hrs) (NOT TO SCALE)
Total Test Time 2 days
Temperature/Pressure Profile For STATIC-O-RING Model I2N Switch from:
Viking Lab Environmental
Environmental Test Report #31203-2, Part of G.E. RPT. 145C3012

TEST CURVE
28

VIMH 1120/8

- NOTE: 1. Rise & Decay times not specified
2. Preirradiated to approximately 5×10^3 RADs
3. ——— curve a)
----- curve b)




Temperature/Pressure Profile for Terry Turbine Electrical Components from TEST SPECIFICATION E/L 20397, Rev. 4

TEST
CURVE
29 a) & b)


PMH 3/20/80

NOTE: 1. Rise time unspecified
2. Accuracy less than 1%
per test, memo suggests
+5% considering humidity.



Temperature/Pressure Profile for G. E. 555 Transmitter from W.H. Burnham
Memo on TEST RPT #430
Part of G. E. RPT 145C3007

Notes: 1. Decay times not specified




Temperature/Pressure Profile for Bostrad⁷ Cable from:
Boston Insulated Wire & Cable Co. Report #B901

TEST
CURVE
31

Notes:

1. Chemical Spray during entire test 1900 ppm Boric Acid, pH 9.0
2. Preirradiated to 1×10^8 Rads




Temperature/Pressure Profile for Kerite.
Cable Splices from FIRL
Test RPT F-C3056

TEST CURVE
32


Notes:

- 1) Decay times not specified
- 2) preirradiated 1.9×10^7 Rads
- 3) Post irradiated 1.3×10^7 Rads



Temperature/Pressure Profile For Target Rock
Solenoid per Summary Sheet GE LTR G-HK=9-123; August 29, 1979

TEST
CURVE
33




Temperature/Pressure Profile Barksdale
PIH Pressure Switch, Per GE Test Summary
NSE 80188 of Test Report No. 596-0398,
MPL #159C 4606

TEST CURVE
#34


Notes:

- 1) Rise & decay times not specified
- 2) Preaged 504 hrs. 150 C
- 3) Preirradiated 200 Megarads
- 4) Sodium Hydroxide and Boric acid spray for first 24 hours.



Temperature/Pressure Profile For Okonite
Ethylene- Propylene Rubber insulation from:
Okonite Report No. NQRN - 1

TEST CURVE
#35




Actual Temperature/Pressure Profile For Simulation of Loss-of-Coolant Accident Environment
From FIRL Test Report F-C4497-2 for GE Vulkene Supreme Insulated Cable (Specimens 2A,B,C,D)

F-C4497-2

TEST CURVE
36


NOTE: Rise/Decay times unspecified



Temperature Profile for G.E. 551 Transmitter
Part of G.E. RPT 145C3006

TEST CURVE

37



Temperature Profile for Rosemount 1152 transmitters
RMT Report No. 117415 Rev. B

TEST CURVE

38

POOR ORIGINAL





FIGURE 1
LOCA TEMPERATURE/PRESSURE PROFILE

TEST CURVE


39

POOR ORIGINAL



TEMPERATURE PROFILE FOR G-E TERMINAL BOARDS EB-25 FROM
SUMMARY OF FRANKLIN INSTITUTE REPORT ATTACHED
QS-R-010-A-01

POOR ORIGINAL



TEMP PROFILE FOR ASCO SOLENOID VALVES

HVA - 90 - 405 - 2A FROM SUMMARY OF ASCO REPORT
383HA820 AND WYLE REPORT 384 HA183 ATTACHED
TO EPRI/PRIOR CUNNERS SUMMARY REPORTS QSR-097-A-01 & QSR-097-A-02

#41

I. DESCRIPTION OF 79-01B EQUIPMENT QUALIFICATION FIELDS

- EQUIP NO - This is the unique equipment number designator for Pilgrim #1 electrical equipment.
- DESCRIP - This is a generalized description of the equipment listed. Included in this column, if applicable, is the associated P & ID Dwg. number.
- SYSTEM - This field lists the systems supported by this component.
- MAN/MODEL # - Contains manufacturer, model number and serial number information.
- SAFE FUNC - This field contains both a BECo coded safety function and a brief description of the equipment safety function. Refer to the list attached for safety function code designation.
- PLT LOC - This is a coded plant location symbol indicating the location of the equipment. Whenever (as is the case for cables) the equipment exists in numerous locations outside containment the word VARIOUS will appear. Refer to attached list for location code designation. Additional information may also be listed to facilitate location information. For instruments mounted on panels such as PNL "C2247A" the panel number is also listed.
- OPER TIME REQ/AVAIL - Listed first is the time frame during which the equipment is required to perform its safety function. When Boston Edison believes that the available information can not substantiate operation to this required time a second listing will identify a shorter time to

which the component is available. NOTE: In all cases the equipment was considered to be capable of operation beyond the required operating time and in no case was a shorter time listed.

The following key will assist in interpreting this information:

NR-LOCA not required for LOCA events

NR-PBOC not required for PBOC events

R-LOCA-1 min ... required actively for LOCA for 1 minute

R-1 min required actively for both LOCA & PBOC for 1 minute

R-LOCA(A)-1 min required for LOCA actively for 1 minute and

R-LOCA(P)-30 day ... passively for 30 days

R-(P)-30 day required passively for LOCA and PBOC for 30 days

- DBE EXPOSED - This field lists the DBE, and the type of environmental conditions to which the component is exposed when it is required to function. ie) PBOC (F/#/%) LOCA (RAD)

- DBE ENV REQ. - Contains the information, first on temperature/pressure/humidity (F/#/%), and second on total integrated radiation (RAD-) to which the component may be exposed.

- QUAL ENVIR - Contains the information, first on temperature/pressure/humidity (F/#/%), and second on total integrated radiation (RAD-) to which the component has been qualified.

- MET OF QUAL - This field describes the methods of qualification including testing, analysis and an indication of the type of testing done (separate or sequential). As necessary, other notation will be included to clarify this information.

- SUPP DOC - This field contains a listing of the principal supporting documents which substantiate the values provided in the OUAL ENVIR field. As necessary, additional notations will be included to clarify this information.

- QUAL STATUS - This field lists the results of BECo.'s qualification evaluation. Acronymic designations were used to facilitate future work. Possible designations and their respective meanings are as follows:

NYI - Not Yet Installed

JCO - Justified for Continued Operation

QPS - Qualified to Plant Specific Requirements

DOR-A - Qualified to DOR Guidelines except for aging

DOR - Qualified to DOR Guidelines

UQ - Unqualified (Reference LER)

NYQ - Not Yet Qualified

- QUAL PLAN - This field lists future qualification efforts and forecast completion dates. Again, acronymic designations were used as follows:

FT - Future Qualification Test

RA - Radiation Analysis

AA - Aging Analysis

HT - Heat Transfer Analysis

ER - Equipment Replacement

II - Installation Inspection

FE - Final Evaluation

Various categories included in the NRC format are not contained on our response.

Generic information on these categories are as follows:

Submergence: Pilgrim Unit #1 is a Mark I BWR. The only area with the potential for submerged equipment post-LOCA is the interior of the torus. No safety related electrical equipment exists in the area.

Chemical Spray: Pilgrim Unit #1 is a Mark I BWR. No chemical solutions are used in systems required for the accidents presently under consideration.

Accuracy: Accuracy information is applicable to instruments only. No instruments in containment are under the scope of 79-01B (none are required for LOCA). Instruments outside containment are not exposed to the LOCA temperature, pressure effects. Some instruments outside containment do experience the effects of PBOC, principally set-point shifts due to temperature effects. These shifts are directly related to instrument internal temperatures not ambient temperatures. For PBOC such shifts are short-term in nature and are significantly less than the shifts due to steady-state elevated temperatures. Test accuracies, if available, are presented on the appropriate Test Curve sheet.

POOR ORIGINAL

II.

Plant Location Code Designations

The following codes are used in the Bulletin 79-01B computer printout to define plant locations.

<u>Code</u>	<u>Building</u>	<u>Elev.</u>	<u>Space Designation</u>
** 1.1	Reactor	(-) 17.6	RHR and Core Spray Pumps Room "A"
** 1.2	Reactor	(-) 17.6	RHR and Core Spray Pumps Room "B"
** 1.3	Reactor	(-) 17.6	HPCI Pump Room
** 1.4	Reactor	(-) 17.6	HPCI Pump Panel and Valve Room
** 1.5	Reactor	(-) 17.6	RCIC Pump Room
** 1.7	Reactor	2-9	RCIC Pump Room Mezzanine
** 1.8	Reactor	2-9	CRD Pump Room Mezzanine
** 1.9	Reactor	23-0	CRD Modules Area - East
** 1.9A	Reactor	23-0	RHR Piping Room
** 1.9C	Reactor	23-0	Drywell Access Room
** 1.10	Reactor	23-0	CRD Modules Area - West
** 1.10A	Reactor	23-0	RCIC Piping Room
** 1.10B	Reactor	23-0	RHR/HPCI Piping Room
** 1.11	Reactor	51.0	Open Area - East Half
** 1.11A	Reactor	51.0	RWCU Hx Ex. & Pump Room
** 1.12	Reactor	51.0	Open Area - West Half
** 1.13 1.13A 1.13B	Reactor	74-3	Fuel Pool Heat Exchanger Area: Reactor Building Closed Cooling Water System
** 1.14	Reactor	74-3	Open Area - North Half
** 1.15	Reactor	91-3	Standby Liquid Control Area
** 1.16 1.16A	Reactor	91-3	Open Area - North Half
** 1.17	Reactor	91-3	Clothing Change and Storage Area

POOR ORIGINAL

	<u>Code</u>	<u>Building</u>	<u>Elev.</u>	<u>Space Designation</u>
**	1.23	Reactor	51-0	Standby Gas Treatment Filter Rooms
	1.23A			
	1.23B			
**	Steam Tunnel	Reactor	23-0	Steam Tunnel between Turbine Building and Drywell
**	Torus Area	Reactor	(-) 17-6	Compartment surrounding Torus
**	Various	Reactor	all	Indicates use in numerous areas.
*	1.30	Reactor		Drywell Interior

NOTES:

* Location for Level I equipment (inside containment)

** Location for Level II equipment (outside containment)

III.

Bulletin 79-01B

Equipment Safety Function Codes

The following codes are used in the Bulletin 79-01 computer printouts to define component safety functions.

<u>Code</u>	<u>Safety Function</u>
1	SCRAM
2	Primary Containment Isolation
2A	Primary Containment Integrity (Electrical Penetrations, Torus Vacuum Breakers)
3	Secondary Containment Isolation
4	Core Cooling (General)
4A	RHR (LPCI)
4B	RHR (Containment Cooling @ Cntm Spray, Torus Spray, Torus Cooling)
4C	RBCCW (Support of Core Cooling)
4D	Salt Service Water (Support of Core Cooling)
10	Pressure Relief
11	Monitoring (General)
12	Electrical Distribution (To Support Other Functions)
13	Standby Gas Treatment

PRINTOUT

ZI

79-01B PIGRM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 1

POOR ORIGINAL

Equipment No	112 KERITE
Description	1/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	KERITE FR INSULATION FR OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #3 RAD-2X10EB
Aging	THERMAL-100 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
QUAL STATUS	DDR-A
QUAL PLAN	AA 3/81 FE 4/81

Equipment No	112 OKONITE
Description	1/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	OKONITE OKONITE INSULATION OKOPRENE INDIVIDUAL & OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #4 RAD-1X10EB
Aging	THERMAL-504 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	OKONITE ENG RPT #127 10/24/71 BPCo SCEQ OKONITE LTR 4/9/80 & attached OKONITE RPT NORN-1 (AGING) WY LE RPT 17446-1
QUAL STATUS	DDR

Equipment No	212 KERITE
Description	2/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	KERITE FR INSULATION FR OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #3 RAD-2X10EB
Aging	THERMAL-100 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
QUAL STATUS	DDR-A
QUAL PLAN	AA 3/81 FE 4/81

Equipment No	212 OKONITE
Description	2/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	OKONITE OKONITE INSULATION OKOPRENE INDIVIDUAL & OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #4 RAD-1X10EB
Aging	THERMAL-504 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	OKONITE ENG RPT #127 10/24/71 BPCo SCEQ OKONITE LTR 4/9/80 & attached OKONITE RPT NORN-1 (AGING) WY

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 2

POOR
ORIGINAL

QUAL STATUS DOR LE RPT 17446-1

Equipment No	312 KERITE BB KERITE
Description	3/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	KERITE FR INSULATION FR OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	I 30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #3 RAD-2X10EB
Aging	THERMAL-100 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
QUAL STATUS DOR-A	
QUAL PLAN AA 3/81 FE 4/81	

Equipment No	312 OKONITE BB OKONITE
Description	3/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	OKONITE OKONITE INSULATION OKOPRENE INDIVIDUAL & OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	I 30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #4 RAD-1X10EB
Aging	THERMAL-504 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	OKONITE ENG RPT #127 10/24/71 BPCo SCEQ OKONITE LTR 4/9/80 & attached OKONITE RPT NQRN-1 (AGING) WY
QUAL STATUS DOR	LE RPT 17446-1

Equipment No	412 KERITE
Description	4/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	KERITE FR INSULATION FR OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	I 30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #3 RAD-2X10EB
Aging	THERMAL-100 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
QUAL STATUS DOR-A	
QUAL PLAN AA 3/81 FE 4/81	

Equipment No	412 OKONITE
Description	4/C STRANDED #12 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	OKONITE OKONITE INSULATION OKOPRENE INDIVIDUAL & OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	I 30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #4 RAD-1X10EB
Aging	THERMAL-504 hrs 150C

74-0TB PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 3

Method of Qualification TEST/SEQUENTIAL
 Supporting Document OKONITE ENG RPT #127 10/24/71 BPCo SCEQ OKONITE LTR 4/9/80 & attached OKONITE RPT NGRN-1 (AGING) WY
 LE RPT 17446-1

QUAL STATUS DOR

Equipment No 512 KERITE B9 KERITE
 Description 5/C STRANDED #12 600V POWER & CONTROL CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE FR INSULATION FR OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1-30 VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
 Qual Envir TEST CURVE #3 RAD-2X10EB
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No 512 OKONITE B9 OKONITE
 Description 5/C STRANDED #12 600V POWER & CONTROL CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model OKONITE OKONITE INSULATION OKOPRENE INDIVIDUAL & OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1-30 VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
 Qual Envir TEST CURVE #4 RAD-1X10EB
 Aging THERMAL-504 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document OKONITE ENG RPT #127 10/24/71 BPCo SCEQ OKONITE LTR 4/9/80 & attached OKONITE RPT NGRN-1 (AGING) WY
 LE RPT 17446-1

QUAL STATUS DOR

Equipment No 712 KERITE
 Description 7/C STRANDED #12 600V POWER & CONTROL CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE FR INSULATION FR OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1-30 VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
 Qual Envir TEST CURVE #3 RAD-2X10EB
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No 712 OKONITE
 Description 7/C STRANDED #12 600V POWER & CONTROL CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model OKONITE OKONITE INSULATION OKOPRENE INDIVIDUAL & OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1-30 VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB

POOR ORIGINAL

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 4

Qual Envir TEST CURVE #4 RAD-1X10EB
 Aging THERMAL 504 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document OKONITE ENG RPT #127 10/24/71 BPCo SCEQ OKONITE LTR 4/9/80 & attached OKONITE RPT NGRN-1 (AGING) WY
 LL RPT 17446-1

QUAL STATUS DOR

Equipment No 912 KERITE
 Description 9/C STRANDED #12 600V POWER & CONTROL CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE FR INSULATION FR OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1 30 VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
 Qual Envir TEST CURVE #3 RAD-2X10EB
 Aging THERMAL 100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

POOR ORIGINAL

Equipment No AD203-1A
 Description FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252 (730E 583)
 System MAIN STEAM RPS CNTM ISOLATION
 Man/Model VARIOUS AVCO/CS159 (SOV) NAMCO/EA740-50100 (LIM SW)
 Safety Function 1/2/11 MSIV SCRAM & SR DSPLY (LIM SW)/MN STM ISO (SOV)
 Plant Location 1 30
 Operating Time Req/Avail R-(A2-30 min (SOV)) R-(P1-30 day (SOV)) R-30 day (LM SW)
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7
 Qual Envir TEST CURVE #14 (SOV) TEST CURVE #15 (SOV) TEST CURVE #18 (LIM SW) RAD-2.04X10EB
 (LIM SW)
 Aging MECH-55 CYCLES during F/#/% test (SOV) THERMAL-200 hrs 93C (LIM SW) MECH-100000 CYCLES (LIM SW)
 Method of Qualification TEST/SEPARATE/SIMILAR EQPT (SOV) TEST/SEQUENTIAL (LIM SW)
 Supporting Document GE LTR G-HK-9-44 ROCKWELL RPT #2792-03-02 (SOV F/#/%) GE PEDEM #126-62 (SOV RAD) NAMCO TEST RPT FO
 R MODEL EA-740 2/20/78 (LIM SW) ATWOOD & MORRILL TEST RPT #STR-060578-1 (LIM SW) WYLE RPT 17446-3a WYLE
 RPT 17446-3b

QUAL STATUS DOR-A(LIM SW) JCD(SV) FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE
 QUAL PLAN AA 2/81(LIM SW) FE 4/81(LIM SW) FE 4/81(SV)

Equipment No AD203-1B
 Description FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252 (730E 583)
 System MAIN STEAM RPS CNTM ISOLATION
 Man/Model VARIOUS AVCO/CS159 (SOV) NAMCO/EA740-50100 (LIM SW)
 Safety Function 1/2/11 MSIV SCRAM & SR DSPLY (LIM SW)/MN STM ISO (SOV)
 Plant Location 1 30
 Operating Time Req/Avail R-(A)-30 min (SOV) R-(P1)-30 day (SOV) R-30 day (LM SW)
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7
 Qual Envir TEST CURVE #14 (SOV) TEST CURVE #15 (SOV) TEST CURVE #18 (LIM SW) RAD-2.04X10EB
 (LIM SW)
 Aging MECH-55 CYCLES during F/#/% test (SOV) THERMAL-200 hrs 93C (LIM SW) MECH-100000 CYCLES (LIM SW)
 Method of Qualification TEST/SEPARATE/SIMILAR EQPT (SOV) TEST/SEQUENTIAL (LIM SW)
 Supporting Document GE LTR G-HK-9-44 ROCKWELL RPT #2792-03-02 (SOV F/#/%) GE PEDEM #126-62 (SOV RAD) NAMCO TEST RPT FO
 R MODEL EA-740 2/20/78 (LIM SW) ATWOOD & MORRILL TEST RPT #STR-060578-1 (LIM SW) WYLE RPT 17446-3a WYLE
 RPT 17446-3b

QUAL STATUS DOR-A(LIM SW) JCD(SV) FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE
 QUAL PLAN AA 2/81(LIM SW) FE 4/81(LIM SW) FE 4/81(SV)

74-018 PHILM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 5

Equipment No	AU003-1C
Description	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252 (730E 583)
System	MAIN STEAM RPS CNTM ISOLATION
Man/Model	VARIOUS AVCO/C5159 (SOV) NAMCO/EA740-50100 (LIM SW)
Safety Function	1/2/11 MSIV SCRAM & SR DISPLAY (LIM SW)/MN STM ISO (SOV)
Plant Location	I-30
Operating Time Req/Avail	R-(A)-30 min (SOV) R-(P)-30 day (SOV) R-30 day (LM SW)
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7
Qual Envir	TEST CURVE #14 (SOV) TEST CURVE #15 (SOV) RAD-3X10E7 (SOV) TEST CURVE #18 (LIM SW) RAD-2.04X10E8 (LIM SW)
Aging	MECH-55 CYCLES during F/#% test (SOV) THERMAL-200 hrs 93C (LIM SW) MECH-100000 CYCLES (LIM SW)
Method of Qualification	TEST/SEPARATE/SIMILAR EQPT (SOV) TEST/SEQUENTIAL (LIM SW)
Supporting Document	GE LTR G-HK-9-44 ROCKWELL RPT #2792-03-02 (SOV F/#%) GE PEDEM #126-62 (SOV RAD) NAMCO TEST RPT FO R MODEL EA-740 2/20/78 (LIM SW) ATWOOD & MORRILL TEST RPT #STR-060578-1 (LIM SW) WYLE RPT 17446-3a WYLE RPT 17446-3b
QUAL STATUS	DDR-A(LIM SW) JCD(SV) FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE
QUAL PLAN	AA 2/81(LIM SW) FE 4/81(LIM SW) FE 4/81(SV)

Equipment No	AU203-1D
Description	FIRST ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252
System	MAIN STEAM RPS CNTM ISOLATION
Man/Model	VARIOUS AVCO/C5159 (SOV) NAMCO/EA740-50100 (LIM SW)
Safety Function	1/2/11 MSIV SCRAM & SR DISPLAY (LIM SW)/MN STM ISO (SOV)
Plant Location	I-30
Operating Time Req/Avail	R-(A)-30 min (SOV) R-(P)-30 day (SOV) R-30 day (LM SW)
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7
Qual Envir	TEST CURVE #14 (SOV) TEST CURVE #15 (SOV) RAD-3X10E7 (SOV) TEST CURVE #18 (LIM SW) RAD-2.04X10E8 (LIM SW)
Aging	MECH-55 CYCLES during F/#% test (SOV) THERMAL-200 hrs 93C (LIM SW) MECH-100000 CYCLES (LIM SW)
Method of Qualification	TEST/SEPARATE/SIMILAR EQPT (SOV) TEST/SEQUENTIAL (LIM SW)
Supporting Document	GE LTR G-HK-9-44 ROCKWELL RPT #2792-03-02 (SOV F/#%) GE PEDEM #126-62 (SOV RAD) NAMCO TEST RPT FO R MODEL EA-740 2/20/78 (LIM SW) ATWOOD & MORRILL TEST RPT #STR-060578-1 (LIM SW) WYLE RPT 17446-3a WYLE RPT 17446-3b
QUAL STATUS	DDR-A(LIM SW) JCD(SV) FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE
QUAL PLAN	AA 2/81(LIM SW) FE 4/81(LIM SW) FE 4/81(SV)

Equipment No	A0220-44
Description	GLOBE VALVE AIR OPERATOR LIMIT SWITCHES M252
System	REACTOR RECIRCULATION SYSTEM SAFETY RELATED DISPLAY
Man/Model	NAMCO EA740-50100
Safety Function	11 SR DISPLAY CNTM ISO VV POSITION
Plant Location	I-30
Operating Time Req/Avail	R-30 day
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #18 RAD-2.04X10E8
Aging	THERMAL-200hrs 93C MECH-100000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	NAMCO TEST RPT FOR MODEL EA-740 2/20/78 ATWOOD & MORRILL TEST RPT #STR-060578-1 WYLE RPT 17446-3b
QUAL STATUS	DDR-A
QUAL PLAN	AA 2/81 FE 4/81

Equipment No	B6 KERITE
Description	3/C STRANDED #6 600V POWER & CONTROL CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	KERITE FR INSULATION FR OVERALL JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	I-30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 6

DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
 Qual Envir TEST CURVE #3 RAD-2X10EB
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No B7 KERITE 310 KERITE
 Description 3/C STRANDED 310 600V POWER & CONTROL CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE FR INSULATION FR OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1 30 VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
 Qual Envir TEST CURVE #3 RAD-2X10EB
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES WYLE RPT 17446-2
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No J208
 Description AU203-1A LIMIT SWITCH JUNCTION BOX
 System MAIN STEAM CNTM ISOLATION SAFETY RELATED DISPLAY
 Man/Model VARIOUS BUCHANAN/525 (TERM BK) HOFFMAN NEMA 4 (ENCLOSURE)
 Safety Function 11/12 SUPPORT OF SR DISPLAY/ELECT DIST
 Plant Location 1 30
 Operating Time Req/Avail R-30 day
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
 Aging THERMAL-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT
 QUA. STATUS DOR
 17446-4

Equipment No J209
 Description AU203-1B LIMIT SWITCH JUNCTION BOX
 System MAIN STEAM CNTM ISOLATION SAFETY RELATED DISPLAY
 Man/Model VARIOUS BUCHANAN/525 (TERM BK) HOFFMAN NEMA 4 (ENCLOSURE)
 Safety Function 11/12 SUPPORT OF SR DISPLAY/ELECT DIST
 Plant Location 1 30
 Operating Time Req/Avail R-30 day
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
 Aging THERMAL-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT
 QUA. STATUS DOR
 17446-4

Equipment No J210
 Description AU203-1C LIMIT SWITCH JUNCTION BOX
 System MAIN STEAM CNTM ISOLATION SAFETY RELATED DISPLAY
 Man/Model VARIOUS BUCHANAN/525 (TERM BK) HOFFMAN NEMA 4 (ENCLOSURE)
 Safety Function 11/12 SUPPORT OF SR DISPLAY/ELECT DIST

Poor Original

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 7

Plant Location 130
 Operating Time Req/Avail R-30 day
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
 Aging THERMAL-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT
 17446-4
 QUAL STATUS DOR

Equipment No J211
 Description A0203-1D LIMIT SWITCH JUNCTION BOX
 System MAIN STEAM CNTM ISOLATION SAFETY RELATED DISPLAY
 Man/Model VARIOUS BUCHANAN/525 (TERM BK) HOFFMAN NEMA 4 (ENCLOSURE)
 Safety Function 11/12 SUPPORT OF SR DISPLAY/ELECT DIST
 Plant Location 130
 Operating Time Req/Avail R-30 day
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
 Aging THERMAL-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT
 17446-4
 QUAL STATUS DOR

Equipment No J212
 Description A0203-1A LIMIT SWITCH JUNCTION BOX
 System MAIN STEAM RPS
 Man/Model VARIOUS BUCHANAN/525 (TERM BK) HOFFMAN NEMA 4 (ENCLOSURE)
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 130
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#%) -NONE not required during loca RAD-NONE not required during loca
 Qual Envir TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
 Aging THERMAL-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT
 17446-4
 QUAL STATUS DOR

Equipment No J213
 Description A0203-1B LIMIT SWITCH JUNCTION BOX
 System MAIN STEAM RPS
 Man/Model VARIOUS BUCHANAN/525 (TERM BK) HOFFMAN NEMA 4 (ENCLOSURE)
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 130
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#%) -NONE not required during loca RAD-NONE not required during loca
 Qual Envir TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
 Aging THERMAL-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT
 17446-4
 QUAL STATUS DOR

Equipment No J214
 Description A0203-1C LIMIT SWITCH JUNCTION BOX
 System MAIN STEAM RPS

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 8

Man/Model	VARIOUS BUCHANAN/525 (TERM BK)	HOFFMAN NEMA 4 (ENCLOSURE)
Safety Function	12 ELECTRICAL DISTRIBUTION	
Plant Location	130	
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min	
DBE Env Req	(F/#%) -NONE not required during loca RAD-NONE not required during loca	
Qual Envir	TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)	
Aging	THERMAL-NOT SIGNIFICANT	
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	
Supporting Document	LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT	
QUAL STATUS DOR	17446-4	

Equipment No	J215
Description	AU203-1D LIMIT SWITCH JUNCTION BOX
System	MAIN STEAM RPS
Man/Model	VARIOUS BUCHANAN/525 (TERM BK)
Safety Function	HOFFMAN NEMA 4 (ENCLOSURE)
Plant Location	130
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min
DBE Env Req	(F/#%) -NONE not required during loca RAD-NONE not required during loca
Qual Envir	TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
Aging	THERMAL-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR
Supporting Document	LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BPCo 2/17/79 (TERM BLOCK) MEMO P&CS 80-184 (aging) WYLE RPT
QUAL STATUS DOR	17446-4

Equipment No	J216
Description	JUNCTION BOX AND TERMINAL BLOCKS
System	CNTM ISOLATION ELECTRICAL DISTRIBUTION
Man/Model	VARIOUS BUCHANAN/525 (TERM BK)
Safety Function	HOFFMAN NEMA 4 (ENCLOSURE)
Plant Location	130
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
Aging	THERMAL-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR (TERM BLOCK)
Supporting Document	LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BECo 2/17 79 (TERM BLOCK) BPCo SCEQ (JUNCTION BOX) BPCo CEQE (JUNCTION BOX) MEMO P&CS 80-184 (aging) WYLE RPT 17446-4
QUAL STATUS DOR	

Equipment No	J43
Description	JUNCTION BOX AND TERMINAL BLOCK
System	CNTM ISOLATION ELECTRICAL DISTRIBUTION
Man/Model	VARIOUS BUCHANAN/525 (TERM BK)
Safety Function	HOFFMAN NEMA 4 (ENCLOSURE)
Plant Location	130
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #11 RAD=2 04X10EB (TERM BLOCK)
Aging	THERMAL-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR (TERM BLOCK)
Supporting Document	LIMITORQUE RPT 600376A/LIMITORQUE LTR TO BECo 2/17 79 (TERM BLOCK) BPCo SCEQ (JUNCTION BOX) BPCo CEQE (JUNCTION BOX) MEMO P&CS 80-184 (aging) WYLE RPT 17446-4
QUAL STATUS DOR	

Equipment No	J44
--------------	-----

POOR ORIGINAL

POOR ORIGINAL

Description	JUNCTION BOX AND TERMINAL BLOCK		
System	CINTM ISOLATION ELECTRICAL DISTRIBUTION		
Man/Model	VARIOUS BUCHANAN/525 (TERM BX) HOFFMAN NEMA 4 (ENCLOSURE)		
Safety Function	12 ELECTRICAL DISTRIBUTION		
Plant Location	1.30		
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #11 RAD-2 04X10EB (TERM BLOCK)		
Aging	THERMAL-NOT SIGNIFICANT		
Method of Qualification	TEST/SEQUENTIAL/SIMILAR (TERM BLOCK)		
Supporting Document	LIMITOTORQUE RPT 600376A/LIMITOTORQUE LTR TO BECo 2/17 79 (TERM BLOCK) BPCo SCEQ (JUNCTION BOX) BPCo CEQE (JUNCTION BOX) MEMO P&CS 80-184 (aging) WYLE RPT 17446-4		
QUAL STATUS	DOR		

Equipment No	J55		
Description	JUNCTION BOX AND TERMINAL BLOCKS		
System	CINTM ISOLATION ELECTRICAL DISTRIBUTION		
Man/Model	VARIOUS BUCHANAN/525 (TERM BX) HOFFMAN NEMA 4 (ENCLOSURE)		
Safety Function	12 ELECTRICAL DISTRIBUTION		
Plant Location	1.30		
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #11 RAD-2 04X10EB (TERM BLOCK)		
Aging	THERMAL-NOT SIGNIFICANT		
Method of Qualification	TEST/SEQUENTIAL/SIMILAR (TERM BLOCK)		
Supporting Document	LIMITOTORQUE RPT 600376A/LIMITOTORQUE LTR TO BECo 2/17 79 (TERM BLOCK) BPCo SCEQ (JUNCTION BOX) BPCo CEQE (JUNCTION BOX) MEMO P&CS 80-184 (aging) WYLE RPT 17446-4		
QUAL STATUS	DOR		

Equipment No	J56		
Description	JUNCTION BOX AND TERMINAL BLOCKS		
System	CINTM ISOLATION ELECTRICAL DISTRIBUTION		
Man/Model	VARIOUS BUCHANAN/525 (TERM BX) HOFFMAN NEMA 4 (ENCLOSURE)		
Safety Function	12 ELECTRICAL DISTRIBUTION		
Plant Location	1.30		
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #11 RAD-2 04X10EB (TERM BLOCK)		
Aging	THERMAL-NOT SIGNIFICANT		
Method of Qualification	TEST/SEQUENTIAL/SIMILAR (TERM BLOCK)		
Supporting Document	LIMITOTORQUE RPT 600376A/LIMITOTORQUE LTR TO BECo 2/17 79 (TERM BLOCK) BPCo SCEQ (JUNCTION BOX) BPCo CEQE (JUNCTION BOX) MEMO P&CS 80-184 (aging) WYLE RPT 17446-4		
QUAL STATUS	DOR		

Equipment No	M01001-50		
Description	MOTOR OPERATOR 20-N14M3 VALVE M241		
System	RHR CINTM ISOLATION		
Man/Model	LIMITOTORQUE SMB-2-40 117163 337511C RELIANCE Y23260BAILU		
Safety Function	2/4A BLOCK VALVE-RHR SHUTDOWN-ALL RHR PUMPS		
Plant Location	1.30		
Operating Time Req/Avail	R-30 day		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB		
Aging	THERMAL-100 hrs 180C MECH-500 CYCLES		
Method of Qualification	TEST/SEQUENTIAL		
Supporting Document	LIMITOTORQUE LETTER TO BPCO 4-27-79 LIMITOTORQUE TWX TO BPCO 5-17-79 LIMITOTORQUE TWX TO BPCO 5-29-79 LIM ITOTORQUE TEST RPT 600198 1-2-69 LIMITOTORQUE TEST RPT 600376A WYLE RPT 17446-5		
QUAL STATUS	DOR		

POOR ORIGINAL

Equipment No	M01001-63
Description	MOTOR OPERATOR 4-N14M3 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00-5 97274A 337511B 1D463515-DV
Safety Function	2 RX VESSEL HD SPRAY BLOCK VALVE
Plant Location	1 30
Operating Time Req/Avail	R-30 day
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB
Aging	THERMAL-100 hrs 180C MECH-500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LIMITORQUE LETTER TO BPCO 4-27-79 LIMITORQUE TWX TO BPCO 5-17-79 LIMITORQUE TWX TO BPCO 5-29-79 LIM ITORQUE TEST RPT 600198 1-2-69 LIMITORQUE TEST RPT 600376A WYLE RPT 17446-5
QUAL STATUS	DR

Equipment No	M01201-2
Description	MOTOR OPERATOR 6-N14M3 VALVE M247
System	RCTR HTR CLEAN-UP CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00-15 99131A 337511H RELIANCE 447271-DU
Safety Function	2 ISO. RECIRC. TO CLEANUP SYSTEM PBOC TERM
Plant Location	1 30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day R-PBOC-30 min
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB
Aging	THERMAL-100 hrs 180C MECH-500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LIMITORQUE LETTER TO BPCO 4-27-79 LIMITORQUE TWX TO BPCO 5-17-79 LIMITORQUE TWX TO BPCO 5-29-79 LIM ITORQUE TEST RPT 600198 1-2-69 LIMITORQUE TEST RPT 600376A WYLE RPT 17446-5
QUAL STATUS	DR

Equipment No	M01301-16
Description	MOTOR OPERATOR N14 VALVES RCIC M245
System	RCIC CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00-10 126352 345137C PEERLESS FX01233
Safety Function	2 RCIC CONT ISO VALVE-INSIDE PBOC TERM
Plant Location	1 30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day R-PBOC-30 min
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB
Aging	THERMAL-100 hrs 180C MECH-500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LIMITORQUE LETTER TO BPCO 4-27-79 LIMITORQUE TWX TO BPCO 5-17-79 LIMITORQUE TWX TO BPCO 5-29-79 LIM ITORQUE TEST RPT 600198 1-2-69 LIMITORQUE TEST RPT 600376A WYLE RPT 17446-5
QUAL STATUS	DR

Equipment No	M0202-5A
Description	MOTOR OPERATOR 28 GATE VALVE M252
System	REACTOR RECIRCULATION SYSTEM RHR
Man/Model	LIMITORQUE SMB-3 99741A 329731-E2 RELIANCE S/N YF276660AIWA
Safety Function	4A RECIRC. PP DISCH. VV (LOOP SEL LGK)
Plant Location	1 30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-BX10E5 (active) RAD-3.5X10E7 (passive)
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB (excluding brake) RAD-1X10E6 (brake)
Aging	THERMAL-100 hrs 180C MECH-500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LIMITORQUE LTR TO BPCO 6/11/79 LIMITORQUE LTR TO EDISONB/31/79 LIMITORQUE TEST RPT 600198 LIMITORQU

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 11

E TEST RPT 600376A WYLE RPT 17446-5 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO BO-238 (RAD brake)
 QUAL STATUS JCD
 QUAL PLAN RA 9/81 FE 9/81
 FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION

Equipment No	M0202-5B
Description	MOTOR OPERATOR 28 GATE VALVE
System	REACTOR RECIRCULATION SYSTEM RHR
Man/Model	LIMITORQUE SMB-3 99742A 329731-E2 RELIANCE S/N Y268507A1
Safety Function	4A RECIRC. PP DISCH. VV (LOOP SEL LGK)
Plant Location	1 30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7 (active) RAD-3 5X10E7 (passive)
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB (excluding brake) RAD-1X10E6 (brake)
Aging	THERMAL-100 hrs 180C MECH-500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LIMITORQUE LTR TO BPCo 6/11/79 LIMITORQUE LTR TO EDISON8/31/79 LIMITORQUE TEST RPT 600198 LIMITORQUE TEST RPT 600376A WYLE RPT 17446-5 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO BO-238 (RAD brake)
QUAL STATUS JCD	FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
QUAL PLAN RA 9/81	FE 9/81

POOR ORIGINAL

Equipment No	M02301-4
Description	MOTOR OPERATOR N14 VALVES HPCI M243
System	HPCI CNTM ISOLATION
Man/Model	LIMITORQUE SMB-2-60 117541 345137M PEERLESS FX01235
Safety Function	2/4 HPCI INJ ISO VALVE PBOC TERM
Plant Location	1 30
Operating Time Req/Avail	R-(A)-5 hr R-(P)-30 day
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB
Aging	THERMAL-100 hrs 180C MECH-500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LIMITORQUE LETTER TO BPCO 4-27-79 LIMITORQUE TWX TO BPCO 5-17-79 LIMITORQUE TWX TO BPCO 5-29-79 LMI TORQUE TEST RPT 600198 1-2-69 LIMITORQUE TEST RPT. 600376A WYLE RPT 17446-5
QUAL STATUS DOR	

Equipment No	M0261-1 M0220-1
Description	MOTOR OPERATOR 3-N14M4 VALVE M252
System	MAIN STEAM CNTM ISOLATION
Man/Model	LIMITORQUE SMB-000-5 121778 345137G PEERLESS FX01632
Safety Function	2 MSIV DRAIN BLOCK VALVE
Plant Location	1 30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day R-PBOC(A)-30 min R-PBOC(P)-30 day
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7
Qual Envir	TEST CURVE #10 TEST CURVE #11 RAD-2X10EB
Aging	THERMAL 100 hrs 180C MECH-500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LIMITORQUE LETTER TO BPCO 4-27-79 LIMITORQUE TWX TO BPCO 5-17-79 LIMITORQUE TWX TO BPCO 5-29-79 LIM TORQUE TEST RPT 600198 1-2-69 LIMITORQUE TEST RPT. 600376A WYLE RPT 17446-5
QUAL STATUS DOR	

Equipment No	Q100A
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 236X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 9
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3 5X10E7

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 12

Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%)
QUAL STATUS	DUR-A
QUAL PLAN	AA 4/81 FE 6/81

POOR ORIGINAL

Equipment No	Q100B
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 9
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBQC
DDE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%)
QUAL STATUS	DUR-A
QUAL PLAN	AA 4/81 FE 6/81

Equipment No	Q100C
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 10
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBQC
DDE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%)
QUAL STATUS	DUR-A
QUAL PLAN	AA 4/81 FE 6/81

Equipment No	Q100D
Description	CONTAINMENT ELECTRICAL PENETRATION NEUTRON MONITORING
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 10
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBQC
DDE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%)
QUAL STATUS	DUR-A
QUAL PLAN	AA 4/81 FE 6/81

Equipment No	Q100E
Description	CONTAINMENT ELECTRICAL PENETRATION LOW VOLTAGE SIGNAL & THERMOCOUPLE
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 9

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 13

Operating Time Req/Avail R-LOCA(P)-30 day NR-PBCC
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #6 RAD-1X10E8 (SEALS)
 Aging outstanding item
 Method of Qualification TEST/SEPARATE
 Supporting Document EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9
 QUAL STATUS DOR-A
 QUAL PLAN AA 4/81 FE 6/81

Equipment No Q101A
 Description CONTAINMENT ELECTRICAL PENETRATION 5 KV POWER
 System CNTM INTEGRITY
 Man/Model PHYSICAL SCIENCE CANISTER TYPE #7060-1
 Safety Function 2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
 Plant Location 1 30 1 9
 Operating Time Req/Avail R-LOCA(P)-30 day NR-PBCC
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #6 RAD-4.5X10E15 HUMIDITY-100%
 Aging PRIMARY SEAL AL203 CERAMIC NOT AFFECTED BY THERMAL AGING
 Method of Qualification F/# TEST RAD-EVALUATION HUMIDITY-EVALUATION
 Supporting Document SPSD-GC-206 BPCo SCEQ BPCo CEQE WYLE RPT 17446-6
 QUAL STATUS DOR

Equipment No Q101B
 Description CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
 System ELECTRICAL DISTRIBUTION CNTM INTEGRITY
 Man/Model GE CANISTER TYPE PENETRATION 238X60*NLG#
 Safety Function 2A/12 CNTM INTEGRITY/ELECT DISTRIBUTION
 Plant Location 1 30 1 9
 Operating Time Req/Avail R-30 day
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #7 RAD-1X10E8 (SEALS)
 Aging outstanding item
 Method of Qualification TEST/SEPARATE
 Supporting Document EPAQ-055/EPAQ-007 (F/#/%) EPAQ-046 (RAD-SEALS) EPAQ-047/AEPAQ-3 (SIS CABLE) BPCo SCEQ WYLE RPT 17446-9
 QUAL STATUS DOR-A
 QUAL PLAN AA 4/81 FE 6/81

Equipment No Q101C
 Description CONTAINMENT ELECTRICAL PENETRATION 5 KV POWER
 System CNTM INTEGRITY
 Man/Model PHYSICAL SCIENCE CANISTER TYPE #7060-2
 Safety Function 2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
 Plant Location 1 30 1 10
 Operating Time Req/Avail R-LOCA(P)-30 day NR-PBCC
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #6 RAD-4.5X10E15 HUMIDITY-100%
 Aging PRIMARY SEAL AL203 CERAMIC NOT AFFECTED BY THERMAL AGING
 Method of Qualification F/# TEST RAD-EVALUATION HUMIDITY-EVALUATION
 Supporting Document SPSD-GC-206 BPCo SCEQ BPCo CEQE WYLE RPT 17446-6
 QUAL STATUS DOR

Equipment No Q102A
 Description CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
 System ELECTRICAL DISTRIBUTION CNTM INTEGRITY
 Man/Model GE CANISTER TYPE PENETRATION 238X60*NLG#
 Safety Function 2A/12 CNTM INTEGRITY/ELECT DISTRIBUTION

POOR ORIGINAL

POOR ORIGINAL

Plant Location	1 30	1 10
Operating Time Req/Avail	R-30 day	
Dut Envir	SERVICE PROFILE 1b	RAD-3 5X10E7
Aging	TEST CURVE #7	RAD-1X10E8 (SEALS)
Method of Qualification	TEST/SEPARATE	
Supporting Document	EPAQ-055/EPAQ-Q07 (F/N%)	EPAQ-046 (RAD-SEALS)
QUAL STATUS	DUR-A	
QUAL PLAN	AA 4/81	FE 6/81
Equipment No	Q1033	CURTAINWALL ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
Description	SYSTEM	ELECTRICAL DISTRIBUTION CNTM INTEGRITY
System	GE CANISTER TYPE PENETRATION 238X60*NLG*	
Man/Model	2A/12	CNTM INTEGRITY/ELECT DISTRIBUTION
Safety Function	1 30	1 9
Plant Location	R-30 day	
Operating Time Req/Avail	SERVICE PROFILE 1a	SERVICE PROFILE 1b
Dut Env Req	TEST CURVE #7	RAD-3 5X10E7
Qual Envir	outstanding item	
Aging	TEST/SEPARATE	
Method of Qualification	EPAQ-055/EPAQ-Q07 (F/N%)	EPAQ-046 (RAD-SEALS)
Supporting Document	446-9	EPAQ-047/AEPAG-3 (SIS CABLE)
QUAL STATUS	DUR-A	
QUAL PLAN	AA 4/81	FE 6/81
Equipment No	Q1034	CURTAINWALL ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
Description	SYSTEM	ELECTRICAL DISTRIBUTION CNTM INTEGRITY
System	GE CANISTER TYPE PENETRATION 238X60*NLG*	
Man/Model	2A/12	CNTM INTEGRITY/ELECT DISTRIBUTION
Safety Function	1 30	1 10
Plant Location	R-30 day	
Operating Time Req/Avail	SERVICE PROFILE 1a	SERVICE PROFILE 1b
Dut Env Req	TEST CURVE #7	RAD-3 5X10E7
Qual Envir	outstanding item	
Aging	TEST/SEPARATE	
Method of Qualification	EPAQ-055/EPAQ-Q07 (F/N%)	EPAQ-046 (RAD-SEALS)
Supporting Document	446-9	EPAQ-047/AEPAG-3 (SIS CABLE)
QUAL STATUS	DUR-A	
QUAL PLAN	AA 4/81	FE 6/81
Equipment No	Q1038	LOW VOLTAGE SIGNAL & THERMOCOUPLE
Description	SYSTEM	CNTM INTEGRITY
System	GE CANISTER TYPE PENETRATION 238X60*NLG*	
Man/Model	2A	CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Safety Function	1 30	1 9
Plant Location	R-LOCAP)-30 day	NR-PBDC
Operating Time Req/Avail	SERVICE PROFILE 1a	SERVICE PROFILE 1b
Dut Env Req	TEST CURVE #3	RAD-3 5X10E7
Qual Envir	outstanding item	
Aging	TEST/SEPARATE	
Method of Qualification	EPAQ-055/EPAQ-Q09/EPAQ-Q10 (F/N%)	EPAQ-046 (PAD-SEALS)
Supporting Document		BPCo SCEQ WYLE RPT 17446-9
QUAL STATUS	DUR-A	
QUAL PLAN	AA 4/81	FE 6/81

7-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 15

POOR ORIGINAL

Equipment No	Q104A		
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION		
System	CNTM INTEGRITY		
Man/Model	GE CANISTER TYPE PENETRATION 23BX60*NLG*		
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY		
Plant Location	1 30 1 9		
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBOC		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #8 RAD-1X10E8 (SEALS)		
Aging	outstanding item		
Method of Qualification	TEST/SEPARATE		
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9		
QUAL STATUS	DOR-A		
QUAL PLAN	AA	4/81	FE 6/81

Equipment No	Q104B		
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION		
System	CNTM INTEGRITY		
Man/Model	GE CANISTER TYPE PENETRATION 23BX60*NLG*		
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY		
Plant Location	1 30 1 9		
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBOC		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #8 RAD-1X10E8 (SEALS)		
Aging	outstanding item		
Method of Qualification	TEST/SEPARATE		
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9		
QUAL STATUS	DOR-A		
QUAL PLAN	AA	4/81	FE 6/81

Equipment No	Q104C		
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION		
System	CNTM INTEGRITY		
Man/Model	GE CANISTER TYPE PENETRATION 23BX60*NLG*		
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY		
Plant Location	1 30 1 9		
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBOC		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #8 RAD-1X10E8 (SEALS)		
Aging	outstanding item		
Method of Qualification	TEST/SEPARATE		
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9		
QUAL STATUS	DOR-A		
QUAL PLAN	AA	4/81	FE 6/81

Equipment No	Q104D		
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION		
System	CNTM INTEGRITY		
Man/Model	GE CANISTER TYPE PENETRATION 23BX60*NLG*		
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY		
Plant Location	1 30 1 9		
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PBOC		
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7		
Qual Envir	TEST CURVE #8 RAD-1X10E8 (SEALS)		
Aging	outstanding item		
Method of Qualification	TEST/SEPARATE		
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#/%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9		
QUAL STATUS	DOR-A		

POOR ORIGINAL

QUAL PLAN AA 4/81 FE 6/81

Equipment No	G104E
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 9
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PDOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9
QUAL STATUS	DUR-A

QUAL PLAN AA 4/81 FE 6/81

Equipment No	G104F
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 9
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PDOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9
QUAL STATUS	DUR-A

QUAL PLAN AA 4/81 FE 6/81

Equipment No	G104G
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION & TIP SYS
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 10
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PDOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE
Supporting Document	EPAQ-060/EPAQ-009/EPAQ-010 (F/#%) EPAQ-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9
QUAL STATUS	DUR-A

QUAL PLAN AA 4/81 FE 6/81

Equipment No	G104H
Description	CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION
System	CNTM INTEGRITY
Man/Model	GE CANISTER TYPE PENETRATION 238X60*NLG*
Safety Function	2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
Plant Location	1 30 1 10
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PDOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #8 RAD-1X10EB (SEALS)
Aging	outstanding item
Method of Qualification	TEST/SEPARATE

74-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 17

Supporting Document EPAG-060/EPAG-009/EPAG-010 (F/#/%) EPAG-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9
 QAL STATUS DOR-A
 QAL PLAN AA 4/81 FE 6/81

Equipment No Q104J
 Description CONTAINMENT ELECTRICAL PENETRATION ROD POSITION INDICATION & TIP SYS
 System CNTM INTEGRITY
 Man/Model GE CANISTER TYPE PENETRATION 238X60*NLG*
 Safety Function 2A CNTM INTEGRITY PRESSURE BOUNDARY ONLY
 Plant Location 1 30 1 10
 Operating Time Req/Avail R-LOCA(P) 30 day NR-PBAC
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #8 RAD-1X10EB (SEALS)
 Aging outstanding item
 Method of Qualification TEST/SEPARATE
 Supporting Document EPAG-060/EPAG-009/EPAG-010 (F/#/%) EPAG-046 (RAD-SEALS) BPCo SCEQ WYLE RPT 17446-9
 QAL STATUS DOR-A
 QAL PLAN AA 4/81 FE 6/81

POOR ORIGINAL

Equipment No Q105A
 Description CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
 System ELECTRICAL DISTRIBUTION CNTM INTEGRITY
 Man/Model GE CANISTER TYPE PENETRATION 238X60*NLG*
 Safety Function 2A/12 CNTM INTEGRITY/ELECT DISTRIBUTION
 Plant Location 1 30 1 9
 Operating Time Req/Avail R-30 day
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #7 RAD-1X10EB (SEALS)
 Aging outstanding item
 Method of Qualification TEST/SEPARATE
 Supporting Document EPAG-055/EPAG-007 (F/#/%) EPAG-046 (RAD-SEALS) EPAG-047/AEPAG-3 (SIS CABLE) BPCo SCEQ WYLE RPT 17446-9
 QAL STATUS DOR-A
 QAL PLAN AA 4/81 FE 6/81

Equipment No Q105B
 Description CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
 System ELECTRICAL DISTRIBUTION CNTM INTEGRITY
 Man/Model GE CANISTER TYPE PENETRATION 238X60*NLG*
 Safety Function 2A/12 CNTM INTEGRITY/ELECT DISTRIBUTION
 Plant Location 1 30 1 10
 Operating Time Req/Avail R-30 day
 DBE Env Req SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
 Qual Envir TEST CURVE #7 RAD-1X10EB (SEALS)
 Aging outstanding item
 Method of Qualification TEST/SEPARATE
 Supporting Document EPAG-055/EPAG-007 (F/#/%) EPAG-046 (RAD-SEALS) EPAG-047/AEPAG-3 (SIS CABLE) BPCo SCEQ WYLE RPT 17446-9
 QAL STATUS DOR-A
 QAL PLAN AA 4/81 FE 6/81

Equipment No Q106B
 Description CONTAINMENT ELECTRICAL PENETRATION 600 VOLT POWER & CONTROL
 System ELECTRICAL DISTRIBUTION CNTM INTEGRITY
 Man/Model GE CANISTER TYPE PENETRATION 238X60*NLG*
 Safety Function 2A/12 CNTM INTEGRITY/ELECT DISTRIBUTION
 Plant Location 1 30 1 9
 Operating Time Req/Avail R-30 day

174-01B PLANT UNIT 1 FINAL REHABILITATION (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 18

DATE FOR Req		SERVICE PROFILE 1a	SERVICE PROFILE 1b	RAD-3 5X10E7
Goal Envir		TEST CURVE #7	RAD-1X10E7 SEALS	
Aging		outstanding item		
Method or Qualification		TEST/SEPARATE	TP 64-0252/EP&Q-QZ (F/N/Z)	EPAQ-047/AEP&Q-3 (SIS CABLE)
Supporting Document	44c-9			
QUAL STATUS	DUR-A			
QUAL PLAN	AA 4/B1	FE 6/B1		

POOR ORIGINAL

Equipment No		G202A		
Description		CONTAINMENT ELECTRICAL PENETRATION TORUS		
System		CHIM INTEGRITY		
Man/Model	CNIMAX	MODULAR TYPE	PRESSURE BOUNDARY ONLY	
Safety Function	2A	CNIM INTEGRITY	PRESSURE BOUNDARY ONLY	
Plant Location	1-30	TORUS AREA		
Operating Time Req/Avail	R-LOCA(P)-30 day	NR-PBUC		
DBT Env Req	SERVICE PROFILE 1a	SERVICE PROFILE 1b	RAD-3 5X10E7	
Goal Envir	TEST CURVE #5	RAD-1X10E8		
Aging	THE R/HAL-16.9hrs 124C			
Method of Qualification	TEST/SEPARATE/SIMILAR			
Supporting Document	CNIMAX RPT IPS-42 REV. A	WYLE RPT 1744b-7		
QUAL STATUS	DUR			

Equipment No		G202B		
Description		CONTAINMENT ELECTRICAL PENETRATION TORUS		
System		CHIM INTEGRITY		
Man/Model	CNIMAX	MODULAR TYPE	PRESSURE BOUNDARY ONLY	
Safety Function	2A	CNIM INTEGRITY	PRESSURE BOUNDARY ONLY	
Plant Location	1-30	TORUS AREA		
Operating Time Req/Avail	R-LOCA(P)-30 day	NR-PBUC		
DBT Env Req	SERVICE PROFILE 1a	SERVICE PROFILE 1b	RAD-3 5X10E7	
Goal Envir	TEST CURVE #5	RAD-1X10E8		
Aging	THE R/HAL-16.9hrs 124C			
Method of Qualification	TEST/SEPARATE/SIMILAR			
Supporting Document	CNIMAX RPT IPS-42 REV. A	WYLE RPT 1744b-7		
QUAL STATUS	DUR			

Equipment No		S15725		
Description		TYPE SIS SWITCHBOARD WIRE N/A		
System		ELECTRICAL DISTRIBUTION		
Man/Model	QE	S1-52275		
Safety Function	12	ELECT DIST		
Plant Location	1-30	VARIOUS		
Operating Time Req/Avail	R-30 day	ASSUMED		
DBT Env Req	SERVICE PROFILE 1a	SERVICE PROFILE 1b	RAD-2X10E8	
Goal Envir	TEST CURVE #9	RAD-2X10E8		
Aging	THE R/HAL-4.2hrs 132C			
Method of Qualification	TEST/SEPARATE			
Supporting Document	EPAQ-015 (F/N/Z)	EPAQ-016 (F/N/Z)	EPAQ-047 (RAD)	AEP&Q-3 (RAD)
QUAL STATUS	DUR	97-2 SIMILAR EQUIPMENT	WYLE RPT 1744b-8	

Equipment No		S157279		
Description		TYPE SIS SWITCHBOARD WIRE		
System		ELECTRICAL DISTRIBUTION		
Man/Model	GE SIS VM-1	S157279		
Safety Function	12	ELECT DIST		
Plant Location	1-30	VARIOUS		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 19

Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #36 RAD-2.2X10EB
Aging	THERMAL-432hrs 132C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	FIRL TEST REPORT F-C4497-2
QUAL STATUS	DDR

Equipment No	SPLICE (600V PENETRATION)
Description	PENETRATION 600V POWER & CONTROL CABLE SPLICES
System	ELECTRICAL DISTRIBUTION
Man/Model	RAYCHEM WCSF-N
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1 30
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-2X10EB
Qual Envir	TEST CURVE #16 RAD-2X10EB
Aging	THERMAL-168 hrs 150C RAD-5X10E7
Method of Qualification	TEST/SIMULTANEOUS
Supporting Document	F-C4033-3 FIRL 43905-2 WYLE WYLE RPT 17446-10
QUAL STATUS	DDR

Equipment No	SPLICE (SOV)
Description	SOV 600V CABLE SPLICES
System	ELECTRICAL DISTRIBUTION
Man/Model	RAYCHEM WCSF-N
Safety Function	12 ELECTRICAL DISISTRIBUTION
Plant Location	1 30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #16 RAD-2X10EB
Aging	THERMAL-168 hrs 150C RAD-5X10E7
Method of Qualification	TEST/SIMULTANEOUS
Supporting Document	F-C4033-3 FIRL 43905-2 WYLE F-C5022-2 FIRL WYLE RPT 17446-10
QUAL STATUS	DDR

Equipment No	SV1001-95A
Description	SOLENOID VALVE FOR AD 1001-95A M241
System	RHR CNTM ISOLATION
Man/Model	ASCO NP8320A184E
Safety Function	2 TESTABLE CK VALVE BYPASS VALVE
Plant Location	1 30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQ52167B/TR WYLE RPT 17446-11
QUAL STATUS	DDR

Equipment No	SV1001-95B
Description	SOLENOID VALVE FOR AD 1001-95B M241
System	RHR CNTM ISOLATION
Man/Model	ASCO NP8320A184E
Safety Function	2 TESTABLE CK VALVE BYPASS VALVE
Plant Location	1 30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7

POOR ORIGINAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) IN CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 20

Qual. Type	TEST CURVE #13 RAD-2X10E3
Aging	THERMAL-268 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR WYLE RPT 17446-11
QUAL. STATUS	DQR

Equipment No	SV1400-51A
Description	SOLENOID VALVE FOR AD140051A M242
System	CORE SPRAY CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	2 TESTABLE CK BYPASS VV SOV
Plant Location	I-30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #13 RAD-2X10E3
Aging	THERMAL-268 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR WYLE RPT 17446-11
QUAL. STATUS	DQR

Equipment No	SV1400-51B
Description	SOLENOID VALVE FOR AD1400-51B M242
System	CORE SPRAY CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	2 TESTABLE CK BYPASS VV SOV
Plant Location	I-30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #13 RAD-2X10E3
Aging	THERMAL-268 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR WYLE RPT 17446-11
QUAL. STATUS	DQR

Equipment No	SV203-3A
Description	RELIEF VALVE SOLENOID VALVE M252
System	MAIN STEAM ADS
Man/Model	TARGET ROCK 1/2SMS-A-01
Safety Function	10 ADS ACTUATION
Plant Location	I-30
Operating Time Req/Avail	R-8 hr
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-1.2X10E7
Qual Envir	TEST CURVE #33 RAD-3.2X10E7
Aging	THERMAL-480 hrs 140C MECH-8000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	TEST SUMMARY per GE LTR G-HK-9-123 9/23/79 WYLE RPT 17446-12
QUAL. STATUS	DQR

Equipment No	SV203-3B
Description	RELIEF VALVE SOLENOID VALVE M252
System	MAIN STEAM ADS
Man/Mod_1	TARGET ROCK 1/2SMS-A-01
Safety Function	10 ADS ACTUATION
Plant Location	I-30
Operating Time Req/Avail	R-8 hr
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-1.2X10E7
Qual Envir	TEST CURVE #33 RAD-3.2X10E7
Aging	THERMAL-480 hrs 140C MECH-8000 CYCLES

POOR ORIGINAL

POOR ORIGINAL

Method of Qualification	TEST/SEQUENTIAL
Supporting Document	TEST SUMMARY per GE LTR G-HK-9-123 9/23/79
QUAL. STATUS	DDR
Equipment No	SV203-3C
Description	RELIEF VALVE SOLENOID VALVE M252
System	MAIN STEAM ADS
Man/Model	TARGET ROCK 1/2SMS-A-01
Safety Function	10 ADS ACTUATION
Plant Location	I-30
Operating Time Req/Avail	R-8 hr
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-1.2X10E7
Qual Envir	TEST CURVE #33 RAD-3.2X10E7
Aging	THERMAL-480 hrs 140C MECH-8000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	TEST SUMMARY per GE LTR G-HK-9-123 9/23/79
QUAL. STATUS	DDR

Equipment No	SV203-3D
Description	RELIEF VALVE SOLENOID VALVE M252
System	MAIN STEAM ADS
Man/Model	TARGET ROCK 1/2SMS-A-01
Safety Function	10 ADS ACTUATION
Plant Location	I-30
Operating Time Req/Avail	R-8 hr
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-1.2X10E7
Qual Envir	TEST CURVE #33 RAD-3.2X10E7
Aging	THERMAL-480 hrs 140C MECH-8000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	TEST SUMMARY per GE LTR G-HK-9-123 9/23/79
QUAL. STATUS	DDR

Equipment No	SV220-44
Description	SOLENOID VALVE FOR AD 220-44 M252
System	REACTOR RECIRCULATION SYSTEM CNIM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	2 SAMPLE SYSTEM ISOLATION
Plant Location	I-30
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day R-PBOC(A)-30 min R-PBOC(P)-30 day
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AGS2167B/TR WYLE RPT 17446-11
QUAL. STATUS	DDR

Equipment No	TERMINATIONS (LESS THAN 4 KV)
Description	STANDARD INDUSTRIAL COMPRESSION TYPE TERMINATIONS
System	ELECTRICAL DISTRIBUTION
Man/Model	VARIOUS VARIOUS MFR OF RING-TONGUE TERMINALS
Safety Function	12 ELECT DIST.
Plant Location	I-30 VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	SERVICE PROFILE 1a SERVICE PROFILE 1b RAD-3.5X10E7
Qual Envir	(F/#%) NOT REQUIRED not a significant failure mechanism RAD-NOT REQUIRED not a significant failure mecha
Aging	NOT A SIGNIFICANT FAILURE MECHANISM
Method of Qualification	ANALYSIS/UTILITY/TESTING LAB

Supporting Document WYLE RPT 17446-12
GUAL STATUS JCTO FINAL EVALUATION TO VERIFY THAT BARRIER TYPE TERMINAL BLOCKS WERE UTILIZED
GUAL PLANT 11 9/81 HT/RA/MS (IF NECESSARY) FE 11/81

POOR ORIGINAL

PRINT OUT

2 II

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 1

Equipment No 210 KERITE
 Description 2/C STRANDED #10 600V POWER & CONTROL
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE FR INSULATION FR OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBDC-1 in area 1.10B assumed worst case RAD-6.2X10E5
 Qual Envir TEST CURVE #3 RAD-2X10E8
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No 410 KERITE
 Description 4/C STRANDED #10 600V POWER & CONTROL
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE FR INSULATION FR OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBDC-1 in area 1.10B assumed worst case RAD-6.2X10E5
 Qual Envir TEST CURVE #3 RAD-2X10E8
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No A1 KERITE
 Description 1/C STRANDED #0000 5KV CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE HT INSULATION NS JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBDC-1 in area 1.10B assumed worst case RAD-1.1X10E7
 Qual Envir TEST CURVE #1 RAD-2X10E8
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL STATUS DOR

Equipment No A1 OKONITE
 Description 1/C STRANDED #0000 5KV CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model OKONITE OKOLITE INSULATION OKOLON JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBDC-1 in area 1.10B assumed worst case RAD-1.1X10E7
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E7
 Aging outstanding item
 Method of Qualification EVALUATION/VENDOR based on TEST/SEPARATE/SIMILAR eqpt
 Supporting Document OKONITE LTR 6/4/79 (F/#/%) OKONITE LTR 7/9/79 (RAD) BPCo SCEQ
 QUAL STATUS DOR-A

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 2

QUAL PLAN AA 3/81 FE 5/81

Equipment No A2 KERITE
 Description 1/C STRANDED 350 MCM SKV CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE HT INSULATION NS JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-1 in area 1.10B assumed worst case RAD-1.1X10E7
 Qual Envir TEST CURVE #1 RAD-2X10EB
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL. STATUS DOR

Equipment No A2 OKONITE
 Description 1/C STRANDED 350MCM SKV CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model OKONITE OKOLITE INSULATION OKOLON JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-1 in area 1.10B assumed worst case RAD-1.1X10E7
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E7
 Aging outstanding item
 Method of Qualification EVALUATION/VENDOR based on TEST/SEPARATE/SIMILAR eqpt
 Supporting Document OKONITE LTR 6/4/79 (F/#%) OKONITE LTR 7/9/79 (RAD) BPCo SCEQ
 QUAL. STATUS DOR-A

QUAL PLAN AA 3/81 FE 5/81

Equipment No A3 KERITE
 Description 1/C STRANDED 500MCM SKV CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE HT INSULATION NS JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-1 in area 1.10B assumed worst case RAD-1.1X10E7
 Qual Envir TEST CURVE #1 RAD-2X10EB
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL. STATUS DOR

Equipment No A4 KERITE
 Description 1/C STRANDED 1250MCM SKV CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE HT INSULATION NS JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-1 in area 1.10B assumed worst case RAD-1.1X10E7
 Qual Envir TEST CURVE #1 RAD-2X10EB
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL. STATUS DOR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 3

11

Equipment No	AO203-2A			
Description	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252			
System	MAIN STEAM RPS CNTM ISOLATION			
Man/Model	VARIOUS AVCO/C5159 (SOV) NAMCO/EA740-50100 (LIM SW)			
Safety Function	1/2/11 MSIV SCRAM & SR DSPLY (LIM SW)/MN STM ISO (SOV)			
Plant Location	STEAM TUNNEL			
Operating Time Req/Avail	R-(A)-30 min (SOV) R-(P)-30 day (SOV) R-30 day (LM SW)			
DBE Env Req	(F/#/%)-PBDC-B RAD-2.5X10E6			
Qual Envir	TEST CURVE #14 (SOV) TEST CURVE #15 (SOV) RAD-3X10E7 (SOV) TEST CURVE #18 (LIM SW) RAD-2.0 4X10E8 (LIM SW)			
Aging	MECH-55 CYCLES during F/#/% test (SOV) THERMAL-200 hrs 93C (LIM SW) MECH-100000 CYCLES (LIM SW)			
Method of Qualification	TEST/SEPARATE/SIMILAR EQPT (SOV) TEST/SEQUENTIAL (LIM SW)			
Supporting Document	GE LTR G-HK-9-44 ROCKWELL RPT #2792-03-02 (SOV F/#/%) GE PEDEM #126-62 (SOV RAD) NAMCO TEST RPT FOR MODEL EA-740 2/20/78 (LIM SW) ATWOOD & MORRILL TEST RPT #STR-060578-1 (LIM SW)			
QUAL STATUS	DOR-A(LIM SW) JCD(SV) FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE			
QUAL PLAN	AA 2/81(LIM SW) FE 4/81(SV)			

Equipment No	AO203-2B			
Description	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252 (730E 583)			
System	MAIN STEAM RPS CNTM ISOLATION			
Man/Model	VARIOUS AVCO/C5159 (SOV) NAMCO/EA740-50100 (LIM SW)			
Safety Function	1/2/11 MSIV SCRAM & SR DSPLY (LIM SW)/MN STM ISO (SOV)			
Plant Location	STEAM TUNNEL			
Operating Time Req/Avail	R-(A)-30 min (SOV) R-(P)-30 day (SOV) R-30 day (LM SW)			
DBE Env Req	(F/#/%)-PBDC-B RAD-2.5X10E6			
Qual Envir	TEST CURVE #14 (SOV) TEST CURVE #15 (SOV) RAD-3X10E7 (SOV) TEST CURVE #18 (LIM SW) RAD-2.0 4X10E8 (LIM SW)			
Aging	MECH-55 CYCLES during F/#/% test (SOV) THERMAL-200 hrs 93C (LIM SW) MECH-100000 CYCLES (LIM SW)			
Method of Qualification	TEST/SEPARATE/SIMILAR EQPT (SOV) TEST/SEQUENTIAL (LIM SW)			
Supporting Document	GE LTR G-HK-9-44 ROCKWELL RPT #2792-03-02 (SOV F/#/%) GE PEDEM #126-62 (SOV RAD) NAMCO TEST RPT FOR MODEL EA-740 2/20/78 (LIM SW) ATWOOD & MORRILL TEST RPT #STR-060578-1 (LIM SW)			
QUAL STATUS	DOR-A(LIM SW) JCD(SV) FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE			
QUAL PLAN	AA 2/81(LIM SW) FE 4/81(SV)			

Equipment No	AO203-2C			
Description	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252 (730E 583)			
System	MAIN STEAM RPS CNTM ISOLATION			
Man/Model	VARIOUS AVCO/C5159 (SOV) NAMCO/EA740-50100 (LIM SW)			
Safety Function	1/2/11 MSIV SCRAM & SR DSPLY (LIM SW)/MN STM ISO (SOV)			
Plant Location	STEAM TUNNEL			
Operating Time Req/Avail	R-(A)-30 min (SOV) R-(P)-30 day (SOV) R-30 day (LM SW)			
DBE Env Req	(F/#/%)-PBDC-B RAD-2.5X10E6			
Qual Envir	TEST CURVE #14 (SOV) TEST CURVE #15 (SOV) RAD-3X10E7 (SOV) TEST CURVE #18 (LIM SW) RAD-2.0 4X10E8 (LIM SW)			
Aging	MECH-55 CYCLES during F/#/% test (SOV) THERMAL-200 hrs 93C (LIM SW) MECH-100000 CYCLES (LIM SW)			
Method of Qualification	TEST/SEPARATE/SIMILAR EQPT (SOV) TEST/SEQUENTIAL (LIM SW)			
Supporting Document	GE LTR G-HK-9-44 ROCKWELL RPT #2792-03-02 (SOV F/#/%) GE PEDEM #126-62 (SOV RAD) NAMCO TEST RPT FOR MODEL EA-740 2/20/78 (LIM SW) ATWOOD & MORRILL TEST RPT #STR-060578-1 (LIM SW)			
QUAL STATUS	DOR-A(LIM SW) JCD(SV) FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE			
QUAL PLAN	AA 2/81(LIM SW) FE 4/81(SV)			

Equipment No	AO203-2D			
Description	SECOND ISOLATION VALVE AIR OPERATOR & VALVE CONTROL SYSTEM M252 (730E 583)			
System	MAIN STEAM RPS CNTM ISOLATION			

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 4

Man/Model	VARIOUS	AVCO/C5159 (SOV)	NAMCO/EA740-50100 (LIM SW)
Safety Function	1/2/11	MSIV SCRAM & SR DSPLY (LIM SW)/MN STM ISO (SOV)	
Plant Location	STEAM TUNNEL		
Operating Time Req/Avail	R-(A)-30 min (SOV)	R-(P)-30 day (SOV)	R-30 day (LM SW)
DBE Env Req	(F/#/%)-PBQC-B	RAD-2.5X10E6	
Qual Envir	TEST CURVE #14 (SOV)	TEST CURVE #15 (SOV)	RAD-3X10E7 (SOV)
Aging	4X10E8 (LIM SW)	TEST CURVE #18 (LIM SW)	RAD-2.0 MECH-55 CYCLES during F/#/% test (SOV)
Method of Qualification	TEST/SEPARATE/SIMILAR eqpt (SOV)	TEST/SEQUENTIAL (LIM SW)	
Supporting Document	GE LTR G-HK-9-44	ROCKWELL RPT #2792-03-02 (SOV F/#/%)	GE PEDEM #126-62 (SOV RAD) NAMCO TEST
QUAL. STATUS	DOR-A(LIM SW)	JCD(SV)	FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING TO SOVs PROVIDED BY GE
QUAL PLAN	AA 2/81(LIM SW)	FE 4/81(LIM SW)	FE 4/81(SV)
Equipment No	B1 KERITE		
Description	1/C STRANDED 350MCM 600V POWER CABLE		
System	ELECTRICAL DISTRIBUTION		
Man/Model	KERITE HT INSULATION FR JACKET		
Safety Function	12 ELECTRICAL ISTRIBUTION		
Plant Location	VARIOUS		
Operating Time Req/Avail	R-30 day ASSUMED		
DBE Env Req	(F/#/%)-PBQC-1 in area 1.108 assumed worst case	RAD-5.4X10E6	
Qual Envir	TEST CURVE #2	RAD-2X10E8	
Aging	THERMAL-100 hrs 150C		
Method of Qualification	TEST/SEQUENTIAL		
Supporting Document	KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES		
QUAL. STATUS	DOR-A		
QUAL PLAN	AA 3/81 FE 4/81		
Equipment No	B17		
Description	AC MOTOR CONTROL CENTER E10		
System	ELECTRICAL DISTRIBUTION		
Man/Model	NELSON ELECTRIC CLASS 1035E		
Safety Function	12 ELECTRICAL DISTRIBUTION		
Plant Location	1.9		
Operating Time Req/Avail	R-30 day ASSUMED		
DBE Env Req	(F/#/%)-PBQC-1 RAD-NONE not exposed to post-loca recirculation rad		
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED	RAD-1X10E6	
Aging	THERM-NOT SIGNIFICANT		
Method of Qualification	EVALUATION/BPCo based on (F/#/%) TEST/SIMILAR eqpt	GENERIC EVALUATION/UTILITY (RAD)	
Supporting Document	FIRL TEST RPT F-C3781-1 BPCo SCEQ BPCo CEQE P&CS MEMO 80-238 (RAD) P&CS 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)		
QUAL. STATUS	JCD	FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING & GENERIC EVALUATIONS	
QUAL PLAN	II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81		
Equipment No	B18		
Description	AC MOTOR CONTROL CENTER E10		
System	ELECTRICAL DISTRIBUTION		
Man/Model	NELSON ELECTRIC CLASS 1035E		
Safety Function	12 ELECTRICAL DISTRIBUTION		
Plant Location	1.10		
Operating Time Req/Avail	R-30 day ASSUMED		
DBE Env Req	(F/#/%)-PBQC-1 RAD-NONE not exposed to post-loca recirculation rad		
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED	RAD-1X10E6	
Aging	THERM-NOT SIGNIFICANT		
Method of Qualification	EVALUATION/BPCo based on (F/#/%) TEST/SIMILAR eqpt	GENERIC EVALUATION/UTILITY (RAD)	
Supporting Document	FIRL TEST RPT F-C3781-1 BPCo SCEQ BPCo CEQE P&CS MEMO 80-238 (RAD) P&CS 80-257 (AGING) P		

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 5

&CS MEMO BO-186 (F/#/%)

QUAL. STATUS JCD FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING & GENERIC EVALUATIONS
 QUAL PLAN II 1/81 RA 5/81 AA5/81 HT 9/81 FE 9/81

Equipment No B2 KERITE
 Description 1/C STRANDED #0000 600V POWER CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE HT INSULATION FR JACKET
 Safety Function 12 ELECTRICAL ISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PB0C-1 in area 1 10B assumed worst case RAD-5.4X10E6
 Qual Envir TEST CURVE #2 RAD-2X10E8
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No B20
 Description AC MOTOR CONTROL CENTER E10
 System ELECTRICAL DISTRIBUTION
 Man/Model NELSON ELECTRIC CLASS 1035E
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.9
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PB0C-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification EVALUATION/BPCo based on (F/#/%) TEST/SIMILAR eqpt GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document FIRL TEST RPT F-C3781-1 BPCo SCEQ BPCo CEQE P&CB MEMO BO-238 (RAD) P&CB BO-257 (AGING) P
 &CS MEMO BO-186 (F/#/%)
 QUAL STATUS JCD FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING & GENERIC EVALUATIONS
 QUAL PLAN II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No B3 KERITE
 Description 1/C STRANDED #00 600V POWER CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE HT INSULATION FR JACKET
 Safety Function 12 ELECTRICAL ISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PB0C-1 in area 1 10B assumed worst case RAD-5.4X10E6
 Qual Envir TEST CURVE #2 RAD-2X10E8
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No B4 KERITE
 Description 1/C STRANDED #0 600V POWER CABLE
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE HT INSULATION FR JACKET
 Safety Function 12 ELECTRICAL ISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PB0C-1 in area 1 10B assumed worst case RAD-5.4X10E6

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 6

Qual Envir	TEST CURVE #2 RAD-2X10E8
Aging	THERMAL-100 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
QUAL. STATUS	DDR-A
QUAL PLAN	AA 3/81 FE 4/81

Equipment No	B5 KERITE
Description	1/C STRANDED #4 600V POWER CABLE
System	ELECTRICAL DISTRIBUTION
Man/Model	KERITE HT INSULATION FR JACKET
Safety Function	12 ELECTRICAL ISTRIBUTION
Plant Location	VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	(F/#/%)-PBDC-1 in area 1.108 assumed worst case RAD-5.4X10E6
Qual Envir	TEST CURVE #2 RAD-2X10E8
Aging	THERMAL-100 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
QUAL. STATUS	DDR-A
QUAL PLAN	AA 3/81 FE 4/81

Equipment No	B65 OKONITE
Description	1/C STRANDED #6 600V POWER & CONTROL
System	ELECTRICAL DISTRIBUTION
Man/Model	OKONITE OKONITE INSULATION OKOLON JACKET
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	(F/#/%)-PBDC-1 in area 1.108 assumed worst case RAD-6.2X10E5
Qual Envir	TEST CURVE #35 RAD-2X10E8
Aging	THERMAL-504 hrs 150C
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	OKONITE RPT NGRN-1
QUAL. STATUS	DDR-A
QUAL PLAN	AA 3/81 FE 4/81

Equipment No	C118
Description	HYDROGEN ANALYZER A M239
System	H2/02 ANALYZER SAFETY RELATED DISPLAY
Man/Model	DELPHI B1B S#259
Safety Function	11 POST LOCA MONITORING NOT REQUIRED FOR PBDC
Plant Location	1.12
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)- NOT REQUIRED RAD-NOT REQUIRED
Aging	outstanding item
Notes	NEW INSTRUMENTS TO BE INSTALLED AS PART OF TMI CAT. B
QUAL. STATUS	DDR-A
QUAL PLAN	ER 10/81 EXISTING EQUIPMENT SCHEDULED FOR REPLACEMENT WITH TMI CAT. B H2/02 ANALYZERS (C172 & C173)

Equipment No	C119
Description	HYDROGEN ANALYZER B M239
System	H2/02 ANALYZER SAFETY RELATED DISPLAY
Man/Model	DELPHI B1B S#260
Safety Function	11 POST LOCA MONITORING NOT REQUIRED FOR PBDC
Plant Location	1.11
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 7

LJ

DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)- NOT REQUIRED RAD-NOT REQUIRED
 Aging outstanding item
 Notes NEW INSTRUMENTS TO BE INSTALLED AS PART OF TMI CAT. B

QUAL STATUS DOR-A
 QUAL PLAN ER 10/81 EXISTING EQUIPMENT SCHEDULED FOR REPLACEMENT WITH TMI CAT. B H2/O2 ANALYZERS (C172 & C173)

Equipment No C12 KERITE
 Description 12/C STRANDED #12 600V POWER & CONTROL
 System ELECTRICAL DISTRIBUTION
 Man/Model KERITE FR INSULATION FR OVERALL JACKET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (E/#/%)-PBDC-1 in area 1 10B assumed worst case RAD-6.2X10E5
 Qual Envir TEST CURVE #3 RAD-2X10E8
 Aging THERMAL-100 hrs 150C
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document KERITE LTR TO EDISON 7/21/80 AND ATTACHED CERTIFIED TEST REPORT SUMMARIES
 QUAL STATUS DOR-A
 QUAL PLAN AA 3/81 FE 4/81

Equipment No C129A
 Description INSTRUMENT RACK
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED IN CONDUIT OR NEMA JB
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.14
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (E/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt
 Supporting Document P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81

Equipment No C129B
 Description INSTRUMENT RACK
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED IN CONDUIT OR NEMA JB
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.14
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt
 Supporting Document P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81

Equipment No C152
 Description SHUTDOWN PANEL

78-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 8

System	ELECTRICAL DISTRIBUTION				
Man/Model	VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25				
Safety Function	12 ELECTRICAL DISTRIBUTION				
Plant Location	1.9				
Operating Time Req/Avail	R-30day				
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad				
Qual Envir	TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)				
Aging	RAD-1X10E4 (SW)				
Method of Qualification	THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB) TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A QING) GENERIC EVALUATION/UTILITY (SW F/#)				
Supporting Document	EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO 80-18 6 (SW & LT F/#/%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)				
QUAL STATUS	JCD	FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES			
QUAL PLAN	RA 2/81	HT 2/81	AA 2/81	FE 3/81	

Equipment No	C153				
Description	SHUTDOWN PANEL				
System	ELECTRICAL DISTRIBUTION				
Man/Model	VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25				
Safety Function	12 ELECTRICAL DISTRIBUTION				
Plant Location	1.10				
Operating Time Req/Avail	R-30day				
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad				
Qual Envir	TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)				
Aging	RAD-1X10E4 (SW)				
Method of Qualification	THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB) TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A QING) GENERIC EVALUATION/UTILITY (SW F/#)				
Supporting Document	EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO 80-18 6 (SW & LT F/#/%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)				
QUAL STATUS	JCD	FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES			
QUAL PLAN	RA 2/81	HT 2/81	AA 2/81	FE 3/81	

Equipment No	C154				
Description	SHUTDOWN PANEL				
System	ELECTRICAL DISTRIBUTION				
Man/Model	VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25				
Safety Function	12 ELECTRICAL DISTRIBUTION				
Plant Location	1.10				
Operating Time Req/Avail	R-30day				
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad				
Qual Envir	TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)				
Aging	RAD-1X10E4 (SW)				
Method of Qualification	THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB) TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A QING) GENERIC EVALUATION/UTILITY (SW F/#)				
Supporting Document	EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO 80-18 6 (SW & LT F/#/%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)				
QUAL STATUS	JCD	FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES			
QUAL PLAN	RA 2/81	HT 2/81	AA 2/81	FE 3/81	

Equipment No	C155				
Description	SHUTDOWN PANEL				
System	ELECTRICAL DISTRIBUTION				
Man/Model	VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25				
Safety Function	12 ELECTRICAL DISTRIBUTION				
Plant Location	1.10				

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 9

Operating Time Req/Avail R-30day
 DBE Env Req (F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)
 RAD-1X10E4 (SW)
 Aging THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB)
 Method of Qualification TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A
 QING) GENERIC EVALUATION/UTILITY (SW F/#)
 Supporting Document EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO 80-18
 6 (SW & LT F/#/%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN RA 2/81 HT 2/81 AA 2/81 FF 3/81

Equipment No C156
 Description SHUTDOWN PANEL
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.9
 Operating Time Req/Avail R-30day
 DBE Env Req (F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)
 RAD-1X10E4 (SW)
 Aging THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB)
 Method of Qualification TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A
 QING) GENERIC EVALUATION/UTILITY (SW F/#)
 Supporting Document EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO 80-18
 6 (SW & LT F/#/%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN RA 2/81 HT 2/81 AA 2/81 FF 3/81

Equipment No C157
 Description SHUTDOWN PANEL
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.10
 Operating Time Req/Avail R-30day
 DBE Env Req (F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)
 RAD-1X10E4 (SW)
 Aging THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB)
 Method of Qualification TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A
 QING) GENERIC EVALUATION/UTILITY (SW F/#)
 Supporting Document EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO 80-18
 6 (SW & LT F/#/%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN RA 2/81 HT 2/81 AA 2/81 FF 3/81

Equipment No C158
 Description SHUTDOWN PANEL
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.10
 Operating Time Req/Avail R-30day
 DBE Env Req (F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)
 RAD-1X10E4 (SW)

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 10

Aging Method of Qualification THERMAL-120HRS BQC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB)
 TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A
 QING) GENERIC EVALUATION/UTILITY (SW F/#)
 Supporting Document EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO BO-1B
 A (SW & LT F/#/%) P&CS MEMO BO-202 (LT & TB AGING) P&CS MEMO BO-238 (LT RAD)
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL. PLAN RA 2/81 HT 2/81 AA 2/81 FE 3/81

Equipment No	C159
Description	SHUTDOWN PANEL
System	ELECTRICAL DISTRIBUTION
Man/Model	VARIOUS SWITCHES-ELECTROSWITCH 24&40
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	I 10
Operating Time Req/Avail	R-30day
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT) RAD-1X10E4 (SW)

RAD-IX10E4 (SW)
 THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB)
 Aging TEST/SEQUENTIAL (TB) TEST SEPARATE (SW % RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#% RAD A
 Method of Qualification QING) GENERIC EVALUATION/UTILITY (SW F/#)
 Supporting Document EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW % RAD AGING) P&CS MEMO 80-18
 A (SW & LT F/#%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN PA 2/81 HT 2/81 AA 2/81 FE 3/81

Equipment No	C163
Description	SHUTDOWN PANEL
System	ELECTRICAL DISTRIBUTION
Man/Model	VARIOUS SWITCHES-ELECTROSWITCH 24&40
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.9
Operating Time Req/Avail	R-30day
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (BW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT) RAD-1X10E6 (BW)

RAD TESTS (SW)
THERM-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB)
Method of Qualification TEST/SEQUENTIAL (TB) TEST SEPARATE (SW X RAD AGING) GENERIC EVALUATION/UTILITY (LT F/# X RAD A
GING) GENERIC EVALUATION/UTILITY (SW F/#)
Supporting Document EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW X RAD AGING) P&CS MEMO 80-18
6 (SW & LT F/#%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)
QUAL. STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES

QUAL PLAN RA 2/81 HT 2/81 AA 2/81 FE 3/81

Equipment No	C172
Description	H2O2 ANALYZER
System	SAFETY RELATED DISPLAY H2/O2 ANALYZER
Safety Function	11 CONTAINMENT ATMOSPHERE
Plant Location	1.14
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-none not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-NOT REQUIRED RAD-NOT REQUIRED
Notes	TMI CATEGORY B
QUAL STATUS	NYI
QUAL PLAN	FT 1/81

Equipment No C173
-rip- H2O2 ANALYZER

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 11

System	H2/D2 ANALYZER SAFETY RELATED DISPLAY			
Safety Function	11 POST LOCA MONITORING NOT REQUIRED FOR PBOC			
Plant Location	1.14			
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC			
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad			
Qual Envir	(F/#/%)-NOT REQUIRED RAD-NOT REQUIRED			
Notes	TMI CATEGORY B			
QUAL STATUS	NYI			
QUAL PLAN	FT 1/81			
Equipment No	C2201			
Description	INSTRUMENT RACK			
System	ELECTRICAL DISTRIBUTION			
Man/Model	VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I N CONDUIT OR NEMA JB			
Safety Function	12 ELECTRICAL DISTRIBUTION			
Plant Location	1.1			
Operating Time Req/Avail	R-30 day ASSUMED			
DBE Env Req	(F/#/%)-PBOC-5 RAD-6.2X10E5			
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6			
Aging	THERM-NOT SIGNIFICANT			
Method of Qualification	TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt			
Supporting Document	P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)			
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES			
QUAL PLAN	II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81			
Equipment No	C2205			
Description	INSTRUMENT RACK			
System	ELECTRICAL DISTRIBUTION			
Man/Model	VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I N CONDUIT OR NEMA JB			
Safety Function	12 ELECTRICAL DISTRIBUTION			
Plant Location	1.11			
Operating Time Req/Avail	R-30 day ASSUMED			
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad			
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6			
Aging	THERM-NOT SIGNIFICANT			
Method of Qualification	TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt			
Supporting Document	P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)			
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES			
QUAL PLAN	II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81			
Equipment No	C2206			
Description	INSTRUMENT RACK			
System	ELECTRICAL DISTRIBUTION			
Man/Model	VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I N CONDUIT OR NEMA JB			
Safety Function	12 ELECTRICAL DISTRIBUTION			
Plant Location	1.12			
Operating Time Req/Avail	R-30 day ASSUMED			
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad			
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6			
Aging	THERM-NOT SIGNIFICANT			
Method of Qualification	TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt			
Supporting Document	P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)			

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 12

QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81

Equipment No C2207
 Description INSTRUMENT RACK
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I
 N CONDUIT OR NEMA JB
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.8
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-5 RAD-6 2X10E5
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt
 Supporting Document P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81

Equipment No C2250
 Description INSTRUMENT RACK
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I
 N CONDUIT OR NEMA JB
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.4
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-6 2X10E5
 Qual Envir (F/#/%)-NOT REQUIRED RAD-5X10E6
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt
 Supporting Document P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81

Equipment No C2251
 Description INSTRUMENT RACK
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I
 N CONDUIT OR NEMA JB
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location 1.9
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt
 Supporting Document P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 4/81 AA 4/81 HT 9/81 FE 9/81

Equipment No C2256
 Description INSTRUMENT RACK
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE
 ENC - D 1

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 13

Safety Function	N CONDUIT OR NEMA JB	12 ELECTRICAL DISTRIBUTION
Plant Location	1.7	
Operating Time Req/Avail	R-1 min	
DBE Env Req	(F/#/%)-PBOC-6 RAD-6 2X10E5	
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6	
Aging	THERM-NOT SIGNIFICANT	
Method of Qualification	TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt	
Supporting Document	P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)	
QUAL STATUS	JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES	
QUAL PLAN	II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81	

Equipment No	C2257A	
Description	INSTRUMENT RACK	
System	ELECTRICAL DISTRIBUTION	
Man/Model	VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I	
Safety Function	N CONDUIT OR NEMA JB	
Plant Location	1.2	
Operating Time Req/Avail	R-5 hr	
DBE Env Req	(F/#/%)-PBOC-5 RAD-6 2X10E5	
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6	
Aging	THERM-NOT SIGNIFICANT	
Method of Qualification	TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt	
Supporting Document	P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)	
QUAL STATUS	JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES	
QUAL PLAN	II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81	

Equipment No	C2257B	
Description	INSTRUMENT RACK	
System	ELECTRICAL DISTRIBUTION	
Man/Model	VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I	
Safety Function	N CONDUIT OR NEMA JB	
Plant Location	1.2	
Operating Time Req/Avail	R-1 min	
DBE Env Req	(F/#/%)-PBOC-6 RAD-6 2X10E5	
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6	
Aging	THERM-NOT SIGNIFICANT	
Method of Qualification	TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR eqpt	
Supporting Document	P&CS MEMO TO FILE #80-12 P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)	
QUAL STATUS	JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES	
QUAL PLAN	II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81	

Equipment No	C2260	
Description	INSTRUMENT RACK	
System	ELECTRICAL DISTRIBUTION	
Man/Model	VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I	
Safety Function	N CONDUIT OR NEMA JB	
Plant Location	1.2	
Operating Time Req/Avail	R-8 hr	
DBE Env Req	(F/#/%)-PBOC-5 RAD-6 2X10E5	
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6	
Aging	THERM-NOT SIGNIFICANT	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 14

Method of Qualification TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR expt
 Supporting Document P&CS MEMO TO FILE #80-12 P&CS MEMO BO-257 (AGING) P&CS MEMO BO-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No C2303
 Description ENCLOSURES & TERM BLOCKS FOR HPCI TURB CNTRLS
 System HPCI
 Man/Model VARIOUS GE/CR151 (TERM BK) PVC 600V CABLE POLYETHYLENE/PVC INSTRUMENT CABLE ALL ENCLOSED I
 N CONDUIT OR NEMA JB
 Safety Function 4 HPCI SUPPORT
 Plant Location 1.3
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
 Qual Envir (F/#/%)-NOT REQUIRED RAD-5X10E6
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification TEST F/#/% (TERM BK) EVALUATION/UTILITY for remainder of parameters based on other TEST/SEPARATE /SIMILAR expt
 Supporting Document P&CS MEMO TO FILE #80-12 P&CS MEMO BO-257 (AGING) P&CS MEMO BO-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No C513AH
 Description SCRAM SOL FUSE PANEL
 System RPS
 Man/Model GE 23BX27BQ1
 Safety Function 1 SCRAM POWER PER GE FAILSAFE DESIGN CONSIDERED NONESSENTIAL BY QE
 Plant Location 1.9 1.10
 Operating Time Req/Avail R-LOCA-1 min
 DBE Env Req (F/#/%)-PBDC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-NOT REQUIRED
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (F/#/%)
 Supporting Document P&CS MEMO #80-125 (F/#/%) P&CS MEMO BO-257 (AGING) P&CS MEMO BO-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No C61A
 Description REACTOR BLDG H&V CONTROL PANEL
 System HVAC ECCS UNIT COOLERS
 Man/Model VARIOUS VULKENE CABLE AGASTAT TIME DELAY RELAYS 2412AN JOHNSON SERVICE COMPANY RELAYS KZ400
 Q-B GE CONTROL SWITCH CR2940
 Safety Function 4C ECCS UNIT COOLERS
 Plant Location 1.9
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir IN EXCESS OF REQUIRED (F/#/%) RAD-NOT REQUIRED
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (F/#/%)
 Supporting Document P&CS MEMO #80-125 (F/#/%) P&CS MEMO BO-257 (AGING) P&CS MEMO BO-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No C61B
 Description REACTOR BUILDING H&V CONTROL PANEL
 System HVAC ECCS UNIT COOLERS
 Man/Model VARIOUS VULKENE CABLE AGASTAT TIME DELAY RELAYS 2412AN JOHNSON SERVICE COMPANY RELAYS KZ4000

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 15

-B GE CONTROL SWITCH CR2940
 Safety Function 4C ECCS UNIT COOLERS
 Plant Location 1.9
 Operating Time Req/Avail R-30 day
 DBE Env Req (E/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir IN EXCESS OF REQUIRED (F/#/%) RAD-NOT REQUIRED
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (F/#/%)
 Supporting Document P&CS MEMO #80-125 (E/#/%) P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No C68
 Description STANDBY GAS TREATMENT FILTER UNIT A PANEL A PANEL A1
 System STANDBY GAS TREATMENT
 Man/Model FARR CO. (FILTER MFR) HONEYWELL/R708BC (RH CONTROLLER) GE/9T55Y46-G7 (XFMR) ALLEN BRADLEY/70
 2L-TOD93 (CONTACTOR) BRONCO/BRONCO 66 (WIRE)
 Safety Function 13 STANDBY GAS TREATMENT
 Plant Location 1.23
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (E/#/%)-NONE not required for pboc RAD-3.2X10E4
 Qual Envir (F/#/%)- NOT REQUIRED RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT
 Supporting Document P&CS MEMO 80-238 (RAD) P&CS MEMO 80-257 (AGING)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QUAL PLAN ER 11/81

Equipment No C68A
 Description STANDBY GAS TREATMENT FILTER UNIT A PANEL A PANEL A1
 System STANDBY GAS TREATMENT
 Man/Model FARR CO. (FILTER MFR) ALLEN BRADLEY/700DC-N300-21 (RELAY) ALLEN BRADLEY/800T-A2A (PUSHBUTTON)
 BRONCO/BRONCO 66 (WIRE)
 Safety Function 13 STANDBY GAS TREATMENT
 Plant Location 1.23
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-2.1X10E8
 Qual Envir (F/#/%)- NOT REQUIRED outstanding item (RAD)
 Aging outstanding item
 QUAL STATUS NYQ
 QUAL PLAN ER 11/81

Equipment No C68B
 Description STANDBY GAS TREATMENT FILTER UNIT A PANEL A PANEL A2
 System STANDBY GAS TREATMENT
 Man/Model FARR CO. (FILTER MFR) ALLEN BRADLEY/700DC-N300-21 (RELAY) ALLEN BRADLEY/800T-A2A (PUSHBUTTON)
 BRONCO/BRONCO 66 (WIRE)
 Safety Function 13 STANDBY GAS TREATMENT
 Plant Location 1.23
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-2.1X10E8
 Qual Envir (F/#/%)- NOT REQUIRED outstanding item (RAD)
 Aging outstanding item
 QUAL STATUS NYQ
 QUAL PLAN ER 11/81

Equipment No C69
 Description STANDBY GAS TREATMENT FILTER UNIT B PANEL B
 System STANDBY GAS TREATMENT

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 16

Man/Model FARR CO. (FILTER MFR) HONEYWELL/R70BBC (RH CONTROLLER) GE/9T55Y46-Q7 (XFMR) ALLEN BRADLEY/70
 2L-TOD93 (CONTACTOR) BRONCO/BRONCO 66 (WIRE)

Safety Function 13 STANDBY GAS TREATMENT

Plant Location 1.23

Operating Time Req/Avail R-LOCA-30 day NR-PBDC

DBE Env Req (F/#/%)-NONE not required for pboc RAD-3.2X10E4

Qual Envir (F/#/%)- NOT REQUIRED RAD-1X10E6

Aging THERM-NOT SIGNIFICANT

Supporting Document P&CS MEMO BO-238 (RAD) P&CS MEMO BO-257 (AGING)

QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES

QUAL PLAN ER 11/81

Equipment No C69A

Description STANDBY GAS TREATMENT FILTER UNIT B PANEL B1

System STANDBY GAS TREATMENT

Man/Model FARR CO. (FILTER MFR) ALLEN BRADLEY/700DC-N300-21 (RELAY) ALLEN BRADLEY/BOOT-A2A (PUSHBUTTON)
 BRONCO/BRONCO 66 (WIRE)

Safety Function 13 STANDBY GAS TREATMENT

Plant Location 1.23

Operating Time Req/Avail R-LOCA-30 day NR-PBDC

DBE Env Req (F/#/%)-NONE not required for pboc RAD-2.1X10E8

Qual Envir (F/#/%)- NOT REQUIRED outstanding item (RAD)

Aging outstanding item

QUAL STATUS NYQ

QUAL PLAN 11/81

Equipment No C69B

Description STANDBY GAS TREATMENT FILTER UNIT B PANEL B2

System STANDBY GAS TREATMENT

Man/Model FARR CO. (FILTER MFR) ALLEN BRADLEY/700DC-N300-21 (RELAY) ALLEN BRADLEY/BOOT-A2A (PUSHBUTTON)
 BRONCO/BRONCO 66 (WIRE)

Safety Function 13 STANDBY GAS TREATMENT

Plant Location 1.23

Operating Time Req/Avail R-LOCA-30 day NR-PBDC

DBE Env Req (F/#/%)-NONE not required for pboc RAD-2.1X10E8

Qual Envir (F/#/%)- NOT REQUIRED outstanding item (RAD)

Aging outstanding item

QUAL STATUS NYQ

QUAL PLAN ER 11/81

Equipment No CV2301-32

Description CONTROL VALVE M244

System HPCI

Man/Model ATKOMATIC 237826

Safety Function 4 HPIC TURB. DRN. TO GLAND SEAL COND. NOT ESSENTIAL TO HPCI

Plant Location 1.3

Operating Time Req/Avail R-5 hr

DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only

Qual Envir (F/#/%)-NOT REQUIRED RAD-2X10E6

Aging outstanding item

Method of Qualification EVALUATION/BPCo

Supporting Document BPCo SCEG BPCo CECE

QUAL STATUS DCR-A

QUAL PLAN AA 4/81 FE 5/81

Equipment No CV906BA

Description SOLENOID VALVE M243

System HPCI

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 17

Man/Model	ATKOMATIC 247214
Safety Function	4 HPCI TURB EXHAUST NOT ESSENTIAL TO HPCI
Plant Location	1.3
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-2X10E6
Aging	outstanding item
Method of Qualification	EVALUATION/BPCo
Supporting Document	BPCo SCEQ BPCo CEQE
QUAL STATUS	DOR-A
QUAL PLAN	AA 4/81 FE 5/81

Equipment No	CV90688
Description	SOLENOID VALVE M243
System	HPCI
Man/Model	ATKOMATIC 247214
Safety Function	4 HPCI TURB EXHAUST NOT ESSENTIAL TO HPCI
Plant Location	1.3
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-2X10E6
Aging	outstanding item
Method of Qualification	EVALUATION/BPCo
Supporting Document	BPCo SCEQ BPCo CEQE
QUAL STATUS	DOR-A
QUAL PLAN	AA 4/81 FE 5/81

Equipment No	D7
Description	DC MOTOR CONTROL CENTER E13
System	ELECTRICAL DISTRIBUTION
Man/Model	CUTLER HAMMER CLASS 1 TYPE B #6AF685046
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.10
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT
Method of Qualification	EVALUATION/BPCo based on (F/#/%) TEST/SIMILAR eqpt GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	FIRL TEST RPT F-C3781-2 BPCo SCEQ BPCo CEQE P&CS MEMO 80-238 (RAD) P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
QUAL STATUS	JCD FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING AND GENERIC STUDIES
QUAL PLAN	II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No	D8
Description	DC MOTOR CONTROL CENTER E13
System	ELECTRICAL DISTRIBUTION
Man/Model	CUTLER HAMMER CLASS 1 TYPE B #6AF685046
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.10
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT
Method of Qualification	EVALUATION/BPCo based on (F/#/%) TEST/SIMILAR eqpt GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	FIRL TEST RPT F-C3781-2 BPCo SCEQ BPCo CEQE P&CS MEMO 80-238 (RAD) P&CS MEMO 80-257 (AGING) P&CS MEMO 80-186 (F/#/%)
QUAL STATUS	JCD FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING AND GENERIC STUDIES
JAL	/81 5/81 AA -'71 HT 9/81 FE 9/81

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 18

Equipment No	D9
Description	DC MOTOR CONTROL CENTER E13
System	ELECTRICAL DISTRIBUTION
Man/Model	CUTLER HAMMER CLASS 1 TYPE B #6AF685046
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.10
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	(F/#/%)-PBDC-1 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-IX10E6
Aging	THERM-NOT SIGNIFICANT
Method of Qualification	EVALUATION/BPCo based on (F/#/%) TEST/SIMILAR eqpt GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	FIRL TEST RPT F-C3781-2 BPCo SCEG BPCo CEGE P&CS MEMO BO-238 (RAD) P&CS MEMO BO-257 (AGING) P&CS MEMO BO-186 (F/#/%)
QUAL STATUS	JCD FINAL EVALUATION TO DETERMINE APPLICABILITY OF TESTING AND GENERIC STUDIES
QUAL PLAN	II 1/81 RA 5/81 AA 5/81 HT 9/81 FE 9/81

Equipment No	DPIS1001-79A
Description	DIFFERENTIAL PRESSURE SWITCH M241
System	RHR
Man/Model	BARTON 289A 289A3230
Safety Function	4A/4B LOW FLOW TRIP SIGNAL TO MO1001-18A
Plant Location	1.1 LOCAL MNTD
Operating Time Req/Avail	R(A)-30 days
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-NONE not required during loca
Qual Envir	TEST CURVE #24 RAD-IX10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3008 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DRR

Equipment No	DPIS1001-79B
Description	DIFFERENTIAL PRESSURE SWITCH M241
System	RHR
Man/Model	BARTON 289A 289A3229
Safety Function	4A/4B LOW FLOW TRIP FOR MO1001-18B
Plant Location	1.2 LOCAL MNTD
Operating Time Req/Avail	R(A)-30 days
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-NONE not required during loca
Qual Envir	TEST CURVE #24 RAD-IX10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3008 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DRR

Equipment No	DPIS1243
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M247
System	RCTR WTR CLEAN-UP CNTM ISOLATION
Man/Model	BARTON 288A 288A-11Q14
Safety Function	2 ISOLATION RECIRC. TO CLEANUP SYSTEM PBDC TERM
Plant Location	1.10 LOCAL MNTD
Operating Time Req/Avail	NR-LOCA R-PBDC-1 min
DBE Env Req	(F/#/%)-PBDC-1 RAD-NONE not required during loca
Qual Envir	TEST CURVE #24 TEST CURVE #25 RAD-IX10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD) P&CS MEMO BO-186 (F/#%)

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 19

QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN HT 6/81 FE 7/81

Equipment No	DPIS1244
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M247
System	RCTR WTR CLEAN-UP CNTM ISOLATION
Man/Model	BARTON 288A 288A-11015
Safety Function	2 ISOLATION RECIRC. TO CLEANUP SYSTEM PBOC TERM
Plant Location	1.10 LOCAL MNTD
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min (F/#/%)-PBOC-1 RAD-NONE not required during loca
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Method of Qualification	GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
Supporting Document	#/%)

QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN HT 6/81 FE 7/81

Equipment No	DPIS1360-1A
Description	DIFF PRESSURE IND SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	BARTON 288 1360-1A
Safety Function	2 AUTO ISO. SIGNAL PBOC TERM
Plant Location	1.7 C2257B
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min (F/#/%)-PBOC-6 RAD-NONE not required during loca
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Method of Qualification	GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
Supporting Document	#/%)

QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN HT 6/81 FE 7/81

Equipment No	DPIS1360-1B
Description	DIFF PRESSURE IND SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	BARTON 288 1360-1B
Safety Function	2 AUTO ISO. SIGNAL PBOC TERM
Plant Location	1.7 C2257B
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min (F/#/%)-PBOC-6 RAD-NONE not required during loca
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Method of Qualification	GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
Supporting Document	#/%)

QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN HT 6/81 FE 7/81

Equipment No	DPIS1459A
Description	DIFFERENTIAL PRESSURE SWITCH M242
System	CORE SPRAY SAFETY RELATED DISPLAY
Man/Model	BARTON 288A 288A5507
Safety Function	4/11 RX VESSEL CORE SPRAY LINE RUPTURE
Plant Location	1.8 LOCAL MNTD
General	NR-1 NCA NR-PBOC

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 20

DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS1459B
 Description DIFFERENTIAL PRESSURE SWITCH M242
 System CORE SPRAY SAFETY RELATED DISPLAY
 Man/Model BARTON 2BB 2BBAS5506
 Safety Function 4/11 RX VESSEL CORE SPRAY LINE RUPTURE
 Plant Location 1.B LOCAL MNTD
 Operating Time Req/Avail NR-LOCA NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS2301-2352
 Description DIFF PRESSURE IND SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model BARTON 2BB
 Safety Function 4/2 HPIC ISO. PBOC TERM
 Plant Location 1.2 C2257A
 Operating Time Req/Avail R-LOCA(P)-5 hr R-PBOC-1 min
 DBE Env Req (F/#/%)-PBOC-5 RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD) P&CS MEMO BO-186 (F/
 %/%)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN HT 6/81 FE 7/81

Equipment No DPIS2301-2353
 Description DIFF PRESSURE IND SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model BARTON 2BB
 Safety Function 4/2 HPIC ISO. PBOC TERM
 Plant Location 1.2 C2257A
 Operating Time Req/Avail R-LOCA(P)-5 hr R-PBOC-1 min
 DBE Env Req (F/#/%)-PBOC-5 RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD) P&CS MEMO BO-186 (F/
 %/%)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN HT 6/81 FE 7/81

Equipment No DPIS261-12A
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System REACTOR RECIRCULATION SYSTEM RHR
 Man/M Safety Function BARTON 2BB 5502
 .. RHF JP E TIO

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 21

Plant Location	1.7 C2251
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)=NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DOOR

Equipment No	DPIS261-12B
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	REACTOR RECIRCULATION SYSTEM RHR
Man/Model	BARTON 288 5503
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.9 C2251
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)=NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DOOR

Equipment No	DPIS261-12C
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	REACTOR RECIRCULATION SYSTEM RHR
Man/Model	BARTON 288 5504
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.2 LOCAL MNID
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)=NONE not required for pboc RAD-6.2X10E5
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DOOR

Equipment No	DPIS261-12D
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	REACTOR RECIRCULATION SYSTEM RHR
Man/Model	BARTON 288 550
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.8 LOCAL MNID
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)=NONE not required for pboc RAD-6.2X10E5
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DOOR

Equipment No	DPIS261-2A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	CNTM ISOLATION
Man/Model	BARTON 278 278-3347
Safety Function	2 MN STM ISO PBOC TERM
Plant Location	1.7 C2256
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 22

DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2B
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3348
 Safety Function 2 MN. STM. ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PBOC-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2C
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3349
 Safety Function 2 MN. STM. ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PBOC-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2D
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3350
 Safety Function 2 MN. STM. ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PBOC-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2E
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3351
 Safety Function 2 MN. STM. ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PBOC-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 23

Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2F
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3352
 Safety Function 2 MN STM ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PB0C-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2G
 Description DIFFERENTIAL PRESSURE INDICATING SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3353
 Safety Function 2 MN STM ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PB0C-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2H
 Description DIFFERENTIAL PRESSURE INDICATING SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3354
 Safety Function 2 MN STM ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PB0C-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-2J
 Description DIFFERENTIAL PRESSURE INDICATING SWITCH M252
 System CNTM ISOLATION
 Man/Model BARTON 278 278-3355
 Safety Function 2 MN STM ISO. PBOC TERM
 Plant Location 1.7 C2256
 Operating Time Req/Avail NR-LOCA R-PB0C-1 min
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 24

Supporting Document
QUAL. STATUS DOR

GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)

Equipment No Description System	DP1S261-2K DIFFERENTIAL PRESSURE INDICATING SWITCH M252 CNTR ISOLATION			
Man/Model	BARTON	278	278-3356	
Safety Function	2 MN STM 150	PBOC TERM		
Plant Location	1.7 C2256			
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min (F/#/%)-NONE not required during hostile pboc		RAD-NONE not required during loca	
D&E Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6			
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT			
Aging	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)		GENERIC EVALUATION/UTILITY (RAD)	
Method of Qualification	TEST/SIMILAR (F/#/%) P&CS MEMO 80-202 (AGING)		P&CS MEMO 80-238 (RAD)	
Supporting Document	GE RPT 145C3009 (F/#/%)			
QUAL. STATUS DOR				

Equipment No Description System	DP1S261-2L DIFFERENTIAL PRESSURE INDICATING SWITCH M252 CNTR ISOLATION			
Man/Model	BARTON	278	278-3357	
Safety Function	2 MN STM 150	PBOC TERM		
Plant Location	1.7 C2256			
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min (F/#/%)-NONE not required during hostile pboc		RAD-NONE not required during loca	
D&E Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6			
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT			
Aging	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)		GENERIC EVALUATION/UTILITY (RAD)	
Method of Qualification	TEST/SIMILAR (F/#/%) P&CS MEMO 80-202 (AGING)		P&CS MEMO 80-238 (RAD)	
Supporting Document	GE RPT 145C3009 (F/#/%)			
QUAL. STATUS DOR				

Equipment No Description System	DP1S261-2M DIFFERENTIAL PRESSURE INDICATOR SWITCH M252 CNTR ISOLATION			
Man/Model	BARTON	278	278-3358	
Safety Function	2 MN STM 150	PBOC TERM		
Plant Location	1.7 C2256			
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min (F/#/%)-NONE not required during hostile pboc		RAD-NONE not required during loca	
D&E Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6			
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT			
Aging	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)		GENERIC EVALUATION/UTILITY (RAD)	
Method of Qualification	TEST/SIMILAR (F/#/%) P&CS MEMO 80-202 (AGING)		P&CS MEMO 80-238 (RAD)	
Supporting Document	GE RPT 145C3009 (F/#/%)			
QUAL. STATUS DOR				

Equipment No Description System	DP1S261-2N DIFFERENTIAL PRESSURE INDICATOR SWITCH M252 CNTR ISOLATION			
Man/Model	BARTON	278	278-3359	
Safety Function	2 MN STM 150	PBOC TERM		
Plant Location	1.7 C2256			
Operating Time Req/Avail	NR-LOCA R-PBOC-1 min (F/#/%)-NONE not required during hostile pboc		RAD-NONE not required during loca	
D&E Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6			
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT			
Aging	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)		GENERIC EVALUATION/UTILITY (RAD)	
Method of Qualification	TEST/SIMILAR (F/#/%) P&CS MEMO 80-202 (AGING)		P&CS MEMO 80-238 (RAD)	
Supporting Document	GE RPT 145C3009 (F/#/%)			
QUAL. STATUS DOR				

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 25

Equipment No	DPIS261-2P
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
System	CNTM ISOLATION
Man/Model	BARTON 2 278-3360
Safety Function	2 MN STM ISO. PBDC TERM
Plant Location	1.7 C2256
Operating Time Req/Avail	NR-LOCA R-PBDC-1 min
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
Qual Envir	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DR
Equipment No	DPIS261-2R
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
System	CNTM ISOLATION
Man/Model	BARTON 278 278-3361
Safety Function	2 MN STM ISO. PBDC TERM
Plant Location	1.7 C2256
Operating Time Req/Avail	NR-LOCA R-PBDC-1 min
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
Qual Envir	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DR
Equipment No	DPIS261-2S
Description	DIFFERENTIAL PRESSURE INDICATING SWITCH M252
System	CNTM ISOLATION
Man/Model	BARTON 278 278-3362
Safety Function	2 MN STM ISO. PBDC TERM
Plant Location	1.7 C2256
Operating Time Req/Avail	NR-LOCA R-PBDC-1 min
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-NONE not required during loca
Qual Envir	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DR
Equipment No	DPIS261-36A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	RHR
Man/Model	BARTON 288 288A5494
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.8 C2207
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6 2X10E5
Qual Envir	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DR
Equipment No	DPIS261-36B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 26

Description	DIFF. PRESSURE INDICATOR SWITCH M252
System	RHR
Man/Model	BARTON 288 288A5495
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.B C2207
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6 2X10E5
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL. STATUS	DOR

Equipment No	DPIS261-37A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	RHR
Man/Model	BARTON 288 288A5500
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.B C2207
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6 2X10E5
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL. STATUS	DOR

Equipment No	DPIS261-37B
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	RHR
Man/Model	BARTON 288 288A5501
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.B C2207
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6 2X10E5
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL. STATUS	DOR

Equipment No	DPIS261-38A
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	RHR
Man/Model	BARTON 288 288A5498
Safety Function	4A RHR LOOP SELECTION
Plant Location	1.B C2207
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6 2X10E5
DBE Env Req	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Qual Envir	
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL. STATUS	DOR

Equipment No	DPIS261-38B
Description	DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
System	RHR

Man/Model BARTON 288 288A5499
 Safety Function 4A RHR LOOP SELECTION
 Plant Location 1.B C2207
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6 2X10E5
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-39A
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System RHR
 Man/Model BARTON 288 288A5496
 Safety Function 4A RHR LOOP SELECTION
 Plant Location 1.B C2207
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6 2X10E5
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS261-39B
 Description DIFFERENTIAL PRESSURE INDICATOR SWITCH M252
 System RHR
 Man/Model BARTON 288 288A5497
 Safety Function 4A RHR LOOP SELECTION
 Plant Location 1.B C2207
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6 2X10E5
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS5040A
 Description DIFFERENTIAL PRESSURE SWITCH M227
 System CNTM INTEGRITY CNTM ISOLATION
 Man/Model BARTON 288A 288A-6547
 Safety Function 2 TORUS VACUUM BREAKER CONTROL
 Plant Location 1.9 LOCAL MNTD
 Operating Time Req/Avail R-LOCA-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No DPIS5040B
 Description DIFFERENTIAL PRESSURE SWITCH M227
 System CNTM ISOLATION CNTM INTEGRITY
 Man/Model BARTON 288A 288A-6548
 Safety Function 2 TORUS VACUUM BREAKER CONTROL

77-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 28

Plant Location	1.9 LOCAL MNTR
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3009 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DDR

Equipment No	DPT1001-604A
Description	LEVEL TRANSMITTER
System	SAFETY RELATED DISPLAY
Man/Model	ROSEMOUNT 1152DP5E22T0280PB
Safety Function	II SR DISPLAY TORUS LEVEL
Plant Location	TORUS AREA
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #38 RAD-1 2X10E7
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEPARATE
Supporting Document	ROSEMOUNT REPORT #117415 (F/#/%/AGING) ROSEMOUNT REPORT #10763 (RAD)
QUAL STATUS	NYI

Equipment No	DPT1001-604B
Description	LEVEL TRANSMITTER
System	SAFETY RELATED DISPLAY
Man/Model	ROSEMOUNT 1152DP5E22T0280PB
Safety Function	II TORUS LEVEL
Plant Location	TORUS AREA
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #38 RAD-1 2X10E7
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEPARATE
Supporting Document	ROSEMOUNT REPORT #117415 (F/#/%/AGING) ROSEMOUNT REPORT #10763 (RAD)
QUAL STATUS	NYI

Equipment No	FS2301-2354
Description	FLOW SWITCH M243
System	HPCI
Man/Model	BARTON 289A 1664
Safety Function	4 HPIC MIN. RECIRC. CONTROL
Plant Location	1.4 C2250
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #24 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3008 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
QUAL STATUS	DDR

Equipment No	FT1461A
Description	FLOW TRANSMITTER
System	CORE SPRAY SAFETY RELATED DISPLAY
Man/Model	GE 555 222005446
Safety Function	II CORE SPRAY FLOW
Plant Location	1.1 C2201
Operating Time Req/Avail	R-30 day

DBE Env Req (F/N/%)-PBOC-5 RAD-6.2X10E5
 Qual Envir TEST CURVE #30 RAD-outstanding item
 Aging outstanding item
 Method of Qualification TEST (F/%) GENERIC EVALUATION/UTILITY (AGING/#/RAD)
 Supporting Document GE RPT 145C3007 P&CS MEMO 80-186 (F/N/%)
 Notes NOT ESSENTIAL TO SYSTEM OPERATION
 QUAL STATUS JCO PURSUING RAD QUALIFICATION WITH EPRI/BWR OWNERS GROUP FINAL EVALUATION TO VERIFY APPLICABILITY OF GENE
 RIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN AA 4/81 HT 4/81 FE 4/81

Equipment No FT14618
 Description FLOW TRANSMITTER
 System CORE SPRAY SAFETY RELATED DISPLAY
 Man/Model GE 555 222005445
 Safety Function 11 CORE SPRAY FLOW
 Plant Location 1 2 C2269
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/N/%)-PBOC-5 RAD-6.2X10E5
 Qual Envir TEST CURVE #30 RAD-outstanding item
 Aging outstanding item
 Method of Qualification TEST (F/%) GENERIC EVALUATION UTILITY (#/AGING/RAD)
 Supporting Document GE RPT 145C3007 P&CS MEMO 80-186 (F/N/%)
 Notes NOT ESSENTIAL TO SYSTEM OPERATION
 QUAL STATUS JCO PURSUING RAD QUALIFICATION WITH EPRI/BWR OWNERS GROUP FINAL EVALUATION TO VERIFY APPLICABILITY OF GENE
 RIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN AA 4/81 HT 4/81 FE 4/81

Equipment No FT2358
 Description FLOW TRANSMITTER M243
 System HPCI SAFETY RELATED DISPLAY
 Man/Model GE 555 2220-05447
 Safety Function 4/11 HPCI MIN. RECIRC. CONTROL
 Plant Location 1 4 C2250
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/N/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #30 RAD-outstanding item
 Aging outstanding item
 Method of Qualification TEST (F/%) GENERIC EVALUATION/UTILITY (#/AGING/RAD)
 Supporting Document GE RPT 145C3007 P&CS MEMO 80-186 (F/N/%)
 QUAL STATUS JCO PURSUING RAD QUALIFICATION WITH EPRI/BWR OWNERS GROUP FINAL EVALUATION TO VERIFY APPLICABILITY OF GENE
 RIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN AA 4/81 HT 4/81 FE 4/81

Equipment No HPCI TURB CONTROL
 Description EGM CONTROL BOX M244
 System HPCI
 Man/Model WOODWARD 8270-B11
 Safety Function 4 HPCI SUPPORT
 Plant Location 1 3 C2303
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/N/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE 29b RAD-5X10E3
 Aging outstanding item
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document TERRY TEST SPEC E/L20397, REV 4 TERRY LTR TO BECo 11/29/79
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS
 QUAL PLAN AA 6/81 RA 6/81 FE 6/81

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 30

Equipment No HPCI TURB CONTROL 1
 Description EGR ACTUATOR ASSEMBLY M244
 System HPCI
 Man/Model WOODWARD 8250-133
 Safety Function 4 HPCI SUPPORT
 Plant Location 1.3 C2303
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE 29a RAD-5X10E3
 Aging outstanding item
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document TERRY TEST SPEC E/L20397;REV 4 TERRY LTR TO BECo 11/29/79
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS
 QUAL PLAN AA 6/81 RA 6/81 FE 8/81

Equipment No HPCI TURB CONTROL 2
 Description DROPPING RESISTOR ASSEMBLY M244
 System HPCI
 Man/Model WOODWARD 8270-281
 Safety Function 4 HPCI SUPPORT
 Plant Location 1.3 C2303
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE 29b RAD-5X10E3
 Aging outstanding item
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document TERRY TEST SPEC E/L20397;REV 4 TERRY LTR TO BECo 11/29/79
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS
 QUAL PLAN AA 6/81 RA 6/81 RE 8/81

Equipment No HPCI TURB CONTROL 3
 Description LOW SPEED POTENTIOMETER M244
 System HPCI
 Man/Model WOODWARD 1657-523
 Safety Function 4 HPCI SUPPORT
 Plant Location 1.3 C2303
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE 29b RAD-5X10E3
 Aging outstanding item
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document TERRY TEST SPEC E/L20397;REV 4 TERRY LTR TO BECo 11/29/79
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS
 QUAL PLAN AA 6/81 RA 6/81 FE 8/81

Equipment No HPCI TURB CONTROL 4
 Description SPEED SIGNAL CONVERTER M244
 System HPCI
 Man/Model WOODWARD 8270-848
 Safety Function 4 HPCI SUPPORT
 Plant Location 1.3 C2303
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE 29b RAD-5X10E3
 Aging outstanding item
 Method of Qualification TEST/SEQUENTIAL/SIMILAR
 Supporting Document TERRY TEST SPEC E/L20397;REV 4 TERRY LTR TO BECo 11/29/79
 QUAL. STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 31

QUAL PLAN AA 6/81 RA 6/81 RE 8/81

Equipment No	HPCI TURB CONTROL 5		
Description	MAGNETIC PICK-UP M244		
System	HPCI		
Man/Model	WOODWARD 1680-622		
Safety Function	4 HPCI SUPPORT		
Plant Location	1.3 TURB SKID		
Operating Time Req/Avail	R-5 hr.		
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3 5X10E4 loca dose only		
Qual Envir	TEST CURVE 29a RAD-5X10E3		
Aging	outstanding item		
Method of Qualification	TEST/SEQUENTIAL/SIMILAR		
Supporting Document	TERRY TEST SPEC E/L20397, REV 4 TERRY LTR TO BECo 11/29/79		
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS		
QUAL PLAN	AA 6/81 RA 6/81 FE 8/81		

Equipment No	HPCI TURB CONTROL 6		
Description	EGR & MAG PK-UP CABLE ASSEMBLIES M244		
System	HPCI		
Man/Model	WOODWARD 203911 203771 203908		
Safety Function	4 HPCI SUPPORT		
Plant Location	1.3 C2303		
Operating Time Req/Avail	R-5 hr.		
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3 5X10E4 loca dose only		
Qual Envir	TEST CURVE 29a RAD-5X10E3		
Aging	outstanding item		
Method of Qualification	TEST/SEQUENTIAL/SIMILAR		
Supporting Document	TERRY TEST SPEC E/L20397, REV 4 TERRY LTR TO BECo 11/29/79		
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS		
QUAL PLAN	AA 6/81 RA 6/81 FE 8/81		

Equipment No	HPCI TURB CONTROL 7		
Description	REMOTE TRIP SOV M244		
System	HPCI		
Man/Model	SKINNER L2-DB-5150		
Safety Function	4 HPCI SUPPORT		
Plant Location	1.3 TURB SKID		
Operating Time Req/Avail	R-5 hr.		
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3 5X10E4 loca dose only		
Qual Envir	(F/#/%)-NOT REQUIRED RAD-7X10E6		
Aging	outstanding item		
Method of Qualification	EVALUATION/UTILITY FAILURE-MODE ANALYSIS/UTILITY		
Supporting Document	MEMO P&CS BO-13 1/7/80		
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS		
QUAL PLAN	AA 6/81 RA 6/81 FE 8/81		

Equipment No	HPCI TURB CONTROL 8		
Description	PRESSURE SWITCH AUX OIL PMP START M244		
System	HPCI		
Man/Model	SQUARE D CLASS 9012 ACH22		
Safety Function	4 HPCI SUPPORT		
Plant Location	1.3 TURB SKID		
Operating Time Req/Avail	R-5 hr.		
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3 5X10E4 loca dose only		
Qual Envir	TEST CURVE 29a RAD-5X10E3		
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT		
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 32

Supporting Document TERRY TEST SPEC E/L20397, REV 4 TERRY LTR TD BECo 11/29/79 P&CS MEMO BO-202 (AGING)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS
 QUAL PLAN AA 6/81 RA 6/81 FE 8/81

Equipment No HPCI TURB CONTROL 9
 Description STOP VV LIMIT SW M244
 System HPCI
 Man/Model NAMCO D1200-G-2
 Safety Function 4 HPCI SUPPORT
 Plant Location 1.3 TURB SKID
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3 5X10E4 loca dose only
 Qual Envir (F/#/%)-NONE not required during hostile pboc RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO BO-238 (RAD)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF TESTING TO INSTALLED COMPONENTS
 QUAL PLAN AA 6/81 RA 6/81 FE 8/81

Equipment No LIS263-57A
 Description LEVEL INDICATING SWITCH M253
 System CNTM ISOLATION RPS SEC CNTM ISOLATION
 Man/Model YARWAY 441BC 26513
 Safety Function 1/2/3 SCRAM & CNTM ISO/MSIV & RECIRC PP TRIP/SEC CNTM ISO
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

Equipment No LIS263-57B
 Description LEVEL INDICATING SWITCH M253
 System CNTM ISOLATION RPS SEC CNTM ISOLATION
 Man/Model YARWAY 441BC 26514
 Safety Function 1/2/3 SCRAM & CNTM ISO/MSIV & RECIRC PP TRIP/SEC CNTM ISO
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

Equipment No LIS263-58A
 Description LEVEL INDICATING SWITCH M253
 System CNTM ISOLATION RPS SEC CNTM ISOLATION
 Man/Model YARWAY 441BC 26515
 Safety Function 1/2/3 SCRAM & CNTM ISO/MSIV & RECIRC PP TRIP/SEC CNTM ISO
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 33

Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No LIS263-58B
 Description LEVEL INDICATING SWITCH M253
 System CNTM ISOLATION RPS SEC CNTM ISOLATION
 Man/Model YARWAY 441BEC 2651B
 Safety Function 1/2/3 SCRAM & CNTM ISO/MSIV & RECIRC PP TRIP/SEC CNTM ISO
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No LIS263-72A
 Description LEVEL INDICATING SWITCH M253
 System RHR CORE SPRAY ADS via CORE SPRAY HPCI via RHR RCIC via CORE SPRAY
 Man/Model YARWAY 441BC
 Safety Function 4A/4B/4/10 RHR PP START/CS & HPCI PP START/ADS INIT
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No LIS263-72B
 Description LEVEL INDICATING SWITCH M253
 System RHR CORE SPRAY ADS via CORE SPRAY HPCI via RHR RCIC via CORE SPRAY
 Man/Model YARWAY 441BC
 Safety Function 4A/4B/4/10 RHR PP START/CS & HPCI PP START/ADS INIT
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No LIS263-72C
 Description LEVEL INDICATING SWITCH M253
 System RHR CORE SPRAY ADS via CORE SPRAY HPCI via RHR RCIC via CORE SPRAY
 Man/Model YARWAY 441BC 26521
 Safety Function 4A/4B/4/10 RHR PP START/CS & HPCI PP START/ADS INIT
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 34

Equipment No LITS263-72D
 Description LEVEL INDICATING SWITCH M253
 System RHR CORE SPRAY ADS via CORE SPRAY HPCI via RHR RCIC via CORE SPRAY
 Man/Model YARWAY 441BEC
 Safety Function 4A/4B/4/10 RHR PP START/CS & HPCI PP START/ADS INIT
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QAL STATUS DOR

Equipment No LITS263-59A
 Description LEVEL TRANSMITTING SWITCH
 System SAFETY RELATED DISPLAY
 Man/Model YARWAY 441BEC
 Safety Function 11 RX VESSEL LEVEL
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED (RETRANSMITTER) TEST CURVE #23 (INDICATING TRANSMITTER) RAD-NOT
 REQUIRED
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification GENERIC EVALUATION/UTILITY (F/#/%)
 Supporting Document P&CS MEMO 80-186 (F/#/%)
 QAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QAL PLAN HT 6/81 FE 6/81

Equipment No LITS263-59B
 Description LEVEL TRANSMITTING SWITCH
 System SAFETY RELATED DISPLAY
 Man/Model YARWAY 441BEC
 Safety Function 11 RX VESSEL LEVEL
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED (RETRANSMITTER) TEST CURVE #23 (INDICATING TRANSMITTER) RAD-NOT
 REQUIRED
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification GENERIC EVALUATION/UTILITY (F/#/%)
 Supporting Document P&CS MEMO 80-186 (F/#/%)
 QAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QAL PLAN HT 6/81 FE 6/81

Equipment No LITS263-73A
 Description LEVEL INDICATING TRANS SWITCH M253
 System RHR SAFETY RELATED DISPLAY
 Man/Model YARWAY 441BEC 26537
 Safety Function 4B/11 CNTM SPRAY PERM/MONITORING
 Plant Location 1.9 C2251
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #23 RAD-NOT REQUIRED
 Aging THERM-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILIT. (AGING) GENERIC EVALUATION/UTILITY (F/#/%)

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 35

Supporting Document GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN HT 6/81 FE 6/81

Equipment No	LITS243-73B
Description	LEVEL INDICATING TRANS SWITCH M253
System	RHR SAFETY RELATED DISPLAY
Man/Model	YARWAY 4418EC 2653B
Safety Function	4B/11 CNTM SPRAY PERM/MONITORING
Plant Location	I 10 C2252
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #23 RAD-NOT REQUIRED
Aging	THERM-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (F/#/%)
Supporting Document	GE RPT 145C3031 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-186 (F/#/%)
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
QUAL PLAN	HT 6/81 FE 6/81

Equipment No	LS2301-2351A
Description	LEVEL SWITCH M243
System	HPCI
Man/Model	ROBERT SHAW SL-702A1
Safety Function	4 OPEN HPCI TORUS SUCTION
Plant Location	TORUS AREA LOCAL MNTRD
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DRR

Equipment No	LS2301-2351B
Description	LEVEL SWITCH M243
System	HPCI
Man/Model	ROBERT SHAW SL-702A1
Safety Function	4 OPEN HPCI TORUS SUCTION
Plant Location	TORUS AREA LOCAL MNTRD
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DRR

Equipment No	LS2301-2365
Description	LEVEL SWITCH M243
System	HPCI
Man/Model	ROBERT SHAW SL-305-E7X D70-L226
Safety Function	4 HPCI DRAIN POT CONTROL
Plant Location	I 3 LOCAL MNTRD
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 36

Supporting Document
QUAL. STATUS DOR

P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)

Equipment No LS2301-2369
 Description LEVEL SWITCH M244
 System HPCI
 Man/Model ROBERT SHAW SL-305-E7X
 Safety Function 4 HPCI DRAIN POT CONTROL
 Plant Location 1.3 LOCAL MNTD
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir (F/#/%)-NOT REQUIRED RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No LS302-82A
 Description LEVEL SWITCH M250
 System CRD SCRAM SYSTEM
 Man/Model ROBERT SHAW SL-305-E7X D70-L233
 Safety Function 1 SCRAM - DISCH. VOLUME
 Plant Location 1.9 LOCAL MNTD
 Operating Time Req/Avail NR-LOCA NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not required during loca
 Qual Envir (F/#/%)- NOT REQUIRED RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No LS302-82B
 Description LEVEL SWITCH M250
 System CRD SCRAM SYSTEM
 Man/Model ROBERT SHAW SL-305-E7X D70-L234
 Safety Function 1 SCRAM - DISCH. VOLUME
 Plant Location 1.9 LOCAL MNTD
 Operating Time Req/Avail NR-LOCA NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not required during loca
 Qual Envir (F/#/%)- NOT REQUIRED RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No LS302-82C
 Description LEVEL SWITCH M250
 System CRD SCRAM SYSTEM
 Man/Model ROBERT SHAW SL-305-E7X D70-L230
 Safety Function 1 SCRAM - DISCH. VOLUME
 Plant Location 1.9 LOCAL MNTD
 Operating Time Req/Avail NR-LOCA NR-PBDC
 DBE Env R (F/#/%)-NONE not required for pboc RAD-NONE not required during loca
 Qual Envir (F/#/%)- NOT REQUIRED RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 37

Equipment No	LS302-B2D
Description	LEVEL SWITCH M250
System	CRD SCRAM SYSTEM
Man/Model	ROBERT SHAW SL-305-E7X D70-L229
Safety Function	1 SCRAM - DISCH. VOLUME
Plant Location	1.9 LOCAL MNTD
Operating Time Req/Avail	(E/#/%)-NONE not required for pboc RAD-NONE not required during loca
DBE Env Req	(F/#/%)- NOT REQUIRED RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Method of Qualification	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
Supporting Document	
QUAL STATUS	GOR
Equipment No	LS8020
Description	LEVEL SWITCH M244
System	HPCI
Man/Model	MCDONNELL & MILLER 63-SV
Safety Function	4 CONTROL HPCI GLAND SEAL COND. CONDENSATE PUMP NOT ESSENTIAL TO HPCI
Plant Location	1.3 LOCAL MNTD
Operating Time Req/Avail	R-5 hr (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
DBE Env Req	(F/#/%)-NOT REQUIRED RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD) EVALUATION/UTILITY (AGING)
Method of Qualification	MEMO P&CS 80-109 P&CS MEMO 80-238 (RAD) P&CS MEMO 80-202 (AGING)
Supporting Document	
QUAL STATUS	GOR
Equipment No	LS8021
Description	LEVEL SWITCH M244
System	HPCI
Man/Model	MCDONNELL & MILLER 63-SV
Safety Function	4 CONTROL HPCI GLAND SEAL COND. CONDENSATE PUMP NOT ESSENTIAL TO HPCI
Plant Location	1.3 LOCAL MNTD
Operating Time Req/Avail	R-5 hr (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
DBE Env Req	(F/#/%)-NOT REQUIRED RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD) EVALUATION/UTILITY (AGING)
Method of Qualification	MEMO P&CS 80-109 P&CS MEMO 80-238 (RAD) P&CS MEMO 80-202 (AGING)
Supporting Document	
QUAL STATUS	GOR
Equipment No	LS9068
Description	LEVEL SWITCH M243
System	HPCI
Man/Model	ROBERT SHAW SL-702A1
Safety Function	4 HPCI TURB EXHAUST
Plant Location	1.3 LOCAL MNTD
Operating Time Req/Avail	R-LOCA (P)-30 days NR-PBOC (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
DBE Env Req	(F/#/%)-NOT REQUIRED RAD-1X10E6
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Method of Qualification	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
Supporting Document	
QUAL STATUS	GOR
Equipment No	LT5038

7Y-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 38

Description LEVEL TRANSMITTER M241
 System SAFETY RELATED DISPLAY
 Man/Model FOXBORO 617B5-3K21-32 2470190
 Safety Function 11 TORUS WATER LEVEL MONITORING
 Plant Location TORUS AREA LOCAL MNID
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-5 RAD-A 2X10ES
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED outstanding item (RAD)
 Aging outstanding item
 Method of Qualification VENDOR EVALUATION
 Supporting Document BPCo SCEQ BPCo CEQE PACS MEMO 80-186
 Notes NEW LEVEL INSTRUMENTS TO BE INSTALLED AS PART OF TMI CAT. B
 QUAL STATUS NYQ NOT ESSENTIAL TO SAFETY SYSTEM OPERATION
 QUAL PLAN ER 1/81

Equipment No LT5049
 Description LEVEL XMTR M227
 System SAFETY RELATED DISPLAY
 Man/Model FOXBORO 617B5-3K21-32 2330799
 Safety Function 11 TORUS LEVEL INDICATION
 Plant Location TORUS AREA LOCAL MNID
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-5 RAD-A 2X10ES
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED outstanding item (RAD)
 Aging outstanding item
 Method of Qualification VENDOR EVALUATION
 Supporting Document BPCo SCEQ BPCo CEQE PACS MEMO 80-186
 Notes NEW INSTRUMENTS TO BE INSTALLED AS PART OF TMI CAT. B
 QUAL STATUS NYQ NOT ESSENTIAL TO SAFETY SYSTEM OPERATION
 QUAL PLAN ER 1/81

Equipment No LT646A
 Description LEVEL TRANSMITTER
 System SAFETY RELATED DISPLAY
 Man/Model GE 555111BCAA3ABA FF2220-05440
 Safety Function 11 RX VESSEL LEVEL
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #30 RAD-NOT REQUIRED
 Aging outstanding item
 Method of Qualification TEST (F/%) GENERIC EVALUATION /UTILITY (#/AGING)
 Supporting Document GE RPT 145C3007 P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN AA 4/81 HT 4/81 FE 4/81

Equipment No LT646B
 Description LEVEL TRANSMITTER
 System SAFETY RELATED DISPLAY
 Man/Model GE 555111BCAA3ABA EK030024-005
 Safety Function 11 RX VESSEL LEVEL
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #30 RAD-NOT REQUIRED
 Aging outstanding item
 Method of Qualification TEST (F/%) GENERIC EVALUATION/UTILITY (#/AGING)
 Supporting Document GE RPT 145C3007 P&CS MEMO 80-186 (F/#/%)

QUAL. STATUS JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN AA 4/81 HT 4/81 FE 4/81

Equipment No	M01001-16A
Description	MOTOR OPERATOR 1B-M139 VALVE M241
System	RHR
Man/Model	LIMITORQUE SMB-2 110685 343979A
Safety Function	4A/4B BLOCK VALVE-RHR HT EXCH BYPASS (E207A)
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DOOR
Equipment No	M01001-16B
Description	MOTOR OPERATOR 1B-N139 VALVE M241
System	RHR
Man/Model	LIMITORQUE SMB-2 110684 343979A
Safety Function	4A/4B BLOCK VALVE-RHR HT EXCH. BYPASS (E207B)
Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DOOR
Equipment No	M01001-18A
Description	MOTOR OPERATOR 3-N26M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 100046 345138A
Safety Function	2/4A/4B RHR(P203A/C) MIN. RECIRC.
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DOOR
Equipment No	M01001-18B
Description	MOTOR OPERATOR 3-N26M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-000 100047 345138B
Safety Function	2/4A/4B RHR (P203B/D) MIN. RECIRC.
Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DOOR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 40

Equipment No	MD1001-21
Description	MOTOR OPERATOR 4-N26 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-000 117864 34513BD RELIANCE 463471??
Safety Function	2 FLOCK VLV-RHR TO CHEM WASTE
Plant Location	1.B
Operating Time Req/Avail	R(A)-1 min R(P)-30 day (F/#/%)-PBDC-5 RAD-6.2X10E5
DBE Env Req	TEST CURVE #21 RAD-1X10E7
Qual Envir	THERMAL-200 hrs 75C MECH-2000 CYCLES
Aging	
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 1/3/80 LMTQE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B0009 LIMITORQUE TEST RPT B0027 BPCo CEQE
QUAL STATUS	DDR

Equipment No	MD1001-23A
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 12632B 34513BE RELIANCE 447107-CV
Safety Function	2/4A/4B BLOCK VALVE FOR CNTM. SPRAY
Plant Location	1.11A
Operating Time Req/Avail	R-30 day (F/#/%)-PBDC-2 RAD-6.2X10E5
DBE Env Req	TEST CURVE #21 RAD-2X10E7 (excluding brake) RAD-1X10E6 (brake)
Qual Envir	THERMAL-200 hrs 75C MECH-2000 CYCLES
Aging	
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 8/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQUE TEST RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
QUAL PLAN	RA 9/81 FE 9/81

Equipment No	MD1001-23B
Description	MOTOR OPERATOR 10-N26M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 122367 34513BF RELIANCE 447107-CV
Safety Function	2/4A/4B BLOCK VALVE FOR CNTM. SPRAY
Plant Location	1.10A
Operating Time Req/Avail	R-30 day (F/#/%)-PBDC-4 RAD-6.2X10E5
DBE Env Req	TEST CURVE #21 RAD-2X10E7 (excluding brake) RAD-1X10E6 (brake)
Qual Envir	THERMAL-200 hrs 75C MECH-2000 CYCLES
Aging	
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 8/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQUE TEST RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)
QUAL STATUS	JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
QUAL PLAN	RA 9/81 FE 9/81

Equipment No	MD1001-26A		
Description	MOTOR OPERATOR 10-N26M4 VALVE M241		
System	RHR CNTM ISOLATION		
Man/Model	LIMITORQUE SMB-0 122368 34513BG RELIANCE ???(447107-CV)		
Safety Function	2/4A/4B BLOCK VALVE FOR CNTM. SPRAY		
Plant Location	1.11A		
era	Time	q/A	1 day

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 41

DBE Env Req (F/#%)=PBOC-2 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7 (excluding brake) RAD-1X10E6 (brake)
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
 ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
 Supporting Document LMTGE LTR TO BPCo 4/27/79 4/30/79 8/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQU
 E RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
 QUAL PLAN RA 9/81 FE 9/81

Equipment No MO1001-26B
 Description MOTOR OPERATOR 10-N26M4 VALVE M241
 System RHR CNTM ISOLATION
 Man/Model LIMITORQUE SMB-0 122369 345138H RELIANCE 447107-CV
 Safety Function 2/4A/4B BLOCK VALVE FOR CNTM SPRAY
 Plant Location 1.10A
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#%)=PBOC-4 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7 (excluding brake) RAD-1X10E6 (brake)
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
 ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
 Supporting Document LMTGE LTR TO BPCo 4/27/79 4/30/79 8/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQU
 E RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
 QUAL PLAN RA 9/81 FE 9/81

Equipment No MO1001-28A
 Description MOTOR OPERATOR 18-N136SP66 VALVE M241
 System RHR CNTM ISOLATION
 Man/Model LIMITORQUE SMB-5 123931 337512A
 Safety Function 2/4A/4B LPC1 THROTTLE GLOBE LOOP A
 Plant Location 1.94
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#%)=PBOC-8 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
 QUAL STATUS DOR

Equipment No MO1001-28B
 Description MOTOR OPERATOR 18-N136SP66 VALVE M241
 System RHR CNTM ISOLATION
 Man/Model LIMITORQUE SMB-5 123932 337512A
 Safety Function 2/4A/4B LPC1 THROTTLE GLOBE LOOP B
 Plant Location 1.10B
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#%)=PBOC-1 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
 QUAL STATUS DOR

Equipment No MO1001-29A
 Description MOTOR OPERATOR 18-N14SP66M3 VALVE M241
 System RHR CNTM ISOLATION

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 42

Man/Model	LIMITORQUE SMB-3 109314 337511G
Safety Function	4A/4B/2 BLOCK VALVE/LPIC/LOOP A
Plant Location	1.9A
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-B RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DDR

Equipment No	M01001-29B
Description	MOTOR OPERATOR 1B-N14SP66M3 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-3 109315 337511G
Safety Function	4A/4B/2 LPC1 LOOP B BLOCK VALVE
Plant Location	1.10B
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-1 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DDR

Equipment No	M01001-32
Description	MOTOR OPERATOR 4-N26 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-000 113141 34513BC
Safety Function	2/4A/4B BLOCK VLV-RHR TO CHEM WASTE
Plant Location	1.8
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DDR

Equipment No	M01001-34A
Description	MOTOR OPERATOR 12-N26 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 110716 34397BA
Safety Function	2/4A/4B BLOCK VALVE: TORUS COOLING & SPRAY LOOP A
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027
QUAL. STATUS	DDR

Equipment No	M01001-34B
Description	MOTOR OPERATOR 12-N26 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 110715 34397BA
Safety Function	2/4A/4B BLOCK VALVE: TORUS COOLING & SPRAY LOOP B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 43

Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT 80003 LIMITORQUE RPT 80027
QUAL. STATUS	DR
Equipment No	M01001-36A
Description	MOTOR OPERATOR 12-N139M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-2 136500 353177D
Safety Function	2/4B BLOCK VALVE - TORUS COOLING / LOOP A
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT 80003 LIMITORQUE RPT 80027
QUAL. STATUS	DR
Equipment No	M01001-36B
Description	MOTOR OPERATOR 12-N139M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-2 136501 353177D
Safety Function	2/4B BLOCK VALVE - TORUS COOLING / LOOP B
Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT 80003 LIMITORQUE RPT 80027
QUAL. STATUS	DR
Equipment No	M01001-37A
Description	MOTOR OPERATOR 6-N139M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 111350 345138I
Safety Function	2/4B GLOBE THROTTLE / BLOCK TORUS SPRAY / LOOP A
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT 80003 LIMITORQUE RPT 80027
QUAL. STATUS	DR
Equipment No	M01001-37B
Description	MOTOR OPERATOR 6-N139M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 111351 345138M
Safety Function	2/4B GLOBE THROTTLE / BLOCK TORUS SPRAY / LOOP B
Plant Location	1.2
Operating Time Req/Avail	R-30 day

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 44

DBE Env Req (F/#/%)-PB0C-5 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging
 Method of Qualification THERMAL-200 hrs 75C MECH-2000 CYCLES
 Supporting Document TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 QUAL STATUS DOR LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST REPORT B0003 LIMITORQUE RPT B0027

Equipment No MO1001-43A
 Description MOTOR OPERATOR 1B-N29 VALVE M241
 System RHR
 Man/Model LIMITORQUE SMB-0 107780 343976A
 Safety Function 4A/4B RHR SHUTDOWN COOLING BLOCK VV-PUMP (P203A)
 Plant Location 1.1
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PB0C-5 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
 7
 QUAL STATUS DOR

Equipment No MO1001-43B
 Description MOTOR OPERATOR 1B-N29 VALVE M241
 System RHR
 Man/Model LIMITORQUE SMB-0 107778 343976A
 Safety Function 4A/4B RHR SHUTDOWN COOLING BLOCK VV-PUMP (P203B)
 Plant Location 1.2
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PB0C-5 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
 7
 QUAL STATUS DOR

Equipment No MO1001-43C
 Description MOTOR OPERATOR 1B-N29 VALVE M241
 System RHR
 Man/Model LIMITORQUE SMB-0 107779 343976A
 Safety Function 4A/4B RHR SHUTDOWN COOLING BLOCK VV-PUMP (P203C)
 Plant Location 1.1
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PB0C-5 RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
 7
 QUAL STATUS DOR

Equipment No MO1001-43D
 Description MOTOR OPERATOR 1B-N29 VALVE M241
 System RHR
 Man/Model LIMITORQUE SMB-0 107777 343976A
 Safety Function 4A/4B RHR SHUTDOWN COOLING BLOCK PP. (P203D)
 Plant Location 1.2

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 45

Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-5 RAD-6 2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT 80003 LIMITORQUE TEST RPT 8002

7
QUAL. STATUS DOR

Equipment No MO1001-47
 Description MOTOR OPERATOR 20-N14M4 VALVE M241
 System RHR CNTM ISOLATION
 Man/Model LIMITORQUE SMB-2 118290 338931A PEERLESS ZD-27226
 Safety Function 2/4A BLOCK VALVE-RHR SHUTDOWN-ALL RHR PUMPS
 Plant Location 1.9A
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-8 RAD-6 2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7 (excluding brake) RAD-1X10E6 (brake)
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 4/27/79 1/3/80 6/20/80 LIMITORQUE TEST RPT 80003 LIMITORQUE TEST RPT 80027
 P&CS MEMO 80-238 (RAD brake)
 Notes VENDOR SEARCH ON MOTOR QUALIFICATION IN PROGRESS

QUAL. STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
 QUAL PLAN RA 1/81 FE 1/81

Equipment No MO1001-60
 Description MOTOR OPERATOR 4-N14M4 VALVE M241
 System RHR CNTM ISOLATION
 Man/Model LIMITORQUE SMB-000 117777 345137J PEERLESS EX00554
 Safety Function 4A/4B/2 BLOCK VALVE-RHR SHUTDOWN-ALL RHR PUMPS/RX. VESSEL HD. SPRAY BLOCK BLOCK VALVE-HEAD SPR
 AY
 Plant Location 1.13
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #21 RAD-1X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
 ION ON NO. SUPERHEAT EFFECTS BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 1/3/80 LMTQE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT 80003 LIMITORQUE TEST
 RPT 80009 LIMITORQUE TEST RPT 80027 BPCo CEQE

QUAL. STATUS DOR

Equipment No MO1001-7A
 Description MOTOR OPERATOR 18-N29M4 VALVE M241
 System RHR CNTM ISOLATION
 Man/Model LIMITORQUE SMB-0 102773 343976A
 Safety Function 4A/4B/2 RHR PUMP (P203A) SUCT. BLOCK VALVE
 Plant Location 1.1
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBDC-5 RAD-6 2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT 80003 LIMITORQUE TEST RPT 8002

7
QUAL. STATUS DOR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 46

Equipment No	MO1001-7B
Description	MOTOR OPERATOR 18-N29M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 107771 343976A
Safety Function	4A/4B/2 RHR PUMP (P203B) SUCT. BLOCK VALVE
Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7

QUAL STATUS DOR

Equipment No	MO1001-7C
Description	MOTOR OPERATOR 18-N29M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 107772 343976A
Safety Function	4A/4B/2 RHR PUMP (P203C) SUCT. BLOCK VALVE
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7

QUAL STATUS DOR

Equipment No	MO1001-7D
Description	MOTOR OPERATOR 18-N29M4 VALVE M241
System	RHR CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 107774 343976A
Safety Function	4A/4B/2 RHR PUMP (P203D) SUCT. BLOCK VALVE
Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7

QUAL STATUS DOR

Equipment No	MO1201-5
Description	MOTOR OPERATOR 6-N14M3 VALVE M247
System	RCTR WTR CLEAN-UP CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 238558 393700A PEERLESS TD22166
Safety Function	2 RECIRC. TO CLEANUP ISO PBOC TERM
Plant Location	1.11A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-6.2X10E5
Qual Envir	TEST CURVE #22 RAD-1X10E7
Aging	THERMAL-100 hrs 180C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	LMTGE LTR TO EDISON 3/12/79 LIMITORQUE TEST RPT B0009

QUAL STATUS DOR

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 47

Equipment No M01201-80
 Description MOTOR OPERATOR 4-N116M3 VALVE M247
 System RCTR WTR CLEAN-UP CNTM ISOLATION
 Man/Model LIMITORQUE SMB-0 98031A 337511F
 Safety Function 2 CLEANUP ISO.
 Plant Location 1.11A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
 QUAL. STATUS DOR 7

Equipment No M01301-17
 Description MOTOR OPERATOR N14 VALVES RCIC M245
 System RCIC CNTM ISOLATION
 Man/Model LIMITORQUE SMB-000 268177 382124B
 Safety Function 2 RCIC CONT ISO VALVE-OUTSIDE PBOC TERM
 Plant Location 1.10A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-4 RAD-6.2X10E5
 Qual Envir TEST CURVE #22 RAD-1X10E7
 Aging THERMAL-100 hrs 180C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document LMTQE LTR TO EDISON 3/12/79 LIMITORQUE TEST RPT B0009
 QUAL. STATUS DOR

Equipment No M01301-25
 Description MOTOR OPERATOR GATE VALVE N29MA M245
 System RCIC CNTM ISOLATION
 Man/Model LIMITORQUE SMB-000 113142 345138P
 Safety Function 2 TORUS SUCT (RCIC) BLOCK VALVE
 Plant Location 1.5
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
 Supporting Document LMYGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
 QUAL. STATUS DOR 7

Equipment No M01301-26
 Description MOTOR OPERATOR GATE VALVE 6-29 M245
 System RCIC CNTM ISOLATION
 Man/Model LIMITORQUE SMB-000 100043 339199A PEERLESS MV84675
 Safety Function 2 TORUS SUCT (RCIC) BLOCK VALVE
 Plant Location 1.5
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #21 RAD-1X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
 Supporting Document ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST
 LMTQE LTR TO BPCo 1/3/80 LMTQE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 48

RPT B0009 LIMITORQUE TEST RPT B0027 BPCo CEQE

QUAL STATUS DOR

Equipment No M01301-60
 Description MOTOR OPERATOR 2-129 VALVES RCIC M245
 System CNTM ISOLATION
 Man/Model LIMITORQUE SMB-00 108600 343458A PEERLESS MW96382
 Safety Function 2 RCIC PUMP MIN. FLOW BYPASS
 Plant Location 1.5
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 (F/#/%)-NONE not required for pboc RAD-6 2X10E5
 DBE Env Req TEST CURVE #21 RAD-1X10E7
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
 Supporting Document ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
 LMTQE LTR TO BPCo 1/3/80 LMTQE LTR TO BPCo 1/30/80 LMTQE TWX TO BPCo 3/17/80 LIMITORQUE TEST
 RPT B0003 LIMITORQUE TEST RPT B0009 LIMITORQUE TEST RPT B0027 BPCo CEQE

QUAL STATUS DOR

Equipment No M01400-24A
 Description MOTOR OPERATOR 1Q - N14SP66 VALVE M242
 System CORE SPRAY CNTM ISOLATION
 Man/Model LIMITORQUE SMB-3 120859 345137E PERLESS FX01691
 Safety Function 4/2 BLOCK VALVE FOR CS INJECTION LOOP A
 Plant Location 1.11A
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-6 2X10E5
 Qual Envir TEST CURVE #21 RAD-2X10E7 (excluding brake) RAD-1X10E6 (brake)
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
 Supporting Document ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
 LMTQE LTR TO BPCo 4/27/79 4/30/79 6/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQU
 E RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)

QUAL STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION

QUAL PLAN RA 9/81 FE 9/81

Equipment No M01400-24B
 Description MOTOR OPERATOR 1Q-N14SP66 VALVE M242
 System CORE SPRAY CNTM ISOLATION
 Man/Model LIMITORQUE SMB-3 120860 345137F PEERLESS FX01692
 Safety Function 4/2 BLOCK VALVE FOR CS INJECTION LOOP B
 Plant Location 1.12
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #21 RAD-2X10E7 (excluding brake) RAD-1X10E6 (brake)
 Aging THERMAL-200 hrs 75C MECH-2000 CYCLES
 Method of Qualification TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
 Supporting Document ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
 LMTQE LTR TO BPCo 4/27/79 4/30/79 6/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQU
 E RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)

QUAL STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION

QUAL PLAN RA 9/81 FE 9/81

Equipment No M01400-25A
 Description MOTOR OPERATOR 1Q-N14SP66M3 VALVE M242
 System CORE SPRAY CNTM ISOLATION
 Man/Model LIMITORQUE SMB-3 109313 337511A RELIANCE Y232409A2
 Safety Function 4/2 BLOCK VALVE FOR CS INJECTION LOOP

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 49

Plant Location	1.11A
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-2 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7 (excluding brake)
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 8/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQU E RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)
QUAL. STATUS	JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
QUAL PLAN	RA 9/81 FE 9/81
Equipment No	MD1400-25B
Description	MOTOR OPERATOR 1Q-N14SP66M3 VALVE M242
System	CORE SPRAY CNTM ISOLATION
Man/Model	LIMITORQUE SMB-3 109312 337511A RELIANCE Y232409AI-KU
Safety Function	4/2 BLOCK VALVE FOR CS INJECTION LOOP B
Plant Location	1.12
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #21 RAD-2X10E7 (excluding brake)
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT ION ON SUPERHEAT EFFECTS BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 8/27/80 1/3/80 2/5/80 LIMITORQUE TEST REPORT B0003 LIMITORQU E RPT B0027 FIRL TEST RPT F-C3271 (brake only) P&CS MEMO 80-238 (RAD brake)
QUAL. STATUS	JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF BRAKE RADIATION
QUAL PLAN	RA 9/81 FE 9/81
Equipment No	MD1400-3A
Description	MOTOR OPERATOR 1B-N29M4 VALVE M242
System	CORE SPRAY CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 107775 343976A
Safety Function	2/4 C.S. PUMP (P215A) SUCT VALVE
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
7	
QUAL. STATUS	DOR
Equipment No	MD1400-3B
Description	MOTOR OPERATOR 1B-N29M4 VALVE M242
System	CORE SPRAY CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 107776 343976A
Safety Function	4/2 CS PUMP (P215B) SUCT VLV
Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
7	
QUAL. STATUS	DOR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 50

Equipment No	MD1400-4A
Description	MOTOR OPERATOR 6-N26M3 VALVE M242
System	CORE SPRAY CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 100679 345138J
Safety Function	2/4 BLOCK VALVE: CS PUMP P215A TEST LINE
Plant Location	1.1
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBQC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
7	
QUAL STATUS	DRR

Equipment No	MD1400-4B
Description	MOTOR OPERATOR 6-N26M3 VALVE M242
System	CORE SPRAY CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 100680 345138K
Safety Function	2/4 BLOCK VALVE CS PUMP P215B TEST LINE
Plant Location	1.2
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBQC-5 RAD-6 2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTGE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002
7	
QUAL STATUS	DRR

Equipment No	MD2301-10
Description	MOTOR OPERATOR N116 VALVE HPCI M243
System	HPCI
Man/Model	LIMITORQUE SMB-2 119753 345137B PEERLESS HX02737
Safety Function	4 HPCI TEST TO COND STOR TK
Plant Location	1.4
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #21 RAD-1X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
Supporting Document	ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST LMTGE LTR TO BPCo 1/3/80 LMTGE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B0009 LIMITORQUE TEST RPT B0027 BPCo CEQE
QUAL STATUS	DRR

Equipment No	MD2301-14
Description	MOTOR OPERATOR 4 GLOBE VALVE M243
System	HPCI CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 103977 339599A RELIANCE 456621-IU
Safety Function	2/4 HPIC PUMP MIN RECIRC BLOCK VALVE
Plant Location	1.3
Operating Time Req/Avail	R-(A)-5 hr R-(P)-30 days
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-1X10E6
Aging	outstanding item
Supporting Document	P&CS MEMO 80-238 (RAD)

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 51

QUAL. STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF RADIATION
 QUAL PLAN RA 1/81 AA 1/81 FE 1/81

Equipment No	M02301-3
Description	MOTOR OPERATOR N14 VALVES HPCI M243
System	HPCI
Man/Model	LIMITORQUE SMB-1 118198 345137K PEERLESS QX01647
Safety Function	4 HPCI - STEAM SUPPLY
Plant Location	1.3
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/N/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #21 RAD-1X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
Supporting Document	ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST LMTGE LTR TO BPCo 1/3/80 LMTGE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B0009 LIMITORQUE TEST RPT B0027 BPCo CEQE
QUAL. STATUS DOR	

Equipment No	M02301-35
Description	MOTOR OPERATOR SUPPRESSION POOL SUCTION LINE VALVE HPCI M243
System	HPCI CNTM ISOLATION
Man/Model	LIMITORQUE SMB-0 114023 339213A RELIANCE 456621-EX
Safety Function	2/4 HPIC TORUS SUCT BLOCK VALVE
Plant Location	1.3
Operating Time Req/Avail	R-(A)-5 hrs R-(P)-30 days
DBE Env Req	(F/N/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #21 RAD-1X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
Supporting Document	ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST LMTGE LTR TO BPCo 1/3/80 LMTGE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B0009 LIMITORQUE TEST RPT B0027 BPCo CEQE
QUAL. STATUS DOR	

Equipment No	M02301-36
Description	MOTOR OPERATOR SUPPRESSION POOL SUCTION LINE VALVE HPCI M243
System	HPCI CNTM ISOLATION
Man/Model	LIMITORQUE SMB-00 113573 343977A RELIANCE 463448-CV
Safety Function	2/4 HPIC TORUS SUCT. BLOCK VALVE
Plant Location	1.3
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/N/%)-NONE not required during hostile phoc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #21 RAD-1X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
Supporting Document	ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST LMTGE LTR TO BPCo 1/3/80 LMTGE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B0009 LIMITORQUE TEST RPT B0027 BPCo CEQE
QUAL. STATUS DOR	

Equipment No	M02301-5
Description	MOTOR OPERATOR N14 VALVES HPCI M243
System	HPCI CNTM ISOLATION
Man/Model	LIMITORQUE SMB-1 272114 3B2124A
Safety Function	2/4 HPCI INJ ISO VALVE PB0C TERM
Plant Location	1.10B
Operating Time Req/Avail	R-(A)-5 hr R-(P)-0 d.

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 52

DBE Env Req	(F/N/Z)-PBDC-1	RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #22	RAD-1X10E7
Aging	THERMAL-100 hrs 180C	MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	LMTQE LTR TO EDISON 3/12/79	LIMITORQUE TEST RPT B0009
QUAL STATUS DOR		
Equipment No	MO2301-8	
Description	MOTOR OPERATOR N10 VALVES HPCI	M243
System	HPCI	
Man/Model	LIMITORQUE	SMB-1 111297 342871A PEERLESS AX96796
Safety Function	4	HPCI PUMP DISCH.
Plant Location	1.10A	
Operating Time Req/Avail	R-(A)-5 hr	R-(P)-30 days
DBE Env Req	(F/N/Z)-PBDC-4	RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #21	RAD-1X10E7
Aging	THERMAL-200 hrs 75C	MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
Supporting Document	ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST	LMTQE LTR TO BPCo 1/3/80 LMTQE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST
QUAL STATUS DOR	RPT B0009	LIMITORQUE TEST RPT B0027 BPCo CEGE
Equipment No	MO2301-9	
Description	MOTOR OPERATOR N10 VALVES HPCI	M243
System	HPCI	
Man/Model	LIMITORQUE	SMB-1 111296 342871A PEERLESS AX96795
Safety Function	4	HPCI PUMP DISCH.
Plant Location	1.3	
Operating Time Req/Avail	R-5 hr	
DBE Env Req	(F/N/Z)-NONE not required during hostile pbdc	RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #21	RAD-1X10E7
Aging	THERMAL-200 hrs 75C	MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
Supporting Document	ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST	LMTQE LTR TO BPCo 1/3/80 LMTQE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST
QUAL STATUS DOR	RPT B0009	LIMITORQUE TEST RPT B0027 BPCo CEGE
Equipment No	MO261-2 MO220-2	
Description	MOTOR OPERATOR 3-N14M4 VALVE	M252
System	MAIN STEAM CNTM ISOLATION	
Man/Model	LIMITORQUE	SMB-000-5 117776 245137H PEERLESS EX00553
Safety Function	2 MSIV DRAIN BLOCK VALVE	
Plant Location	STEAM TUNNEL	
Operating Time Req/Avail	R-LOCA(A)-1 min	R-LOCA(P)-30 day R-PBDC(A)-30 min R-PBDC(P)-30 day
DBE Env Req	(F/N/Z)-PBDC-B	RAD-6.2X10E5
Qual Envir	TEST CURVE #21	RAD-1X10E7
Aging	THERMAL-200 hrs 75C	MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	VENDOR EVALUATION OF INDIVIDUAL COMPONENTS TO ONES TESTED BPCo EVALUAT
Supporting Document	ION ON NO SUPERHEAT EFFECTS BASED ON VENDOR TEST	LMTQE LTR TO BPCo 1/3/80 LMTQE LTR TO BPCo 1/30/80 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST
QUAL STATUS DOR	RPT B0009	LIMITORQUE TEST RPT B0027 BPCo CEGE
Equipment No	MO4002	
Description	MOTOR OPERATOR 6-29 GATE VALVE	M215
System	PBDC4 CNTM ISOLATION	

79-016 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 53

Man/Model	LIMITORQUE SMB-000 113230 345606A
Safety Function	2/4C RBCCW CONT. ISO. VALVE
Plant Location	TORUS AREA
Operating Time Req/Avail	R-(A)-10 min (TO ALLOW TIME FOR REMOTE MANUAL OPERATION)
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7
QUAL STATUS DOR

Equipment No	MO4010A
Description	MOTOR OPERATOR 12-29 GATE VALVE M215
System	RBCCW
Man/Model	LIMITORQUE SMB-00 99972A 339189A
Safety Function	4C RHR HT EXCH
Plant Location	1.2
Operating Time Req/Avail	R-(A)-30 day
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7
QUAL STATUS DOR

Equipment No	MO4010B
Description	MOTOR OPERATOR 12-29 GATE VALVE M215
System	RBCCW
Man/Model	LIMITORQUE SMB-00 99973A 339189A
Safety Function	4C RHR HT EXCH
Plant Location	1.2
Operating Time Req/Avail	R-(A)-30 day
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7
QUAL STATUS DOR

Equipment No	MO4060A
Description	MOTOR OPERATOR 12-29 GATE VALVE M215
System	RBCCW
Man/Model	LIMITORQUE SMB-00 99974A 339189A
Safety Function	AC RHR HT EXCH INLET
Plant Location	1.1
Operating Time Req/Avail	R-(A)-30 day
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7
QUAL STATUS DOR

Equipment No MO4060B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 54

Description	MOTOR OPERATOR 12-29 GATE VALVE M215
System	RBCCW
Man/Model	LIMITORQUE SMB-00 99975A 339189A
Safety Function	4C RHR HT EXCH
Plant Location	1.1
Operating Time Req/Avail	R-(A)-30 day
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6 BX10E5
Qual Envir	TEST CURVE #21 RAD-2X10E7
Aging	THERMAL-200 hrs 75C MECH-2000 CYCLES
Method of Qualification	TEST/SEQUENTIAL/SIMILAR BPCo SUPERHEAT EVALUATION BASED ON VENDOR TEST
Supporting Document	LMTQE LTR TO BPCo 4/27/79 4/30/79 & 6/11/79 LIMITORQUE TEST RPT B0003 LIMITORQUE TEST RPT B002

7
QUAL. STATUS DOR

Equipment No	MON109
Description	OUTLET DAMPER FOR VEX210A M294
System	STANDBY GAS TREATMENT
Man/Model	HONEYWELL ACTIONATOR M940A1067-1
Safety Function	13 STANDBY GAS TREATMENT
Plant Location	1.23
Operating Time Req/Avail	R-LOCA(P)-30 day NR-PB0C
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-8 BX10E6
Qual Envir	(F/#/%)- NOT REQUIRED outstanding item (RAD)
Aging	outstanding item
QUAL. STATUS	NYQ
QUAL PLAN	ER 11/81

Equipment No	MON113
Description	OUTLET DAMPER FOR VEX210B M294
System	STANDBY GAS TREATMENT
Man/Model	HONEYWELL ACTIONATOR M940A1067-1
Safety Function	13 STANDBY GAS TREATMENT
Plant Location	1.23
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PB0C
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-8 BX10E6
Qual Envir	(F/#/%)- NOT REQUIRED outstanding item (RAD)
Aging	outstanding item
QUAL. STATUS	NYG
QUAL PLAN	ER 11/81

Equipment No	N550
Description	SHUTDOWN PANEL
System	ELECTRICAL DISTRIBUTION
Man/Model	VARIOUS SWITCHES-ELECTROSWITCH 24&40 LIGHTS-GE ET-16 TERMINAL BLOCKS-GE EB-25
Safety Function	12 ELECTRICAL DISTRIBUTION
Plant Location	1.10
Operating Time Req/Avail	R-30day
DBE Env Req	(F/#/%)-PB0C-1 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #40 (TB) (F/#/%)-IN EXCESS OF REQUIRED (SW & LT) RAD-5X10E6 (TB) RAD-1X10E6 (LT)
Aging	RAD-1X10E4 (SW)
Method of Qualification	THERMAL-120hrs BOC (SW) MECH-10000 CYCLES (SW) THERM-NOT SIGNIFICANT (LT & TB) TEST/SEQUENTIAL (TB) TEST SEPARATE (SW & RAD AGING) GENERIC EVALUATION/UTILITY (LT F/#/% RAD A QING) GENERIC EVALUATION/UTILITY (SW F/#%)
Supporting Document	EPRI/BWR GSR-010-A-01 (TB) ELECTROSWITCH ENG TEST RPT 2392-14 (SW & RAD AGING) P&CS MEMO 80-18 & (SW & LT F/#/%) P&CS MEMO 80-202 (LT & TB AGING) P&CS MEMO 80-238 (LT RAD)
QUAL. STATUS	JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC STUDY
QUAL PLAN	RA 2/81 HT 2/81 AA 2/81 FE 3/81

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 55

11

Equipment No	P203A
Description	RHR PUMP M241
System	RHR
Man/Model	GE 5K6339XCB7A JFJ909007
Safety Function	4A/4B
Plant Location	1.1
Operating Time Req/Avail	R-30 day (F/#/%)-PBOC-5 RAD-6.2X10E5
DBE Env Req	RAD-9X10E7
Qual Envir	THERM-114000hrs 40C (estimated life)
Aging	TEST/SIMILAR EQUIPMENT (F/#/%) EVALUATION/VENDOR (RAD/AGING)
Method of Qualification	
Supporting Document	QE LTR Q-HK-0-163
QUAL STATUS	DDR

Equipment No	P203B
Description	RHR PUMP M241
System	RHR
Man/Model	GE 5K6339XCB7A JFJ909008
Safety Function	4A/4B
Plant Location	1.2
Operating Time Req/Avail	R-30 day (F/#/%)-PBOC-5 RAD-6.2X10E5
DBE Env Req	RAD - 9X10E7
Qual Envir	THERM-114000hrs 40C (estimated life)
Aging	TEST/SIMILAR EQUIPMENT (F/#/%) EVALUATION/VENDOR (RAD/AGING)
Method of Qualification	
Supporting Document	QE LTR Q-HK-0-163
QUAL STATUS	DDR

Equipment No	P203C
Description	RHR PUMP M241
System	RHR
Man/Model	GE 5K6339XCB7A JFJ909006
Safety Function	4A/4B
Plant Location	1.1
Operating Time Req/Avail	R-30 day (F/#/%)-PBOC-5 RAD-6.2X10E5
DBE Env Req	RAD - 9X10E7
Qual Envir	THERM-114000hrs 40C (estimated life)
Aging	TEST/SIMILAR EQUIPMENT (F/#/%) EVALUATION/VENDOR (RAD/AGING)
Method of Qualification	
Supporting Document	QE LTR Q-HK-0-163
QUAL STATUS	DDR

Equipment No	P203D
Description	RHR PUMP M241
System	RHR
Man/Model	GE 5K6339XCB7A JFJ12A9006
Safety Function	4A/4B
Plant Location	1.2
Operating Time Req/Avail	R-30 day (F/#/%)-PBOC-5 RAD-6.2X10E5
DBE Env Req	RAD - 9X10E7
Qual Envir	THERM-114000hrs 40C (estimated life)
Aging	TEST/SIMILAR EQUIPMENT (F/#/%) EVALUATION/VENDOR (RAD/AGING)
Method of Qualification	
upp. to E tent	
QUAL STATUS	DDR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 56

System	CORE SPRAY	
Man/Model	GE 5K6337XC93A FEJ618021	
Safety Function	4	
Plant Location	1.1	
Operating Time Req/Avail	R-30 day	
DBE Env Req	(F/#/%)-PBOC-5	RAD-6.2X10E5
Qual Envir.	RAD = 9X10E7	
Aging	THERM-114000hrs 40C (estimated life)	
Method of Qualification	TEST/SIMILAR EQUIPMENT (F/#/%) EVALUATION/VENDOR (RAD/AQING)	
Supporting Document	GE LTR G-HK-0-163	
QUAL. STATUS	DOR	

Equipment No	P215B	
Description	CORE SPRAY PUMP M242	
System	CORE SPRAY	
Man/Model	GE 5K6337XC93A FEJ618022	
Safety Function	4	
Plant Location	1.2	
Operating Time Req/Avail	R-30 day	
DBE Env Req	(F/#/%)-PBOC-5	RAD-6.2X10E5
Qual Envir.	RAD = 9X10E7	
Aging	THERM-114000hrs 40C (estimated life)	
Method of Qualification	TEST/SIMILAR EQUIPMENT (F/#/%) EVALUATION/VENDOR (RAD/AQING)	
Supporting Document	GE LTR G-HK-0-163	
QUAL. STATUS	DOR	

Equipment No	PS1001-104A	
Description	PRESSURE SWITCH M241	
System	RHR ADS	
Man/Model	STATIC-O-RING SN-AA3 72-4-1-1753	
Safety Function	10 ADS AUTO ACTUATION PERMISSIVE SIGNAL	
Plant Location	1.1 LOCAL MNTD	
Operating Time Req/Avail	R-8 hr	
DBE Env Req	(F/#/%)-PBOC-5 RAD-5X10E4 loca dose only	
Qual Envir.	TEST CURVE #27 RAD-1X10E6	
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT	
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AQING) GENERIC EVALUATION/UTILITY (RAD)	
Supporting Document	GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AQING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)	
QUAL. STATUS	JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY	
QUAL PLAN	HT 4/81 FE 4/81	

Equipment No	PS1001-104B	
Description	PRESSURE SWITCH M241	
System	RHR ADS	
Man/Model	STATIC-O-RING SN-AA3 70-9-936	
Safety Function	10 ADS PERMISSIVE	
Plant Location	1.2 LOCAL MNTD	
Operating Time Req/Avail	R-8 hr	
DBE Env Req	(F/#/%)-PBOC-5 RAD-5X10E4 loca dose only	
Qual Envir.	TEST CURVE #27 RAD-1X10E6	
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT	
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AQING) GENERIC EVALUATION/UTILITY (RAD)	
Supporting Document	GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AQING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)	
QUAL. STATUS	JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY	
QUAL PLAN	HT 4/81 FE 4/81	

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 57

Equipment No PS1001-104C
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 5N-AA3-X3PP 72-4-1749
 Safety Function 10 ADS AUTO ACTUATION PERMISSIVE SIGNAL
 Plant Location 1.1 LOCAL MNTD
 Operating Time Req/Avail R-B hr
 DBE Env Req (F/#/%)-PBDC-5 RAD-5X10E4 loca dose only
 Qual Envir TEST CURVE #27 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 #/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No PS1001-104D
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 5N-AA3-X3PP 70-9-937
 Safety Function 10 ADS PERMISSIVE
 Plant Location 1.2 LOCAL MNTD
 Operating Time Req/Avail R-B hr
 DBE Env Req (F/#/%)-PBDC-5 RAD-5X10E4 loca dose only
 Qual Envir TEST CURVE #27 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 #/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No PS1001-83A
 Description PRESSURE SWITCH M241
 System RHR
 Man/Model STATIC-O-RING 12N-AA4-PP 69-11-110
 Safety Function 4B DRYWELL SPRAY VALVE PERMISSIVE
 Plant Location 1.14 C129A
 Operating Time Req/Avail R-LOCA-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pbdc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #28 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No PS1001-83B
 Description PRESSURE SWITCH M241
 System RHR
 Man/Model STATIC-O-RING 12N-AA4-PP 69-11-99
 Safety Function 4B DRYWELL SPRAY VALVE PERMISSIVE
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-LOCA-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pbdc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #28 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 58

QUAL STATUS DOR

Equipment No PS1001-B3C
 Description PRESSURE SWITCH M241
 System RHR
 Man/Model STATIC-O-RING 12NAA5 70-11-1547
 Safety Function 4B DRYWELL SPRAY VALVE PERMISSIVE
 Plant Location 1.14 C129A
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #2B RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

Equipment No PS1001-B3D
 Description PRESSURE SWITCH M241
 System RHR
 Man/Model STATIC-O-RING 12NAA5 70-11-1546
 Safety Function 4B DRYWELL SPRAY VALVE PERMISSIVE
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #2B RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

Equipment No PS1001-B9A
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 12N-AAS 69-11-109
 Safety Function 10 ADS PERMISSIVE
 Plant Location 1.14 C129B
 Operating Time Req/Avail R-8 hr
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #2B RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

Equipment No PS1001-B9B
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 12N-AA4-PP 69-11-100
 Safety Function 10 ADS PERMISSIVE
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-8 hr
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #2B RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO BO-202 (AGING) P&CS MEMO BO-238 (RAD)
 QUAL STATUS DOR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 59

Equipment No	PS1001-B9C
Description	PRESSURE SWITCH M241
System	RHR ADS
Man/Model	STATIC-O-RING 12N-AA4-PP 69-11-104
Safety Function	10 ADS PERMISSIVE
Plant Location	1.14 C129A
Operating Time Req/Avail	R-8 hr
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #28 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DDR

Equipment No	PS1001-B9D
Description	PRESSURE SWITCH M241
System	RHR ADS
Man/Model	STATIC-O-RING 12N-AA5 69-11-102
Safety Function	10 ADS PERMISSIVE
Plant Location	1.12 C2206
Operating Time Req/Avail	R-8 hr
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #28 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DDR

Equipment No	PS1001-90A
Description	PRESSURE SWITCH M241
System	RHR CORE SPRAY HPCI via CORE SPRAY
Man/Model	STATIC-O-RING 12N-AA4-PP 69-11-106
Safety Function	4A/4B/4 PERM SIG (RHR/CS/HPCI INIT)
Plant Location	1.14 C129B
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #28 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DDR

Equipment No	PS1001-90B
Description	PRESSURE SWITCH M241
System	RHR CORE SPRAY HPCI via CORE SPRAY
Man/Model	STATIC-O-RING 12N-AA4-PP 69-11-105
Safety Function	4A/4B/4 PERM SIG (RHR/CS/HPCI INIT)
Plant Location	1.12 C2206
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #28 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DDR

Equipment No	PS1001-90C
Description	PRESSURE SWITCH M241

78-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 60

System RHR CORE SPRAY HPCI via CORE SPRAY
 Man/Model STATIC-O-RING 12N-AA4-PP 69-11-111
 Safety Function 4A/4B/4 PERM SIG (RHR/CS/HPCI INIT)
 Plant Location 1.14 C129A
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #28 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DQR

Equipment No PS1001-90D
 Description PRESSURE SWITCH M241
 System RHR CORE SPRAY HPCI via CORE SPRAY
 Man/Model STATIC-O-RING 12N-AA4-PP 69-11-101
 Safety Function 4A/4B/4 PERM SIG (RHR/CS/HPCI INIT)
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #28 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DQR

Equipment No PS1001-93A
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 5N-AA3 70-10-1167
 Safety Function 10 ADS AUTO ACTUATION PERMISSIVE SIGNAL
 Plant Location 1.1 LOCAL MNTD
 Operating Time Req/Avail R-8 hr
 DBE Env Req (F/#/%)-PBOC-5 RAD-5X10E4 loca dose only
 Qual Envir TEST CURVE #27 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 %/%)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No PS1001-93B
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 5N-AA3 70-10-1164
 Safety Function 10 ADS AUTO ACTUATION PERMISSIVE SIGNAL
 Plant Location 1.2 LOCAL MNTD
 Operating Time Req/Avail R-8 hr
 DBE Env Req (F/#/%)-PBOC-5 RAD-5X10E4 loca dose only
 Qual Envir TEST CURVE #27 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 %/%)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No PS1001-93C
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 5N-AA3 70-10-1165
 Safety Function 10 ADS AUTO ACTUATION PERMISSIVE SIGNAL
 Plant Location 1.1 LOCAL MNTD
 Operating Time Req/Avail R-8 hr
 DBE Env Req (F/#/%)-PBOC-5 RAD-5X10E4 loca dose only
 Qual Envir TEST CURVE #27 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 #/%)
 GUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 GUAL PLAN HT 4/81 FE 4/81

Equipment No PS1001-93D
 Description PRESSURE SWITCH M241
 System RHR ADS
 Man/Model STATIC-O-RING 5N-AA3 70-10-1166
 Safety Function 10 ADS AUTO ACTUATION PERMISSIVE SIGNAL
 Plant Location 1.2 LOCAL MNTD
 Operating Time Req/Avail R-8 hr
 DBE Env Req (F/#/%)-PBOC-5 RAD-5X10E4 loca dose only
 Qual Envir TEST CURVE #27 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 #/%)
 GUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 GUAL PLAN HT 4/81 FE 4/81

Equipment No PS1360-9A
 Description PRESSURE SWITCH M245
 System RCIC CNTM ISOLATION
 Man/Model BARKSDALE B2T-A12SS 13609A
 Safety Function 2 RCIC ISO PBOC TERM
 Plant Location 1.7 C2257B
 Operating Time Req/Avail NR-LOCA R-PBOC-1 min
 DBE Env Req (F/#/%)-PBOC-6 RAD-NONE not required during loca
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 #/%)
 GUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 GUAL PLAN HT 4/81 FE 4/81

Equipment No PS1360-9B
 Description PRESSURE SWITCH M245
 System RCIC CNTM ISOLATION
 Man/Model BARKSDALE B2T-A12SS 13609B
 Safety Function 2 RCIC ISO PBOC TERM
 Plant Location 1.7 C2257B
 Operating Time Req/Avail NR-LOCA R-PBOC-1 min
 DBE Env Req (F/#/%)-PBOC-6 RAD-NONE not required during loca
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 62

Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/
 #/%)

QUAL. STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No	PS1360-9C
Description	PRESSURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	BARKSDALE B2T-1A2SS 13609C
Safety Function	2 RCIC ISO PBDC TERM
Plant Location	1.7 C2257B
Operating Time Req/Avail	NR-LOCA R-PBDC-1 min
DBE Env Req	(F/#/%)-PBDC-6 RAD-NONE not required during loca
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/ #/%)

QUAL. STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No	PS1360-9D
Description	PRESSURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	BARKSDALE B2T-1A2SS 13609D
Safety Function	2 RCIC ISO PBDC TERM
Plant Location	1.7 C2257B
Operating Time Req/Avail	NR-LOCA R-PBDC-1 min
DBE Env Req	(F/#/%)-PBDC-6 RAD-NONE not required during loca
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/ #/%)

QUAL. STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No	PS1451A
Description	PRESSURE SWITCH M242
System	CORE SPRAY ADS
Man/Model	STATIC-O-RING SN-AA3 70-11-1548
Safety Function	1Q CORE SPRAY-(ADS PERMISSIVE)
Plant Location	1.1 C2201
Operating Time Req/Avail	R-B hr
DBE Env Req	(F/#/%)-PBDC-5 RAD-5X10E4 loca dose only
Qual Envir	TEST CURVE #27 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/ #/%)

QUAL. STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 4/81 FE 4/81

Equipment No	PS1451B
Description	PRESSURE SWITCH M242
System	CORE SPRAY ADS
Man/Model	STATIC-O-RING SN-AA3 70-11-1555

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 63

Safety Function	10 CORE SPRAY-(ADS PERMISSIVE)
Plant Location	1 2 C2260
Operating Time Req/Avail	R-8 hr
DBE Env Req	(F/#/%)-PBDC-5 RAD-5X10E4 loca dose only
Qual Envir	TEST CURVE #27 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#%)
QUAL STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY	
QUAL PLAN	HT 4/81 FE 4/81

Equipment No	PS1464A
Description	PRESSURE SWITCH M242
System	CORE SPRAY ADS
Man/Model	STATIC-O-RING SN-AA3 70-10-1548
Safety Function	10 CORE SPRAY-(ADS PERMISSIVE)
Plant Location	1 1 C2201
Operating Time Req/Avail	R-8 hr
DBE Env Req	(F/#/%)-PBDC-5 RAD-5X10E4 loca dose only
Qual Envir	TEST CURVE #27 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#%)
QUAL STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY	
QUAL PLAN	HT 4/81 FE 4/81

Equipment No	PS1464B
Description	PRESSURE SWITCH M242
System	CORE SPRAY ADS
Man/Model	STATIC-O-RING SN-AA3 71-B-206
Safety Function	10 CORE SPRAY-(ADS PERMISSIVE)
Plant Location	1 2 C2260
Operating Time Req/Avail	R-8 hr
DBE Env Req	(F/#/%)-PBDC-5 RAD-5X10E4 loca dose only
Qual Envir	TEST CURVE #27 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3011 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#%)
QUAL STATUS JCO FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY	
QUAL PLAN	HT 4/81 FE 4/81

Equipment No	PS2301-236BA
Description	PRESS SWITCH M244
System	HPCI
Man/Model	MERCOID DA23-B04 30749813
Safety Function	4 HPCI TURBINE TRIP LOGIC
Plant Location	1 4 C2250
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS DGR	

79-U1B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 64

Equipment No	PS2301-2368B
Description	PRESS SWITCH M244
System	HPCI
Man/Model	MERCOID DA23-804
Safety Function	4 HPCI TURBINE TRIP LOGIC
Plant Location	1.4 C2250
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOA
Equipment No	PS2301-2389A
Description	PRESSURE SWITCH M243
System	HPCI
Man/Model	BARKSDALE PIH-M855SV
Safety Function	4 HPCI SUPPORT LOW PRESSURE TRIP
Plant Location	1.2 C2257A
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #34 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD) TEST/SEQUENTIAL/SIMILAR (F/#/%)
Supporting Document	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) GE LTR Q-HK-O-79 & SUMMARY NSEB01BB (F/#/%)
QUAL STATUS	DOA
Equipment No	PS2301-2389B
Description	PRESSURE SWITCH M243
System	HPCI
Man/Model	BARKSDALE PIH-M855SV
Safety Function	4 HPCI SUPPORT LOW PRESS TRIP
Plant Location	1.2 C2257A
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #34 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD) TEST/SEQUENTIAL/SIMILAR (F/#/%)
Supporting Document	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) GE LTR Q-HK-O-79 & SUMMARY NSEB01BB (F/#/%)
QUAL STATUS	DOA
Equipment No	PS2301-2389C
Description	PRESSURE SWITCH M243
System	HPCI
Man/Model	BARKSDALE PIH-M855SV
Safety Function	4 HPCI SUPPORT LOW PRESS TRIP
Plant Location	1.2 C2257A
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
Qual Envir	TEST CURVE #34 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD) TEST/SEQUENTIAL/SIMILAR (F/#/%)
Supporting Document	P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) GE LTR Q-HK-O-79 & SUMMARY NSEB01BB (F/#/%)
QUAL STATUS	DOA
Equipment No	PS2301-2389D
Description	PRESSURE SWITCH M243

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 65

System HPCI
 Man/Model BARKSDALE PIH-MB555V
 Safety Function 4 HPCI SUPPORT LOW PRESS TRIP
 Plant Location 1.2 C2257A
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #34 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD) TEST/SEQUENTIAL/SIMILAR (F/#/%)
 Supporting Document P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) GE LTR Q-HK-0-79 & SUMMARY NSEB0188 (F/#/%)
 QUAL STATUS DOR

Equipment No PS2360-1
 Description PRESS SWITCH M244
 System HPCI
 Man/Model BARKSDALE D2H-A150-SS
 Safety Function 4 HPIC TURBINE TRIP LOGIC
 Plant Location 1.4 C2250
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3046 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No PS261-23A
 Description PRESSURE SWITCH M252
 System RHR CNTM ISOLATION
 Man/Model BARKSDALE B2T-A12SS
 Safety Function 4A/4B/2 CLOSE SHUTDOWN SYS & HD SPR ISO VALVE
 Plant Location 1.8 C2207
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-5 RAD-6 2X10E5
 Qual Envir TEST CURVE #26 RAD-3X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 7/81 FE 7/81

Equipment No PS261-23B
 Description PRESSURE SWITCH M252
 System RHR CNTM ISOLATION
 Man/Model BARKSDALE B2T-A12SS
 Safety Function 4A/4B/2 CLOSE SHUTDOWN SYS & HD SPR ISO VALVE
 Plant Location 1.8 C2207
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-5 RAD-6 2X10E5
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)

QUAL STATUS JCD FINAL EVALUATION TO VERIFY ACCEPTABILITY OF GENERIC TRANSIENT HIGH TEMPERATURE STUDY
 QUAL PLAN HT 7/81 FE 7/81

7-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 66

Equipment No PS263-49A
 Description PRESSURE SWITCH M253
 System RHR
 Man/Model BARKSDALE B2T-M12SS
 Safety Function 4A LOOP SELECTION
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No PS263-49B
 Description PRESSURE SWITCH M253
 System RHR
 Man/Model BARKSDALE B2T-M12SS
 Safety Function 4A LOOP SELECTION
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No PS263-50A
 Description PRESSURE SWITCH M253
 System RHR
 Man/Model BARKSDALE B2T-M12SS
 Safety Function 4A LOOP SELECTION
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No PS263-50B
 Description PRESSURE SWITCH M253
 System RHR
 Man/Model BARKSDALE B2T-M12SS
 Safety Function 4A LOOP SELECTION
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 67

System	RPS
Man/Model	BARKSDALE B2T-A12SS
Safety Function	1 SCRAM BYPASS PERM
Plant Location	1.11 C2205
Operating Time Req/Avail	R-LOCA=1 min R-PBOC=30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOB
Equipment No	PS263-51B
Description	PRESSURE SWITCH M253
System	RPS
Man/Model	BARKSDALE B2T-A12SS
Safety Function	1 SCRAM BYPASS
Plant Location	1.11 LOCAL MNTD
Operating Time Req/Avail	R-LOCA=1 min R-PBOC=30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOB
Equipment No	PS263-51C
Description	PRESSURE SWITCH M253
System	RPS
Man/Model	BARKSDALE B2T-A12SS
Safety Function	1 SCRAM BYPASS PERM
Plant Location	1.12 C2206
Operating Time Req/Avail	R-LOCA=1 min R-PBOC=30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOB
Equipment No	PS263-51D
Description	PRESSURE SWITCH M253
System	RPS
Man/Model	BARKSDALE B2T-A12SS
Safety Function	1 SCRAM BYPASS PERM
Plant Location	1.12 C2206
Operating Time Req/Avail	R-LOCA=1 min R-PBOC=30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOB
Equipment No	PS263-52A
Description	PRESSURE SWITCH M253
System	F CD PRA
Man/Model	BARKSDALE B2T-M12SS

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 68

Safety Function 4/4A/4B C. S. & RHR VLV OPEN PERM
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #24 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No PS263-52B
 Description PRESSURE SWITCH M253
 System RHR CORE SPRAY
 Man/Model BARTON 288A 288A-6694S
 Safety Function 4/4A/4B C. S. & RHR VLV OPEN PERM.
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #24 TEST CURVE #25 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3009 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No PS263-53A
 Description PRESSURE SWITCH M253
 System RHR CORE SPRAY
 Man/Model BARKSDALE B2T-M12SS
 Safety Function 4/4A/4B C. S. & RHR PP. PERM.
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #24 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No PS263-53B
 Description PRESSURE SWITCH M253
 System RHR CORE SPRAY
 Man/Model BARKSDALE B2T-M12SS 26353B
 Safety Function 4/4A/4B C. S. & RHR PP. PERM.
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #24 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL. STATUS DOR

Equipment No PS263-55A
 Description PRESSURE SWITCH M253
 System RPS
 Man/Model BARKSDALE B2T-A12SS
 Safety Function 1 SCRAM - HI. PRESS. RX.
 Int. tior

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 69

Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to pos-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No PS263-55B
 Description PRESSURE SWITCH M253
 System RPS
 Man/Model BARKSDALE B2T-A12SS
 Safety Function 1 SCRAM - HI PRESS RX
 Plant Location 1.11 C2205
 Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No PS263-55C
 Description PRESSURE SWITCH M253
 System RPS
 Man/Model BARKSDALE B2T-A12SS
 Safety Function 1 SCRAM - HI PRESS RX
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No PS263-55D
 Description PRESSURE SWITCH M253
 System RPS
 Man/Model BARKSDALE B2T-A12SS
 Safety Function 1 SCRAM - HI PRESS RX
 Plant Location 1.12 C2206
 Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #26 RAD-1X10E6
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING) GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document GE RPT 145C3010 (F/#/%) P&CS MEMO 80-202 (AGING) P&CS MEMO 80-238 (RAD)
 QUAL STATUS DOR

Equipment No PS503A
 Description PRESSURE SWITCH M207
 System MAIN STEAM RPS
 Man/Model BARKSDALE DIT-H18SS
 Safety Function 1 SCRAM-COND. LOW VAC
 Plant Location 2 11A LOCAL MNTD
 Operating Time Req/Avail NR-LOCA NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not required during loca

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 70

Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)
Supporting Document	GE RPT 145C3028 (F/#/%) P&CS MEMO 80-202 (AGING)
Qual STATUS	GENERIC EVALUATION/UTILITY (RAD) P&CS MEMO 80-238 (RAD)

Equipment No	PS503B
Description	PRESSURE SWITCH M207
System	MAIN STEAM RPS
Man/Model	BARKSDALE DIT-H18SS
Safety Function	1 SCRAM-COND. LOW VAC
Plant Location	2 11A LOCAL MNTD
Operating Time Req/Avail	NR-LOCA NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not required during loca
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)
Supporting Document	GE RPT 145C3028 (F/#/%) P&CS MEMO 80-202 (AGING)
Qual STATUS	GENERIC EVALUATION/UTILITY (RAD) P&CS MEMO 80-238 (RAD)

Equipment No	PS503C
Description	PRESSURE SWITCH M207
System	MAIN STEAM RPS
Man/Model	BARKSDALE DIT-H18SS
Safety Function	1 SCRAM-COND. LOW VAC
Plant Location	2 12A LOCAL MNTD
Operating Time Req/Avail	NR-LOCA NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not required during loca
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)
Supporting Document	GE RPT 145C3028 (F/#/%) P&CS MEMO 80-202 (AGING)
Qual STATUS	GENERIC EVALUATION/UTILITY (RAD) P&CS MEMO 80-238 (RAD)

Equipment No	PS503D
Description	PRESSURE SWITCH M207
System	MAIN STEAM RPS
Man/Model	BARKSDALE DIT-H18SS
Safety Function	1 SCRAM-COND. LOW VAC
Plant Location	2 12A LOCAL MNTD
Operating Time Req/Avail	NR-LOCA NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not required during loca
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SIMILAR (F/#/%) EVALUATION/UTILITY (AGING)
Supporting Document	GE RPT 145C3028 (F/#/%) P&CS MEMO 80-202 (AGING)
Qual STATUS	GENERIC EVALUATION/UTILITY (RAD) P&CS MEMO 80-238 (RAD)

Equipment No	PS504A
Description	PRESSURE SWITCH M203
System	MAIN STEAM RPS
Man/Model	BARKSDALE B2T-A12SS
Safety Function	1 SCRAM-TURB. VLV FAST CLOSURE
Plant Location	2 11 LOCAL MNTD
Operating Time Req/Avail	NR-LOCA NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not required during loca
Qual Envir	TEST CURVE #26 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 71

Method of Qualification	TEST/SIMILAR (F/#/%)	EVALUATION/UTILITY (AGING)	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%)	P&CS MEMO 80-202 (AGING)	P&CS MEMO 80-238 (RAD)
QUAL. STATUS DOR			
Equipment No	PS504B		
Description	PRESSURE SWITCH M203		
System	MAIN STEAM RPS		
Man/Model	BARKSDALE B2T-A12SS		
Safety Function	1 SCRAM-TURB VLV FAST CLOSURE		
Plant Location	2 11 LOCAL MNTD		
Operating Time Req/Avail	NR-LOCA NR-PBDC		
DBE Env Req	(F/#/%) -NONE not required for pbdc	RAD-NONE not required during loca	
Qual Envir	TEST CURVE #26 RAD-1X10E6		
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT		
Method of Qualification	TEST/SIMILAR (F/#/%)	EVALUATION/UTILITY (AGING)	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%)	P&CS MEMO 80-202 (AGING)	P&CS MEMO 80-238 (RAD)
QUAL. STATUS DOR			
Equipment No	PS504C		
Description	PRESSURE SWITCH M203		
System	MAIN STEAM RPS		
Man/Model	BARKSDALE B2T-A12SS		
Safety Function	1 SCRAM-TURB VLV FAST CLOSURE		
Plant Location	2 11 LOCAL MNTD		
Operating Time Req/Avail	NR-LOCA NR-PBDC		
DBE Env Req	(F/#/%) -NONE not required for pbdc	RAD-NONE not required during loca	
Qual Envir	TEST CURVE #26 RAD-1X10E6		
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT		
Method of Qualification	TEST/SIMILAR (F/#/%)	EVALUATION/UTILITY (AGING)	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%)	P&CS MEMO 80-202 (AGING)	P&CS MEMO 80-238 (RAD)
QUAL. STATUS DOR			
Equipment No	PS504D		
Description	PRESSURE SWITCH M203		
System	MAIN STEAM RPS		
Man/Model	BARKSDALE B2T-A12SS		
Safety Function	1 SCRAM-TURB VLV FAST CLOSURE		
Plant Location	2 12 LOCAL MNTD		
Operating Time Req/Avail	NR-LOCA NR-PBCC		
DBE Env Req	(F/#/%) -NONE not required for pbdc	RAD-NONE not required during loca	
Qual Envir	TEST CURVE #26 RAD-1X10E6		
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT		
Method of Qualification	TEST/SIMILAR (F/#/%)	EVALUATION/UTILITY (AGING)	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3010 (F/#/%)	P&CS MEMO 80-202 (AGING)	P&CS MEMO 80-238 (RAD)
QUAL. STATUS DOR			
Equipment No	PS512A		
Description	PRESSURE SWITCH M241		
System	RPS SEC CNTM ISOLATION		
Man/Model	STATIC-O-RING 12N-AA4-PP 69-11-112		
Safety Function	1/3 SCRAM PERM. /SEC. CNTM. INIT		
Plant Location	1 14 C129A		
Operating Time Req/Avail	R-LOCA-1 min R-PBDC-30 min		
DBE Env Req	(F/#/%) -PBDC-2 RAD-NONE not exposed to post-loca recirculation rad		
Qual Envir	TEST CURVE #28 RAD-1X10E6		
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT		
Method of Qualification	TEST (F/#/%)	EVALUATION/UTILITY (AGING)	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	GE RPT 145C3012 (F/#/%)	P&CS MEMO 80-202 (AGING)	P&CS MEMO 80-238 (RAD)

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 72

QUAL STATUS DOR

Equipment No	PS512B
Description	PRESSURE SWITCH M241
System	RPS SEC CNTM ISOLATION
Man/Model	STATIC-O-RING 12N-AA4-PP 69-11-103
Safety Function	1/3 SCRAM PERM./SEC. CNTM. INIT.
Plant Location	1.14 C129B
Operating Time Req/Avail	R-LOCA-1 min R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #28 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AQING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	OE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AQING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOR

Equipment No	PS512C
Description	PRESSURE SWITCH M241
System	RPS SEC CNTM ISOLATION
Man/Model	STATIC-O-RING 12N-AA4-PP 69-11-108
Safety Function	1/3 SCRAM PERM./SEC. CNTM. INIT.
Plant Location	1.17 C2206
Operating Time Req/Avail	R-LOCA-1 min R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #28 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AQING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	OE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AQING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOR

Equipment No	PS512D
Description	PRESSURE SWITCH M241
System	RPS SEC CNTM ISOLATION
Man/Model	STATIC-O-RING 12N-AA4-PP 69-11-107
Safety Function	1/3 SCRAM PERM./SEC. CNTM. INIT.
Plant Location	1.12 C2206
Operating Time Req/Avail	R-LOCA-1 min R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #28 RAD-1X10E6
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST (F/#/%) EVALUATION/UTILITY (AQING) GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	OE RPT 145C3012 (F/#/%) P&CS MEMO 80-202 (AQING) P&CS MEMO 80-238 (RAD)
QUAL STATUS	DOR

Equipment No	PS8135
Description	PRESSURE SWITCH FAN CONTROL CKT M294
System	STANDBY GAS TREATMENT
Man/Model	MERCOID AP7021-153 3759
Safety Function	13 STANDBY GAS TREATMENT
Plant Location	1.23
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-5 BX10E6
Qual Envir	(F/#/%)- NOT REQUIRED outstanding item (RAD)
Aging	outstanding item
QUAL STATUS	NYQ NUT ESSENTIAL TO SGTS OPERATION. MANUAL CONTROL AVAILABLE
QUAL PLAN	ER 11/81

Equipment No PS8136

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 73

Description	PRESSURE SWITCH FAN CONTROL CKT. M294
System	STANDBY GAS TREATMENT
Man/Model	MERCOID AP7021-153 3760
Safety Function	13 STANDBY GAS TREATMENT
Plant Location	1.23
Operating Time Req/Avail	R-LOCA-30 day NR-PB0C (F/#/%)-NONE not required for pboc RAD-5. BX10E6
DBE Env Req	(F/#/%)- NOT REQUIRED outstanding item (RAD)
Qual Envir	outstanding item
Aging	QUAL STATUS NY3 NOT ESSENTIAL TO SYSTEM OPERATION. MANUAL CONTROL AVAILABLE
QUAL PLAN	ER 11/81
Equipment No	PT1001-600A
Description	PRESSURE TRANSMITTER
System	SAFETY RELATED DISPLAY
Man/Model	ROSEMOUNT 1152GP7E22T0280PB
Safety Function	11 DRYWELL PRESSURE
Plant Location	1.14
Operating Time Req/Avail	R-30 day (F/#/%)-PB0C-2 RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #38 RAD-1.2X10E7
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEPARATE
Method of Qualification	ROSEMOUNT REPORT #117415 (F/#/%/AGING) ROSEMOUNT REPORT #10763 (RAD)
Supporting Document	
QUAL STATUS	NY1
Equipment No	PT1001-600B
Description	PRESSURE TRANSMITTER
System	SAFETY RELATED DISPLAY
Man/Model	ROSEMOUNT 1152GP7E22T0280PB
Safety Function	11 DRYWELL PRESSURE
Plant Location	1.14
Operating Time Req/Avail	R-30 day (F/#/%)-PB0C-2 RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #38 RAD-1.2X10E7
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEPARATE
Method of Qualification	ROSEMOUNT REPORT #117415 (F/#/%/AGING) ROSEMOUNT REPORT #10763 (RAD)
Supporting Document	
QUAL STATUS	NY1
Equipment No	PT1001-601A
Description	PRESSURE TRANSMITTER
System	SAFETY RELATED DISPLAY
Man/Model	ROSEMOUNT 1152AP5E22T0280PB
Safety Function	11 DRYWELL PRESSURE
Plant Location	1.14
Operating Time Req/Avail	R-30 day (F/#/%)-PB0C-2 RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #38 RAD-1.2X10E7
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEPARATE
Method of Qualification	ROSEMOUNT REPORT #117415 (F/#/%/AGING) ROSEMOUNT REPORT #10763 (RAD)
Supporting Document	
QUAL STATUS	NY1
Equipment No	PT1001-601B
Description	PRESSURE TRANSMITTER
System	SAFETY RELATED DISPLAY
Man/Model	ROSEMOUNT 1152AP5E22T0280PB

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 74

Safety Function	11 DRYWELL PRESSURE
Plant Location	1 14
Operating Time Req/Avail	R-30 day (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #38 RAD-1.2X10E7
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEPARATE
Method of Qualification	ROSEMOUNT REPORT #117415 (F/#/%/AGING)
Supporting Document	ROSEMOUNT REPORT #10763 (RAD)
QUAL. STATUS	NYI
Equipment No	PT647A
Description	PRESSURE XMTR
System	SAFETY RELATED DISPLAY
Man/Model	GE 551 4532K11001
Safety Function	11 RX VESSEL PRESSURE
Plant Location	1 11 C2205
* Operating Time Req/Avail	R-30 day (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	IN EXCESS OF REQUIRED (F/#/%) RAD-NOT REQUIRED
Qual Envir	outstanding item
Aging	TEST (F/%) GENERIC EVALUATION/UTILITY (#/AGING)
Method of Qualification	GE RPT 145C3006 (F/%) P&CS MEMO 80-186 (F/#/%)
Supporting Document	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
QUAL. STATUS	AA 4/81 HT 4/81 FE 4/81
Equipment No	PT647B
Description	PRESSURE XMTR
System	SAFETY RELATED DISPLAY
Man/Model	GE 551 FF2220-05326
Safety Function	11 RX VESSEL PRESSURE
Plant Location	1.12 C2206
Operating Time Req/Avail	R-30 day (F/#/%)-PBOC-2 RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	IN EXCESS OF REQUIRED (F/#/%) RAD-NOT REQUIRED
Qual Envir	outstanding item
Aging	TEST (F/%) GENERIC EVALUATION/UTILITY (#/AGING)
Method of Qualification	GE RPT 145C3006 (F/%) P&CS MEMO 80-186 (F/#/%)
Supporting Document	JCD FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
QUAL. STATUS	AA 4/81 HT 4/81 FE 4/81
Equipment No	PT9016
Description	PRESSURE TRANSMITTER M227
System	SAFETY RELATED DISPLAY CNTM ATMOS CONTROL
Man/Model	GE 553133BN223
Safety Function	11 DRYWELL PRESSURE INDICATION
Plant Location	1 14
Operating Time Req/Avail	R-30 day (F/#/%)-PBOC2 RAD-NONE not exposed to post-loca reirculation rad
DBE Env Req	IN EXCESS OF REQUIRED (F/#/%) RAD-NOT REQUIRED
Qual Envir	GENERIC EVALUATION/UTILITY (F/#/%)
Method of Qualification	P&CS MEMO 80-186 (F/#/%)
Supporting Document	NEW INSTRUMENTS TO BE INSTALLED AS PART OF CAT. B
Notes	NOT ESSENTIAL TO SYSTEM OPERATION. SAFETY FUNCTION TO BE TRANSFERED TO TMI CAT B INSTRUMENT TO BE INSTAL
QUAL. STATUS	JCD LED 1/81.
QUAL PLAN	ER 1/81
Equipment No	PT9017
Description	PRESSURE TRANSMITTER M-227

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 75

System	SAFETY RELATED DISPLAY	CNTM ATMOS CONTROL
Man/Model	GE 553122BN223	
Safety Function	11 DRYWELL PRESSURE	
Plant Location	1.12	
Operating Time Req/Avail	R-30 day	
DBE Env Req	(F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad	
Qual Envir	IN EXCESS OF REQUIRED (F/#/%) RAD-NOT REQUIRED	
Method of Qualification	GENERIC EVALUATION/UTILITY (F/#/%)	
Supporting Document	P&CS MEMO 80-186 (F/#/%)	
Notes	NEW INSTRUMENTS TO BE INSTALLED AS PART OF TMI CAT B	
QUAL STATUS	JCO NOT ESSENTIAL TO SYSTEM OPERATION	SAFETY FUNCTION TO BE TRANSFERED TO TMI CAT B INSTRUMENT TO BE INSTAL
	LED 1/81	
QUAL PLAN	ER 1/81	

Equipment No	PT9046	
Description	PRESSURE TRANSMITTER	
System	SAFETY RELATED DISPLAY	CNTM ATMOS CONTROL
Man/Model	GE 553122BN223	4532K13001
Safety Function	11 DRYWELL PRESSURE	
Plant Location	1.14	
Operating Time Req/Avail	R-30 day	
DBE Env Req	(F/#/%)-PBDC-2 RAD-NONE not exposed to post-loca recirculation rad	
Qual Envir	IN EXCESS OF REQUIRED (F/#/%) RAD-NOT REQUIRED	
Aging	outstanding item	
Method of Qualification	GENERIC EVALUATION/UTILITY (F/#/%)	
Supporting Document	P&CS MEMO 80-186 (F/#/%)	
Notes	NEW INSTRUMENTS TO BE INSTALLED AS PART OF TME CAT B	
QUAL STATUS	JCO NOT ESSENTIAL TO SYSTEM OPERATION	SAFETY FUNCTION TO BE TRANSFERED TO TMI CAT B INSTRUMENT 1/81.
QUAL PLAN	ER 1/81	

Equipment No	RE1001-606A	
Description	RADIATION DETECTOR	
System	SAFETY RELATED DISPLAY	
Safety Function	11 DRYWELL RADIATION	
Plant Location	1.10	
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC	
DBE Env Req	(F/#/%)-NONE not required for pboc	RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)- NOT REQUIRED	
QUAL STATUS	NYI	
QUAL PLAN	FT 1/81 FE 1/81	

Equipment No	RE1001-606B	
Description	RADIATION DETECTOR	
System	SAFETY RELATED DISPLAY	
Safety Function	11 DRYWELL RADIATION	
Plant Location	1.10	
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC	
DBE Env Req	(F/#/%)-NONE not required for pboc	RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)- NOT REQUIRED	
QUAL STATUS	NYI	
QUAL PLAN	FT 1/81 FE 1/81	

Equipment No	RE1001-607A	
Description	RADIATION DETECTOR	
System	SAFETY RELATED DISPLAY	
Safety Function	11 TORUS RADIATION	
Plant Location	TORUS AREA	
Operating Time Req/Avail	R-LOCA-30 day NR-PBDC	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 76

DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)- NOT REQUIRED
 GUAL STATUS NYI
 GUAL PLAN FT 1/81 FE 1/81

Equipment No RE1001-607B
 Description RADIATION DETECTOR
 System SAFETY RELATED DISPLAY
 Safety Function 11 TORUS RADIATION
 Plant Location TORUS AREA
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)- NOT REQUIRED
 GUAL STATUS NYI
 GUAL PLAN FT 1/81 FE 1/81

Equipment No S1
 Description 2/C #16 TWISTED SHIELDED PAIR
 System ELECTRICAL DISTRIBUTION
 Man/Model VARIOUS OKONITE or BERKSHIRE or S. MOORE or CONTINENTAL POLYETHYLENE INSULATION PVC JACK
 ET
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-1 in area 1.108 assumed worst case RAD-6.2X10E5
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-5X10E6
 Aging outstanding item
 Method of Qualification EVALUATION/UTILITY based on other TEST/SIMILAR eqpt
 Supporting Document P&CS MEMO #80-12
 GUAL STATUS DOR-A
 GUAL PLAN AA 6/81 FE 6/81

Equipment No S3
 Description 3/C #16 SHIELDED
 System ELECTRICAL DISTRIBUTION
 Man/Model BOSTON INSULATED WIRE BOSTRAD
 Safety Function 12 ELECTRICAL DISTRIBUTION
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day ASSUMED
 DBE Env Req (F/#/%)-PBOC-1 in area 1.108 assumed worst case RAD-6.2X10E5
 Qual Envir TEST CURVE #31 RAD-4X10E8
 Aging THERMAL-168 hrs 12IC
 Method of Qualification TEST/SEPARATE/SIMILAR
 Supporting Document BOSTON INSULATED WIRE RPT B901
 GUAL STATUS DOR-A
 GUAL PLAN AA 6/81 FE 6/81

Equipment No S0117
 Description SOLENOID VALVE (TYP. OF 145) M250 (919D615)
 System CRD SCRAM SYSTEM
 Man/Model ASCO HVA-90-405
 Safety Function 1 SCRAM SOLENOID
 Plant Location 1.9 1.10
 Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #41 RAD-6.5X10E4
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification EVALUATION/SIMILAR/VENDOR

Supporting Document GE LTR TO BECo Q-HK-9-72 6/5/79 EPRI/BWR GSR-097-A-01 (F/B/X) EPRI/BWR GSR-097-A-02 (F/B/X RAD)

Notes
QUAL. STATUS DOR
QUAL PLAN FE 6/81

PM PROGRAM PER GE SIL12B REPLACES ALL AOE SENSITIVE COMPONENTS

Equipment No SV11B
 Description SOLENOID VALVE (TYP. OF 145) M250 (919D615)
 System CRD SCRAM SYSTEM
 Man/Model ASCO HVA-90-405
 Safety Function 1 SCRAM SOLENOIDS
 Plant Location 1.9 1.10
 Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/B/X)-PBOC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #41 RAD-6.5X10E4
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification EVALUATION/SIMILAR/VENDOR
 Supporting Document GE LTR TO BECo Q-HK-9-72 6/5/79 EPRI/BWR GSR-097-A-01 (F/B/X) EPRI/BWR GSR-097-A-02 (F/B/X RAD)

Notes
QUAL. STATUS DOR
QUAL PLAN FE 6/81

PM PROGRAM PER GE SIL12B REPLACES ALL AOE BENSITIVE COMPONENTS

Equipment No SV1301-12
 Description SOLENOID VALVE FOR A01301-12 M246
 System RCIC CNTM ISOLATION
 Man/Model ASCO NP8320A184E
 Safety Function 2 RCIC ISOLATION
 Plant Location 1.5
 Operating Time Req/Avail NR-LOCA NR-PBOC
 DBE Env Req (F/B/X)-NONE not required for phoc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 Notes EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E5
 5 RADs PER ASCO LTR TO BPCo 4/26/79

QUAL. STATUS JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT 80V DETERMINED TO BE LESS THAN 4X10E5

Equipment No SV1301-13
 Description SOV FOR A01301-13 M246
 System RCIC CNTM ISOLATION
 Man/Model ASCO NP8320A184E
 Safety Function 2 RCIC ISOLATION
 Plant Location 1.5
 Operating Time Req/Avail NR-LOCA NR-PBOC
 DBE Env Req (F/B/X)-NONE not required for phoc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 Notes EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E5
 5 RADs PER ASCO LTR TO BPCo 4/26/79

QUAL. STATUS JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No SV1301-34
 Description SOLENOID VALVE FOR A01301-34 M245
 System RCIC CNTM ISOLATION

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 76

Man/Model	ASCO NP8320A184E	
Safety Function	2 RCIC STM DRAIN ISO	
Plant Location	1.5	
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6 2X10E5	
DBE Env Req		
Qual Envir	TEST CURVE #13 RAD-2X10E8	
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES	
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS2167B/TR	
Notes	EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E 5 RADS PER ASCO LTR TO BPCo 4/26/79	
QUAL. STATUS	JCD	REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No	SV1301-35	
Description	SOV FOR A01301-35 M245	
System	RCIC CNTM ISOLATION	
Man/Model	ASCO NP8320A184E	
Safety Function	2 RCIC STM LINE DRAIN ISO	
Plant Location	1.5	
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6 2X10E5	
DBE Env Req		
Qual Envir	TEST CURVE #13 RAD-2X10E8	
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES	
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS2167B/TR	
Notes	EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E 5 RADS PER ASCO LTR TO BPCo 4/26/79	
QUAL. STATUS	JCD	REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No	SV1301-71	
Description	SOLENOID VALVE FOR A0 1301-71 M245	
System	RCIC CNTM ISOLATION	
Man/Model	ASCO NP8320A184E	
Safety Function	2 TEST CHECK BYPASS	
Plant Location	STEAM TUNNEL	
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6 2X10E5	
DBE Env Req		
Qual Envir	TEST CURVE #13 RAD-2X10E8	
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES	
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS2167B/TR	
Notes	EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E 5 RADS PER ASCO LTR TO BPCo 4/26/79	
QUAL. STATUS	JCD	REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No	SV220-45	
Description	SOLENOID VALVE FOR A0 220-45 M252	
System	REACTOR RECIRCULATION SYSTEM CNTM ISOLATION	
Man/Model	ASCO NP8320A184E	
Safety Function	2 SAMPLE SYS ISOLATION	
Plant Location	1.11A	
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day R-PBOC(A)-30 min R-PBOC(P)-30 day (F/#/%)-PBOC-2 RAD-6 2X10E5	
DBE Env Req		
Qual Envir	TEST CURVE #13 RAD-2X10E8	
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES	
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS2167B/TR	
QUAL. STATUS	DOR	

Equipment No	SV2301-29
Description	SOLENOID VALVE M243
System	HPCI CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	2/4 HPCI DRAIN TO MAIN COND
Plant Location	1.3
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-5 hr NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
Notes	EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E 5 RADs PER ASCO LTR TO BPCo 4/26/79
QUAL. STATUS	JCO REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No	SV2301-30
Description	SOV FOR A02301-30 M243
System	HPCI CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E 125VDC
Safety Function	2/4 HPCI DRAIN TO MN. CONDENSER
Plant Location	1.3
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-5 hr NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
Notes	EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E 5 RADs PER ASCO LTR TO BPCo 4/26/79
QUAL. STATUS	JCO REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5
QUAL PLAN	ER 11/81

Equipment No	SV2301-31
Description	SOV FOR A02301-31 M243
System	HPCI
Man/Model	ASCO NP8320A1B4E 120 VDC
Safety Function	4 HPCI DRAIN POT LEVEL CONTROL
Plant Location	1.3
Operating Time Req/Avail	NR-LOCA NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL - 288 HRS 132C MECH - 4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
Notes	EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E 5 RADs PER ASCO LTR TO BPCo 4/26/79
QUAL. STATUS	JCO REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5
QUAL PLAN	ER 11/81

Equipment No	SV2301-32
System	HPCI
Man/Model	ASCO NP8320A1B4E 120 VDC
Safety Function	2/4 HPCI TURBINE EXHAUST DRAIN
Plant Location	1.3
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-5 hr NR-PBOC
Qual Envir	TEST CURVE #13 RAD - 2X10E8

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 80

Aging THERMAL - 288 HRS 132C MECH - 4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL STATUS NYQ
 QUAL PLAN ER 11/81

Equipment No SV2301-64
 Description SOLENOID VALVE M244
 System HPCI CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E
 Safety Function 2/4 HPCI GLAND SEAL DRAIN
 Plant Location 1.3
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-5 hrs NR-PBOC
 DBE Env Req (F/#%) - NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO HTB320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E5
 5 RAD/S PER ASCO LTR TO BPCo 4/26/79
 GUAL STATUS JCO REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No SV2301-65
 Description SOV FOR A02301-65 M244
 System HPCI CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E 120 VDC
 Safety Function 2/4 HPCI GLAND SEAL TO CRW
 Plant Location 1.3
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-5 hrs NR-PBOC
 DBE Env Req (F/#%) - NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL - 288 HRS 132C MECH - 4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 GUAL STATUS NYQ
 GUAL PLAN ER 11/81

Equipment No SV2301-9312
 Description SOLENOID VALVE FOR A0 9312 M243
 System HPCI CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E
 Safety Function 2 N2 SUPPLY TO HPCI
 Plant Location 1.3
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-5 hrs NR-PBOC
 DBE Env Req (F/#%) - NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 GUAL STATUS DOR

Equipment No SV2301-9313
 Description SOLENOID VALVE FOR A0 9313 M243
 System HPCI CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E
 Safety Function 2 N2 SUPPLY TO HPCI

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 81

Plant Location	1.3
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-5 hr NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for phoc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
QUAL STATUS	DOR
Equipment No	SV2301-94
Description	SOLENOID VALVE M243
System	HPCI CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	2 HPCI/CHK. BYPASS
Plant Location	STEAM TUNNEL
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-5 hrs NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for phoc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
Notes	EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E 5 RADs PER ASCO LTR TO BECo 4/26/79
QUAL STATUS	JCO REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5
Equipment No	SV302-19A
Description	SOV M250
System	CRD SCRAM SYSTEM
Man/Model	ASCO WP-LB-831636 (MODIFIED)
Safety Function	1 SCRAM
Plant Location	1.8
Operating Time Req/Avail	R-LOCA-1 min R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-5 RAD-less than 1X10E4 loca dose only
Qual Envir	IN EXCESS OF REQUIRED (F/#/%) RAD-4X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	OPERATING EXPERIENCE/GE EVALUATION/SIMILAR/VENDOR (RAD) GENERIC EVALUATION/UTILITY (F/#/%)
Supporting Document	GE LTR TO BECo G-HK-9-72 6/5/79 P&CS MEMO 80-186 (F/#/%) ASCO LTR TO BECo 4/26/79 (RAD)
QUAL STATUS	JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC INFORMATION
QUAL PLAN	AA 4/81 RA 4/81 HT 7/81 FE 9/81
Equipment No	SV302-19B
Description	SOV M250
System	CRD SCRAM SYSTEM
Man/Model	ASCO WP-LB-831636 (MODIFIED)
Safety Function	1 SCRAM
Plant Location	1.8
Operating Time Req/Avail	R-LOCA-1 min R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-5 RAD-less than 1X10E4 loca dose only
Qual Envir	IN EXCESS OF REQUIRED (F/#/%) RAD-4X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	OPERATING EXPERIENCE/GE EVALUATION/SIMILAR/VENDOR (RAD) GENERIC EVALUATION/UTILITY (F/#/%)
Supporting Document	GE LTR TO BECo G-HK-9-72 6/5/79 P&CS MEMO 80-186 (F/#/%) ASCO LTR TO BECo 4/26/79 (RAD)
QUAL STATUS	JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC INFORMATION
QUAL PLAN	AA 4/81 RA 4/81 HT 9/81 FE 9/81
Equipment No	SV302-20A
Description	SOLENOID VALVE M250
System	CRD SCRAM SYSTEM CNTM ISOLATION

7Y-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 82

Man/Model ASCO HVA-90-405-2A
 Safety Function 2 SCRAM VOLUME ISO
 Plant Location 1.8
 Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-5 RAD-less than 1X10E4 loca dose only
 Qual Envir TEST CURVE #41 RAD-6.5X10E4
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification OPERATING EXPERIENCE/GE EVALUATION/SIMILAR/VENDOR (RAD) GENERIC EVALUATION/UTILITY (F/#/%)
 Supporting Document GE LTR TO BECo Q-HK-9-72 6/5/79 EPRI/BWR GSR-097-A-01 (F/#/%) EPRI/BWR GSR-097-A-02 (F/#/% RAD
) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN AA 4/81 HT 9/81 FE 9/81

Equipment No SV302-20B
 Description SOLENOID VALVE M250
 System CRD SCRAM SYSTEM CNTM ISOLATION
 Man/Model ASCO HVA-90-405-2A
 Safety Function 2 SCRAM VOLUME ISO
 Plant Location 1.8
 Operating Time Req/Avail R-LOCA-1 min R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-5 RAD-less than 1X10E4 loca dose only
 Qual Envir TEST CURVE #41 RAD-6.5X10E4
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification OPERATING EXPERIENCE/GE EVALUATION/SIMILAR/VENDOR (RAD) GENERIC EVALUATION/UTILITY (F/#/%)
 Supporting Document GE LTR TO BECo Q-HK-9-72 6/5/79 EPRI/BWR GSR-097-A-01 (F/#/%) EPRI/BWR GSR-097-A-02 (F/#/% RAD
) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC TRANSIENT TEMPERATURE STUDY
 QUAL PLAN AA 4/81 HT 9/81 FE 9/81

Equipment No SV4044A
 Description AIR OPERATOR SOLENOID VALVE M215
 System RBCCW
 Man/Model ASCO NP8320A1B4E
 Safety Function 4C HPCI AREA COOLER
 Plant Location 1.3
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/IR
 Notes EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 6/81 EXISTING
 VALVES QUALIFIED TO 4X10E5 RAD PER ASCO LTR
 QUAL STATUS DOR-A EXISTING VALVES QUALIFIED TO 4X10E5 RAD PER ASCO LTR TO BPCo 4/26/79
 QUAL PLAN ER 6/81

Equipment No SV40/4B
 Description AIR OPERATOR SOLENOID VALVE M215
 System RBCCW
 Man/Model ASCO NP8320A1B4E
 Safety Function 4C HPCI AREA COOLER
 Plant Location 1.3
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 83

Notes EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 6/81 EXISTING
 QUA. STATUS DOR-A VALVES QUALIFIED TO 4X10E5 RAD PER ASCO LTR
 QUA. PLAN ER 6/81 EXISTING VALVES QUALIFIED TO 4X10E5 RAD PER ASCO LTR TO BPCo 4/26/79

Equipment No	SV5033A
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	2 DRYWELL N2 MAKEUP ISOLATION
Plant Location	1.9C
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUA. STATUS	DOR

Equipment No	SV5033B
Description	DRY NOID VV FOR AQS2167B M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	2 DRYWELL PURGE SUPPLY
Plant Location	1.9
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUA. STATUS	DOR

Equipment No	SV5033C
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	2 TORUS N2 MAKEUP ISOLATION
Plant Location	1.9C
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUA. STATUS	DOR

Equipment No	SV5035A
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	2 ISOLATE DRYWELL PURGE AIR
Plant Location	1.9C
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL

Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL STATUS DOR

Equipment No SV5035B
 Description AIR OPERATOR SOLENOID VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E
 Safety Function 2 ISOLATION DRYWELL PURGE AIR
 Plant Location 1.9C
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL STATUS DOR

Equipment No SV5036A
 Description AIR OPERATOR SOLENOID VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E
 Safety Function 2 ISOLATE TORUS PURGE AIR
 Plant Location 1.9C
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL STATUS DOR

Equipment No SV5036B
 Description AIR OPERATOR SOLENOID VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E
 Safety Function 2 ISOLATE TORUS PURGE AIR
 Plant Location 1.9C
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL STATUS DOR

Equipment No SV5040A
 Description AIR OPERATOR SOLENOID VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION CNTM INTEGRITY
 Man/Model ASCO NP8320A1B4E
 Safety Function 2/2A TORUS VACUUM BREAKERS
 Plant Location 1.10A
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL STATUS DOR

Equipment No	SV5040B
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION CNTM INTEGRITY
Man/Model	ASCO NPB320A1B4E
Safety Function	2/2A TORUS VACUUM BREAKERS
Plant Location	1.10A
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AGS2167B/TR
QUAL STATUS	DR
Equipment No	SV5041A
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E
Safety Function	2 ISOLATE TORUS NORMAL EXH
Plant Location	1.10A
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AGS2167B/TR
QUAL STATUS	DR
Equipment No	SV5041B
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E
Safety Function	2 ISOLATION TORUS NORMAL EXH.
Plant Location	1.10A
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AGS2167B/TR
QUAL STATUS	DR
Equipment No	SV5042A
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E
Safety Function	2 ISOLATE TORUS PURGE EXHAUST
Plant Location	1.10A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AGS2167B/TR
QUAL STATUS	DR
Equipment No	SV5042B

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE B6

Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	2 ISOLATE TORUS PURGE EXH.
Plant Location	1.10A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUAL STATUS	DR
Equipment No	SV5043A
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	2 CONT EXHAUST ISOLATION
Plant Location	1.13A
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUAL STATUS	DR
Equipment No	SV5043B
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	2 CONT EXHAUST ISOLATION
Plant Location	1.13A
Operating Time Req/Avail	R-LOCA(A)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUAL STATUS	DR
Equipment No	SV5044A
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	2 ISOLATE CONT PURGE EXIT
Plant Location	1.13A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUAL STATUS	DR
Equipment No	SV5044B
Description	AIR OPERATOR SOLENOID VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 8/

Man/Model	ASCO NP8320A1B4E
Safety Function	2 ISOLATE CONT PURGE EXH
Plant Location	1.13A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
QUAL. STATUS	GOR

Equipment No	SV5065-10
Description	SOLENOID VALVE FOR CONTROL VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E 120 VAC
Safety Function	2 O2 ANALYZER SUPPLY ISOLATION
Plant Location	1.13B
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
Notes	EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
QUAL. STATUS	GOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No	SV5065-11
Description	SOLENOID VALVE FOR CONTROL VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E 120 VAC
Safety Function	2 O2 ANALYZER SUPPLY ISOLATION
Plant Location	1.10
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
QUAL. STATUS	GOR

Equipment No	SV5065-11A
Description	CONTROL VALVE FOR H2/O2 ANALYZER
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	VALCOR ENGR P/N 10417 V526-5295-12
Safety Function	2 H2/O2 ANALYZER SUPPLY ISOLATION
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6.2X10E5
DBE Env Req	
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-V877-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 10/81
QUAL. STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-12
Description	SOLENOID VALVE FOR CONTROL VALVE M227

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 88

System	CNTM ATMOS CONTROL	CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E	120 VAC
Safety Function	2 O2 ANALYZER SUPPLY ISOLATION	
Plant Location	1 10	
Operating Time Req/Avail	R-LOCA(A)-1 min	R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE	not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13	RAD-2X10EB
Aging	THERMAL-288 hrs	132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS21678/TR	
Notes	EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81	
QUAL STATUS	DOR-A	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No	SV5065-13	
Description	SOLENOID VALVE FOR CONTROL VALVE M227	
System	CNTM ATMOS CONTROL	CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E	120 VAC
Safety Function	2 O2 ANALYZER SUPPLY ISOLATION	
Plant Location	1.10	
Operating Time Req/Avail	R-LOCA(A)-1 min	R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE	not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13	RAD-2X10EB
Aging	THERMAL-288 hrs	132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS21678/TR	
Notes	EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81	
QUAL STATUS	DOR-A	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No	SV5065-13B	
Description	CONTROL VALVE FOR H2/O2 ANALYZER	
System	CNTM ATMOS CONTROL	CNTM ISOLATION
Man/Model	VALCOR ENGR CORP P/N 10417	V526-5295-12
Safety Function	11 POST LOCA MONITORING	
Plant Location	TORUS	
Operating Time Req/Avail	R-LOCA-30day	NR-PBOC
DBE Env Req	(F/#/%)-NONE	not required for pboc RAD-6.2X10E5
Qual Envir	(F/#/%)-TEST CURVE #39	RAD-2X10EB
Aging	THERMAL-172hrs	31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01	
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 10/81	
QUAL STATUS	NYI	
QUAL PLAN	FE 2/81	

Equipment No	SV5065-14	
Description	SOLENOID VALVE FOR CONTROL VALVE M227	
System	CNTM ATMOS CONTROL	CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E	120 VAC
Safety Function	2 O2 ANALYZER SUPPLY ISOLATION	
Plant Location	1.10	
Operating Time Req/Avail	R-LOCA(A)-1 min	R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE	not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13	RAD-2X10EB
Aging	THERMAL-288 hrs	132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS21678/TR	
Notes	EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81	
QUAL STATUS	DOR-A	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 89

Equipment No	SV5065-14A
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
System	H ₂ /O ₂ ANALYZER SAFETY RELATED DISPLAY
Man/Model	VALCOR ENGR CORP P/N 10417 V526-5295-12
Safety Function	2 H ₂ /O ₂ ANALYZER SUPPLY ISOLATION
Plant Location	1.10
Operating Time Req/Avail	R-LOCA-30day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 10/81
QUAL. STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-15
Description	SOLENOID VALVE FOR CONTROL VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A184E 120 VAC
Safety Function	2 O ₂ ANALYZER SUPPLY ISOLATION
Plant Location	1.10
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUAL. STATUS	DR

Equipment No	SV5065-15B
Description	CONTROL VALVE FOR H ₂ /O ₂ ANALYZER
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	VALCOR ENGR CORP P/N 10417 V526-5295-12
Safety Function	2 H ₂ /O ₂ ANALYZER SUPPLY ISOLATION
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-6.2X10E5
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 10/81
QUAL. STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-16
Description	SOLENOID VALVE FOR CONTROL VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	2 O ₂ ANALYZER SUPPLY ISOLATION
Plant Location	1.10A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pbdc RAD-6.2X10E5
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/10) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PHM 70

Supporting Document ASCO TEST RPT AGS2167B/TR
 Notes EXISTING VALVES (ASCO HT8320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E
 5 RAD/S PER ASCO LTR TO BPCo 4/26/79
 QUAL STATUS JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No SV5065-17
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A184E 125 VDC
 Safety Function 2 O2 ANALYZER SUPPLY ISOLATION
 Plant Location 1.13B
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 DBE Env Req TEST CURVE #13 RAD-2X10E5
 Qual Envir THERMAL-288 hrs 132C MECH-40000 CYCLES
 Aging TEST/SEQUENTIAL
 Method of Qualification Supporting Document ASCO TEST RPT AGS2167B/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No SV5065-18
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A184E 125 VDC
 Safety Function 2 O2 ANALYZER SUPPLY ISOLATION
 Plant Location 1.10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 DBE Env Req TEST CURVE #13 RAD-2X10E5
 Qual Envir THERMAL-288 hrs 132C MECH-40000 CYCLES
 Aging TEST/SEQUENTIAL
 Method of Qualification Supporting Document ASCO TEST RPT AGS2167B/TR
 QUAL STATUS DOR

Equipment No SV5065-18A
 Description CONTROL VALVE FOR H2/O2 ANALYZER
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function 2 H2/O2 ANALYZER SUPPLY ISOLATION
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 DBE Env Req (F/#/%)-TEST CURVE #39 RAD-2X10E5
 Qual Envir THERMAL-172hrs 31BF MECH-7500 CYCLES
 Aging TEST/SEQUENTIAL
 Method of Qualification Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-19
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A184E 125 VDC
 Safety Function 2 O2 ANALYZER SUPPLY ISOLATION
 Plant Location 1.10 1.12
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad

74-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 91

Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQ521678/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No SV5065-20
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NPB320A184E 125 VDC
 Safety Function 2 O2 ANALYZER SUPPLY ISOLATION
 Plant Location 1-10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad.
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQ521678/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No SV5065-20B
 Description CONTROL VALVE FOR H2/O2 ANALYZER
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function 2 H2/O2 ANALYZER SUPPLY ISOLATION
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-21
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NPB320A184E 125 VDC
 Safety Function 2 O2 ANALYZER SUPPLY ISOLATION
 Plant Location 1-10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad.
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQ521678/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No SV5065-21A
 Description CONTROL VALVE FOR H2/O2 ANALYZER
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function 2 H2/O2 ANALYZER SUPPLY ISOLATION

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 92

Plant Location 1.10
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL. STATUS NYI
 QAL PLAN FE 2/81

Equipment No SV5065-22
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NPB320A1B4E 125 VDC
 Safety Function 2 02 ANALYZER SUPPLY ISOLATION
 Plant Location 1.10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QAL STATUS DOR

Equipment No SV5065-22B
 Description CONTROL VALVE FOR H2/02 ANALYZER
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model VALCOR ENGR CORP P/N 10416 V326-5295-12
 Safety Function 2 H2/02 ANALYZER SUPPLY ISOLATION
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QAL STATUS NYI
 QAL PLAN FE 2/81

Equipment No SV5065-23
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NPB320A1B4E
 Safety Function 2 02 ANALYZER SUPPLY ISOLATION
 Plant Location 1.10A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO HTB320A22) TO BE REPLACED PRIOR TO 6/81 EXISTING VALVES QUALIFIED TO 4X10E5
 5 RAD/S PER ASCO LTR TO BPCo 4/26/79
 QAL STATUS JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE-ACTUAL DOSE AT SOV DETERMINED TO BE LESS THAN 4X10E5

Equipment No SV5065-24

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 93

Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E 125 VDC
 Safety Function 2 02 ANALYZER DISCHARGE ISOLATION
 Plant Location 1.10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQ521678/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No SV5065-24A
 Description CONTROL VALVE FOR H2/02 ANALYZER
 System H2/02 ANALYZER SAFETY RELATED DISPLAY
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function 2 H2/02 ANALYZER DISCHARG ISOLATION
 Plant Location 1.12
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 318F MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-25
 Description SOLENOID VALVE FOR CONTROL VALVE M227
 System CNTM ATMOS CONTROL CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E 125 VDC
 Safety Function 2 02 ANALYZER DISCHARGE ISOLATION
 Plant Location 1.10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQ521678/TR
 QUAL STATUS DOR

Equipment No SV5065-25B
 Description CONTROL VALVE FOR H2/02 ANALYZER
 System CNIM ATMOS CONTROL CNIM ISOLATION
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function 2 H2/02 ANALYZER DISCHARGE ISOLATION
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6 2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 318F MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL STATUS NYI

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 94

QUAL PLAN FE 2/81

Equipment No	SV5065-26
Description	SOLENOID VALVE FOR CONTROL VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A184E 120 VAC
Safety Function	2 02 ANALYZER DISCHARGE ISOLATION
Plant Location	1.10
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#%)--NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	Thermal-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
Notes	EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
QUAL. STATUS	DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No	SV5065-26A
Description	CONTROL VALVE FOR H2/02 ANALYZER
System	H2/02 ANALYZER SAFETY RELATED DISPLAY
Man/Model	VALCOR ENGR CORP P/N 10417 V526-5295-12
Safety Function	2 H2/02 ANALYZER DISCHARGE ISOLATION
Plant Location	1.12
Operating Time Req/Avail	R-LOCA-30day NR-PBOC
DBE Env Req	(F/#%)--NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#%)--TEST CURVE #39 RAD-2X10E8
Aging	Thermal-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 10/81
QUAL. STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-27
Description	SOLENOID VALVE FOR CONTROL VALVE M227
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	ASCO NP8320A184E 120 VAC
Safety Function	2 02 ANALYZER DISCHARGE ISOLATION
Plant Location	1.10
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#%)--NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10E8
Aging	Thermal-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
QUAL. STATUS	DOR

Equipment No	SV5065-27B
Description	CONTROL VALVE FOR H2/02 ANALYZER
System	CNTM ATMOS CONTROL CNTM ISOLATION
Man/Model	VALCOR ENGR CORP P/N 10417 V526-5295-12
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30day NR-PBOC
DBE Env Req	(F/#%)--NONE not required for pboc RAD-6.2X10E5
Qual Envir	(F/#%)--TEST CURVE #39 RAD-2X10E8
Aging	Thermal-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 95

Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-31
 Description SOLENOID VALVE FOR CONTROL VALVE M239
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model ASCO NP8320A1B4E 120 VAC
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.11
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL STATUS DOR

Equipment No SV5065-31B
 Description CONTROL VALVE FOR H2/O2 ANALYZER
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model VALCOR ENGR CORP P/N 10417 V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.14
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-32
 Description SOLENOID VALVE FOR CONTROL VALVE M239
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model ASCO NP8320A1B4E 120 VAC
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.11
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL STATUS DOR

Equipment No SV5065-33
 Description SOLENOID VALVE FOR CONTROL VALVE M239
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model ASCO NP8320A1B4E 120 VAC
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.12
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 96

Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL. STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No SV5065-33A
 Description CONTROL VALVE FOR H2/O2 ANALYZER
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model VALCOR ENGR CORP P/N 10417 V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.13
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#%) -NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#%) -TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-V877-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 10/81
 QUAL. STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SY5065-34
 Description SOLENOID VALVE FOR CONTROL VALVE M239
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model ASCO NP8320A1B4E 120 VAC
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.12
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#%) -NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
 QUAL. STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No SY5065-35
 Description SOLENOID VALVE FOR CONTROL VALVE M239
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model ASCO NP8320A1B4E 125 VDC
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.11
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#%) -NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 QUAL. STATUS DOR

Equipment No SY5065-35B
 Description CONTROL VALVE FOR H2/O2 ANALYZER
 System H2/O2 ANALYZER SAFETY RELATED DISPLAY
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.14
 Operating Time Req/Avail R-LOCA-30day NR-PBOC

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 97

DBE Env Req	(F/#/%)-NONE not required for pboc	RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39	RAD-2X10EB
Aging	THERMAL-172hrs 31BF	MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01	
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 10/81	
QUAL STATUS	NYI	
QUAL PLAN	FE 2/81	

Equipment No	SV5065-36	
Description	SOLENOID VALVE FOR CONTROL VALVE M239	
System	H2/02 ANALYZER SAFETY RELATED DISPLAY	
Man/Model	ASCO NP8320A184E 125 VDC	
Safety Function	11 POST LOCA MONITORING	
Plant Location	1.11	
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC	
DBE Env Req	(F/#/%)-NONE not required for pboc	RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13	RAD-2X10EB
Aging	THERMAL-288 hrs 132C	MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS2167B/TR	
QUAL STATUS	DR	

Equipment No	SV5065-37	
Description	SOLENOID VALVE FOR CONTROL VALVE M239	
System	H2/02 ANALYZER SAFETY RELATED DISPLAY	
Man/Model	ASCO NP8320A184E 125 VDC	
Safety Function	11 POST LOCA MONITORING	
Plant Location	1.12	
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC	
DBE Env Req	(F/#/%)-NONE not required for pboc	RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13	RAD-2X10EB
Aging	THERMAL-288 hrs 132C	MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ASCO TEST RPT AQS2167B/TR	
Notes	EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81	
QUAL STATUS	DR-A	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No	SV5065-37A	
Description	CONTROL VALVE FOR H2/02 ANALYZER	
System	H2/02 ANALYZER SAFETY RELATED DISPLAY	
Man/Model	VALCOR ENGR CORP P/N 10416 V526-5295-12	
Safety Function	11 POST LOCA MONITORING	
Plant Location	1.13	
Operating Time Req/Avail	R-LOCA-30day NR-PBOC	
DBE Env Req	(F/#/%)-NONE not required for pboc	RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39	RAD-2X10EB
Aging	THERMAL-172hrs 31BF	MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01	
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 10/81	
QUAL STATUS	NYI	
QUAL PLAN	FE 2/81	

Equipment No	SV5065-38	
Description	SOLENOID VALVE FOR CONTROL VALVE M239	
System	H2/02 ANALYZER SAFETY RELATED DISPLAY	
Man/Model	ASCO NP8320A184E 125 VDC	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 98

Safety Function	11 POST LOCA MONITORING
Plant Location	I-12
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #13 RAD-2X10E8
Qual Envir	
Aging	THERMAL-288 hrs 132C MECH-40000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AGS21678/TR
Notes	EXISTING VALVES TO BE REPLACED WITH ABOVE LISTED ASCO VALVES PRIOR TO 6/81
QUAL STATUS	DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs

Equipment No	SV5065-63
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP V526-5683
Safety Function	11 POST LOCA MONITORING
Plant Location	I-10
Operating Time Req/Avail	R-LOCA-30day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Qual Envir	
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-64
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP
Safety Function	11 POST LOCA MONITORING
Plant Location	I-10
Operating Time Req/Avail	R-LOCA-30day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Qual Envir	
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-65
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP V526-5683
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6.2X10E5
DBE Env Req	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Qual Envir	
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB17-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-66
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
D&E Env Req	(F/#/%)-NONE not required for pboc RAD-6.2X10E5
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB17-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-67
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP P/N 10416 V526-5295-12
Safety Function	11 POST LOCA MONITORING
Plant Location	1 11
Operating Time Req/Avail	R-LOCA-30day NR-PBOC
D&E Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-68
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP P/N 10417 V526-5295-12
Safety Function	11 POST LOCA MONITORING
Plant Location	1 11
Operating Time Req/Avail	R-LOCA-30day NR-PBOC
D&E Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-69
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP P/N 10416 V526-5295-12
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
D&E Env Req	(F/#/%)-NONE not required for pboc RAD-6.2 0E5
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10E8

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 100

Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB17-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-70
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP P/N 10417 V526-5295-12
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6.2X10E5
DBE Env Req	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Qual Envir	
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB17-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-71
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP V526-5683
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6.2X10E5
DBE Env Req	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Qual Envir	
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB17-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-72
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP V526-5683
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6.2X10E5
DBE Env Req	(F/#/%)-TEST CURVE #39 RAD-2X10E8
Qual Envir	
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB17-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-73
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 101

Man/Model VALCOR ENGR CORP V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.12
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/N/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/N/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-74
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location 1.12
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/N/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/N/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB77-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-75
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/N/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/N/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-76
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/N/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/N/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82

QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-77
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP V526-5683
 Safety Function II POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82

QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-78
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP V526-5683
 Safety Function II POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82

QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-79
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function II POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82

QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-80
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP P/N 10417 V526-5295-12
 Safety Function II POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 103

DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-81
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP P/N 10416 V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-82
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP P/N 10417 V526-5295-12
 Safety Function 11 POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-83
 Description CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
 System POST ACCIDENT SAMPLING
 Man/Model VALCOR ENGR CORP V-526-5683
 Safety Function 11 POST LOCA MONITORING
 Plant Location TORUS
 Operating Time Req/Avail R-LOCA-30 day NR-PBDC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10E8
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO IFR-VB17-01
 Notes TMI CAT B ITEMS--FUNCTIONAL BY 1/82
 QUAL STATUS NYI
 QUAL PLAN FE 2/81

Equipment No SV5065-84

PY-Y-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 104

Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP V526-5683
Safety Function	11 POST LOCA MONITORING
Plant Location	TORUS
Operating Time Req/Avail	R-LOCA-30 day NR-PDOC
DBE Env Req	(F/#%) -NONE not required for pdoc RAD-6.2X10E5
Qual Envir	(F/#%) -TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB17-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-85
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP V526-5683
Safety Function	11 POST LOCA MONITORING
Plant Location	1.9
Operating Time Req/Avail	R-LOCA-30day NR-PDOC
DBE Env Req	(F/#%) -NONE not required for pdoc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#%) -TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5065-86
Description	CONTROL VALVE FOR POST ACCIDENT SAMPLING SYSTEM
System	POST ACCIDENT SAMPLING
Man/Model	VALCOR ENGR CORP V526-5683
Safety Function	11 POST LOCA MONITORING
Plant Location	1.9
Operating Time Req/Avail	R-LOCA-30day NR-PDOC
DBE Env Req	(F/#%) -NONE not required for pdoc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#%) -TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO IFR-VB77-01
Notes	TMI CAT B ITEMS--FUNCTIONAL BY 1/82
QUAL STATUS	NYI
QUAL PLAN	FE 2/81

Equipment No	SV5081A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 ISOLATE DRYWELL EMERGENCY EXIT
Plant Location	1.14
Operating Time Req/Avail	R-LOCA-30day NR-PDOC
DBE Env Req	(F/#%) -NONE not required for pdoc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#%) -TEST CURVE #39 RAD-2X10E8
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL

Supporting Document	ISOMEDIX TEST REPORT NO. IFR-V877-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL. STATUS DOR	
Equipment No	SV5081B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 ISOLATE DRYWELL EMERGENCY EXIT
Plant Location	1.14
Operating Time Req/Avail	R-LOCA-30day NR-PB0C
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-V877-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL. STATUS DOR	
Equipment No	SV5082A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 ISOLATE DRYWELL EMERGENCY EXIT
Plant Location	1.14
Operating Time Req/Avail	R-LOCA-30day NR-PB0C
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-V877-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL. STATUS DOR	
Equipment No	SV5082B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 ISOLATE DRYWELL EMERGENCY EXIT
Plant Location	1.14
Operating Time Req/Avail	R-LOCA-30day NR-PB0C
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-V877-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL. STATUS DOR	
Equipment No	SV5083A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 ISOLATE TORUS EMERGENCY PURGE EXIT
Plant Location	1.10
Operating Time Req/Avail	R-LOCA-30day NR-PB0C
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB

Aging	THERMAL-172hrs 318F	MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01	
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80	
QUAL. STATUS DOR		
Equipment No	SV5083B	
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL	
System	CNTM ATMOS CONTROL	
Man/Model	VALCOR ENG CORP V526-5292-31	
Safety Function	2 ISOLATE TORUS EMERGENCY PURGE EXIT	
Plant Location	1.10	
Operating Time Req/Avail	R-LOCA-30day NR-PBOC	
DBE Env Req	(F/#%)--NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad	
Qual Envir	(F/#%)--TEST CURVE #39 RAD-2X10EB	
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES	
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01	
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80	
QUAL. STATUS DOR		
Equipment No	SV5084A	
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL	
System	CNTM ATMOS CONTROL	
Man/Model	VALCOR ENG CORP V526-5292-31	
Safety Function	2 ISOLATE TORUS EMERGENCY PURGE EXIT	
Plant Location	1.10	
Operating Time Req/Avail	R-LOCA-30day NR-PBOC	
DBE Env Req	(F/#%)--NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad	
Qual Envir	(F/#%)--TEST CURVE #39 RAD-2X10EB	
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES	
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01	
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80	
QUAL. STATUS DOR		
Equipment No	SV5084B	
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL	
System	CNTM ATMOS CONTROL	
Man/Model	VALCOR ENG CORP V526-5292-31	
Safety Function	2 ISOLATE TORUS EMERGENCY PURGE EXIT	
Plant Location	1.10	
Operating Time Req/Avail	R-LOCA-30day NR-PBOC	
DBE Env Req	(F/#%)--NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad	
Qual Envir	(F/#%)--TEST CURVE #39 RAD-2X10EB	
Aging	THERMAL-172hrs 318F MECH-7500 CYCLES	
Method of Qualification	TEST/SEQUENTIAL	
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01	
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80	
QUAL. STATUS DOR		
Equipment No	SV5085A	
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL	
System	CNTM ATMOS CONTROL	
Man/Model	VALCOR ENG CORP V526-5292-31	
Safety Function	2 DRYWELL N2 MAKEUP ISOLATION	
Plant Location	1.25	
Operating Time Req/Avail	R-LOCA-30day NR-PBOC	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 107

DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL STATUS	DR

Equipment No	SV5085B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 DRYWELL N2 MAKEUP ISOLATION
Plant Location	1.25
Operating Time Req/Avail	R-LOCA-30day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL STATUS	DR

Equipment No	SV5086A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 DRYWELL N2 MAKEUP ISOLATION
Plant Location	1.25
Operating Time Req/Avail	R-LOCA-30day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL STATUS	DR

Equipment No	SV5086B
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 DRYWELL N2 MAKEUP ISOLATION
Plant Location	1.25
Operating Time Req/Avail	R-LOCA-30day NR-PBDC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	(F/#/%)-TEST CURVE #39 RAD-2X10EB
Aging	THERMAL-172hrs 31BF MECH-7500 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ISOMEDIX TEST REPORT NO. IFR-VB77-01
Notes	TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
QUAL STATUS	DR

Equipment No	SV5087A
Description	CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
System	CNTM ATMOS CONTROL
Man/Model	VALCOR ENG CORP V526-5292-31
Safety Function	2 TORUS N2 MAKEUP ISOLATION

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 108

Plant Location 1.25
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO. IFR-VB77-01
 Notes TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
 QUAL. STATUS DOR

Equipment No SV5087B
 Description CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
 System CNTM ATMOS CONTROL
 Man/Model VALCOR ENG CORP V526-5292-31
 Safety Function 2 TORUS N2 MAKEUP ISOLATION
 Plant Location 1.25
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO. IFR-VB77-01
 Notes TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
 QUAL. STATUS DOR

Equipment No SV5088A
 Description CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
 System CNTM ATMOS CONTROL
 Man/Model VALCOR ENG CORP V526-5292-31
 Safety Function 2 TORUS N2 MAKEUP ISOLATION
 Plant Location 1.25
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO. IFR-VB77-01
 Notes TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
 QUAL. STATUS DOR

Equipment No SV5088B
 Description CONTROL VALVE FOR EMERGENCY CNTM ATMOS CONTROL
 System CNTM ATMOS CONTROL
 Man/Model VALCOR ENG CORP V526-5292-31
 Safety Function 2 TORUS MAKEUP ISOLATION
 Plant Location 1.25
 Operating Time Req/Avail R-LOCA-30day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir (F/#/%)-TEST CURVE #39 RAD-2X10EB
 Aging THERMAL-172hrs 31BF MECH-7500 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ISOMEDIX TEST REPORT NO. IFR-VB77-01
 Notes TMI CAT ITEMS--FUNCTIONAL AS OF 1/80
 QUAL. STATUS DOR

Equipment No SV7011A
 Description AIR OPERATOR SOLENOID VALVE M232
 System RADWASTE SYSTEM CNTM ISOLATION

Man/Model ASCO NPB320A1B4E
 Safety Function 2 DRYWELL EQUIPMENT DRAIN SUMP PUMP DISCHARGE
 Plant Location TORUS AREA
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/M/Z)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 QUAL STATUS DOR

Equipment No SV7011B
 Description AIR OPERATOR SOLENOID VALVE M232
 System RADWASTE SYSTEM CNTM ISOLATION
 Man/Model ASCO NPB320A1B4E
 Safety Function 2 DRYWELL EQUIPMENT DRAIN SUMP PUMP DISCHARGE
 Plant Location TORUS AREA
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/M/Z)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 QUAL STATUS DOR

Equipment No SV7017A
 Description AIR OPERATOR SOLENOID VALVE M232
 System RADWASTE SYSTEM CNTM ISOLATION
 Man/Model ASCO NPB320A1B4E
 Safety Function 2 SUMP PUMP (DRYWELL FLOOR) DISCH VALVE
 Plant Location TORUS AREA
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/M/Z)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 QUAL STATUS DOR

Equipment No SV7017B
 Description AIR OPERATOR SOLENOID VALVE M232
 System RADWASTE SYSTEM CNTM ISOLATION
 Man/Model ASCO NPB320A1B4E
 Safety Function 2 SUMP PUMP (DRYWELL FLOOR) DISCH VALVE
 Plant Location TORUS AREA
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/M/Z)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288 hrs 132C MECH-40000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 QUAL STATUS DOR

Equipment No SV9007
 Description SOLENOID VALVE SPRINKLER SOV (S.C.T.S.) M294
 System STANDBY GAS TREATMENT
 Man/Model ASCO HTB210C22 125 VDC
 Safety Function 13 STANDBY GAS TREATMENT

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 110

Plant Location 1.23
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-2.1X10EB
 Qual Envir (F/#/%)- NOT REQUIRED outstanding item (RAD)
 Aging outstanding item
 QUAL. STATUS NYO NOT ESSENTIAL TO SGTS OPERATION
 QUAL PLAN ER 11/81

Equipment No SV9008
 Description SOLENOID VALVE SPRINKLER SOV (S.G.T.S.) [M294
 System STANDBY GAS TREATMENT
 Man/Model ASCO HT8210C22 125 VDC
 Safety Function 13 STANDBY GAS TREATMENT
 Plant Location 1.23
 Operating Time Req/Avail R-LOCA-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-2.1X10EB
 Qual Envir (F/#/%)- NOT REQUIRED outstanding item (RAD)
 Aging outstanding item
 QUAL. STATUS NYO NOT ESSENTIAL TO SGTS OPERATION
 QUAL PLAN ER 11/81

Equipment No SVL43
 Description SOLENOID VALVE FOR 79A&B M283
 System STANDBY GAS TREATMENT SEC CNTM ISOLATION
 Man/Model ASCO NP8320A1B4
 Safety Function 3/13 REFUELING BLDG VENT ISOLATION NOT REQUIRED FOR PBOC
 Plant Location 1.14A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING VALVE
 REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs
 QUAL. STATUS DOR-A
 QUAL PLAN ER 11/81

Equipment No SVL44
 Description SOLENOID VALVE FOR AON 79A&B M283
 System STANDBY GAS TREATMENT SEC CNTM ISOLATION
 Man/Model ASCO NP8320A1B4E
 Safety Function 3/13 REFUELING BLDG VENT ISOLATION NOT REQUIRED FOR PBOC
 Plant Location 1.14A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING VALVE
 REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs
 QUAL. STATUS DOR-A
 QUAL PLAN ER 11/81

Equipment No SVL45

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 111

Description	SOLENOID VALVE FOR ADN BOA&B M283		
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION		
Man/Model	ASCO NPB320A184E		
Safety Function	3/13 REFUELING BLDG VENT ISOLATION NOT REQUIRED FOR PBOC		
Plant Location	1 14B		
Operating Time Req/Avail	R-LOCA(A)-1 min	R-LOCA(P)-30 day	NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad		
Qual Envir	TEST CURVE #13 RAD-2X10EB		
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES		
Method of Qualification	TEST/SEQUENTIAL		
Supporting Document	ASCO TEST RPT AGS2167B/TR		
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE		
QUAL. STATUS	DOR-A	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs	
QUAL PLAN	ER 11/81		

Equipment No	SVL46		
Description	SOLENOID VALVE FOR ADN B1A&B M283		
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION		
Man/Model	ASCO NPB320A184E		
Safety Function	3/13 REFUELING BLDG VENT ISOLATION NOT REQUIRED FOR PBOC		
Plant Location	1 14B		
Operating Time Req/Avail	R-LOCA(A)-1 min	R-LOCA(P)-30 day	NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad		
Qual Envir	TEST CURVE #13 RAD-2X10EB		
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES		
Method of Qualification	TEST/SEQUENTIAL		
Supporting Document	ASCO TEST RPT AGS2167B/TR		
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE		
QUAL. STATUS	DOR-A	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs	
QUAL PLAN	ER 11/81		

Equipment No	SVL47		
Description	SOLENOID VALVE FOR AD NB2A&B M283		
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION		
Man/Model	ASCO NPB320A184E		
Safety Function	3/13 REFUELING FLOOR VENT SUPPLY ISO. NOT REQUIRED FOR PBOC		
Plant Location	1 16A		
Operating Time Req/Avail	R-LOCA(A)-1 min	R-LOCA(P)-30 day	NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad		
Qual Envir	TEST CURVE #13 RAD-2X10EB		
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES		
Method of Qualification	TEST/SEQUENTIAL		
Supporting Document	ASCO TEST RPT AGS2167B/TR		
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE		
QUAL. STATUS	DOR-A	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs	
QUAL PLAN	ER 11/81		

Equipment No	SVL48		
Description	SOLENOID VALVE FOR AD NB3A&B M283		
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION		
Man/Model	ASCO NPB320A184E		
Safety Function	3/13 REFUELING FLOOR VENT SUPPLY ISO. NOT REQUIRED FOR PBOC		

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 112

Plant Location	1.16A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #13 RAD-2X10E8
Qual Envir	THERMAL-288hrs 132C MECH-4000 CYCLES
Aging	
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE
QUAL STATUS	DOR-A
QUAL PLAN	ER 11/81
REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs	

Equipment No	SVL49
Description	SOLENOID VALVE FOR AD N90ABCD M283
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E
Safety Function	3 REFUELING FLOOR VENT EXHAUST ISO NOT REQUIRED FOR PBOC
Plant Location	1.12
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #13 RAD-2X10E8
Qual Envir	THERMAL-288hrs 132C MECH-4000 CYCLES
Aging	
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE
QUAL STATUS	DOR-A
QUAL PLAN	ER 11/81
REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs	

Equipment No	SVL50
Description	SOLENOID VALVE FOR AD N91ABCD
System	STANDBY GAS TREATMENT
Man/Model	ASCO NPB320A1B4E
Safety Function	3/13 STANDBY GAS TREATMENT/SEC CONT ISO
Plant Location	1.12
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	TEST CURVE #13 RAD-2X10E8
Qual Envir	THERMAL-288hrs 132C MECH-4000 CYCLES
Aging	
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS21678/TR
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE
QUAL STATUS	DOR-A
QUAL PLAN	ER 11/81
REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs	

Equipment No	SVL51
Description	SOLENOID VALVE FOR AON92A/B M283
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION
Man/Model	ASCO NPB320A1B4E 120 VDC
Safety Function	3/13 REFUELING BLDG VENT ISOLATION NOT REQUIRED FOR PBOC
Plant Location	1.238
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-3.2X10E4
DBE Env Req	TEST CURVE #13 RAD-2X10E8
Qual Envir	

Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS21678/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79

QUAL STATUS DOR-A
 QUAL PLAN ER 11/81

Equipment No SVL52
 Description SOLENOID VALVE FOR AON 93A&B M283
 System STANDBY GAS TREATMENT SEC CNTM ISOLATION
 Man/Model ASCO NP8320A184E 120 VDC
 Safety Function 3/13 REFUELING BLDG VENT ISOLATION NOT REQUIRED FOR PBDC
 Plant Location 1.23B
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
 (F/#/%)-NONE not required for pbdc RAD-3.2X10E4
 DBE Env Req
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS21678/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79

QUAL STATUS DOR-A
 QUAL PLAN ER 11/81

Equipment No SVL53
 Description SOLENOID VALVE FOR AON95A&B M283
 System STANDBY GAS TREATMENT SEC CNTM ISOLATION
 Man/Model ASCO NP8320A184E 120 VDC
 Safety Function 3/13 CONT. COMP. VENT ISOLATION NOT REQUIRED FOR PBDC
 Plant Location 1.23A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
 (F/#/%)-NONE not required for pbdc RAD-3.2X10E4
 DBE Env Req
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS21678/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79

QUAL STATUS DOR-A
 QUAL PLAN ER 11/81

Equipment No SVL54
 Description SOLENOID VALVE FOR AON 94A&B M283
 System STANDBY GAS TREATMENT SEC CNTM ISOLATION
 Man/Model ASCO NP8320A184E 120 VDC
 Safety Function 3/13 CONT COMP VENT ISOLATION NOT REQUIRED FOR PBDC
 Plant Location 1.23A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBDC
 (F/#/%)-NONE not required for pbdc RAD-3.2X10E4
 DBE Env Req
 Qual Envir TEST CURVE #13 RAD-2X10E8
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS21678/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79

QUAL STATUS DOR-A
 QUAL PLAN ER 11/81

Equipment No	SVL55
Description	SOLENOID VALVE FOR AON96 M283
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	3/13 CRD MAINT RM VENT ISOLATION NOT REQUIRED FOR PBOC
Plant Location	1.12
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE
QUAL STATUS	DOR-A
QUAL PLAN	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs ER 11/81

Equipment No	SVL56
Description	SOLENOID VALVE FOR AON97 M283
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION
Man/Model	ASCO NP8320A1B4E
Safety Function	3/13 CRD MAINT. RM. VENT. ISOLATION NOT REQUIRED FOR PBOC
Plant Location	1.12
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
DBE Env Req	
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE
QUAL STATUS	DOR-A
QUAL PLAN	REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs ER 11/81

Equipment No	SVL57
Description	SOLENOID VALVE FOR AON98
System	STANDBY GAS TREATMENT
Man/Model	ASCO NP8320A1B4E 120 VDC
Safety Function	3/13 RB CONT. EXH. TO SGTS NOT REQUIRED FOR PBOC
Plant Location	1.10A
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC (F/#/%)-NONE not required for pboc RAD-6.2X10E5
DBE Env Req	
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQS2167B/TR
Notes	EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79
QUAL STATUS	JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE- VALUE AT 60V DETERMINED TO BE WITHIN QUALIFIED VALUE
QUAL PLAN	ER 11/81

Equipment No	SVL58
Description	SOLENOID VALVE FOR AON99
System	STANDBY GAS TREATMENT
Man/Model	ASCO NP8320A1B4E 120 VDC

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST

SE 115

Safety Function 3/13 SGTS FLTR A INLET NOT R. RED FOR PBOC
 Plant Location 1.10A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79
 QUAL STATUS JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE- VALUE AT SOV DETERMINED TO BE WITHIN QUALIFIED VALUE
 QUAL PLAN ER 11/81

Equipment No SVL60
 Description SOLENOID VALVE FOR AON101
 System STANDBY GAS TREATMENT
 Man/Model ASCO NP8320A184E 120 VDC
 Safety Function 3/13 REFUEL TO SGTS INLET NOT REQUIRED FOR PBOC
 Plant Location 1.10A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79
 QUAL STATUS JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE- VALUE AT SOV DETERMINED TO BE WITHIN QUALIFIED VALUE
 QUAL PLAN ER 11/81

Equipment No SVL62
 Description SOLENOID VALVE FOR AON106
 System STANDBY GAS TREATMENT
 Man/Model ASCO NP8320A184E 120 VDC
 Safety Function 13 SGTS FILTER B INLET NOT REQUIRED FOR PBOC
 Plant Location 1.10A
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR TO BPCo 4/26/79
 QUAL STATUS JCD REQUIRED RAD BASED ON PIPE CONTACT DOSE- VALUE AT SOV DETERMINED TO BE WITHIN QUALIFIED VALUE
 QUAL PLAN ER 11/81

Equipment No SVL67
 Description SOLENOID VALVE FOR AON 108
 System STANDBY GAS TREATMENT
 Man/Model ASCO NP8320A184E 120 VDC
 Safety Function 13 SGTS FILTER A OUTLET NOT REQUIRED FOR PBOC
 Plant Location 1.23
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 116

Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES
 QUAL STATUS NYQ
 QUAL PLAN ER 12/80

Equipment No SVL70
 Description SOLENOID VALVE FOR AON112
 System STANDBY GAS TREATMENT
 Man/Model ASCO NPB320A1B4E 120VDC
 Safety Function 13 SQTS FILTER B OUTLET NOT REQUIRED FOR PBOC
 Plant Location 1.23
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES
 QUAL STATUS NYQ
 QUAL PLAN ER 12/80

Equipment No SVL71
 Description SOLENOID VALVE FOR AON114 M283
 System STANDBY GAS TREATMENT SEC CNTM ISOLATION
 Man/Model ASCO NPB320A1B4E
 Safety Function 3/13 SEC CONT ACCESS LOCK VENT ISOLATION NOT REQUIRED FOR PBOC
 Plant Location 1.10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO E XISTING VALVE
 QUAL STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs
 QUAL PLAN ER 11/81

Equipment No SVL72
 Description SOLENOID VALVE FOR AON115 M283
 System STANDBY GAS TREATMENT SEC CNTM ISOLATION
 Man/Model ASCO NPB320A1B4E
 Safety Function 3/13 SEC CONT. ACCESS LOCK VENT ISOLATION NOT REQUIRED FOR PBOC
 Plant Location 1.10
 Operating Time Req/Avail R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AQS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THT8320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO E XISTING VALVE
 QUAL STATUS DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs
 QUAL PLAN ER 11/81

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 117

Equipment No	SVL73
Description	SOLENOID VALVE FOR ADN116 M283
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	3/13 SEC CONT ACCESS LOCK VENT. ISOLATION NOT REQUIRED FOR PBOC
Plant Location	1.10
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQ521678/TR
Notes	EXISTING VALVES (ASCO MODEL THTB320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE
QUAL STATUS	DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs
QUAL PLAN	ER 11/81

Equipment No	SVL74
Description	SOLENOID VALVE FOR ADN117 M283
System	STANDBY GAS TREATMENT SEC CNTM ISOLATION
Man/Model	ASCO NPB320A184E
Safety Function	3/13 SEC CONT ACCESS LOCK VENT ISOLATION NOT REQUIRED FOR PBOC
Plant Location	1.10
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-NONE not exposed to post-loca recirculation rad
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQ521678/TR
Notes	EXISTING VALVES (ASCO MODEL THTB320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES QUAL STATUS SHOWN BELOW IS APPLICABLE TO EXISTING VALVE
QUAL STATUS	DOR-A REPLACEMENT OF THIS COMPONENT WILL BE MADE TO ACHIEVE STANDARDIZATION OF SOVs
QUAL PLAN	ER 11/81

Equipment No	SVL77
Description	SOLENOID VALVE FOR ADN135
System	STANDBY GAS TREATMENT
Man/Model	ASCO NPB320A184E 120VDC
Safety Function	13 BOTS FLTR MINIMUM FLOW NOT REQUIRED FOR PBOC
Plant Location	1.23
Operating Time Req/Avail	R-LOCA(A)-1 min R-LOCA(P)-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc
Qual Envir	TEST CURVE #13 RAD-2X10EB
Aging	THERMAL-288hrs 132C MECH-4000 CYCLES
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	ASCO TEST RPT AQ521678/TR
Notes	EXISTING VALVES (ASCO MODEL THTB320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81 QUAL INFO SHOWN ABOVE IS APPLICABLE TO REPLACEMENT VALVES
QUAL STATUS	NYQ
QUAL PLAN	ER 12/80

Equipment No	SVL78
Description	SOLENOID VALVE FOR ADN136
System	STANDBY GAS TREATMENT
Man/Model	ASCO NPB320A184E 120VDC

Safety Function 13 SGIS FLIR INLET XTE NOT REQUIRED FOR PBOC
 Plant Location 1.23
 Operating Time Req/Avail R-LOCA(A)-1min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboe
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THTB320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 QUAL STATUS NYQ XTE NOT ESSENTIAL TO SYSTEM OPERATION
 QUAL PLAN ER 12/80

Equipment No SVL79
 Description SOLENOID VALVE FOR ADN 100
 System STANDBY GAS TREATMENT
 Man/Model ASCO NP8320A1B4E 120VDC
 Safety Function 13 RB CLEAN EXH TO SOTS INLET NOT REQUIRED FOR PBOC
 Plant Location 1.10A
 Operating Time Req/Avail R-LOCA(A)-L min R-LOCA(P)-30 day NR-PBOC
 DBE Env Req (F/#/%)-NONE not required for pboe RAD-6.2X10E5
 Qual Envir TEST CURVE #13 RAD-2X10EB
 Aging THERMAL-288hrs 132C MECH-4000 CYCLES
 Method of Qualification TEST/SEQUENTIAL
 Supporting Document ASCO TEST RPT AGS2167B/TR
 Notes EXISTING VALVES (ASCO MODEL THTB320A107) TO BE REPLACED WITH ABOVE LISTED VALVES PRIOR TO 11/81
 EXISTING SOVs QUALIFIED TO 4X10E5 PER ASCO LTR 1D BPCo 4/26/79
 QUAL STATUS JCO REQUIRED RAD BASED ON PIPE CONTACT DOSE- VALUE AT SOV DETERMINED TO BE WITHIN QUALIFIED VALUE
 QUAL PLAN ER 11/81

Equipment No T1
 Description HEAT TRACING FOR BWR CNTM GAS MONITORING & POST ACCIDENT SAMPLING SAMPLE LINES
 System POST ACCIDENT SAMPLING
 Man/Model VARIOUS
 Safety Function 12 SUPPORT SYSTEM FOR POST LOCA SAMPLING & CNTM GAS MONITORING
 Plant Location VARIOUS
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-1 IN AREA 1.10B ASSUMED WORST CASE RAD-5.4X10E6
 Qual Envir OUTSTANDING ITEM (F/#/%) OUTSTANDING ITEM (RAD)
 Method of Qualification OUTSTANDING ITEM
 Supporting Document OUTSTANDING ITEM
 Notes TMI SUPPORT EQUIPMENT - FUNCTIONAL BY 10/81
 QUAL STATUS NYI
 QUAL PLAN FT 6/81

Equipment No TE5047
 Description TEMPERATURE ELEMENT (RTD) M227
 System CNTM ATMOS CONTROL SAFETY RELATED DISPLAY
 Man/Model ELECTRIC THERMOMETER 35-447-10-939
 Safety Function 11 TORUS WTR. STORAGE
 Plant Location TORUS AREA
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-5 RAD-6.2X10E5
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
 Aging outstanding item
 Method of Qualification EVALUATION
 Supporting Document BPCo SCEQ BPCo CEQE PACSMEMO 80-186 (F/#/%) PACS MEMO 80-238 (RAD)
 Notes EXISTING RTD TO BE REPLACED WITH QUALIFIED COMPONENT BY 12/80

QUAL STATUS JCO
QUAL PLAN ER 12/80

Equipment No	TE5048
Description	TEMPERATURE ELEMENT M227
System	CNTM ATMOS CONTROL SAFETY RELATED DISPLAY
Man/Model	ELECTRIC THERMOMETER 35-447-10.939
Safety Function	11 TORUS WTR STORAGE
Plant Location	TORUS AREA
Operating Time Req/Avail	R-30 day
DBE Env Req	(F/#/%)-PBDC-5 RAD-6.2X10E5
Qual Envir	(F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
Aging	outstanding item
Method of Qualification	EVALUATION
Supporting Document	BPCo SCEQ BPCo CEQE PACS MEMO 80-186 (F/#/%) P&CS MEMO 80-238 (RAD)
Notes	EXISTING RTD TO BE REPLACED WITH QUALIFIED COMPONENT BY 12/80
QUAL STATUS JCO	
QUAL PLAN ER 12/80	

Equipment No	TERMINATIONS (4 Kv)
Description	4 Kv CABLE SPLICES & MOTOR TERMINATIONS
System	ELECTRICAL DISTRIBUTION
Man/Model	KERITE
Safety Function	12 ELECT DIST.
Plant Location	VARIOUS
Operating Time Req/Avail	R-30 day ASSUMED
DBE Env Req	(F/#/%)-PBDC-1 in area 1.10B assumed worst case RAD-6.2X10E5
Qual Envir	TEST CURVE #32 RAD-1X10E8
Aging	outstanding item
Method of Qualification	TEST/SEQUENTIAL
Supporting Document	FIRL TEST RPT F-C3056 KERITE SUMMARY RPT 6/11/71
QUAL STATUS DOR-A	
QUAL PLAN AA 11/81	FE 11/81

Equipment No	TS1291-14C
Description	TEMPERATURE SWITCH M247
System	RCTR WTR CLEAN-UP CNTM ISOLATION
Man/Model	FENWAL 17002-40 6903
Safety Function	2 CLEANUP LEAK DETECTION PBDC TERM
Plant Location	1.11 IN HV DUCT FROM BACKWASH RCVR TK ROOM
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min
DBE Env Req	(F/#/%)-PBDC-2 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS DOR	

Equipment No	TS1291-14D
Description	TEMPERATURE SWITCH M247
System	RCTR WTR CLEAN-UP CNTM ISOLATION
Man/Model	FENWAL 17002-40 6903
Safety Function	2 CLEANUP LEAK DETECTION PBDC TERM
Plant Location	1.11 IN HV DUCT FROM BACKWASH RCVR TK ROOM
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min
DBE Env Req	(F/#/%)-PBDC-2 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 120

Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS1291-14E
 Description TEMPERATURE SWITCH M247
 System RCTR WTR CLEAN-UP CNTM ISOLATION
 Man/Model FENWAL 17002-40 6903
 Safety Function 2 CLEANUP LEAK DETECTION PBOC TERM
 Plant Location 1 11 IN HV DUCT FROM RWCU HX ROOM
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS1291-14F
 Description TEMPERATURE SWITCH M247
 System RCTR WTR CLEAN-UP CNTM ISOLATION
 Man/Model FENWAL 17002-40 6903
 Safety Function 2 CLEANUP LEAK DETECTION PBOC TERM
 Plant Location 1 11 IN HV DUCT FROM RWCU HX ROOM
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-2 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS1291-14G
 Description TEMPERATURE SWITCH M247
 System RCTR WTR CLEAN-UP CNTM ISOLATION
 Man/Model FENWAL 17002-40 6902
 Safety Function 2 CLEANUP LEAK DETECTION PBOC TERM
 Plant Location 1 9A WALL MOUNTED
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-8 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS1291-14H
 Description TEMPERATURE SWITCH M247
 System RCTR WTR CLEAN-UP CNTM ISOLATION
 Man/Model FENWAL 17002-40 6903
 Safety Function 2 CLEANUP LEAK DETECTION PBOC TERM
 Plant Location 1 9A WALL MOUNTED
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-8 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)

QUAL STATUS DOR

Equipment No	TS1291-14J
Description	TEMPERATURE SWITCH M247
System	RCTR WTR CLEAN-UP CNTM ISOLATION
Man/Model	FENWAL 17002-40 7105
Safety Function	2 CLEANUP LEAK DETECTION PBOC TERM
Plant Location	1.9 IN HV DUCT FROM RHR A VV ROOM
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#%) -PBOC-1 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOR

Equipment No	TS1291-14K
Description	TEMPERATURE SWITCH M247
System	RCTR WTR CLEAN-UP CNTM ISOLATION
Man/Model	FENWAL 17002-40 6903
Safety Function	2 CLEANUP LEAK DETECTION PBOC TERM
Plant Location	1.9 IN HV DUCT FROM RHR A VV ROOM
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#%) -PBOC-1 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOR

Equipment No	TS1360-14C
Description	TEMPERATURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	FENWAL 17023-6 7107
Safety Function	2 RCIC LEAK DETECTION SYSTEM PBOC TERM
Plant Location	1.10A WALL MOUNTED
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#%) -PBOC-4 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOR

Equipment No	TS1360-14D
Description	TEMPERATURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	FENWAL 17023-6 65010
Safety Function	2 RCIC LEAK DETECTION SYSTEM PBOC TERM
Plant Location	1.10A WALL MOUNTED
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#%) -PBOC-4 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOR

74-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 122

Equipment No	TS1360-15A
Description	TEMPERATURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	FENWAL 17023-6 65010
Safety Function	2 RCIC LEAK DETECTION SYSTEM PBDC TERM
Plant Location	1 5 WALL MOUNTED
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min (F/#/%)-PBDC-6 RAD-NONE not required during loca
DBE Env Req	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Method of Qualification	
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DDR
Equipment No	TS1360-15B
Description	TEMPERATURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	FENWAL 17023-6 65010
Safety Function	2 RCIC LEAK DETECTION SYSTEM PBDC TERM
Plant Location	1 5 WALL MOUNTED
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min (F/#/%)-PBDC-6 RAD-NONE not required during loca
DBE Env Req	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Method of Qualification	
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DDR
Equipment No	TS1360-15C
Description	TEMPERATURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	FENWAL 17023-6 7306
Safety Function	2 RCIC LEAK DETECTION SYSTEM PBDC TERM
Plant Location	1 10A IN HV DUCT FROM TORUS AREA
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min (F/#/%)-PBDC-4 RAD-NONE not required during loca
DBE Env Req	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Method of Qualification	
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DDR
Equipment No	TS1360-15D
Description	TEMPERATURE SWITCH M245
System	RCIC CNTM ISOLATION
Man/Model	FENWAL 17023-6 65010
Safety Function	2 RCIC LEAK DETECTION SYSTEM PBDC TERM
Plant Location	1 10A IN HV DUCT FROM TORUS AREA
Operating Time Req/Avail	NR-LOCA R-PBDC-30 min (F/#/%)-PBDC-4 RAD-NONE not required during loca
DBE Env Req	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Qual Envir	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Aging	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Method of Qualification	
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DDR
Equipment No	TS1360-16C
Description	TEMPERATURE SWITCH M245

79-018 PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 123

System RCIC CNTM ISOLATION
 Man/Model FENWAL 17023-6 6911
 Safety Function 2 RCIC LEAK DETECTION SYSTEM PBOC TERM
 Plant Location 1 10A WALL MOUNTED
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-4 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS1360-16D
 Description TEMPERATURE SWITCH M245
 System RCIC CNTM ISOLATION
 Man/Model FENWAL 17023-6 6911
 Safety Function 2 RCIC LEAK DETECTION SYSTEM PBOC TERM
 Plant Location 1 10A WALL MOUNTED
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-4 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS1360-17A
 Description TEMPERATURE SWITCH M245
 System RCIC CNTM ISOLATION
 Man/Model FENWAL 17023-6
 Safety Function 2 RCIC LEAK DETECTION SYSTEM PBOC TERM
 Plant Location 1.5 WALL MOUNTED
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-6 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS1360-17B
 Description TEMPERATURE SWITCH M245
 System RCIC CNTM ISOLATION
 Man/Model FENWAL 17023-6
 Safety Function 2 RCIC LEAK DETECTION SYSTEM PBOC TERM
 Plant Location 1.5 WALL MOUNTED
 Operating Time Req/Avail NR-LOCA R-PBOC-30 min
 DBE Env Req (F/#/%)-PBOC-6 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS1360-17C
 Description TEMPERATURE SWITCH M245
 System RCIC CNTM ISOLATION
 Man/Model FENWAL 17023-6

7-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 124

Safety Function 2. RCIC LEAK DETECTION SYSTEM PBDC TERM
 Plant Location 1. 10A IN HV DUCT FROM TORUS AREA
 Operating Time Req/Avail NR-L0CA R-PBDC-30 min
 DBE Env Req (F/#%) -PBDC-4 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS1360-17D
 Description TEMPERATURE SWITCH M245
 System RCIC CNTM ISOLATION
 Man/Model FENWAL 17023-6
 Safety Function 2. RCIC LEAK DETECTION SYSTEM PBDC TERM
 Plant Location 1. 10A IN HV DUCT FROM TORUS AREA
 Operating Time Req/Avail NR-L0CA R-PBDC-30 min
 DBE Env Req (F/#%) -PBDC-4 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS2370C
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 7206
 Safety Function 2. HPCI ISO PBDC TERM
 Plant Location 1. 10 IN HV DUCT FROM HPCI VV ROOM
 Operating Time Req/Avail R-L0CA(P)-5 hr R-PBDC-30 min
 DBE Env Req (F/#%) -PBDC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS2370D
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 7306
 Safety Function 2. HPCI ISO PBDC TERM
 Plant Location 1. 10 IN HV DUCT FROM HPCI VV ROOM
 Operating Time Req/Avail R-L0CA(P)-5 hr R-PBDC-30 min
 DBE Env Req (F/#%) -PBDC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL. STATUS DOR

Equipment No TS2371A
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 7107
 Safety Function 2. HPCI ISO PBDC TERM
 Plant Location 1. 2 IN HV DUCT FROM HPCI PP ROOM

74-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 125

Operating Time Req/Avail	R-LOCA(P)-5 hr	R-PBOC-30 min
DBE Env Req	(F/#%)	PBOC-5 RAD-3 5X10E4 loca dose only
Qual Envir	TEST CURVE #19	TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT	MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1	GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOOR	
Equipment No	TS2371B	
Description	TEMPERATURE SWITCH M243	
System	HPCI CNIM ISOLATION	
Man/Model	FENWAL 17023-6 65010	
Safety Function	2 HPCI ISO PBOC TERM	
Plant Location	1.2 IN HV DUCT FROM HPCI PP ROOM	
Operating Time Req/Avail	R-LOCA(P)-5 hr	R-PBOC-30 min
DBE Env Req	(F/#%)	PBOC-5 RAD-3 5X10E4 loca dose only
Qual Envir	TEST CURVE #19	TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT	MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1	GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOOR	
Equipment No	TS2371C	
Description	TEMPERATURE SWITCH M243	
System	HPCI CNIM ISOLATION	
Man/Model	FENWAL 17023-6 7306	
Safety Function	2 HPCI ISO PBOC TERM	
Plant Location	1.10A IN HV DUCT FROM TORUS AREA	
Operating Time Req/Avail	R-LOCA(P)-5 hr	R-PBOC-30 min
DBE Env Req	(F/#%)	PBOC-4 RAD-3 5X10E4 loca dose only
Qual Envir	TEST CURVE #19	TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT	MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1	GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOOR	
Equipment No	TS2371D	
Description	TEMPERATURE SWITCH M243	
System	HPCI CNIM ISOLATION	
Man/Model	FENWAL 17023-6 7306	
Safety Function	2 HPCI ISO PBOC TERM	
Plant Location	1.10A IN HV DUCT FROM TORUS AREA	
Operating Time Req/Avail	R-LOCA(P)-5 hr	R-PBOC-30 min
DBE Env Req	(F/#%)	PBOC-4 RAD-3 5X10E4 loca dose only
Qual Envir	TEST CURVE #19	TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT	MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR	EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1	GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS	DOOR	
Equipment No	TS2372C	
Description	TEMPERATURE SWITCH M243	
System	HPCI CNIM ISOLATION	
Man/Model	FENWAL 17023-6 7306	
Safety Function	2 HPCI ISO PBOC TERM	
Plant Location	1.10 IN HV DUCT FROM HPCI UV ROOM	
Operating Time Req/Avail	R-LOCA(P)-5 hr	R-PBOC-30 min
DBE Env Req	(F/#%)	PBOC-1 RAD-NONE not exposed to post-loca recirculation rad

Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS2372D
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 7306
 Safety Function 2 HPCI ISO PBDC TERM
 Plant Location 1.10 IN HV DUCT FROM HPCI VV ROOM
 Operating Time Req/Avail R-LOCA(P)-5 hr R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-1 RAD-NONE not exposed to post-loca recirculation rad
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS2373A
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 65010
 Safety Function 2 HPCI ISO PBDC TERM
 Plant Location 1.2 IN HV DUCT FROM HPCI PP ROOM
 Operating Time Req/Avail R-LOCA(P)-5 hr R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-5 RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS2373B
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 7210
 Safety Function 2 HPCI ISO PBDC TERM
 Plant Location 1.2 IN DUCT FROM HPCI PP ROOM
 Operating Time Req/Avail R-LOCA(P)-5 hr R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-5 RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS2373C
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 7306
 Safety Function 2 HPCI ISO PBDC TERM
 Plant Location 1.10A IN HV DUCT FROM TORUS AREA
 Operating Time Req/Avail R-LOCA(P)-5 hr R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-4 RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT

V7-JID PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 12

Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS2373D
 Description TEMPERATURE SWITCH M243
 System HPCI CNTM ISOLATION
 Man/Model FENWAL 17023-6 7306
 Safety Function 2 HPCI ISO PBDC TERM
 Plant Location 1 10A IN HV DUCT FROM TORUS AREA
 Operating Time Req/Avail R-LOCA(P)-5 hr R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-4 RAD-3.5X10E4 loca dose only
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS261-15A
 Description TEMPERATURE SWITCH M252
 System MAIN STEAM CNTM ISOLATION
 Man/Model FENWAL 17002-40 7308
 Safety Function 2 MAIN STM LINE LEAK DETECTION PBDC TERM
 Plant Location 1 10A IN HV DUCT FROM STEAM TUNNEL
 Operating Time Req/Avail NR-LOCA R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-4 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS261-15B
 Description TEMPERATURE SWITCH M252
 System MAIN STEAM CNTM ISOLATION
 Man/Model FENWAL 17002-40 7308
 Safety Function 2 MAIN STEAM LINE LEAK DETECTION PBDC TERM
 Plant Location 1 10A IN HV DUCT FROM STEAM TUNNEL
 Operating Time Req/Avail NR-LOCA R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-4 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
 QUAL STATUS DOR

Equipment No TS261-15C
 Description TEMPERATURE SWITCH M252
 System MAIN STEAM CNTM ISOLATION
 Man/Model FENWAL 17002-40 7304
 Safety Function 2 MAIN STM LINE LEAK DETECTION PBDC TERM
 Plant Location 1 10A IN HV DUCT FROM STEAM TUNNEL
 Operating Time Req/Avail NR-LOCA R-PBDC-30 min
 DBE Env Req (F/#/%)-PBDC-4 RAD-NONE not required during loca
 Qual Envir TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
 Aging THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
 Method of Qualification TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
 Supporting Document WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)

79-JIB PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 128

QUAL STATUS DOR

Equipment No	TS261-15D
Description	TEMPERATURE SWITCH M252
System	MAIN STEAM CNTM ISOLATION
Man/Model	FENWAL 17002-40 7303
Safety Function	2 MAIN STM LINE LEAK DETECTION PBOC TERM
Plant Location	1 10A IN HV DUCT FROM STEAM TUNNEL
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-4 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS DOR	
Equipment No	TS261-16A
Description	TEMPERATURE SWITCH M252
System	MAIN STEAM CNTM ISOLATION
Man/Model	FENWAL 17002-40 7304
Safety Function	2 MAIN STM LINE LEAK DETECTION PBOC TERM
Plant Location	2 11 IN TURB BLDG HV EXH DUCT
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-7 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS DOR	
Equipment No	TS261-16B
Description	TEMPERATURE SWITCH M252
System	MAIN STEAM CNTM ISOLATION
Man/Model	FENWAL 17002-40 7304
Safety Function	2 MAIN STM LINE LEAK DETECTION PBOC TERM
Plant Location	2 11 IN TURB BLDG HV EXH DUCT
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-7 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS DOR	
Equipment No	TS261-16C
Description	TEMPERATURE SWITCH M252
System	MAIN STEAM CNTM ISOLATION
Man/Model	FENWAL 17002-40 7304
Safety Function	2 MAIN STM LINE LEAK DETECTION PBOC TERM
Plant Location	2 11 IN TURB BLDG HV EXH DUCT
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-7 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AGING)
QUAL STATUS DOR	

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 129

Equipment No	TS261-16D
Description	TEMPERATURE SWITCH M252
System	MAIN STEAM CNTM ISOLATION
Man/Model	FENWAL 17002-40 7304
Safety Function	2 MAIN SIM LINE LEAK DETECTION PBOC TERM
Plant Location	2 11 IN TURB BLDG HV EXH DUCT
Operating Time Req/Avail	NR-LOCA R-PBOC-30 min
DBE Env Req	(F/#/%)-PBOC-7 RAD-NONE not required during loca
Qual Envir	TEST CURVE #19 TEST CURVE #20 RAD-1.7X10E5
Aging	THERM-NOT SIGNIFICANT MECH-NOT SIGNIFICANT
Method of Qualification	TEST/SEQUENTIAL/SIMILAR EVALUATION/UTILITY (AGING)
Supporting Document	WYLE RPT 43854-1 GE RPT 145C3004 P&CS MEMO 80-202 (AQING)
QUAL STATUS DOR	
Equipment No	TSD-41
Description	THERMOSTAT M282
System	HVAC ECCS UNIT COOLERS
Man/Model	JOHNSON CONTROL
Safety Function	4C RCIC AREA COOLER
Plant Location	1.5
Operating Time Req/Avail	NR-LOCA NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboe RAD-NONE not required during loca
Qual Envir	(F/#/%)- NOT REQUIRED RAD-1X10E6
Aging	outstanding item
Method of Qualification	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	P&CS MEMO 80-238 (RAD)
Notes	SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
QUAL STATUS NYQ	POST-PBOC OPERABILITY UNVERIFIED
QUAL PLAN ER	2/81
Equipment No	TSD-42
Description	THERMOSTAT M282
System	HVAC ECCS UNIT COOLERS
Man/Model	JOHNSON CONTROL
Safety Function	4C RCIC AREA COOLER
Plant Location	1.5
Operating Time Req/Avail	NR-LOCA NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboe RAD-NONE not required during loca
Qual Envir	(F/#/%)- NOT REQUIRED RAD-1X10E6
Aging	outstanding item
Method of Qualification	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	P&CS MEMO 80-238 (RAD)
Notes	SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
QUAL STATUS NYQ	POST-PBOC OPERABILITY UNVERIFIED
QUAL PLAN ER	2/81
Equipment No	TSD-43
Description	THERMOSTAT M282
System	HVAC ECCS UNIT COOLERS
Man/Model	JOHNSON CONTROL
Safety Function	4C HPCI AREA COOLER
Plant Location	1.3
Operating Time Req/Avail	R-5 hr
DBE Env Req	(F/#/%)-NONE not required during hostile pboe RAD-3.5X10E4 loca dose only
Qual Envir	(F/#/%)-NOT REQUIRED RAD-1X10E6
Aging	outstanding item
Method of Qualification	GENERIC EVALUATION/UTILITY (RAD)
Supporting Document	P&CS MEMO 80-238 (RAD)

79-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 130

Notes SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
 QUAL STATUS NYQ POST-PBOC OPERABILITY UNVERIFIED MANUAL CONTROL OF AREA COOLERS AVAILABLE FOR CONTROL PNL
 QUAL PLAN ER 2/81

Equipment No TSD-44
 Description THERMOSTAT M282
 System HVAC ECCS UNIT COOLERS
 Man/Model JOHNSON CONTROL
 Safety Function 4C HPCI AREA COOLER
 Plant Location 1.3
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir (F/#/%)-NOT REQUIRED RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD)
 Notes SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
 QUA L STATUS NYQ POST-PBOC OPERABILITY UNVERIFIED MANUAL CONTROL OF AREA COOLERS AVAILABLE FOR CONTROL PNL
 QUAL PLAN ER 2/81

Equipment No TSD-45
 Description THERMOSTAT M282
 System HVAC ECCS UNIT COOLERS
 Man/Model JOHNSON CONTROL
 Safety Function 4C RHR AREA COOLER
 Plant Location 1.1
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-5 RAD-6.2X10E5
 Qual Envir outstanding item (F/#/%) RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD)
 Notes SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
 QUA L STATUS NYQ POST-PBOC OPERABILITY UNVERIFIED MANUAL CONTROL OF AREA COOLERS AVAILABLE FOR CONTROL PNL
 QUAL PLAN ER 2/81

Equipment No TSD-46
 Description THERMOSTAT M282
 System HVAC ECCS UNIT COOLERS
 Man/Model JOHNSON CONTROL
 Safety Function 4C RHR AREA COOLER
 Plant Location 1.1
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-5 RAD-6.2X10E5
 Qual Envir outstanding item (F/#/%) RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD)
 Notes SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
 QUA L STATUS NYQ POST-PBOC OPERABILITY UNVERIFIED MANUAL CONTROL OF AREA COOLERS AVAILABLE FOR CONTROL PNL
 QUAL PLAN ER 2/81

Equipment No TSD-47
 Description THERMOSTAT M282
 System HVAC ECCS UNIT COOLERS
 Man/Model JOHNSON CONTROL
 Safety Function 4C RHR AREA COOLER
 Plant Location 1.2

Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-5 RAD-6.2X10E5
 Qual Envir outstanding item (F/#/%) RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD)
 Notes SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
 QUAL STATUS NYO POST-PBOC OPERABILITY UNVERIFIED MANUAL CONTROL OF AREA COOLERS AVAILABLE FOR CONTROL PNL
 QUAL PLAN ER 2/81

Equipment No TSD-48
 Description THERMOSTAT M282
 System HVAC ECCS UNIT COOLERS
 Man/Model JOHNSON CONTROL
 Safety Function 4C RHR AREA COOLER
 Plant Location 1 2
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PBOC-5 RAD-6.2X10E5
 Qual Envir outstanding item (F/#/%) RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD)
 Notes SCHEDULED REPLACEMENT WITH QUALIFIED UNITS BY 2/81
 QUAL STATUS NYO POST-PBOC OPERABILITY UNVERIFIED MANUAL CONTROL OF AREA COOLERS AVAILABLE FOR CONTROL PNL
 QUAL PLAN ER 2/81

Equipment No VAC201A
 Description HPCI UNIT COOLER M215
 System HVAC ECCS UNIT COOLERS
 Man/Model GE 5K1B4AL217 outstanding item
 Safety Function 4C HPCI AREA COOLING
 Plant Location 1 3
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir (F/#/%)-NOT REQUIRED RAD-5X10E5
 Aging outstanding item
 Supporting Document GE LTR 8/1/80
 QUAL STATUS DOR-A
 QUAL PLAN AA 7/81 FF 7/81

Equipment No VAC201B
 Description HPIC UNIT COOLER M215
 System HVAC ECCS UNIT COOLERS
 Man/Model GE 5K1B4AL217 outstanding item
 Safety Function 4C HPIC AREA COOLING
 Plant Location 1 3
 Operating Time Req/Avail R-5 hr
 DBE Env Req (F/#/%)-NONE not required during hostile pboc RAD-3.5X10E4 loca dose only
 Qual Envir (F/#/%)-NOT REQUIRED RAD-5X10E5
 Aging outstanding item
 Supporting Document GE LTR 8/1/80
 QUAL STATUS DOR-A
 QUAL PLAN AA 7/81 FF 7/81

Equipment No VAC204A
 Description RHR UNIT COOLER M215
 System HVAC ECCS UNIT COOLERS
 Man/Model LOUIS-ALLIS CO TYPE CGQ4B 026-2853002

7Y-01B PILGRIM UNIT 1 FINAL RESPONSE (11/80) OUTSIDE CONTAINMENT EQUIPMENT EVALUATION LIST PAGE 132

Safety Function 4C RHR AREA COOLING
 Plant Location 1 1
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PB0C-5 RAD-6 2X10E5
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)
 QUAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QAL PLAN AA 9/81 RA 9/81 FE 9/81

Equipment No VAC204B
 Description RHR UNIT COOLER M215
 System HVAC ECCS UNIT COOLERS
 Man/Model LOUIS-ALLIS CO TYPE CGQ4B 026-2853003
 Safety Function 4C RHR AREA COOLING
 Plant Location 1.1
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PB0C-5 RAD-6 2X10E5
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)
 QAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QAL PLAN AA 9/81 RA 9/81 FE 9/81

Equipment No VAC204C
 Description RHR UNIT COOLER M215
 System HVAC ECCS UNIT COOLERS
 Man/Model LOUIS-ALLIS CO TYPE CGQ4B 026-2853004
 Safety Function 4C RHR AREA COOLING
 Plant Location 1.2
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PB0C-5 RAD-6 2X10E5
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)
 QAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QAL PLAN AA 9/81 RA 9/81 FE 9/81

Equipment No VAC204D
 Description RHR UNIT COOLER M215
 System HVAC ECCS UNIT COOLERS
 Man/Model LOUIS-ALLIS CO TYPE CGQ4B 026-2853001
 Safety Function 4C RHR AREA COOLING
 Plant Location 1.2
 Operating Time Req/Avail R-30 day
 DBE Env Req (F/#/%)-PB0C-5 RAD-6 2X10E5
 Qual Envir (F/#/%)-IN EXCESS OF REQUIRED RAD-1X10E6
 Aging outstanding item
 Method of Qualification GENERIC EVALUATION/UTILITY (RAD)
 Supporting Document P&CS MEMO 80-238 (RAD) P&CS MEMO 80-186 (F/#/%)
 QAL STATUS JCO FINAL EVALUATION TO VERIFY APPLICABILITY OF GENERIC STUDIES
 QAL PLAN AA 9/81 RA 9/81 FE 9/81

Equipment No VEX210A
 Description EXHAUST FAN

System	STANDBY GAS TREATMENT
Man/Model	GE 5K254AK299-W1A 6264010
Safety Function	3/13 SEC CNTM ISO/STNBY GAS TRTMNT
Plant Location	1 23
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-5.8X10E6
Qual Envir	(F/#/%)- NOT REQUIRED RAD-5X10E5
Aging	outstanding item
Supporting Document	GE LTR TO BECo 8/1/80
QUAL STATUS	JCO TEMPORARY SHIELDING TO BE INSTALLED TO REDUCE RAD DOSE TO BELOW 5X10E5
QUAL PLAN	ER 11/81
Equipment No	VEX210B
Description	EXHAUST FAN
System	STANDBY GAS TREATMENT
Man/Model	GE 5K254AK299-W1A 6262047
Safety Function	3/13 SEC CNTM ISO/STNBY GAS TRTMNT
Plant Location	1 23
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-5.8X10E6
Qual Envir	(F/#/%)- NOT REQUIRED RAD-5X10E5
Aging	outstanding item
Supporting Document	GE LTR TO BECo 8/1/80
QUAL STATUS	JCO TEMPORARY SHIELDING TO BE ERECTED TO REDUCE RAD DOSE TO BELOW 5X10E5
QUAL PLAN	ER 11/81
Equipment No	VQTF201A
Description	STANDBY GAS TREATMENT FILTER UNIT A
System	STANDBY GAS TREATMENT
Man/Model	FARR CO. (FILTER MFR) CHROMALOX (HEATER) ASCO/B210C22 (SOV) HONEYWELL/Q464-A (RH SENSOR) F ENHAL/18023-0 (CARBON TEMP SW) FENWAL/40-102010-115 (HEATER TEMP SW) BRONCO/BRONCO 66 (WIRE)
Safety Function	13 STNDBY GAS TRTMNT HEATER/WIRING & MISC ELECT EQPT
Plant Location	1 23
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-2.1X10E8
Qual Envir	(F/#/%)- NOT REQUIRED outstanding item (RAD)
Aging	outstanding item
QUAL STATUS	NYQ
QUAL PLAN	ER 11/81
Equipment No	VQTF201B
Description	STANDBY GAS TREATMENT FILTER UNIT B
System	STANDBY GAS TREATMENT
Man/Model	FARR CO. (FILTER MFR) CHROMALOX (HEATER) ASCO/B210C22 (SOV) HONEYWELL/Q464-A (RH SENSOR) F ENHAL/18023-0 (CARBON TEMP SW) FENWAL/40-102010-115 (HEATER TEMP SW) BRONCO/BRONCO 66 (WIRE)
Safety Function	13 STNDBY GAS TRTMNT HEATER/WIRING & MISC ELECT EQPT
Plant Location	1 23
Operating Time Req/Avail	R-LOCA-30 day NR-PBOC
DBE Env Req	(F/#/%)-NONE not required for pboc RAD-2.1X10E8
Qual Envir	(F/#/%)- NOT REQUIRED outstanding item(RAD)
Aging	outstanding item
QUAL STATUS	NYQ
QUAL PLAN	ER 11/81

REFERENCES

1. BECo. Ltr. #79-55 to NRC; March 6, 1979
2. BECo Ltr. #79-65 to NRC; March 28, 1979
3. BECo Ltr. #79-117 to NRC; June 15, 1979
4. BECo. Ltr. #79-121 to NRC; June 19, 1979
5. BECo. Ltr. #79-125 to NRC; June 26, 1979
6. BECo. Ltr. #79-171 to NRC; August 28, 1979
7. BECo. Ltr. #80-50 to NRC; March 12, 1980
8. BECo. Ltr. #80-77 to NRC; April 22, 1980
9. BECo. Ltr. #80-151 to NRC; July 22, 1980