

Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

SOUTH REGION
ATLANTA, GEORGIA



Vogtle Project

Aug 2 16

Southern Company Services, Inc.
Post Office Box: 2625
Birmingham, Alabama 35202
Telephone 205 870-6011

July 28, 1982

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

File: X7BG10
Log: GN-183

Reference: ID: II:
50-424/82-11
50-425/82-11

Attention: F. J. Long

Gentlemen:

The Georgia Power Company wishes to submit the following information concerning the violations discussed in your inspection report 50-424/82-11 and 50-425/82-11.

We concur with the finding identified concerning failure to control the storage and preservation of material. The reason for the violation was failure to properly follow procedures in storing the piping assemblies.

The affected pipe spools have been stored correctly. Contractors have been directed to use more care in the storage of pipe spools. The contractor will be more selective in requisitioning pipe spools in order to reduce the amount of storage required. The contractor will be more selective in choosing spool storage areas and will assign additional personnel to monitor the storage.

Full compliance was achieved on May 11, 1982.


We concur with the finding identified concerning failure to have survey procedures. The reason for the violation was the survey procedures that existed were deleted because experience indicated that normal survey practice was adequate to ensure quality work.

A new field procedure to control survey activities was approved on July 25, 1982. Our ongoing training program on procedure requirements and audit program on procedure implementation should prevent reoccurrence of further violations.

Full compliance should be achieved by August 13, 1982.

This response contains no proprietary information and may be placed
in the NRC Public Document Room upon receipt.

Yours truly,


D. O. Foster
Project General Manager

DOF/CWH/tlp

xc: U. S. Nuclear Regulatory Commission
Attn: Victor J. Stello, Jr., Director
Office of Inspection and Enforcement
Washington, D. C. 20555

R. J. Kelly
R. E. conway
G. F. Head
J. T. Beckham, Jr.
J. H. Boykin
D. E. Dutton
R. H. Pinson
D. L. McCrary
R. A. Thomas
J. A. Bailey
O. Batum
H. H. Gregory, III
E. D. Groover
L. T. Gucwa
M. Malcom
C. R. Miles, Jr.
M. Manry
P. D. Rice
R. W. Staffa
J. L. Vota
W. F. Sanders - Resident Inspector