

**BALTIMORE GAS AND ELECTRIC COMPANY**

DISTRIBUTION  
SERVICES UNIT

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

1980 NOV 21 PM 3 21

ARTHUR E. LUNDVALL, JR.  
VICE PRESIDENT  
SUPPLY

November 18, 1980

50-317

Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

ATTENTION: Mr. R. A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing


SUBJECT: Calvert Cliffs Nuclear Power Plant  
Unit No. 1, Docket No. 50-317  
Amendment to Operating License DPR-53  
Fifth Cycle License Application  
Responses to NRC Staff Questions

Gentlemen:

Enclosed are our responses to questions posed by NRC staff on the subject application.

Very truly yours,

BALTIMORE GAS AND ELECTRIC COMPANY



A. E. Lundvall, Jr.  
Vice President - Supply

AEL/WJL/mit

Copy To: J. A. Biddison, Esquire (w/out Encl.)  
G. F. Trowbridge, Esquire (w/out Encl.)  
Messrs. E. L. Conner, Jr., NRC  
P. W. Kruse, CE

Enclosure (40 copies)

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

8011240134

P

## ENCLOSURE

### QUESTION 1X

Provide comparative Steam Line Break analyses between CESEC-SLB and old version of CESEC. The comparison should include the following cases:

- a. CESEC-SLB with pumps off
- b. CESEC-SLB with pumps on
- c. old CESEC version with pumps off
- d. old CESEC version with pumps on.

Also, provide the minimum DNBR for these cases and the conditions used to calculate the DNBR.

### RESPONSE

Figures 1X-1 to 1X-5 present the NSSS response during a SLB event with RCP's off using the version of CESEC named CESEC-SLB.

Figures 1X-6 to 1X-10 present the NSSS response during a SLB event with RCP's on using the version of CESEC named CESEC-SLB.

Figures 1X-11 to 1X-15 present the NSSS response during a SLB event with RCP's off using the old version of CESEC named CESEC-Cycle 7.

Figures 1X-16 to 1X-20 present the NSSS response during a SLB event with pumps on using the old version of CESEC named CESEC-Cycle 7.

Table 1X-1 presents the key input parameters for calculating DNBR and also presents the transient minimum DNBR values. The DNBR's were calculated using the MacBeth rod cluster correlation (Reference 1X-1) with Lee non-uniform heat flux correction factor (Reference 1X-2).

A few important points to note about the graphs are given below:

## ENCLOSURE

QUESTION 1X  
Page 2


1. The SLB event with RCP's off, analyzed with code version CESEC-SLB, determines the moderator reactivity feedback based on the cold edge inlet temperature. For all other SLB events presented the moderator reactivity feedback is calculated using the core average moderator temperature.
2. The SLB event with RCP's on, analyzed with code version CESEC-SLB determines the moderator reactivity feedback based on the average moderator temperature. The use of cold edge temperatures will only result in an additional .3%  $\Delta\rho$  and has no significant impact on the DNBR results presented.
3. The SLB event with RCP's on analyzed with code versions CESEC-SLB and CESEC-Cycle 7, show that the core remains subcritical by at least 1.6%  $\Delta\rho$ , even though the magnitude of subcriticality varies between the two code versions used.
4. The limiting SLB event is with the RCP's off analyzed using the code version CESEC-SLB. This event is presented in the Calvert Cliffs Unit 1, Cycle 5 license submittal (Reference 1X-3).
5. The minimum DNBR for the limiting SLB event is greater than 1.6.

Table 1X-1

MINIMUM DNBR DURING SLB EVENT  
FOR CALVERT CLIFFS UNIT 1, CYCLE 5

	Code Version CESEC-SLB		Code Version CESEC-Cycle 7	
	w/o RCPs	with RCPs	w/o RCPs	with RCPs
Time of Maximum Post-Trip Reactivity (seconds)	121	68	168	54
Core Average Fission Power (BTU/hr-ft <sup>2</sup> )	8550	3180	52	3510
Core Average Decay Power (BTU/hr-ft <sup>2</sup> )	6690	8010	6290	8760
3-D Fission Power Peak	45	45	45	45
3-D Decay Power Peak	2.2	2.2	2.2	2.2
Axial Power Distribution	Fig. 1X-21	Fig. 1X-21	Fig. 1X-21	Fig. 1X-21
Core Average Mass Flow (lbm/hr-ft <sup>2</sup> )	$2.12 \times 10^5$	$5.51 \times 10^6$	$1.46 \times 10^5$	$2.87 \times 10^6$
Minimum DNBR	1.6	>10	>10	>10

FIGURE 1Y-1  
CESEC-SLB  
Pumps OFF  
REACTIVITY VS TIME




46 1320

K&E 10 X 10 TO 1/2 INCH 7 1/2 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE 1X-2

CESEC - SLB  
Pumps OFF  
CORE POWER VS TIME



46 1320

K&E 10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KEUFEL & ESSER CO.

CESEC - SLB  
PUMPS OFF  
CORE HEAT FLUX VS TIME





FIGURE IX-4

CESEC - SLB  
Pumps OFF  
RCS TEMPERATURES VS TIME




46 1320

K-E 10 X 10 TO 1/4 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.



FIGURE IX-5


CESEC - SLB  
Pumps OFF  
RCS PRESSURE VS TIME



46 1320

K&E 10 X 10 TO 1/2 INCH 7 X 10 INCHES  
HEUFFEL & ESCHER CO. MADE IN U.S.A.

FIGURE IX-6  
CESEC - SLB  
Pumps ON  
REACTIVITY VS TIME




46 1320

K-E 10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-7

CESEC-SLB  
Pumps ON  
CORE POWER VS TIME


CORE POWER VS TIME



TIME, SECONDS

FIGURE IX-8

CESEC - SLB  
Pumps ON  
CORE HEAT FLUX VS TIME




46 1320

K-E 10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KUPFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-9

CESEC - SLB  
Pumps ON  
RCS TEMPERATURES VS TIME




46 1320

KE 10 X 10 TO 1/2 INCH  
MEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-10

CESEC-SLB  
Pumps ON  
RCS PRESSURE VS TIME




46 1320

10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-11

CESEC Cy-7  
Pumps OFF  
REACTIVITY VS TIME




46 1320

K-E 10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-12

CESEC Cy. 7  
Pumps OFF  
CORE POWER VS TIME

Core Power, % of 2700 Mw<sub>t</sub>




Time, Seconds



FIGURE IX-13

CESEC Cy 7  
Pumps OFF  
CORE HEAT FLUX VS TIME

CORE HEAT FLUX, % OF 2700 MWt




Time, Seconds

46 1320

K-E 10 X 10 TO 15 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-14

CESEC Cy 7  
Pumps OFF  
RCS TEMPERATURES VS TIME




46 1320

K-E 10 X 10 TO 1 1/2 INCH 7 X 10 INCHES  
KEUFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-15

CESEC Cy 7  
Pumps OFF  
RCS PRESSURE VS TIME




46 1320

K&E 10 X 10 TO 1 1/2 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-16

CESEC Cy 7  
Pumps ON  
REACTIVITY VS TIME




46 1320

10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-17

CESEC Cy 7  
Pumps ON  
CORE POWER VS TIME




46 1320

10 X 10 TO 1/4 INCH 7 X 10 INCHES  
KUFFEL & ESSEN CO. WYOMING, WY.

K&E

FIGURE IX-18

CESEC Cy 7  
Pumps ON  
CORE HEAT FLUX VS TIME




46 1320

K&E  
10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-19

CESEC Cy 7  
Pumps ON  
RCS TEMPERATURES VS TIME




46 1320

K&E 10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.

FIGURE IX-20

CESEC Cy 7  
Pumps ON  
RCS PRESSURE VS TIME




46 1320

K&E  
10 X 10 TO 1/2 INCH 7 X 10 INCHES  
KEUFFEL & ESSER CO. MADE IN U.S.A.



FIGURE IX-21

AXPD FOR DNBR CALCULATIONS



References for Question IX

- IX-1. R. V. Macbeth, "An appraisal of Forced Convection Burn-Out Data", Proc. Instn. Mech. Engrs., 1965-66, Vol. 180, Pt. 3C, pp. 37-50.
- IX-2. D. H. Lee, "An Experimental Investigation of Forced Convection Burnout in High Pressure Water; Part IV, Large Diameter Tubes at About 1600 psia", AEEW-R 479, November, 1966.
- IX-3. Calvert Cliffs Unit 1, Cycle 5 License Submittal, Letter dated September 22, 1980.