

NUCLEAR REGULATORY COMMISSION

T-1125

ORIGINAL

In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
268TH GENERAL MEETING

DATE: August 13, 1982 PAGES: 259 - 408
AT: Washington, D. C.

TRφ4

Delete B. White

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
- - -

3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
4 268th GENERAL MEETING
- - -

5 Room 1046
6 1717 H Street, N.W.
7 Washington, D.C.
8 Friday, August 13, 1982

9 The Committee met, pursuant to notice, at
10 1:45 p.m., PAUL G. SHEWMON (Chairman of the Committee)
11 presiding.

12 ACRS MEMBERS PRESENT:

13 PAUL G. SHEWMON
14 J. CARSON MARK
15 MILTON S. PLESSET
16 CHESTER P. SIESS
17 DADE W. MOELLER
18 MYER BENDER
19 WILLIAM KERR
20 MAX W. CARBON
21 HAROLD ETHERINGTON
22 DAVID A. WARD
23 JESSE C. EBERSOLE
24 HAROLD W. LEWIS
25 DAVID OKRENT

ALSO PRESENT:

J. RAULSTON
R. PIERCE
L. MILLS
D. ORMSBY
B. COTTLE
P. SHEMANSKI
T. KENYON
E. ANDENSAM
T. NOVAK

DESIGNATED FEDERAL EMPLOYEE:

RAYMOND F. FRALEY

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

P R O C E E D I N G S

1
2 MR. EBERSOLE: We're going to talk about Watts
3 Bar Unit 2. I'm not sure how many of the committee here
4 are familiar with the degree similarity between Watts
5 Bar and Sequoyah. To give you an idea about what this
6 is, about 40 years ago we had a hydro project in
7 Tennessee called Cherokee and we needed to make lots of
8 electricity to make aluminum to make bombers in a
9 hurry. So they found a convenient place in the valley
10 changed the elevations above sealevel, and set this
11 plant down in modular form in another part of the
12 country over there.

13 That entire project, as I recall, was started,
14 and it was from the time of the start of operation until
15 the time they put it into functioning operation, which
16 was one year. In all the intervening years, I think
17 this project represents the sole attempt to attempt to
18 duplicate that process. It is my impression, at least,
19 that TVA has taken a great deal of advantage of the use
20 of identical drawings at Sequoyah and may have in fact
21 reproduced a great many of them. I'm not sure how
22 many.

23 But it is fair to say that if Sequoyah is a
24 good plant to operate, then Watts Bar is probably
25 better, except for of course the considerations of

1 quality assurance and administrative matters of that
2 sort. If the designs are essentially the same with some
3 improvements, some of which one might argue about, like
4 the Westinghouse 3-D steam generator, which was thought
5 to be an improvement in a recent day.

6 I want to comment on some of those
7 differences, most of which are mentioned in our proposed
8 letter on the topic. Late in the construction program,
9 in 1981, early '82, there was rather a serious quality
10 assurance breakdown, principally in the construction,
11 but not only that, also in the design area. This has
12 resulted in a monumental flow of deficiency reports.

13 This problem was picked up and a rather large
14 shift in the organization and management of the QA
15 problem which was invoked. Insofar as I can tell, it's
16 presently working. That doesn't mean the job is done by
17 far. There is still a great inflow of paper and
18 processing of paper on the deficiency reports and how to
19 handle them.

20 TVA plans to have an independent contractor
21 review the design and the construction of what they call
22 a typical vertical cross-section of this, which is
23 really just a way of saying they are going to pick some
24 fraction of the plant that represents a top to bottom
25 view of what the design is and examine it in intensive

1 detail and see whether or not the quality assurance
2 reorientation has in fact covered the aberrations that
3 occurred in this interval.

4 Regarding the site, it is interesting to note
5 that from a seismic point of view I think the plant is
6 essentially in the same seismic area as Watts Bar. It's
7 only about 35 or 40 miles away. They have hydrology
8 problems that are quite similar. They use a flooding
9 type concept of design which resembles very strongly
10 that of Sequoyah, which permits the plants to be
11 flooded, the plant to be flooded, after a prescribed
12 interval of time which they think they can forecast,
13 within which time they go in and rig the plant to take
14 the flooded condition for an indefinite interval.

15 One of the interesting aspects of the plant
16 problem down there was to me the use of cement mortar to
17 line the cooling water system piping and perhaps some
18 other piping down there, in the course of doing this, to
19 recognize a rather new approach to the use of piping,
20 changing out carbon steel to stainless steel for the
21 smaller sizes, but for the larger pipes to go through
22 this process of lining the pipes with mortar.

23 I believe they have had a little QA problem in
24 this particular aspect itself, and this, as you might
25 expect, one will be interested in the seismic

1 performance of this lining material, particularly if it
2 tends to deteriorate over time and becomes cocked or
3 loosened so that it doesn't perform in the way that it
4 was originally shown to perform when they did bending
5 tests on it.

6 In short, if it cocks itself to represent a
7 potential cascade failure in the event we have seismic
8 shocks or other mechanical upsets, then by some sudden
9 entrainment of this debris you could have various
10 consequences in the performance of the piping systems.

11 We are a little bit, not too much, off
12 schedule here already. I think it would be better and
13 more profitable to simply plunge into the presentation
14 by TVA, for which we have here about three and a
15 half-odd hours. And we're going to start that by a
16 status.

17 However, I want to ask other members of the
18 Committee -- Mr. Bender, Mr. Ward -- if they have
19 anything to add to this presentation.

20 We had a meeting, incidentally, on the 10th.
21 We had a meeting at the site on April the 30th,
22 including a site visit. And topics will be brought up
23 at least in some of the cases which were discussed at
24 those meetings.

25 MR. MARK: The Staff and the Applicant will

1 point out the differences between this and Sequoyah?

2 MR. EBERSOLE: There are differences,
3 outstanding issues, et cetera. The agenda is in the
4 pink-covered sheet. Does everyone have the pink
5 handout?

6 MR. MARK: Watts Bar has a nice little dam
7 about three miles up above.

8 MR. EBERSOLE: It has a dam above the plant
9 proper, very few miles. It also has an old steam plant,
10 TVA's original steam plant.

11 MR. MARK: And it has hydroelectric. Is that
12 important to the backup of the plant?

13 MR. EBERSOLE: Is it important to the backup
14 of the plant? I can't say that. Maybe TVA can say
15 whether or not local power from Watts Bar is a prime
16 asset for offsite power. I suspect it is.

17 MR. MARK: It's a very few miles away. There
18 is about a 20-foot dam with a hydroelectric generating
19 unit.

20 MR. EBERSOLE: I believe it's higher than
21 that. I don't know whether they have deliberately
22 enhanced --

23 MR. MARK: It has nothing to do except to feed
24 Watts Bar if it wants to.

25 MR. EBERSOLE: Maybe whoever's going to do the

1 presentation can talk about the value or lack of it
2 above the nuclear plant.

3 MR. SHEWMON: Whoever is rubbing their
4 microphone, would they stop it.

5 (Laughter.)

6 MR. MILLS: Are you ready for us to proceed,
7 sir?

8 MR. SHEWMON: That's what we're waiting for.

9 MR. MILLS: I'm Larry Mills, Manager of
10 Nuclear Licensing for TVA.

11 The Watts Bar nuclear plant, which consists of
12 two identical units, was constructed and will be
13 operated by TVA. These units employ pressurized water
14 reactors furnished by Westinghouse. Each unit will
15 operate at 3411 thermal megawatts, with an electrical
16 output of 1218 megawatts.

17 Completion of these two units will provide TVA
18 with seven operating nuclear units, including those
19 currently in operation at Sequoyah and Browns Ferry
20 nuclear plants, with a nuclear generating capability of
21 approximately eight million kilowatts of electrical
22 power.

23 The Watts Bar plant site is located in East
24 Tennessee, and Dave Ormsby is pointing out the location
25 of that.

1 (Slide.)

2 This slide also shows the locations of
3 Sequoyah and Browns Ferry. Watts Bar is approximately
4 31 miles north-northeast of the Sequoyah nuclear plant
5 and 45 miles north-northeast of Chattanooga, Tennessee.
6 The plant site consists of a tract of approximately 1770
7 acres in Rhea County on the west bank of the Tennessee
8 River. The 1770 acre reservation is owned by the United
9 States and is in the custody of TVA. Also located
10 within the reservation are the Watts Bar hydroelectric
11 plant and the Watts Bar steam plant.

12 The contract for Watts Bar nuclear steam
13 supply system was awarded to Westinghouse on August 27,
14 1970, and a construction permit was issued on January
15 23rd, 1973. TVA submitted a final safety analysis
16 report on July 1, 1976, in support of an application for
17 an operating license. This application was docketed by
18 the NRC on October 4, 1976.

19 The construction completion schedule of August
20 1983 for Unit 1 and August 1984 for Unit 2 remains the
21 same as we specified during the last ACRS Subcommittee
22 meeting in April. This schedule includes plant
23 modifications as a result of TMI-related requirements
24 and modifications resulting from the Sequoyah licensing
25 review. These modifications were included at Watts Bar

1 because of the similarities between Sequoyah and Watts
2 Bar.

3 Later today we will be providing more specific
4 information on TVA organizations and training, but
5 briefly: Staffing of the plant operating personnel was
6 initiated with the appointment of a plant superintendent
7 in July 1976.

8 Since that time the staff has grown to a
9 present level of approximately 190 engineering and
10 maintenance employees, 65 administrative and support
11 employees, 7 senior reactor operators, 4 reactor
12 operators, and 100 auxilliary unit operators. By fuel
13 loading for Unit 1, 2 more senior reactor operators and
14 12 more reactor operators will be added.

15 The onsite operations personnel are currently
16 involved in becoming familiar with plant systems and
17 equipment and operating various systems and equipment
18 during the plant construction test program.

19 Total plant staff for operation of both units
20 will be approximately 560 people, composed of
21 approximately 130 operators, 315 engineering and
22 maintenance personnel, 120 administrative and support
23 employees.

24 The remainder of the plant operations
25 personnel are being trained by the Nuclear Training

1 Branch in the Division of Nuclear Power at TVA. TVA's
2 training program conforms with the requirements set
3 forth in ANSI N18.1.

4 When we receive a license to operate Watts
5 Bar, TVA will have accumulated approximately 31 reactor
6 years of operating experience from operation of Sequoyah
7 and Browns Ferry nuclear plants.

8 Now, David Ormsby, our licensing project
9 engineer, will present a discussion of the comparison
10 between Sequoyah and Watts Bar. And at the conclusion
11 of that, I think we have a gentleman here who can
12 address the location of the Watts Bar hydroplant and
13 steam plant with regard to offsite power of the Watts
14 Bar nuclear plant.

15 MR. MARK: Mr. Mills.

16 MR. MILLS: Yes?

17 MR. MARK: I'm just slightly curious. You
18 have four operators at the moment and seven senior
19 operators.

20 MR. MILLS: Yes.

21 MR. MARK: And you are going to add a fair
22 number of operators within a rather -- well, not a
23 terribly short time, but like a year. Where do you get
24 operators? Do you grow them down there in Tennessee?
25 Or do you swipe them from Oklahoma, or what do you do?

1 (Laughter.)

2 MR. MILLS: Dr. Mark, I couldn't say that they
3 grow well on the hills of Tennessee. But in reality, we
4 have our own training facility down there, and Mr.
5 Cottle might like to address this, but --

6 MR. MILLS: When you say you have more coming
7 --

8 MR. COTTLE: We have them on site. The seven
9 senior reactor operators Mr. Mills referred to are shift
10 engineers, assistant shift engineers, that we have on
11 site that have been licensed on Sequoyah or Browns
12 Ferry. We also have four individuals on site who hold
13 or have held a reactor operator license.

14 We already have additional people for the
15 remainder of the positions on site. They just do not
16 hold a license on any of our other units.

17 MR. MARK: Okay. That's exactly the picture I
18 wanted to get a feeling for.

19 MR. COTTLE: I have a little more
20 information.

21 MR. MARK: You know the people. They haven't
22 passed their graduation exams, but they are there.

23 MR. COTTLE: Yes, sir.

24 MR. MARK: That was all.

25 MR. MILLS: Thank you, sir.

1 Dave, did you want to proceed?

2 MR. ORMSBY: Thank you.

3 The Watts Bar and Sequoyah nuclear plants are
4 similar in most respects. The cores are similar and
5 each plant utilizes a free-standing steel vessel with an
6 ice condenser and a reinforced concrete shield
7 building. The plants' mechanical systems, containment
8 systems, emergency core cooling systems, instrument and
9 control systems, electrical power systems, radioactive
10 waste systems, and steam and power conversion systems
11 are also very similar in design and materials.

12 Most differences are either site specific or
13 are the result of the fact that two to three years
14 separate the design phases of Sequoyah and Watts Bar.
15 Although the design philosophy was the same, there were
16 some instances when more current technology was used for
17 Watts Bar.

18 (Slide.)

19 This vugraph provides a table showing design
20 differences between the two plants. As I stated
21 previously, there is a two to three-year difference in
22 the design phases for Watts Bar and Sequoyah. During
23 that time, some design changes were made for Watts Bar
24 which increased the efficiency of the system. There are
25 also some instances where equipment was upgraded or

1 provided by a different manufacturer.

2 A couple of examples are the following. You
3 will notice that there is a difference in the increased
4 primary system flow rate and therefore a difference in
5 the maximum heat flux. That is primarily due to the
6 fact that, although the reactor coolant pumps themselves
7 are the same for the two plants, Sequoyah utilizes a
8 6,000 horsepower pump motor and Watts Bar utilizes a
9 7,000 horsepower pump motor.

10 Because of the increase in the reactor coolant
11 system flow, there is a need for greater PORV relieving
12 capacity for load mismatch and to accommodate a 50
13 percent load rejection. The PORV's for Watts Bar are
14 provided by a different manufacturer than those for
15 Sequoyah.

16 You will also note that there is an increase
17 in turbine generator and gross electrical output. These
18 differences are due to increased equipment and system
19 efficiency and also to the difference in steam
20 generators.

21 As you can see from the slide, we have a model
22 D steam generator for Watts Bar and a model 51 for
23 Sequoyah. The steam generators for the two plants are
24 similar vertical shell and U-tube evaporators, with
25 integral moisture separating equipment. The reactor

1 coolant flows through the inverted U-tubes, entering,
2 then leaving through the nozzles located in the
3 hemispherical bottom head of the steam generators.
4 Steam is generated in the shell side and flows upward
5 through the moisture separators to the outlet nozzle at
6 the top of the vessel.

7 Now, the primary difference between these,
8 aside from minor differences in surface areas and U-tube
9 design, are the fact that the Model 51 for Sequoyah
10 utilizes a feed ring, whereas the Model D for Watts Bar
11 utilizes a preheater section. The differences in the
12 two steam generators show that we have an increased
13 secondary steam flow rate.

14 MR. MARK: You mentioned that you had pumps
15 from a different manufacturer. They were bigger, I
16 believe.

17 MR. ORMSBY: I don't think from a different
18 manufacturer. The pump motors are different in size.

19 MR. BEAL: The PORV's are different
20 manufacturers.

21 MR. ORMSBY: Yes.

22 MR. MARK: Is this a better manufacturer?

23 MR. ORMSBY: I hesitate to say a better
24 manufacturer. I would say that there is more
25 qualification documentation in the PORV's for the Watts

1 Bar valves than there are currently for the Sequoyah
2 valves.

3 MR. MARK: So you would have the expectation
4 that these things are at least as good, maybe better?

5 MR. ORMSBY: Yes.

6 Are there any other questions?

7 MR. ETHERINGTON: The reactors are identical,
8 are they, the core and so on?

9 MR. ORMSBY: Yes, the cores are essentially
10 identical.

11 MR. EBERSOLE: Is that the end of your
12 presentation?

13 MR. ORMSBY: Yes, sir.

14 MR. MILLS: Mr. Ebersole, would you like for
15 us to hit the items you mentioned before about the Watts
16 Bar hydro?

17 MR. EBERSOLE: Yes, please, if we have someone
18 here to do that.

19 MR. GRAVES: My name is Ron Graves, from the
20 TVA.

21 I would like to address the question of
22 interdependency between the Watts Bar hydro plant and
23 the Watts Bar nuclear plant. The Watts Bar hydro plant
24 feeds power into the 161 KV grid which is the source of
25 two circuits that supply offsite power to the shutdown

1 boards inside the plant. The shutdown boards inside the
2 plant have each a diesel generator as an additional
3 source of power to the shutdown boards.

4 The 161 KV grid is also interconnected with
5 the entire TVA grid, and I believe that we have two
6 other lines going to the grid in one of the buses in
7 that switchyard, and we have three interconnections with
8 the grid on the other bus.

9 The final conclusion is that Watts Bar hydro
10 is not essential for the reliable operation of the
11 shutdown system.

12 MR. MARK: Is there any arrangement whereby
13 the Watts Bar plant would get special attention in case
14 the grid had trouble?

15 MR. COTTLE: I'll answer that from up here.
16 We do have some postulated failures. We have an
17 Athens-Sequoyah line going out of Watts Bar that is one
18 of our primary feeders. In the event that that line is
19 down, laid on the ground from weather considerations, we
20 do have or are in the process of implementing some
21 procedures where we do get special preference from the
22 hydro plant in terms of splitting the bus, dedicating
23 that basically to the Watts Bar unit plant. And that is
24 to prevent a fall in the hydro switchyard from further
25 degrading loss of offsite power.

1 MR. ETHERINGTON: Are there periods of low
2 flow when the hydro plant is closed down?

3 MR. COTTLE: There are some periods throughout
4 the year where we have, mainly during the nighttime
5 hours, essentially zero flow. That is not particular
6 significant to us at the nuclear plant unless, as I said
7 before, we are in a special case where we do have the
8 Athens-Sequoyah line out.

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. MARK: My point in raising the question
2 here was that I thought that you were particularly
3 favorably located to a possible source of power, or the
4 lines were short.

5 MR. COTTLE: There are certainly some other
6 considerations, if you have a complete grid blackout,
7 about restoration of power and starting up the
8 hydroplant units first, allowing us to regain a source
9 of power, if you lost that whole TVA grid -- and we do
10 have provision for that, as well.

11 MR. EBERSOLE: Do the Watts Bar cover
12 generators spend a large part of their time with
13 condensers ready to take water, in the event you need
14 them?

15 MR. CARBON: Not a large percentage of the
16 time. There are some periods of time when the running
17 is synchronous.

18 MR. EBERSOLE: Is the old fossile plant in
19 operation?

20 MR. CARBON: It is in condition for a standby
21 mode of operation. It is typically not run except
22 during --

23 MR. EBERSOLE: For the general information of
24 the committee, I would ask TVA about the rather ancient
25 practice of deriving auxiliary power from the output of

1 the particular unit, meeting that power. And I came
2 across the revelation that maybe Watts Bar is a type of
3 design that would use that.

4 They consider the 161 Kv system here is not a
5 particularly better system; not as good as the 500 Kv.
6 Therefore, it is not an optimum system from which to
7 continuously draw power for the operation of the station
8 auxiliary. So they therefore use unit outputs to run
9 the station auxiliary.

10 In that configuration, they always lose
11 station output when the unit gets in trouble, and it is
12 mandatory that they accomplish an electrical transfer.
13 They do this by, I think, instantaneously transferring
14 to the 161 Kv as an alternate source, inspite of its
15 ordinarily lower stability. And they do other switching
16 to get the other non-1E loads across to a source of
17 power.

18 I understand that at Belefonte it will be
19 having a steady source of power from other than the
20 other unit itself to run the station auxiliary. The TVA
21 should correct me if I am wrong in that statement. Was
22 that correct?

23 MR. GRAVES: I believe you are correct, Mr.
24 Ebersole.

25 MR. EBERSOLE: Any other questions on this

1 topic?

2 (No response.-

3 Let's go to the outstanding issues we have.

4 We have Mr. Kenyon down for this.

5 (Slide.)

6 MR. KENYON: I am here to present the
7 licensing status of the Watts Bar plant. The SER was
8 issued in June of this year, and the review was unique
9 in that it relied more heavily on the review performed
10 on the Sequoyah plant, because as we have been
11 discussing, the designs were so similar.

12 The SER contained 17 open items, 41
13 confirmatory items, and 37 license conditions. Of the
14 37 license conditions, 21 were TMI related, and can be
15 characterized in a number of different ways. Some of
16 the items were imposed to insure completion of work such
17 as physical plant modifications or to ensure the
18 completion of long-term generic analysis programs that
19 were going on.

20 Other TMI-related license conditions have been
21 imposed just to insure the submittal of information in
22 accordance with the schedule consistent with
23 NUREG-0737. The non-TMI related open items consisted of
24 items which the staff had reviewed and discussed with
25 TVA and determined that the regulations could be best

1 met only if -- through the imposition of the license
2 conditions.

3 In addition, some of these non-TMI related
4 license conditions have been imposed to insure that
5 plant modifications would be completed in accordance
6 with the specified schedule.

7 MR. MARK: In view of the rather large
8 similarity between this plant and Sequoyah, the fact
9 that you are dealing with the same management, are these
10 open items that you mentioned also open at Sequoyah, or
11 have they been closed there but are still not closed
12 here, or are they different items?

13 MR. KENYON: Sir, it is a mixture of all,
14 actually. Some of these --

15 (Slide.)

16 This is a list of the open items remaining
17 since the SER was issued. Some of them are -- were open
18 on Sequoyah and have been either closed or perhaps are
19 still under review. Some of them are very site specific
20 to Watts Bar, and the problem just did not come up on
21 Sequoyah, such as the potential for liquefaction beneath
22 the ERCW pipelines. Some of them are simply due to the
23 normal evolving process of the licensing process.

24 As you know, it has been about two years since
25 the Sequoyah Unit 1 was licensed. New requirements

1 sometimes come up in addition, or more likely, they are
2 new interpretations of requirements that become policy.
3 In a lot of these cases, sometimes the open issue arose
4 because there was a different reviewer looking at Watts
5 Bar than looked at Sequoyah, and he put a different
6 emphasis in his review in a different area.

7 Of these open issues remaining, they are
8 primarily just issues where we are waiting for TVA to
9 submit information. In fact, TVA has submitted
10 information on six or seven of these items already, and
11 the staff is just reviewing it, so it is awaiting their
12 review.

13 MR. MARK: Fine.

14 MR. KERR: In addition, I guess, one of the
15 plant-specific problems is for the Model D-3 steam
16 generator. As I was going to say, back in December, the
17 staff had issued a draft SER that contained 80 or 90
18 open items. Probably more appropriately, I should say
19 concerns. They were raised simply because the staff
20 lacked information about the Watts Bar plant.

21 TVA submitted the information in response to
22 our questions; we reviewed it and closed the item.

23 MR. MARK: I wasn't meaning to delay you.

24 MR. KERR: Are there any questions about the
25 open issues?

1 MR. EBERSOLE: Have there been other designs
2 like this one that used a steel piling retaining wall
3 with an earth fill to act as a causeway, and
4 simultaneously embed the ERCW pipelines in 1E component
5 work? This is a fairly long causeway, I believe. It is
6 a steel piling causeway.

7 MR. KENYON: Yes.

8 MR. EBERSOLE: Have you had any designs like
9 this before this particular one that you can recall?

10 MR. KENYON: Not that I am aware of. I don't
11 believe we have anybody --

12 MR. EBERSOLE: Anyway, that is one of the
13 differences in this design between Watts Bar and
14 Sequoyah. They to carry these critical water lines and
15 the corresponding electrical services in the
16 earth-filled causeway surrounded by steel pilings, and
17 are retained by deadmen supports to tension bars.

18 There will be some discussion of this later
19 one, corrosion protection and the long-term viability of
20 this type of construction.

21 MR. CARBON: I would like to ask one question
22 similar to Dr. Mark's actually. Could you or Mr. Novak
23 or someone make any kind of comment on has there been
24 appreciably -- has it required appreciably less effort
25 on the staff's part to review this plant, in view of all

1 the similarities with the Sequoyah plant?

2 MR. KENYON: Well, sir, when the review
3 started on Watts Bar, we requested TVA to present a
4 comparison between Sequoyah and Watts Bar. In addition
5 to that, in many instances we used the same reviewer who
6 had worked on Sequoyah to look at the Watts Bar plant.
7 The reviewer, where he could, went back and reviewed the
8 comparison and --

9 MR. CARBON: I am sure he did that. My
10 question is simply, do you have any feeling for how much
11 less effort it may have taken to review this plant than
12 the first one?

13 MR. KENYON: Quantitatively, I couldn't give
14 you a good answer. The best response I could give you
15 is I do know in many instances there were -- in many
16 review branches they put less work into the review of
17 Watts Bar simply because they knew what was done on
18 Sequoyah and TVA said that their systems were identical
19 or essentially identical, and that lessened the review
20 work done on it.

21 MR. CARBON: Fine, thank you.

22 MR. EBERSOLE: Other questions?

23 (No response.)

24 If not, you can proceed into the next topic
25 which is organization and management, and I believe Mr.

1 Cottle will give that presentation.

2 MR. NOVAK: I would like to add one comment.
3 I would say overall, the staff review effort was
4 comparable to Sequoyah. Realistically, if you look at
5 how long an application resides in the licensing
6 process there is a building factor. It is an
7 integration. And both Sequoyah and Watts Bar have
8 relatively long periods of time in construction, and in
9 a sense, the licensing process was extended.

10 I think where there was no reason to go back
11 and do it over again, that was the course that was
12 followed. Just simply because of the difference in
13 time, certain areas were looked at perhaps in more
14 detail on Watts Bar than they were on Sequoyah. I think
15 we continue to learn about plants from reviews. I don't
16 think we will ever say that we won't learn anything
17 about it on the next one.

18 MR. CARBON: But to a first approximation or a
19 first best guess, it has taken about the same amount of
20 effort, not time but effort, for both plants?

21 MR. NOVAK: That would be my judgment, yes.

22 MR. COTTLE: I am Bill Cottle, Plant
23 Superintendent at Watts Bar. I would like to take these
24 next few minutes to go through just a very brief
25 summation of the experience requirements or the

1 experience that key members of my staff have at the
2 plant, and we will get back into the actual staffing
3 numbers that we touched on a little earlier.

4 (Slide.)

5 The key members -- and there is a handout, I
6 believe each one of you has. We tried to break it down
7 to the individual, the position he holds and as I said,
8 I am Plant Superintendent. I have two assistant plant
9 superintendents; assistant superintendent for operations
10 and engineering, and an assistant superintendent for
11 maintenance. I am going to have a third individual that
12 is almost on the same level as an assistant
13 superintendent that is a field services supervisors who
14 is responsible for refueling outages and major
15 maintenance outages at the unit.

16 I would like to go through just briefly the
17 background of those individuals and then focus on just
18 those other key positions that are directly in the line
19 of operation of the unit.

20 We have got it broken down to where we are
21 only really talking about either general fossile plant
22 experience or experience at a nuclear facility. I have
23 about a total of 13 1/2 years experience in nuclear,
24 between nuclear Navy background, previous experience
25 with the Alabama Power Company and the startup of Farley

1 Unit 1, the experience at Sequoyah nuclear plant prior
2 to coming to Watts Bar as assistant superintendent for
3 operations and engineering, and intertwined in there two
4 years experience with the I&E staff of the NRC as a
5 project inspector and resident inspector.

6 Of the 13 years' experience at the plant, I
7 guess if you broke it down between the two categories of
8 maybe pre-operational phase and training, it would be
9 about 7 years, and experience at an operating facility
10 about 6 years.

11 MR. MARK: Where do you categorize your
12 experience with I&E? It doesn't sound either like
13 operating --

14 MR. COTTLE: Most of my experience with the
15 I&E group in Atlanta was as resident inspector involving
16 with startup of units. We classify that as operational
17 experience.

18 (Slide.)

19 Assisant superintendent in charge of -- direct
20 charge of the operations of the engineering group has
21 some 10 years prior experience in the fossile field,
22 some 20 years' experience in the nuclear field including
23 experimental gas cold reactor project in Browns Ferry
24 and Sequoyah projects. Most of this has been in a
25 pre-operational and training capacity. I would say

1 probably 18 to 19 years in that capacity, and about a
2 year involved with the startup of Sequoyah unit, and Mr.
3 Lewis does hold a senior reactor operator license at the
4 present time.

5 (Slide.)

6 Assistant plant superintendent in charge of
7 maintenance, Mr. Ed Ennis has about 13 years of fossile
8 experience, five years of applicable nuclear experience
9 all at Watts Bar and all basically in the
10 pre-operational phase. He has recently completed what
11 we would call the equivalent of a cold license
12 certification course, meaning that training which we
13 would require prior to our certifying him to take an NRC
14 license exam on the Sequoyah facility.

15 (Slide.)

16 Field services supervisor, the individual who
17 is primarily responsible for planning and scheduling and
18 conducting our major maintenance and refueling outages
19 has some 11 years of nuclear experience, including five
20 years in the nuclear Navy propulsion program. A
21 breakdown of his experience shows about six years pre-op
22 and training phase, and five years at an operating
23 facility.

24 (Slide.)

25 Operations supervisor, that individual

1 directly over the operations group, has some 15 years of
2 fossile experience with TVA, about 14 years associated
3 with the nuclear program at TVA including a significant
4 amount of time as the senior reactor operator at the
5 Browns Ferry facility. The breakdown of his nuclear
6 experience would be about 10 years pre-operational
7 testing phase, and four to five years in an operational
8 capacity, primarily at Browns Ferry.

9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 (Slide.)

2 We have two assistant operations supervisors.
3 The first, Mr. Norman, has about seven years' experience
4 in our fossil operations, ten years' experience in
5 nuclear, and all of that ten years primarily in the
6 preoperational and training capacity.

7 (Slide.)

8 The second assistant operations supervisor,
9 Mr. Yarbrough, has some fifteen years of fossil
10 experience, about ten years of nuclear experience. Mr.
11 Yarbrough came to us as a shift engineer from Sequoyah
12 and holds an SRO license on Sequoyah and was one of the
13 original shift engineers for the startup of initial
14 operation of the Sequoyah units.

15 In addition, in the last kind of individual
16 background we'd like to look at we have a special
17 projects supervisor or special projects coordinator that
18 is assigned to assist the assistant plant supervisor of
19 plant engineering, Mr. Eckard. Mr. Eckard has about 19
20 years of fossil plant experience, 11 years of nuclear
21 plant experience.

22 (Slide.)

23 Mr. Eckard was previously the operations
24 supervisor at Sequoyah. He holds a license on the
25 Sequoyah unit and served as operations supervisor during

1 the startup of the Sequoyah units.

2 (Slide.)

3 MR. CARBON: Mr. Cottle, I am favorably
4 impressed by the experience that I see here of your
5 people. Just to understand where they came from and so
6 on, I guess they are all long-term TVA people except
7 yourself, is that correct?

8 MR. COTTLE: Except myself almost all of the
9 years' experience that we've talked about have been in
10 the TVA organization, yes, sir.

11 MR. CARBON: Thank you.

12 MR. MARK: A mild question. A number of
13 people that you displayed for us have had a part or
14 maybe even a large part of their experience at Sequoyah
15 or Browns Ferry. Do you have to steal those guys from
16 Sequoyah, or does TVA assign them to Watts Bar? We are
17 very familiar with plants which have been in the spot
18 where they have had to steal or lure their people from
19 somewhere else.

20 MR. COTTLE: For the most the experience that
21 these individuals got at Sequoyah was while they were in
22 fact assigned as Watts Bar individuals; but the
23 assistant plant superintendent for operations and
24 engineering was licensed on Sequoyah while he was
25 assigned to Watts Bar.

1 MR. MARK: So it isn't so much a matter of
2 assignment as --

3 MR. COTTLE: It's more of assignment and
4 trying to accomplish a transfer of experience and get
5 the benefit of the experience on the Sequoyah startup up
6 to Watts Bar.

7 MR. MARK: That's just what I was trying to
8 get a feeling for.

9 MR. COTTLE: Yes, sir.

10 (Slide.)

11 I'd like to look at just our shift engineer
12 classification, and the shift engineer is synonymous, I
13 guess, with the NUREG terms of shift supervisor: our
14 lead individual on each shift. I won't go over all of
15 the individual statistics. Let me point out a couple of
16 what I feel like are important aspects of the slide.

17 Six out of nine of our shift engineers have
18 either -- two of them have held a license on the Browns
19 Ferry units; I guess five have held a license on the
20 Sequoyah unit; four have held a license on the Sequoyah
21 unit, and they currently hold that license and are
22 staying current in the Sequoyah requalification
23 program. An additional superintendent does not hold a
24 license on any of our units. However, he has a
25 significant Navy background.

1 The last individual listed on the slide is Mr.
2 Jenkins. Mr. Jenkins has just come to us. He is
3 working as a shift engineer in a rather limited
4 capacity. We went out and got Mr. Jenkins because of
5 his extensive experience in fossil plants and his
6 extensive experience in the training of assistant unit
7 operators. He is at Watts Bar with the primary purpose
8 of working with our unit operators to get what I call a
9 common sense powerhouse approach towards looking at the
10 equipment.

11 We are looking at our training program. We
12 are very comfortable with the basics of nuclear theory
13 and the systems knowledge these individuals have. We
14 have identified some areas of weakness in just plain
15 checking out, running pieces of equipment, and
16 diagnosing problems with pieces of equipment. That is
17 what he will be primarily working on.

18 MR. MARK: Where do the people who we are
19 looking at here and hundreds of others, where do they
20 live? They don't live on the site. Do they live in
21 Knoxville or Chattanooga?

22 MR. COTTLE: Most of them live in several
23 smaller towns around the site -- Athens, Tennessee;
24 Sweetwater, Dayton, Tennessee -- within a 20-mile radius
25 of the site basically.

1 MR. MARK: Sweetwater is a fine crossroads on
2 the highway.

3 (Laughter.)

4 MR. EBERSOLE: Mr. Cottle, I guess I don't
5 know what you mean by shift engineers. I take it it's
6 really an administrative title and not meant to imply --

7 MR. COTTLE: The shift engineer is an
8 administrative position type.

9 MR. EBERSOLE: It doesn't necessarily mean
10 you'll turn the shift over to an individual?

11 MR. COTTLE: No, sir. We don't in fact have
12 our individual in the license training program.

13 MR. EBERSOLE: So that's really an
14 administrative title.

15 MR. COTTLE: We're trying to upgrade our
16 junior operations people.

17 MR. EBERSOLE: On the other hand, are the
18 others functionally really shift engineers?

19 MR. COTTLE: The others are functionally shift
20 engineers. The one exception to that would be Mr.
21 Pauley. We have a shift engineer position that we
22 dedicate to operator license training, and he's
23 qualified for that, and he has considerable experience
24 at the Sequoyah plant. His job function primarily is
25 the overall direction and preparation of the license

1 program, that part that we do on site.

2 MR. EBERSOLE: Mr. Cottle, who is your current
3 counterpart at Sequoyah down the road a little bit?

4 MR. COTTLE: The superintendent at Sequoyah is
5 Chuck Mason.

6 MR. EBERSOLE: I see. Thank you.

7 (Slide.)

8 MR. COTTLE: The next senior position on our
9 operating shifts is assistant shift engineer. The
10 assistant shift engineer is that individual who would
11 hold a senior reactor operator license and would have
12 accountability for the operation of an assigned unit,
13 either Unit 1 or Unit 2.

14 We currently have 11. Out of those 11 we have
15 2 that hold a current reactor operator license on
16 Sequoyah. We will be upgrading them to senior reactor
17 operator. We have one individual who previously held a
18 reactor operator license on a Browns Ferry unit. All of
19 the remaining individuals either have in the very recent
20 past or we are in the process of right now having those
21 individuals participate in the activities down at
22 Sequoyah, and a good number of them will be
23 participating. They have been reviewing the outage on
24 Sequoyah Unit 1.

25 (Slide.)

1 So the last classification we will take a look
2 at is our unit operator classification. We currently
3 have 17 individuals, 2 of which hold a current reactor
4 operator license on Sequoyah and are continuing to
5 maintain the validity of that license.

6 Again, pretty much in the same light, all of
7 our unit operator -- and there will be candidates for
8 reactor operator licensing -- either have participated
9 or will be participating in the activities at our
10 Sequoyah units.

11 (Slide.)

12 MR. MARK: Can you make just a comment about
13 your maintenance people? Have they also been drawn from
14 within the organization, knowing how to fix up a motor
15 and that sort of thing?

16 MR. COTTLE: Most of our maintenance people do
17 have either previous fossil experience, and in some
18 cases significant amounts of it, with TVA in the
19 practical maintenance application and/or a combination
20 of previous nuclear experience either at Browns Ferry or
21 Sequoyah.

22 We do have some of our key maintenance people
23 who have not spent a significant amount of time in an
24 operating nuclear unit, and those individuals, we are
25 rotating those down to Sequoyah now and have been for

1 the last several months, and they are actually going
2 down and serving in their counterpart positions at
3 Sequoyah either as group supervisor or to cover a
4 special project at Sequoyah.

5 MR. EBERSOLE: Mr. Cottle, I'd like to ask you
6 to give us your views. You're an ex-Navy man. I think
7 a lot of your experience was on submarines. These
8 plants in one view are sort of compromises between
9 having lots of people and lots of automation. My own
10 view of the Navy is they would have 1,000 men down at
11 Watts Bar with a speaking tube to every valve and a man
12 standing by it.

13 (Laughter.)

14 I hear lots of comments from Navy people.
15 We've heard it from high quarters that we're too highly
16 automated and we need more and smarter people to run
17 these plants.

18 What's your own perspective view on the amount
19 of manning versus the amount of automation?

20 MR. COTTLE: I guess I might agree with the
21 Navy that we're too highly automated. If we're willing
22 to build plants with a factor of ten less output and
23 drop down to a hundred megawatt plant, we would have very
24 little people and very little automation. You don't
25 accomplish a lot of economy of scale doing that.

1 On the primary plant I guess I would say I
2 feel very comfortable with the degree of automation and
3 limited amount of manning we have to place on the
4 primary plant. I do feel at times, primarily in the
5 supporting and secondary systems, that we lean a little
6 too much towards our automation phase, and at times we
7 have extra people to compensate for that. It may be
8 because of design problems, it may be because of lack of
9 operations, of individuals' confidence in the design.

10 MR. EBERSOLE: Some long time ago we were
11 looking at the single failure criterion in the context
12 of its value for preventing spurious trips, not just for
13 a safety function but for preserving continuity of
14 operation.

15 In reviewing the peripheral safety question
16 that it's better to have a safely running plant than to
17 throw it into shutdown, we didn't get very far with the
18 operating people to invoke coincidence requirements for
19 tripping functions. As a result, many of the plants
20 have places where you can find touch points. I'm sure
21 yours is no exception. You can go up and hit it with a
22 broom, and you can trip it out.

23 Do you ever look over the plant for such
24 operational weaknesses in this context and maybe provoke
25 a few arguments here and there sometimes that you'd

1 rather not have those weak points?

2 MR. COTTLE: Yes, sir, we do. As you may be
3 aware, we have made some significant changes on
4 secondary plant originated trips at the Sequoyah unit.
5 We're following those up at the Watts Bar unit with the
6 same type of changes.

7 We have identified, for example, a single
8 control fuse on the full flow condensate polishing unit
9 at Sequoyah where blowing a single fuse gives you a
10 trip. I proved that twice. We had two unit trips. We
11 don't have the same condition today, and we are
12 continually looking for that, both from the standpoint
13 of challenging the safety systems and from the
14 standpoint of good engineering practice and economics.

15 MR. EBERSOLE: What kind of staff do you have
16 that are running this sort of thing down?

17 MR. COTTLE: It would be a combination of the
18 engineering positions of the station, primarily those
19 assigned both to the engineering results group and that
20 engineering support that's assigned to the maintenance
21 group.

22 MR. EBERSOLE: Do you pump any out of
23 Knoxville?

24 MR. COTTLE: Yes.

25 MR. EBERSOLE: Do you have them looking at

1 that?

2 MR. COTTLE: In Knoxville we don't have a
3 formal program, and maybe someone else can maybe give me
4 some help on this. We don't have a formal program.
5 There have been several instances when I was primarily
6 involved at Sequoyah that there was a motivating factor
7 and those types of items came out as a result of
8 engineering results.

9 MR. EBERSOLE: Have you done anything with the
10 turbine generator, the point at which the safety and
11 nonsafety systems merge, a trip results in a
12 multi-channel trip by necessity, so what you really have
13 is contact multiplication at the head; and a hydrometer
14 trip or something like that in a single configuration
15 can easily spuriously cut you off.

16 MR. COTTLE: Most of the improvements we've
17 made along these lines have not been directly associated
18 with the turbine. They've been more associated at this
19 point in time with like inputs into the turbine trips,
20 seal water injection function on main feedwater pumps,
21 loss of both main feedwater pumps which gives the
22 turbine trip. We're still one stage below basically
23 looking at that.

24 MR. EBERSOLE: I see.

25 MR. SHEWMON: Does that bring your discussion

1 to an end?

2 MR. COTTLE: Yes, sir, it does.

3 MR. MOELLER: Could I ask a question? You
4 have a person who is chief of industrial and
5 radiological hygiene branch that handles radiation
6 protection. Can you tell me his or her qualifications?

7 MR. COTTLE: No, sir, I can't right at the
8 moment. I can certainly get it for you. We were in the
9 process of accomplishing a reorganization in the area of
10 radiological hygiene. Previous to this time most of the
11 responsibility and direction of our in plant health
12 physics dosimetry/dose assessment program had been
13 handled out of Mussel Shoals, out of our department of
14 radiology. We transfer most of our functions into
15 Chattanooga now.

16 MR. MOELLER: Could you tell me the
17 qualifications of the top radiation protection program
18 at the plant site?

19 MR. COTTLE: I can give you a basic outline of
20 our plant health physicist's background. I don't have
21 the details with me right now.

22 MR. SHEWMON: Would you get it before the day
23 is over?

24 MR. COTTLE: Yes, sir.

25 MR. SHEWMON: Thank you.

1 Any other questions?

2 MR. EBERSOLE: Thank you, Mr. Cottle.

3 Our next topic before our break is TVA nuclear
4 safety review staff function by Mr. Harrison Culver.

5 MR. CULVER: I am Harrison Culver, the
6 director of the nuclear safety review staff.

7 Following TMI, TVA established a task force to
8 identify actions that could be taken to further
9 strengthen and improve their overall nuclear programs.
10 As an outgrowth of that study, a report was prepared,
11 and a number of actions were identified that related to
12 design changes in the operating organization, changes in
13 the design organization. And the one action that I want
14 to talk about is the action to create the TVA nuclear
15 safety review staff.

16 What I want to do today is to give you some
17 idea about what our group is all about, the things that
18 we have been doing, and the direction we intend to go in
19 in the future.

20 (Slide.)

21 I believe you all got a handout, so please
22 don't fail to look at your handouts.

23 The basic functions of our staff is shown on
24 this first vu-graph. In this vu-graph you can see that
25 the staff that I direct does have an involvement with

1 all aspects of the TVA nuclear program. We do get
2 involved to some extent at looking at design,
3 construction, operations, training, emergency
4 preparedness programs and the health physics program.
5 We get involved with some of the operational events at
6 the site, we get involved with making investigations,
7 and we also get involved with a program where we look at
8 employee concerns.

9 Now, as I get into my descriptions, I will be
10 able to show how we have managed to touch upon a number
11 of these items.

12 (Slide.)

13 As a point of clarification, I would like to
14 make sure that it's understood that our group does not
15 replace the functions that exist within the line
16 organizations. From time to time people like to think
17 that we get involved with all the details at TVA, and
18 obviously when you see the number of people I've got,
19 it's not possible to get involved with all the details.

20 So the key thing, our function is really to
21 monitor the overall activities at TVA, not to replace
22 the things that are assigned to the line organizations.
23 In some respects we are similar to the functions of the
24 I&E people or the NRR people. They look at certain
25 aspects of the design, they look at certain aspects of

1 the operation, and most of this is done on a sampling
2 program or on an audit basis.

3 Now, in order to do these things, when I
4 joined the staff we had built up our staff. I believe
5 when I joined the group in January of 1980 we had about
6 seven technical people. During the past two, two and a
7 half years we have increased our staff to the point
8 where now we have roughly 21 technical people.

9 Now, in building up the staff the two
10 objectives I had were to try to get as much independence
11 in our group as I could so that we could in fact go out
12 and look at the operations of TVA and make impartial
13 viewpoints on these things. At the same time, we
14 attempted to create a staff that was pretty much senior
15 level, people with a wide variety of backgrounds so that
16 we could in fact get involved with these issues.

17 As you can see from the vu-graph, I think we
18 were fairly successful. More than half of our staff has
19 come from the outside of TVA. We have had people come
20 from DOE and NRC. Primarily these people were involved
21 with either the safety review or audit activities. We
22 have had people come from other utilities where the
23 intent was to bring in different perspectives from how
24 other people do things. At the same time, we attempted
25 to maintain some people from the TVA system, since we

1 felt like it was important that we have people who
2 understood the system within TVA, and we tried to get
3 people out of the major parts of the system.

4 As you can see in that upper righthand corner,
5 we have had some people from design, some people from
6 the construction organization, some from the nuke power
7 division, and one individual from the public safety.

8 Now I have given you some indication of our
9 experience by indicating the distribution of our
10 people. It comes out to be, we have an overall average
11 of about 15 years of nuclear experience in our staff.

12 In that bottom set of data I indicate where
13 that experience primarily lies. Mainly because of the
14 emphasis that we have placed upon the audit and safety
15 review function, we do have people who are more oriented
16 towards the regulatory audit background as well as from
17 the operations aspect. We have enough people to look at
18 design and construction, and in those areas we have a
19 smaller amount of background.

20 (Slide.)

21 I would like to amplify a little bit now about
22 what we do. We make basically two types of reviews. We
23 make either what we call management reviews, which are
24 rather broad types of reviews, and we also make rather
25 specialized types of reviews which are on perhaps one

1 specific area, and these are much more detailed.

2 In the past two and a half years this will
3 give you some indication of the types of things we've
4 gotten involved with. It also indicates the types of
5 subjects. In the first group I have indicated our
6 management reviews. I will say some more about these in
7 my next vu-graphs.

8 In our management reviews we have basically
9 gone in and looked at the entire part of the
10 organization to see how that organization is set up to
11 function. In the first grouping I've indicated that we
12 have in fact in the past two and a half years looked at
13 the office of power in one of these reviews. We made
14 two reviews in the office of engineering design
15 construction where we looked at both the design process
16 and the construction process. As a part of that we also
17 had a review of the purchasing part of the organization
18 so that we could in fact look at both the controls that
19 were established by TVA in design, as well as their
20 interface with purchasing.

21 We had two specialized types of management
22 reviews, one that dealt in security and the other that
23 dealt with the quality assurance program. When we
24 reviewed the office of power, because of the integral
25 tieup between power and the health physics function, we

1 also as a part of that review made an examination of the
2 office of health and safety.

3 Now, in the next group where I talk about
4 specialized types of reviews, these were mostly reviews
5 that we did in the early part of 1980 before our staff
6 had attained the level of size that we have today. Most
7 of these were rather limited types of reviews in very
8 specialized areas.

9 From that you can see that we made more
10 reviews of operations than we did of design and
11 construction. The primary reason we did that is that at
12 that point in time most of our experience was in that
13 area.

14 There was also a time period where we wanted
15 to look at what was going on at Browns Ferry and
16 Sequoyah.

17 MR. EBERSOLE: Before you take that down,
18 there are some interesting characteristics about the
19 design construction bullet lists there. I look at it
20 and of the sets you have I see one that I guess I can
21 associate, rather materialistic looks at physical
22 features of the plant.

23 As you well know -- I know your past history,
24 and I see evidence there of why that's there and others
25 are not.

1 MR. CULVER: Part of that is because of our
2 philosophy of what we're really trying to do.

3 MR. EBERSOLE: Would you, as a case in point
4 -- I remember some issues in the earlier plants where we
5 were having difficulty ascertaining that the purge
6 valves for the containment probably wouldn't work and
7 that had to be investigated. The main steam isolation
8 valves also probably would not work without certain
9 stroke effects.

10 Do you get involved in assessment of the
11 detailed mechanical aspects of such matters as that?

12 MR. CULVER: We have only to a limited degree
13 up to this point.

14 MR. EBERSOLE: Do you anticipate extending
15 your scope up into these matters?

16 MR. CULVER: I'll get to that a little bit
17 later.

18 MR. EBERSOLE: Okay.

19 MR. CULVER: When I get through with telling
20 you about what we do now, I'll get into that a little
21 bit more.

22 MR. CARBON: Mr. Culver, before you leave
23 that, unless you are going to discuss it later, a
24 question about your review of the division of
25 purchasing. Was that heavily directed at such things as

1 being sure that the procedures that purchasing followed
2 would ensure that you were getting the equipment to the
3 right specifications, that nothing was falling between
4 the cracks, or what was the real aim there?

5 MR. CULVER: The basic concern we had or what
6 we were really looking for is that you come out of
7 design with a certain design intent. What we were
8 really looking for were controls that were imposed on
9 the whole process to make sure that you actually ended
10 up going to the vendors with the right information, and
11 then when things came back that you got what you had
12 ordered.

13 That whole thing, well, our whole review of
14 the design process, the construction process is really
15 directed towards examining the programs to see if in
16 fact a program exists and that it is in fact followed so
17 that you will end up getting what you hoped to get.

18 Now, to get into it a little bit, as I show
19 you the vu-graphs I'll show you that.

20 MR. CARBON: My second question, have you
21 developed this review system strictly within TVA, or has
22 it come about in considerable part working with other
23 organizations or INPO or someone, or is it pretty much
24 totally independent?

25 MR. CULVER: I guess a fair way to say it is

1 when I initially got started in this I, of course, had
2 my own ideas from my own background where I had been
3 involved with the review business for some years back in
4 AEC and DOE. At the same time, when I arrived on my new
5 job I felt fortunate to have some people who had come
6 from NRC who had already begun to do some of these
7 things. So I relied very heavily on both some of the
8 information that they had obtained while working within
9 NRC, and I had one individual in particular who had been
10 working on setting up a system of what they called their
11 PAT, P-A.T. Basically, that was a program where they
12 were going to go in and look at performance evaluations.

13 I can show you -- in fact, my next vu-graph, I
14 think, shows you what we came up with.

15 (Slide.)

16 This particular slide here demonstrates the
17 process that we go through. It really had its beginning
18 in the NRC. Of course, I am a firm believer if someone
19 has developed that looks pretty good, you might as well
20 use it.

21 This really came out of some of the work that
22 was being done in I guess it was I&E in Washington. One
23 of the gentleman that was on my staff, Morris Englewood,
24 worked on this when he was up here in Washington. We
25 basically in principle use this type of a management

1 evaluation tree when we go in and look at, for example,
2 the office of power or the office of engineering design
3 and construction.

4 We basically look at, first of all, do they
5 have a program in place to accomplish the functions that
6 we are talking about, and there are a specific number of
7 things we look at. We look both at that program all the
8 way from the top level, the corporate level all the way
9 down to the site. That is the left branch of the tree.

10 Now, when we look at programs we're really
11 looking at the adequacy of the program as measured
12 against regulatory requirements, commitments you may
13 have in the safety analysis which may eventually get you
14 back to the ASME code standards and what not.

15 We look to see if the program is fair, if the
16 program is adequate. We look to see, beyond that, was
17 it being implemented. These other two merely indicate
18 that as you are doing this, you really like to make sure
19 that the people who have to conduct the program are in
20 fact aware of the program. As a part of that, you have
21 to get involved with looking at qualification and
22 training of people.

23 We have basically followed that system in all
24 of our major reviews. In doing that we basically look
25 at each of these functional areas.

1 (Slide.)

2 That is a vu-graph I put together when we
3 talked about OECD. The functional areas are basically
4 the same when we looked at operations. When we go out
5 and look at these reviews, we will in fact look at each
6 of these functional areas. We have a review report that
7 addresses each of these areas. By the nature of that
8 these reviews are very time consuming, and we spend a
9 lot of time on those reviews.

10 Before we go out on the review, for example,
11 we may spend up to -- we spend a lot of time just on the
12 initial review in just pointing out the review and
13 figuring out exactly what we want to look at in each of
14 these areas.

15 Before we go out and review we in fact have in
16 our group all the procedures, administrative controls,
17 and our people will actually go through those so that
18 we're very familiar with them before we go out to make
19 the review.

20 We do that for two reasons. One is that you
21 really have a background to make a meaningful review,
22 and you need that to minimize the impact on the people
23 you are reviewing.

24 So we do in fact do that, and then we will
25 issue a report on it.

1 MR. EBERSOLE: Can I ask a question? In the
2 time phasing of your activity you had an active role in
3 trying to unsnarl this terrible matter of the QA
4 program. Could you comment on your activities in that
5 period of time when you straightened out the
6 administrative disabilities present at that time?

7 We will have that as a separate topic, but I
8 thought while you were up here you could make a comment
9 on it.

10 MR. CULVER: We did get involved in looking at
11 QA. I guess that came about about a year and a half
12 ago. It came about after, I believe it was after one of
13 the SALP reports came into TVA, and the general manager
14 asked us to specifically look at TVA.

15 The truth of the matter is, and I pointed it
16 out to him, in a sense we had been looking at QA as a
17 part of looking at the overall organization, because
18 when we go in and look at these functional areas, we not
19 only look to see what the line organization is doing, we
20 also look to see what the QA organization is doing.

21 So we had a head start on that, but we then
22 issued a report which specifically dealt with QA. It
23 dealt with things beyond these functional areas here.
24 We drew very heavily upon our reviews that we had
25 already made, but in our QA report we looked at such

1 things as how the QA organization was in fact
2 organized: the areas we had addressed, the degree of
3 fragmentation, the fact that the individual QA units
4 were in different places in TVA.

5 MR. SHEWMON: You've about taken up your
6 twenty minutes. Could you get on with it?

7 (Slide.)

8 MR. CULVER: Let me just show one more slide.
9 In the other session people were interested in well,
10 what are we going to be doing in the future. What I've
11 shown here, I'll just quickly indicate that as we get
12 more and more out of the types of reviews we have been
13 making, we will be getting more involved with these
14 types of activities which are more directed toward more
15 fundamental issues.

16 This happened to be a slide I pulled together
17 really from my budget, and this is the basic breakdown
18 on our activities.

19 MR. ETHERINGTON: All of your people are
20 located at TVA headquarters?

21 MR. CULVER: All of my people are in
22 Knoxville, yes.

23 In my handout I indicated how we handle our
24 reports and our dealings with the general manager and
25 the board, which is, I think, an important part of our

1 program.

2 MR. EBERSOLE: Questions for Mr. Culver?

3 (No response.)

4 MR. EBERSOLE: Ten minutes we have scheduled.

5 We will have a break, Mr. Chairman. A pretty short
6 recess.

7 (Recess.)

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. SHEWMON: Jeff, I am told that the TVA
2 people have the information on the qualifications of the
3 health physicists, so we can take that first.

4 MR. EBERSOLE: If you don't mind.

5 MR. SHEWMON: Can we please quiet things
6 down.

7 Go ahead.

8 MR. COTTLE: The plant superintendent, Mr.
9 Ralph Beck, is my health physics supervisor at the
10 station. If I can just briefly cover Mr. Beck's
11 background. He has four years experience in the nuclear
12 navy program as an engineering laboratory technician in
13 the navy chemistry health physics aspect; two years
14 experience in the navy shipyard as a shift supervisor,
15 refueling and overhaul, outages; seven years experience
16 in the naval shipyard as a lead technician on
17 callibration and dosimetry aspects of the health physics
18 program; and then six years experience with William and
19 Mary College as a health physics technician and a lead
20 health physicists for their space radiation effects
21 laboratory that they were conducting under the direction
22 of the NASA program.

23 He has been with TVA for three years,
24 primarily at the Watts Bar nuclear plant. And he is
25 currently participating in the activities down at

1 Sequoyah and will participate during the portion of the
2 refueling outages.

3 MR. MOELLER: Thank you. That's good.

4 MR. SHEWMON: No question on level of
5 certification?

6 MR. MOELLER: I'm sure he's working on it.

7 MR. EBERSOLE: You might notice by the length
8 of time, at least I regard this as a major topic, the
9 refueling problem. Certainly I am apprehensive to see
10 this enormous flow of deficiency reports and recognize
11 it's a continuing problem and will be throughout the
12 remainder of the system.

13 To me it's the most significant topic we have
14 on the board.

15 MR. BEASLEY: My name is Greg Beasley. I am
16 manager of quality assurance for TVA's Office of Design
17 and Construction.

18 Frequently throughout the presentation, I may
19 refer to OEDC. That's the acronym for TVA's Office of
20 Engineering Design and Construction.

21 I would first like to talk about the
22 identified problems in quality assurance. Prior to 1980
23 we did not identify any significant or unusual quality
24 assurance problems in the design and construction
25 program at Watts Bar. We did have the usual number

1 nonconformances, the usual noncompliances that were
2 identified there.

3 During the 1980 time frame, our QA problems
4 came to light. 1981, 1982, there were several major
5 problems related to quality that arose. One of the
6 first that arose concerned our heating and ventilating
7 systems.

8 In January 1980, a routine quality assurance
9 audit found that some aspects of the safety-related
10 heating, ventilating and air conditioning systems were
11 being installed without having a QA program over the
12 installation. There was corrective action, which
13 extended over a period of approximately six months.

14 Work was then resumed with a later
15 identification for more corrective action, and after a
16 period of about a year there was a confirmation of
17 action letter from Region II, and subsequent to that we
18 had a stop work order on this order which lasted for
19 several months. And after about 18 months after the
20 identification, we got the program back on track and
21 work was totally resumed on that and had the corrective
22 action implementation which has continued up until this
23 time.

24 On the identification of problems, one of the
25 second problems was a series of welding and weld

1 inspection problems that arose. This problem was not
2 unique to the Watts Bar site. There was a task force
3 that addressed these generically for all TVA plants
4 under construction.

5 There were some problems that were identified
6 relative to the transfer process where we transfer
7 systems and equipment from the construction organization
8 to the operating organization. And in one of these
9 processes while a system was being transferred, we were
10 using some of the safety-related equipment to provide
11 flushing water, and in the course of this one of the
12 safety-related pumps was destroyed.

13 We did not have adequate control over that
14 situation in the transfer process and the use of this.
15 So there was corrective action in that area.

16 We also found we had a fairly large number of
17 problems with our quality records. We did not have them
18 all together. We did not have the traceability to trace
19 some of the inspections through from front to back. We
20 still have corrective action going on in that particular
21 area.

22 Now, these are four major things which we
23 identified which concerned us and which have gotten very
24 high visibility relative to our quality assurance
25 program. There is another factor which came into this,

1 although not directly. In the 1981-1982 time frame, we
2 had extremely low morale at our construction project.
3 We had some major management changes there and we had a
4 significant manpower turnover. While this is not
5 directly related to quality, it does affect it. It does
6 affect traceability of records. It does address
7 application and use procedures.

8 Now, all these things put together indicates
9 that we just generally have a problem of management
10 control with our quality. It is a serious problem. We
11 have treated it very seriously. It has gotten high
12 visibility, which we think is proper.

13 But we feel at this time we have identified
14 our own problems and we have our corrective action
15 moving, although it has been slow and difficult to get
16 it moving.

17 I would just now like to address the steps we
18 have taken to correct this problem. As the usual case,
19 each identified deficiency or inadequacy has had its
20 individual corrective action, and appropriate previous
21 work has been reviewed to be sure that the previous work
22 was adequate.

23 We have had numerous changes in our quality
24 assurance procedures. Some of the procedures were
25 expanded and broken down into a series of procedures.

1 Some of the procedures were made more definitive with
2 the new requirements put in them. Some procedures have
3 additional acceptance criteria.

4 Now, all of this work in the quality area --
5 the procedure changes, the looking at the deficiencies,
6 and the looking back at the previous work -- has
7 resulted in a lot of review, a lot of manpower, and much
8 more documentation.

9 In some cases we have actually zeroed our
10 records. That is, we just started over: total
11 reinspection, total new inspection records on pipe
12 location, pipe hangers. We actually went through this
13 process and went back to the plant and relocated
14 dimensionally all of the pipes, so that we had it right
15 to start with.

16 Now, the rework and the reinspection has
17 resulted in a very large number of nonconformances.
18 Many of these we did determine to be significant on an
19 individual basis. We feel like we have a good program
20 of identifying nonconformances and we have a good low
21 threshold so that the problems do get identified.

22 On the current status of the quality program,
23 we in the OEDC management feel like we have our quality
24 assurance program back on track. We have some
25 corrective action which we are still in the process of

1 defining. We have even more corrective action where the
2 implementation is not complete. In some cases we are
3 reviewing tens of thousands of records, and this takes a
4 long time to go through and take and see that we have
5 each record and it was properly signed off, and this is
6 being done through an accountability program.

7 On the current status, one item was disturbing
8 to us. Just recently, just within the past few weeks,
9 we discovered a breakdown in some of our seismic
10 analysis work. The corrective action for that is in the
11 process of being determined and being implemented. This
12 deficiency was defined on nonconformance reports by our
13 line organization and it was duly reported to Region
14 II.

15 In addition to the work on each individual
16 deficiency, in looking back at our program about a year
17 ago we became concerned that we may not be getting back
18 to our root causes. So we instituted a study to
19 determine what our root causes were for our quality
20 program. This was for all of OEDC, not just for the
21 Watts Bar plant.

22 We went through and identified some very basic
23 root causes and set about a program to correct those.
24 Just for information, some of the root causes concerned
25 attitude and approach towards our quality program. We

1 have had corrective action in this area. We have given
2 the quality program much more attention and visibility
3 by our top management, and we feel we have seen a
4 turn-around in this attitude and approach to quality.

5 We found that in some cases a lack of
6 definition of authority and responsibility had affected
7 our program, and not holding people accountable for
8 their responsibilities was affecting it. Timeliness was
9 a big factor in the response to this corrective action.
10 We think this is a major thing. We think this is a very
11 difficult problem to deal with, but we felt that more
12 timely corrective action was important.

13 As I mentioned, in our procedures we found
14 that 50 percent of all our deficiencies had their root
15 cause in procedures, either the people not following the
16 procedure or the procedure was not adequately
17 interpreted, or we didn't have a procedure that
18 correctly covered this.

19 So we have had a massive program going on on
20 procedures. All of these root causes are being
21 addressed across the office program. And while some of
22 them we will not complete the action until the end of
23 the year, we feel we have seen some changes in that.
24 And of course, some of these are going to result in
25 further change which will extend out into 1983 or even

1 further.

2 One of the major concerns when you have a
3 quality assurance problem such as we have had at Watts
4 Bar is, have you found all the things that went wrong,
5 all the things that were not done correctly, all of the
6 deficiencies? This is of paramount concern in OEDC. I
7 think this is one of the concerns of our top management,
8 one of the concerns of Region II.

9 We in OEDC feel like we have basically
10 accomplished going out and ferreting out our problems.
11 There will be more NCR's as we go through the program,
12 but we don't feel that we have those in the program like
13 occurred in the 1982-83 time frame.

14 Now, as Mr. Culver mentioned, one of the
15 things that they had done is made two management reviews
16 of OEDC, one on the Bellefont project and one on the
17 Watts Bar project. The one on Watts Bar was recently
18 completed. They have a number of findings against OEDC,
19 some of them against the design program, some of them
20 against the construction program, and some of them
21 against the quality program.

22 We are addressing each one of these findings
23 and forwarding that back to the nuclear safety review
24 staff and we will resolve these internally. We are in
25 the process of getting the NSRS report and there are

1 responses we're making back to the findings they've had
2 forwarded to Region II and to NRR.

3 Now, as I said the NSRS review of Watts Bar
4 had a number of findings. We are instituting corrective
5 action for those. They are continuing concerns. We in
6 OEDC did not pick up any major new quality issues there
7 and we did not conclude that we had not covered --
8 failed to find all the holes in our program.

9 Now, as part of this review of the Watts Bar
10 program, NSRS did make a recommendation for a further
11 independent review, a further independent review being
12 for the purpose of assuring TVA management that Watts
13 Bar has been designed and constructed in accordance with
14 the requirements.

15 Now, in some meetings with Region II,
16 specifically a meeting at the site back on February the
17 18th, a meeting with NRR where Region II was present,
18 and in a routine inspection in Knoxville in late June,
19 in all three of these meetings Region II recommended
20 further independent verification that the plant had been
21 constructed in accordance with design.

22 Now, we in OEDC are in the process of
23 arranging for this independent review. It will be done
24 by an independent organization, that is an organization
25 outside TVA, an organization that does not have a major

1 dependence upon TVA for their resources. The objective
2 of this independent review will be to enable TVA, TVA
3 top management, to reach a conclusion that Watts Bar has
4 been designed and constructed in accordance with the
5 license application and the license commitments.

6 The review by this independent organization
7 will be available to NRC -- their findings, their work
8 -- without any sanitization by TVA. The review will be,
9 as Mr. Ebersole mentioned, a vertical slice. It will be
10 on some safety-related feature and it will be broad
11 enough to cover most of the disciplines that go into the
12 design of the system -- the mechanical, the fluid
13 discipline, the electrical and control discipline, the
14 structural, seismic. And it will have some interfaces
15 with the other programs, like our NSSS.

16 This independent reviewer will basically look
17 at the development of the design details, will look at
18 the calculations and analyses that are necessary to
19 support these design details, and in the development of
20 the information that is given to the Division of
21 Construction to construct the plant. They will also
22 look at the construction up to the point of the transfer
23 of the systems and equipment to the operations
24 organization.

25 The independent review will recognize the

1 vintage of some of the requirements. It was mentioned
2 earlier that our construction permit dates back to early
3 1973. We've been at it for about 9-1/2 years. So some
4 of the requirements are vintage requirements and the
5 review will recognize that, that we will not be
6 reviewing against the current state of the art in
7 regulation.

8 Now, from this review we anticipate that our
9 TVA corporate management will be able to look at that,
10 to look at the NSRS reviews that have been made of our
11 program, plus the internal reviews that we have had, to
12 reach satisfactory conclusions relative to Watts Bar.

13 I would like to briefly compare the quality
14 program and the quality situation at Watts Bar with that
15 of our other TVA plants. Except for the cases that I
16 mentioned earlier and some related cases, we find no
17 reason to think that Watts Bar is significantly
18 different from our other nuclear plants. Specifically,
19 the heating and vent problem was unique to Watts Bar.

20 The morale factor -- well, morale was
21 difficult to judge and be objective about, and we can't
22 quantify it, but we feel that the morale problem was
23 basically unique to Watts Bar and much of our management
24 control was there.

25 Some of the root causes, as I mentioned, were

1 program-wide, but overall we didn't find Watts Bar being
2 that different. Also, we did a detailed comparison of
3 our NSRS report on Belefont to our comparison of the
4 report on Watts Bar. Of course, there were some things
5 that had happened in the time period between those. And
6 we didn't find anything in the NSRS report that made
7 Watts Bar significantly different from our Belefont
8 plant.

9 We have had a very large number of
10 nonconformance reports. As I mentioned, we feel we have
11 a low threshold for this. And in rectifying some of
12 these problems that we have had, we have issued a large
13 number of NCR's. With respect to one bulletin, there
14 was something in the range of 50 or 60. I believe there
15 were over 70 NCR's written relative to the heating,
16 ventilating and air conditioning problem getting it back
17 on track.

18 MR. KERR: What do you mean by having a low
19 threshold for them?

20 MR. BEASLEY: A situation comes up and you can
21 write an NCR for this and make it significant, and it
22 gets reviewed by management and gets reportable. We
23 find that we report things, that we have a low threshold
24 for making items significant and making them
25 reportable. This is part of our TVA policy.

1 MR. KERR: I heard the use of the term "low
2 threshold." I don't know what it means. How do you
3 judge a low threshold?

4 MR. BEASLEY: Well, I think by just taking and
5 comparing what we report from what we see reported on
6 other plants, other TVA plants and other
7 organizations'.

8 MR. SIESS: That doesn't prove anything. You
9 might just be doing a poorer job than anybody else.

10 MR. BEASLEY: Well, the point is that we don't
11 feel that comparing numbers of NCR's is a valid basis
12 for comparison at the plant.

13 MR. EBERSOLE: I take it you mean you report
14 items that might be considered marginal?

15 MR. BEASLEY: That's correct. If it's
16 marginal we compare it.

17 MR. SIESS: Marginal by whom, and in
18 comparison to what? Could you give us an example of an
19 NCR that you think probably wouldn't be reported by
20 someone else?

21 MR. BEASLEY: I don't have any specific
22 examples in mind. I can probably think of one. If you
23 look at the bases for reportability, the use of the word
24 "significant," it is used several times. In one
25 person's judgment it may not be significant; in another

1 person's judgment it is.

2 We have had problems, and the point I was
3 trying to make was that we don't consider the number of
4 NCR's important. We consider the problems we have with
5 the program what was important, and we did have
6 problems, there was no question there.

7 MR. KERR: Well, I could convince myself that
8 a large number of NCR's were good. It means that people
9 who are responsible are on their toes. Do you look at
10 NCR's as bad?

11 MR. BEASLEY: No, sir, I don't. Well, they're
12 good and bad. If you have problems they're bad, but
13 it's good when you confess them and report them.

14 MR. KERR: I like that language. It sounds
15 like you've got religion.

16 (Laughter.)

17 MR. BEASLEY: We have been approaching our
18 quality program with a religious approach. We feel that
19 it has to be something instilled. Our manager of our
20 office has repeatedly told our office that in the
21 quality program everybody has to believe in it,
22 everybody has to carry it out.

23 It's just like he refers to industrial
24 safety. You can have -- a few people can foul it up.
25 So we've been trying to get everybody on board.

1 MR. EBERSOLE: Would you say the number of
2 these reports reflects the intensity of the review
3 process?

4 MR. BEASLEY: I think that's fair, yes.

5 MR. SIESS: Well, I don't quite understand. I
6 guess one way I could look at it, a large number of
7 NCR's would indicate you have a very effective QC/QA
8 program.

9 MR. BEASLEY: Yes.

10 MR. SIESS: It might also indicate you have a
11 lousy construction program. If there have been a lot of
12 nonconformances, deficiencies in construction, I guess
13 even a poor QA program could pick up a lot of NCR's.

14 MR. BEASLEY: That's correct.

15 MR. SIESS: So it's a relative thing, and I
16 don't see how you could draw any conclusion regarding
17 quality of the plant as opposed to the quality of the QA
18 program from the number of NCR's.

19 Could you give us an example of, one or two
20 examples of the actual deficiencies in design or
21 construction that have been discovered at the Watts Bar
22 plant?

23 MR. EBERSOLE: Let me offer one. The one that
24 struck me as being particularly bad was the progressive
25 installation of hangers on embedded plants up to,

1 evidently, far beyond their ultimate carrying loads,
2 with no integration of the loads as they proceeded
3 compared against the ultimate strength.

4 MR. SIESS: These are the steel plates cast
5 into the walls for attaching things to? They have those
6 at Watts Bar?

7 MR. BEASLEY: Yes.

8 MR. EBERSOLE: People were hanging things on
9 these indiscriminately. There was no definition of the
10 ultimate hanger load that could be put on them. I
11 wondered when I read it, is there any real knowledge as
12 to how many embedment tie rods there are back in the
13 concrete which really maintain the security of the
14 concrete.

15 MR. SIESS: If that's not shown on the
16 drawing, that's a more serious deficiency than you
17 cite.

18 MR. EBERSOLE: My question is, even though
19 they're shown on the drawings, do these exist in fact?

20 MR. SIESS: On one of the plants they use
21 bolts, and you can see them on the other side of the
22 wall.

23 MR. EBERSOLE: That's good evidence.

24 MR. WARD: Was that an example of a low
25 threshold?

1 MR. EBERSOLE: I thought this wasn't a low
2 threshold. I thought it was a high threshold.

3 Can you give us another good example?

4 MR. BEASLEY: I think that's a good example.
5 Larry?

6 MR. MILLS: We might have a couple of examples
7 here. John Faulston might have a couple of examples on
8 the NCR's, where we think we have a rather low threshold
9 type item.

10 MR. BEASLEY: By way of introduction while
11 he's getting the mike, John Raulston is the chief
12 nuclear engineer for the Division of Design, and his
13 organization handles the actual reporting of these items
14 to Region II.

15 MR. RAULSTON: I guess one of the classic
16 examples of an NCR, that I don't know whether it was
17 reported or not but it was deemed significant, was where
18 we had written an earlier NCR and in the corrective
19 action defined certain milestones that had to be met and
20 we failed to meet one of those milestones by, I believe
21 it was, two days, and we wrote an NCR on that failure to
22 meet the milestone and deemed that one to be
23 significant, which meant it was evaluated for
24 reportability.

25 I kind of feel that's a low threshold of a

1 writing of an NCR. But that's a fairly common practice
2 in the design organization. I've talked to other
3 architect-engineer firms on the subject and I think by
4 comparison with their programs I think ours is quite
5 good and we have a low threshold.

6 MR. SHEWMON: Fine. Go on.

7 MR. BEASLEY: When we had --

8 MR. SIESS: Let me follow up just a minute on
9 the example that Mr. Ebersole gave me. Can anyone tell
10 me whether they have followed up on that problem and
11 found instances where the integrity of those anchors are
12 actually deficient because of that practice? I admit it
13 was a bad practice. I'm wondering now whether it led to
14 a safety issue.

15 MR. BEASLEY: Ralph Pierce, the OEDC manager
16 for the Watts Bar project. He's manager over design and
17 construction. He might want to respond.

18 MR. PIERCE: We have made a follow-up on all
19 of the embedded plates. We are looking at the loadings
20 on the embedded plates, and we have looked at some of
21 the worst loadings that we had and did a sampling, and I
22 think the number was 60 of the worst cases of embedded
23 plates.

24 And we found only one plate that was
25 marginally overloaded in this whole review, and this was

1 reported to OI&E in Atlanta, and that's all we found in
2 this review. We are continuing with the program of
3 better keeping up with the loading on embedded plates.

4 MR. SIESS: Thank you.

5 MR. EBERSOLE: May I ask a question in this
6 connection? When you're dealing with something like
7 that, there are two areas I find difficulty imagining
8 how you proceed. Do you take it for granted that what
9 you saw in the construction drawing was actually
10 realized, that the embedment was not just a solid steel
11 plate but it had other attachments thereto and those
12 were in fact put on?

13 MR. PIERCE: Yes. We have our documentation
14 program on the construction site, which we have the QA
15 records, the accountability records of these inspections
16 of the embedments: the number of studs that were on
17 this, that they did meet the design requirements, that
18 they are in that location and that these records are
19 complete.

20 MR. EBERSOLE: You have the records of the
21 embedments?

22 MR. PIERCE: We have paper records of
23 everything.

24 MR. EBERSOLE: The other question is, if I
25 have a highly responsible weld, perhaps in the raw

1 service water system, and I don't have any paper on it,
2 how in the world do I accommodate myself to this
3 situation, knowing that the quality of that weld is
4 procedurally independent and there's no way to test
5 whether it's any good or not?

6 MR. PIERCE: Are you saying a
7 pressure-retaining weld?

8 MR. EBERSOLE: Yes.

9 MR. PIERCE: Are you talking about ASME
10 Section 3? We have all these records on the inspection
11 of these?

12 MR. EBERSOLE: You don't have any problem with
13 other structural members other than piping?

14 MR. PIERCE: Structural members?

15 MR. EBERSOLE: Yes. Do you have adequate weld
16 records on all of those?

17 MR. PIERCE: Yes, we do. Cable tray supports,
18 you name it, hangers; we have complete records on it.
19 Documentation right now on Watts Bar amounts to
20 something like 360,000 separate records.

21 MR. EBERSOLE: Thank you.

22 MR. MOELLER: Excuse me. You have of course
23 told about your QA program and the problems and your
24 efforts to correct them. Now, I understand that INPO is
25 reviewing or has reviewed your QA program. Is their

1 report out?

2 MR. BEASLEY: INPO has a new organization
3 looking at design and construction which is in the
4 process. TVA is participating in and supporting that
5 program. We have had some people working with the
6 steering policy group on that. We had people working
7 with INPO in setting up the criteria by which they
8 evaluate, and we have had two people spending full time
9 in the evaluation team.

10 The brackets for the INPO reviews cover plants
11 that are at least 20 percent and not yet up to the 80
12 percent point. Watts Bar we figure is too far along to
13 go through the INPO review. It's mainly looking at and
14 evaluating the program.

15 We are doing a self-evaluation on our Belefont
16 plant. But the program we have with ourselves, with the
17 nuclear safety review staff and with the independent
18 review, we think will be better than going through the
19 INPO evaluation.

20 MR. MOELLER: Well, the SER prepared by the
21 Staff says at the top of page 1-6: "The Applicant has
22 proposed to have INPO perform an independent audit of
23 Watts Bar design and construction program before fuel
24 loading. The Staff has not yet determined the
25 acceptability of this proposal."

1 That doesn't --

2 MR. BEASLEY: I'm sorry, I can't address
3 that.

4 MR. PAULSTON: This is John Raulston.

5 I think that refers to about an April 26th
6 meeting we had with the Staff, where at that time we
7 were suggesting that perhaps the INPO review program
8 would be a suitable type of review to do on the Watts
9 Bar units. We have since, in discussions with INPO,
10 decided that that was not appropriate.

11 MR. MOELLER: Well, again on page 1-11 in the
12 SER, where it has "Summary of principal review matters,"
13 it says that -- well, it says: "TVA's QA program for
14 the operation of the facility is a principal review
15 matter." But I guess it doesn't say there that you are
16 depending on INPO.

17 So the SER on 1-6, it's not -- I've read it
18 wrong or it's not right or what?

19 MR. BEASLEY: The review by INPO --

20 MR. MOELLER: Let me ask the Staff.

21 MR. KENYON: I'm Tom Kenyon, project manager.

22 The item on page 1-6 was in reference to the
23 April meeting with TVA. At that time they had indicated
24 they wanted -- they were considering using the INPO
25 program.

1 MR. MOELLER: But it's changed?

2 MR. KENYON: Since then it's changed, and we
3 didn't have time to take it out of the SER.

4 MR. MOELLER: All right.

5 MR. EBERSOLE: Go ahead.

6 MR. BEASLEY: Okay. I'd like to go back and
7 summarize. We have had our major quality problems.
8 Their roots began prior to 1980. We began finding them
9 out, getting on top of them in 1980. And we now feel
10 very good about our Watts Bar plant. We feel good about
11 the design. We feel we have an excellent design. We
12 feel good about our hardware.

13 When we were going through our root causes and
14 looking at the major problems back in 1981, we found
15 that in general we had very good work; we just had
16 trouble assuring that work. We had other problems with
17 management control relative to QA, the transfer of
18 design information in the field --

19 MR. KERR: Excuse me. What does it mean, you
20 are sure you have good work but you have trouble
21 assuring the work?

22 MR. BEASLEY: We feel comfortable when we look
23 at our work that we have had good workmanship going in.
24 Looking at the plants, the things that we have had to
25 correct after we identify problems, we go back through,

1 we feel like we have had a very good record there.

2 MR. EBERSOLE: My impression, Bill, is what he
3 means is this -- correct me if I'm wrong -- that he's
4 found good work where he looked at it, where there was
5 absence of the paper record. Is that correct?

6 MR. BEASLEY: That's basically correct.
7 Overall we feel good about the work. You can see good
8 workmanship. You can see things go around. And we see
9 evidence of good workmanship in many of the things we
10 look at.

11 MR. SHEWMON: We get the point. Why don't you
12 go on with your summary.

13 MR. BEASLEY: Okay, I think I was basically
14 through with the summary.

15 On our quality problems, we're confident that
16 when we complete the corrective actions and based on
17 completing the corrective actions for the nuclear safety
18 review staff, completing action on the items that Region
19 II has identified, we are confident that our independent
20 review will verify that we do have a good design, a good
21 construction, and our quality program will be such that
22 we will have an adequate plant.

23

24

25

1 MR. EBERSOLE: Thank you. The next topic we
2 have is --

3 MR. MOELLER: Could I ask, I think this is an
4 appropriate place to ask it. I am again reading in the
5 SER on pages 1-8 and 1-9. On 1-8 it gives the total
6 reactor coolant flow rate. We are talking about design
7 here. I think the numbers are wrong. It says
8 14,300,000, or 14,030,000 pounds per hour. I think it
9 means 140 million. But then, it has Sequoyah and Watts
10 Bar and McGuire all about the same. And yet, on page
11 1-9 where it gives the reactor coolant pump flow rates,
12 there is a significant difference between Sequoyah and
13 Watts Bar.

14 Why is that? Why can you use different pumps
15 to pump the same pounds per hour but a whole lot less
16 gallons per minute?

17 MR. BEASLEY: Larry, can someone pick up on
18 that?

19 MR. MOELLER: Do you have the SER, page 1-8
20 and 1-9, and then, on the same question, like on page
21 4-21, when you talk about the same -- or, when the staff
22 talks about it, I presume they took these numbers from
23 your safety analysis report. On 4-21 the flow rates are
24 totally different than those on 1-8.

25 MR. KERR: It is possible that --

1 MR. NOVAK: Perhaps the staff needs a QA
2 program.

3 MR. KERR: My experience would indicate that
4 it is possible that something from a previous SER --
5 that the word "processor" indicates the computer might
6 have stuck in a flow rate from Grand Gulf SER
7 inadvertently.

8 (Laughter.)

9 MR. MOELLER: They could look this up and tell
10 me later.

11 MR. SHEWMON: Fine.

12 MR. MOELLER: Do you follow on page 4-21 are
13 not the same on page 1-8, and the gallons per minute on
14 1-9 do not correspond at all with the flow rates in
15 pounds per hour.

16 MR. SHEWMON: Are you Mr. Williams? Please
17 come on up.

18 MR. EBERSOLE: The next topic is the margin of
19 safety above SSE. I think there is a growing
20 realization that the assignment of the SSE is, to any
21 extent, somewhat arbitrary. And if one wants to feel
22 warm about whether plant will really survive a safe
23 shutdown earthquake, we have to have some feeling for
24 the range of margins that must effect a safe shutdown.

25 This really has led to this topic here, and

1 Mr. Williams is going to present it for us.

2 (Slide.)

3 MR. WILLIAMS: I am John Williams, Division of
4 Engineering Design, Supervisor of the Component
5 Qualification Section. All safety-related electrical
6 and mechanical equipment has been qualified to levels
7 which envelope conditions defined for its as-installed
8 configuration.

9 TVA's equipment seismic qualification program
10 is in full compliance with NRC and industrial
11 recommended procedures, guides, codes and standards and
12 good engineering practice.

13 Our construction permit was granted in January
14 of 1973. We have gone back and updated the
15 qualification methods to comply with IEEE 344-75. As a
16 matter of fact, our seismic qualification instructions
17 to vendors which were made a part of our equipment
18 specifications included draft versions of 344-75.

19 We also were looking ahead to expedite
20 licensing for Watts Bar and included operability
21 requirements for active pumps and valves to comply with
22 Reg Guide 1.4A. This included going back and working
23 with Westinghouse for their scope of supply and their
24 nuclear steam supply system for both the seismic
25 qualification and also, the operability assurance.

1 Equipment qualification reports provide a
2 conservative demonstration that the equipment is capable
3 of withstanding its prescribed seismic conditions. The
4 current philosophy regarding seismic qualification
5 throughout the industry -- and TVA's program is typical
6 -- does not require that the effort be extended to
7 determine how much better the equipment is than it needs
8 to be, nor does the qualification data lend itself to
9 the extraction of such information.

10 The seismic qualification program, as we know
11 it, cannot be transformed into an equipment reliability
12 program. Re-evaluation effort would provide indications
13 of margins of conservatism in qualification of specific
14 items of equipment.

15 (Slide.)

16 MR. SHEWMON: Sir, are you reading from
17 something I have?

18 MR. WILLIAMS: I hope so.

19 MR. SHEWMON: If I understand what you just
20 told me, you said that it is very difficult, from the
21 qualification test, to tell what margins are. Now, with
22 regard to reliability I would grant that, but I would
23 hope that if you have to have a piece of equipment that
24 will cope with an acceleration of 1g that you don't quit
25 at 1g, instead of seeing whether it might take 2g. Can

1 you help me?

2 MR. WILLIAMS: The effort you have referred to
3 would be more in a fragility test. Equipment is
4 qualified both by test and analysis.

5 MR. SHEWMON: Yes.

6 MR. WILLIAMS: If it fits the analysis
7 criteria, of course. Typically, equipment is qualified
8 so that the test response spectra envelopes the required
9 response spectra. So that if you have some margin
10 between these, you can evaluate that. But unless you go
11 into a fragility test program, you do not have what you
12 referred to.

13 MR. SHEWMON: You don't have reliability.

14 MR. WILLIAMS: You don't have the requirement
15 to go until the equipment breaks, as you would in a
16 fragility test.

17 MR. SHEWMON: I know that, but how far do you
18 go?

19 MR. WILLIAMS: The instructions are in the
20 industry guides, which require that you, in the case of
21 a test, that the test response spectra envelopes the
22 required response spectra.

23 MR. SHEWMON: So someone will do a different
24 test on every piece of equipment they ship, doing just
25 what they have to for a plant with the lowest design

1 base SSE, and testing a little bit higher for that which
2 has a higher SSE?

3 MR. WILLIAMS: Well, this is typically true.
4 And most of our effort is evaluating previous test
5 equipment to satisfy the TVA requirements.

6 MR. SHEWMON: So you don't do the test and
7 tell them to test as low as they possibly can? Someone
8 has already done a test that should bracket things?

9 MR. WILLIAMS: That is correct.

10 MR. SHEWMON: So indeed, if you read what the
11 person who did the test provided for data, it may well
12 tell you something of the margins, would it not?

13 MR. WILLIAMS: It would if it is qualified to
14 a higher response spectra than is required for your
15 application.

16 MR. SHEWMON: What is the SSE for your plant?

17 MR. WILLIAMS: The ground input motion is .18g.

18 MR. SHEWMON: That is not too exciting, given
19 what goes on in this country. Do you know how often the
20 equipment you have was tested to higher levels than what
21 you needed in your particular location?

22 MR. WILLIAMS: Not exactly.

23 MR. SHEWMON: Usually they did go higher, or
24 usually you had to call them up and ask them to have
25 things requalified to meet your specs?

1 MR. WILLIAMS: The equipment that we purchased
2 is qualified to meet our specifications.

3 MR. SHEWMON: But you don't even inquire about
4 whether it is qualified to meet more? Is that what you
5 are saying?

6 MR. WILLIAMS: That is correct.

7 MR. SHEWMON: But you could find out if you
8 asked, because they sell the same equipment to plants
9 with larger SSEs.

10 MR. WILLIAMS: Sometimes you have to pay them
11 extra for this information, and there are, of course,
12 generic programs to compare qualification at other
13 plants. Of course, we have a unique opportunity in
14 looking at equipment that is qualified for seven
15 different plants for progressively increasing seismic
16 environments.

17 MR. SHEWMON: Thank you.

18 MR. SIESS: Paul, could I help you a bit?

19 MR. WILLIAMS: Another feature of the NSSS
20 supplier --

21 MR. SIESS: Excuse me. Could you put up your
22 third slide?

23 (Slide.)

24 The one that says "minimum factors of
25 conservatism of Browns Ferry equipment." Was the 250

1 volt DC circuit breaker board qualified by tests?

2 MR. WILLIAMS: Yes.

3 MR. SIESS: Then can I conclude for breaker
4 trip, it was qualified to an acceleration of 5.45 or
5 some value higher, or is all of that 5.45 in the FRs and
6 FRe?

7 MR. WILLIAMS: I am not prepared to answer
8 that.

9 MR. SIESS: FRs says structure response
10 factor, which is test response over actual response. It
11 looks to me like some part of that margin is the ratio
12 of a test acceleration to actual. I don't really know
13 what "to actual" -- I don't really know what the words
14 mean. But this is a specific example of the types Dr.
15 Shewmon is asking about. I thought that would help.

16 MR. WILLIAMS: That is correct, but he was
17 asking for a general idea.

18 MR. SHEWMON: I was asking for the specific
19 words you used, and I don't have a copy of what you are
20 reading. But go back and read it and I will pay
21 attention.

22 MR. SIESS: I had the same question, Paul.
23 The NSSS supplied equipment -- TVA, as you
24 pointed out, has relatively low seismic. For all the
25 equipment that was qualified by test by Westinghouse,

1 you are qualified to much higher levels than are
2 required for the TVA plant. It is probably somewhere
3 1.5 and 2.

4 MR. SHEWMON: That would be my impression, but
5 that is not the impression I get from the presentation.
6 Please go on. It is just the viewgraphs, it not what
7 you are reading.

8 (Slide.)

9 MR. WILLIAMS: To address the seismic margin
10 of conservatism, the Sequoyah nuclear plant has just
11 undergone a re-evaluation of equipment qualified against
12 the higher seismic levels of the site-specific spectra,
13 and it demonstrated that the qualification had been
14 accomplished with a factor of conservatism of at least
15 1.5.

16 In other words, the equipment and structures
17 were re-evaluated to a higher level seismic input by a
18 factor of 1 1/2. The equipment, structures, piping were
19 shown to be adequate for this new site-specific
20 spectra. So that demonstrates a conservatism of at
21 least 1.5. So I am saying that that isn't a minimum,
22 but it has been shown that it at least has a factor of 1
23 1/2.

24 MR. SHEWMON: Did the staff change your SSE by
25 1 1/2? Is that it?

1 MR. WILLIAMS: We were required to look at the
2 84 percentile seismic event.

3 MR. SIESS: Yes, it got changed. I forget
4 whether it was 1 1/2, but it got changed.

5 MR. WILLIAMS: That is what it represented.
6 The Browns Ferry nuclear plant has just
7 undergone a probabilistic risk assessment study which
8 included the consideration of equipment qualification.
9 The study found that most equipment reflects large
10 margins of conservatisms beyond the prescribed seismic
11 conditions. The weakest link is relay chatter in the
12 electrical equipment.

13 The Watts Bar nuclear plant will undergo a
14 similar study, and the current schedule has a target
15 completion day of May of 1984.

16 To address the results, --

17 MR. EBERSOLE: May I address the relay
18 chatter? One might address -- if that is the weakest
19 link, then one might consider fixing it. So we inquired
20 at the subcommittee meeting what was the consequence of
21 relay chatter. And I will pass on the answer, as I
22 understand it, to the full committee here.

23 We were told by the electrical people that
24 whatever the relay chatter did, it did not reflect a
25 terminally ruined set of electrical apparatus. That

1 they could go back and reset, by manual or other means,
2 and therefore, relay chatter should not be considered in
3 the light of broken machinery beyond recovery. Does
4 anybody want to comment?

5 MR. SIESS: Does it do something when it
6 chatters? Does it open or close components?

7 MR. EBERSOLE: I am sure it creates a variety
8 of transients. I take it that TVA has stated that those
9 transients are damage of no permanent significance so
10 that you cannot reset the plant and realign it and
11 continue on your shutdown process. Am I correct? Would
12 one of the electrical people comment on this? I have a
13 little difficulty believing that you can start motors in
14 succession within the period of a few seconds without
15 getting a little trouble here and there.

16 MR. LEE: My name is Ron Lee, Electrical
17 Engineering Branch. The testimony that was given
18 Tuesday was as you stated. I really can't add anything
19 further than that, except it was stated that we could.
20 When you reset the equipment it would not be damaged and
21 we could recover from that.

22 MR. EBERSOLE: The chattering relay will send
23 contradictory signals to equipment. It will not be in
24 coordination.

25 MR. SHEWMON: But then, the wave doesn't

1 continue, and the next time you try, presumably it will
2 work.

3 MR. EBERSOLE: A momentary impulse can close
4 and seal in a function which you would rather not have
5 occur. Is that a complex investigation, may I ask TVA?
6 Is a relay chatter investigation -- do you really do an
7 intensive investigation of the ultimate potential relay
8 chatter considering seal-in functions and contradictory
9 functions? It sounds like an extensive problem.

10 MR. WILLIAMS: Mr. Ebersole, we do that when
11 we note this in the seismic qualification report. We
12 ask the electrical people to evaluate the operability or
13 the acceptability of the relay chatter, and in this
14 case, it was indicated Tuesday that it does not cause
15 failure of latching which occurred at a factor of 5.45,
16 as the failure.

17 MR. EBERSOLE: Is there a summary report that
18 might be titled the effect of relay chatter,
19 uncoordinated relay chatter in the Watts Bar plant?

20 MR. SIESS: As a transient, not as permanently
21 disabling equipment.

22 MR. LEE: Not to my knowledge.

23 MR. EBERSOLE: Where is this information
24 buried, that you can tolerate relay chatter without
25 serious permanent effect? It sounds like it has a

1 degree of casualness about it that may be inappropriate.

2 MR. WARD: Could I understand something here?
3 You are not saying that at the design basis, your .18
4 earthquake, that you are getting relay chatter? You say
5 as you go to higher seismic loadings, that is the first
6 thing that you have? I don't know --

7 MR. SIESS: Dave, that figure up there says
8 they have a factor of 1.4, taking into account three
9 conservatisms. So I don't know what the range is.

10 MR. WARD: I think it is obvious that they
11 don't have all seismic safety margins defined; nobody
12 does.

13 MR. SHEWMON: We have a presentation.

14 MR. EBERSOLE: We are doing pretty good on
15 schedule, Paul.

16 MR. SHEWMON: I would like to keep it that way.

17 MR. EBERSOLE: Before we drop this, the staff
18 would like to say something, and I wish they would,
19 about the generic aspects of the problem.

20 MR. NOVAK: I would only point out prior to
21 the licensing of the Trojan nuclear plant there was a
22 substantial amount of review done on electrical
23 components specifically with regard to chattering
24 effects on electrical equipment. It was done mostly
25 around the nuclear steam supply system equipment, and

1 the resolution was well defined.

2 I don't want to try to speculate on that, but
3 I do know that because of the seismic design
4 requirements placed on that facility sort of late in the
5 design a question arose as to whether those components
6 would, in fact, perform acceptably. They would induce
7 transients That was clearly one of the things that
8 would happen.

9 But the emphasis was could you accomplish a
10 safe shutdown, and the answer was yes.

11 MR. BUSELL: George Buswell from
12 Westinghouse. I would just like to confirm Mr. Novak's
13 statement. As far as my memory goes, we only ended up
14 changing our relays on protection systems for two or
15 maybe three peices of seismic qualified equipment.
16 Protection systems for Westinghouse for this level of
17 plant do not have a relay chatter problem at all.

18 MR. EBERSOLE: Thank you, let's carry on.

19 MR. WILLIAMS: Okay. Continuing on the Browns
20 Ferry equipment, the reactor pressure vessel internals,
21 the factor of conservatism 2.45; diesel generator
22 transformer, diesel generators 2 1/2, transformers 2.8
23 -- no, I am sorry, I am off a line here. The control
24 rod drive housing, 3.85; all other equipment, larger
25 margins.

1 (Slide.)

2 There are several generic programs underway to
3 address seismic margins of conservatism. I am sure you
4 are familiar with the seismic safety margins research
5 program underway under the direction of Lawrence
6 Livermore Labs.

7 I pulled a quote out which I like, "An
8 important observation is that most mechanical and
9 electrical equipment is inherently rugged and will
10 survive acceleration levels far in excess of building
11 responses associated with the safe shutdown earthquake."

12 Another generic program is the seismic design
13 margins of pumps, valves and piping fluid system
14 components, sponsored by the NRC, done by Mr. Everett
15 Rodenbaum. It was written by Mr. Butterworth. The
16 Watts Bar plant is in a low seismic area relative to
17 other plants, and the numbers that you see are
18 representative of the margin of conservatism that the
19 Watts Bar equipment would have.

20 (Slide.)

21 From the first program, the minimum fragility
22 values of Zion, the factors of conservatism -- and
23 remember the other slide which had the definition -- the
24 125 volt AC distribution panel, the factor of
25 conservatism is 3 1/2; service water pumps, 3.7; 4000

1 160-volt switchgear, 4.2; other equipment, larger.

2 MR. SHEWMON: Sir, were those by test or by
3 calculation?

4 MR. WILLIAMS: The 125-volt AC distribution
5 panel and the 4000 160-volt switchgear would be by test,
6 together with the other factors. The test is only one
7 part of it. The service water pumps would be by
8 analysis.

9 MR. SHEWMON: I guess it is with data like
10 that that I did not understand your original comment,
11 nor does the qualification data lend itself to
12 extraction of such information. It talks about how much
13 better equipment is than it needs to be for the SSE.
14 But I did find what you are reading, so go on.

15 MR. WILLIAMS: Okay. The program, as it
16 currently is, does not require that we establish
17 monitors.

18 MR. SHEWMON: Requiring wasn't the question.
19 It was whether it is easy or difficult.

20 MR. WILLIAMS: It is difficult.

21 MR. KERR: Is TVA convinced that the current
22 requirements are adequate?

23 MR. WILLIAMS: I would say that they are.

24 (Slide.)

25 Looking at the design margins for fluid system

1 components, what we see here is simply the margins or
2 the nominal margins, which is simply a ratio of the
3 yield or the ultimate for the material divided by the
4 code allowable stresses. And the figures are as you
5 see. And this is simply what is in the code for the
6 material. Also, for the AISC manual.

7 In other words, a factor of 1.67 is simply
8 your allowable stress of 20,000 psi. That contains a
9 factor of 1 2/3 on the yield. This does not address the
10 other margin that is available. Typically, material is
11 1.2 times minimum specified values and other factors
12 that are inherent. For instance, standard flanges are
13 designed to an allowable stress of 7000 psi, which is
14 quite a bit more conservative than these values.

15 MR. EBERSOLE: John, I am not a structural
16 man. What is the meaning of .55, if I am looking at a
17 pump or a valve and I have a shaft linearity problem,
18 where any kind of distortion of the shaft alignment will
19 cease the shaft and lock up the pump?

20 MR. WILLIAMS: In this case, you wouldn't be
21 allowed to go to the yield criteria. That is an
22 operability question.

23 MR. EBERSOLE: Is that a second set of numbers
24 that is not here?

25 MR. WILLIAMS: It would be the bottom number

1 here of the 1.1 to 4.8. There you would only go to
2 service level B conditions.

3 At the time, the code of record for Watts Bar
4 does not address operability per se in the code. The
5 current editions of the code do address operability and
6 they limit the stresses to service level B, which would
7 give you the 1.1 to 4.8 factor.

8 MR. EBERSOLE: You went back and looked at the
9 components to see that?

10 MR. WILLIAMS: Yes, yes. We do have the
11 operability program in place for Watts Bar.

12 MR. EBERSOLE: Also in place for Sequoyah?

13 MR. WILLIAMS: For the seismic qualified
14 components, yes, we did look at that.

15 MR. EBERSOLE: Did you find any fixes
16 necessary?

17 MR. WILLIAMS: Well, you are pressing my
18 memory.

19 MR. EBERSOLE: All right. As long as you have
20 methodical program to turn to to look it up.

21 MR. SHEWMON: Is that about it?

22 MR. WILLIAMS: Yes, I believe it is.

23 MR. SIESS: Mr. Chairman, may I explore a
24 little bit on this margin business? We need some
25 information in connection with what we have putting into

1 letters. Could you go back to that third slide on the
2 Browns Ferry equipment where, at least for that case,
3 the factor of conservatism was defined as being made up
4 of three components.

5 Let's take again that circuit breaker board
6 which I am sure was qualified by test. Would the FCe
7 strength-load ratio have any application there, or would
8 that factor of conservatism be only involved in the
9 other two?

10 MR. WILLIAMS: In the case of tests, it is
11 very difficult to evaluate that factor.

12 MR. SIESS: That doesn't answer my question.
13 Does the FCe equipment capacity factor equal to strength
14 over load having any bearing on that first number?

15 MR. WILLIAMS: I don't see how it could.

16 MR. SIESS: The second factor, which is test
17 response or actual response, I don't understand. If it
18 said test spectra over actual spectra I would understand
19 it. Is there any chance that is what it means, or does
20 it mean something else? Test and actual are usually the
21 same thing, to me. Does it mean test over computed or
22 expected?

23 And the next item takes a ratio of design to
24 anticipated. Could you explain what that means? I know
25 what the design floor spectra are.

1 MR. WILLIAMS: I would have to go into the
2 report to read it in more detail.

3 MR. SIESS: Is this a report the NRC has?
4 Could you give us a reference to the report?

5 MR. WILLIAMS: No. This is a Browns Ferry
6 report. I don't imagine it has been submitted to the
7 NRC as yet.

8 MR. SIESS: Because in connection with
9 previous cases where the ACRS has asked for seismic
10 margins on things like piping, of course, people have
11 come back and given us stresses pretty much like you had
12 on the last figure, and have essentially ignored the
13 fact that there are other conservatisms built into the
14 calculation of spectra of the earthquake, et cetera and
15 so forth in the analysis method.

16 This, I think, is one of the first instances I
17 have seen where there is an attempt to look at the
18 conservatisms due to differences between --
19 conservatisms built into the analysis, actually giving
20 floor spectra and so forth.

21 But I think we would be interested in seeing
22 what was done there. If you could provide us with a
23 reference, I think that would be helpful.

24 MR. WILLIAMS: Well, the reference is the
25 Browns Ferry PRA study.

1 MR. SIESS: It is in the Browns Ferry PRA
2 study?

3 MR. WILLIAMS: Right.

4 MR. SIESS: Has this been published? Does the
5 NRC have a copy of that? He says the answers to my
6 questions are in there, so I would like to get the
7 document that has the answers to my questions.

8 MR. MILLS: Sir, I have just been told that
9 this report will not be issued until sometime next
10 year. But I wonder if we could get back through the
11 staff to you with perhaps extracted material from that
12 report.

13 MR. SIESS: Anything that indicates what these
14 things are would be very helpful. And other things we
15 are doing, not just Browns Ferry. I mean, not just
16 Watts Bar.

17 MR. SHEWMON: Okay, thank you very much.
18
19
20
21
22
23
24
25

1 MR. EBERSOLE: I'll comment on the next
2 topic. TVA experienced what I believe was an
3 extraordinary corrosion problem in certain carbon steel
4 piping, and resorted to a process of mortar lining of
5 the critical water pipes. The first thing that springs
6 to mind is whether this material will degrade over time,
7 and while it may not be physically, it may potentially
8 be loosened so that under subsequent seismic loads it
9 will unload and, in a common mode fashion, plug up the
10 process pipes.

11 We have Chuck Bowman here, who has a
12 presentation on what they did about this and why they
13 did it. It was really a pressure drop problem. Chuck,
14 it's all yours.

15 MR. BOWMAN: My name is Chuck Bowman. I'm
16 supervisor of a Section in the Mechanical Engineering,
17 Branch of Engineering Design, responsible for the
18 central raw cooling water system.

19 During preoperational tests in the emergency
20 cooling water system at Browns Ferry nuclear plant in
21 1976, certain heat exchangers were found to be receiving
22 inadequate cooling water flow due to a buildup of
23 corrosion products in the interior of the pipe of carbon
24 steel piping servicing this equipment.

25 Since carbon steel piping was extensively used

1 in both safety-related and non-safety-related piping
2 systems at other TVA nuclear plants, a study was
3 undertaken to determine the pervasiveness of this
4 problem in the TVA service system and to develop the
5 recommended practice to mitigate its effects.

6 Approximately 50 sections of carbon steel raw
7 water piping were removed from 9 different TVA steam
8 plants. Both normally stagnant and normally flowing
9 piping systems, as well as both vertical and horizontal
10 rows of piping were sampled.

11 In virtually every case, the primary mechanism
12 was found to be corrosion in the steel piping by aerated
13 water river and redeposition of corrosion products. The
14 problem was found to a significant degree at all the TVA
15 plants that were sampled, and the result is a random
16 pitting in the pipe wall and the formation of a tubercle
17 over each pit. And I have a sample from Browns Ferry if
18 you care to look at it.

19 (Slide.)

20 The equivalent average diameter reduction as a
21 result of corrosion products buildup as a function of
22 years of service is shown here in Figure 1. The deposit
23 in each sample was removed and analyzed for various
24 constituents. In virtually every case, it was found to
25 be principally iron oxide.

1 We have plotted a decrease in diameter of the
2 pipe versus service years for the samples that were
3 taken. Tests were performed at Widows Creek, Kingston,
4 and Gallatin steam plants to evaluate the effects of
5 corrosion product buildup on pressure drop. These sites
6 were selected to cover a range of ages as well as a
7 variety of water sources.

8 Samples removed from each test line were
9 analyzed to determine the percent volume reduction of
10 the pipe interior due to the corrosion product buildup.
11 The corresponding diameter reduction for each test line
12 was then used with the pressure drop test data to
13 develop appropriate equations for pressure drop.

14 Several figures were generated in an attempt
15 to find a correlation between diameter reduction and
16 Hazen-Williams C factor. Values of C were assumed and
17 corresponding values of diameter were calculated for
18 each test to give you the required pressure drop.
19 Finally, a dimensionless parameter which we call D, was
20 developed for use in correlating the above calculated
21 value of d with the measured value of diameter
22 reduction.

23 (Slide.)

24 Using this relationship for each of the three
25 pressure drop tests conducted as shown in the following

1 figure, good agreement was discovered --

2 (Slide.)

3 -- good agreement was discovered for values of
4 d equal to 2 and a Hazen-Williams C factor of 57. We
5 have adopted a slightly more conservative value of C
6 equals 55 in our design equations. The result from this
7 analysis is a modified Hazen-Williams equation.

8 (Slide.)

9 Figure 3 shows the comparison with the factor
10 of 5 and d equals 2, and reducing the nominal diameter
11 by two times measured diameter we have produced this
12 modified Hazen-Williams equation, which has proven to
13 give us good correlation for all of the tests that were
14 conducted.

15 (Slide.)

16 Here we see the comparison between the
17 predictive model and the actual test data taken on a
18 3-inch line at Widows Creek. Note also the head loss
19 predicted by the normally used Hazen-Williams equals C
20 equals 100.

21 Similarly, we have comparisons with the other
22 tests that were conducted. Here is a test that was
23 conducted at Kingston on a 6-inch line, which gave you
24 -- which also gave you good agreement with the
25 predictive model.

1 (Slide.)

2 And the test that was conducted on the
3 Gallatin 8-inch line, which also gives you good
4 agreement with the predictive model.

5 (Slide.)

6 TVA is now using this equation to evaluate the
7 heat rejection system, fire protection, raw cooling
8 water system, and raw service water system at Watts
9 Bar. Most significantly, however, we have completed our
10 evaluation of the Watts Bar ERCW system, and the
11 remainder of this presentation discusses results of that
12 evaluation.

13 The analysis of the ERCW system determined
14 that delivery of design flow rate to system users over
15 plant life could not be guaranteed with the original
16 design. Consequently, changes were defined to bring the
17 system within the 40-year design basis.

18 (Slide.)

19 These changes include: Replacement of
20 selected segments of carbon steel piping within the
21 buildings with stainless steel;

22 Requalifying certain system users to a lower
23 ERCW flow rate by refinement of the heat transfer design
24 calculations;

25 And finally, by applying a cement mortar

1 lining to the existing carbon steel piping in the yard
2 in situ.

3 Before making a final decision to cement
4 mortar line the ERCW system yard piping, a telephone
5 survey was conducted to determine how well it had
6 performed in service. In Table I which you have in your
7 handout, you see there that a total of 11 other
8 utilities, 2 A-E's and 5 municipal water systems which
9 have cement mortar lined piping in service were
10 canvassed.

11 Although a few problems were reported, in
12 general the experience reported was very good. All of
13 the problems identified could be attributed to either
14 the pipe being out of round or a failure to properly
15 protect the pipe joints.

16 Mr. Ebersole, in response to your concern
17 about the seismic event, during the 1971 San Fernando
18 earthquake, within three miles of the quake epicenter a
19 96 inch above-ground water line owned by the Los Angeles
20 Department of Water suffered both vertical and
21 horizontal displacement due to surface acceleration.
22 The pipe was broken from its supports and accordioned.
23 The 34-year-old cement mortar lining was undamaged
24 except at the place where the pipe was accordioned,
25 where it did spall.

1 A 24-inch diameter steel tunnel liner, the
2 Foothill Feeder in Seguna, California, Metropolitan
3 Water District of Southern California, was buried 50
4 feet underground and did not deform from the
5 earthquake. Buildings on the surface were destroyed and
6 equipment in the tunnel itself was shaken down.
7 However, the cement lining that had just been in place
8 only 12 hours was not damaged, nor was the older lining
9 damaged.

10 The Balboa pipeline, owned by the Metropolitan
11 Water District of Southern California, a 14-foot line to
12 the Jennison Treatment Plant, separated about 3 inches
13 in two locations and then was driven back together, one
14 section inside the other. The lining was only damaged
15 where the pipe separated. And the plant was 75 percent
16 destroyed.

17 It appears that unless there is deformation of
18 the pipe the cement lining is not damaged. We will
19 address the seismic qualification of the piping later in
20 this presentation.

21 The procedure for applying the cement mortar
22 lining requires that the piping first be cleaned by
23 scraping off existing tubercles. Thereafter, the mortar
24 is centrifugally applied from a spinning head and
25 immediately trowelled onto the inside surfaces, using a

1 machine which is pulled through from one end. Closure
2 pieces and certain elbows are thereafter hand-mortared
3 to complete the process. The closure weld-affected
4 region is hand-lined from inside the pipe.

5 MR. SHEWMON: What diameter can you go down to
6 on that?

7 MR. BOWMAN: We lined pipe 24-inch and
8 larger.

9 MR. SHEWMON: Okay.

10 MR. BOWMAN: We only lined pipe in
11 safety-related systems.

12 MR. SHEWMON: For this (Indicating)?

13 MR. BOWMAN: For that we replace it with
14 stainless steel.

15 Humidity is carefully controlled after
16 application to ensure proper curing, and each foot of
17 piping is carefully inspected prior to plant operation.

18 TVA specified the necessary level of quality
19 assurance on the lining process and a number of
20 nonconformances to the specifications have occurred.
21 These have included: both high and low mortar slump;
22 high mortar temperature; low mortar compressive
23 strength; low relative humidity; surface cracks; mortar
24 applied too thin; end caps that were not replaced; pipe
25 damage; and exterior coating damage.

1 Where appropriate, repairs have been made in
2 accordance with approved procedures.

3 Very good experience has been reported with
4 cement mortar lining by other utilities. However, since
5 this is the first application by TVA and since the ERCW
6 system is a safety Class 3 system, provision is being
7 made in the design to facilitate periodic inspection of
8 a portion of the system after it has been placed in
9 service.

10 Now Frank Hand will come and address seismic
11 qualification.

12 MR. EBERSOLE: A question. Are the tubercles
13 thought to come from the tube itself or from the
14 boiler?

15 MR. BOWMAN: There's been quite a bit of
16 literature published in the AAWA journals. The general
17 consensus of opinion is that you have anaerobic
18 digestion of suspended solids, creating an oxygen
19 deficient cell, which creates acids, and you begin to
20 have the pipe wall eroded. The corrossions come from the
21 pipe.

22 On the surface of the tubercle you will find
23 bacteria. That is probably from the water.

24 MR. ETHERINGTON: It might have been from
25 steam?

1 MR. BOWMAN: You'll get different people's
2 opinions, but for my judgment it comes from the pipe.
3 It comes out of the pipe, the metal from the pipe.

4 MR. KERR: That word is spelled p-i-p-e,
5 Harold.

6 (Laughter.)

7 MR. EBERSOLE: Some people just don't
8 understood good English.

9 MR. BOWMAN: I have a sample of a pipe that's
10 been pickled. There is pitting occurring in the pipe
11 wall. We have done studies on the pitting, which was
12 reported in the Subcommittee meeting.

13 MR. SHEWMON: Fine.

14 MR. MOELLER: A quick question. In terms of
15 the problems of the corrosion and so forth, the volume
16 of water you are dealing with is just far too great to
17 do any chemical control of it, is that correct?

18 MR. EBERSOLE: It is once-through.

19 MR. MOELLER: That's what I mean. In other
20 words, it would just be impossible?

21 MR. SHEWMON: There's no city water.

22 MR. BOWMAN: At Watts Bar it is once-through.
23 We have considered closed systems where the water
24 chemistry can be controlled. However, you would have to
25 de-oxygenate the water to be assured of good water

1 chemistry control.

2 MR. ETHERINGTON: Let me try once again, if I
3 may, on my question. Do you get the same tubercles in
4 stainless steel pipe?

5 MR. BOWMAN: No, sir.

6 MR. ETHERINGTON: So it's a local effect.

7 MR. KERR: Incidentally, I knew southerners
8 didn't pronounce the word "APE", but I didn't know they
9 started taking iron out of the word.

10 (Laughter.)

11 MR. HAND: I am Frank Hand with the Civil
12 Engineering Branch of TVA. We were assigned
13 responsibility for seismically qualifying the cement
14 mortar lining that's going to be installed in the pipe
15 in the test program which will be described here.

16 (Slide.)

17 We had several specimens that we were going to
18 line, because we were going to run several different
19 types of tests. We were testing full-sized pieces of
20 pipe, primarily 30-inch diameter pipe. We had one long
21 40-foot piece, another long 30-foot piece. We had
22 another long piece over here that we subsequently cut
23 into two-foot sections after it was lined for a specific
24 type of test.

25 We had one 90-degree elbow with two five-foot

1 extensions on it that was lined and then, to see what
2 the difference was between a large diameter pipe and a
3 smaller one, we lined one 18-inch diameter piece of pipe
4 and cut it into two-foot sections also.

5 (Slide.)

6 The lining equipment looks like this little
7 dolly that comes through the pipe. The mortar is slung
8 out from this particular head. It is immediately
9 trowelled in this operation with two spinning arms,
10 which will give us a gun-barrel type of an appearance.

11 In the very foreground of this slide you can
12 see the slicker mortar. There's a little bit of overlap
13 or a rise where the mortar joints coming from the
14 spinning trowel aren't particularly smooth. The orange
15 peel-rough looking surface back here is untrowelled
16 mortar that's been slung on, and the shiny surface in
17 the far back is an unlined piece of pipe.

18 The reason we have this particular view, we
19 are looking at an elbow. This was machine-troweled,
20 this was hand-troweled, then this would be
21 machine-troweled over here coming in from the other
22 side.

23 (Slide.)

24 Of the types of tests we ran on the two-foot
25 specimens, we ran a simple three-inch bearing test, in

1 which we would supply load along the line at the top and
2 we would check the deformation. We were able to squeeze
3 these pieces of pipe three inches --

4 (Slide.)

5 -- out of a 30-inch diameter, which gives us a
6 10 percent distortion rate. We lost no mortar in any of
7 our testing for this particular apparatus.

8 (Slide.)

9 We have here a piece before we lined it --
10 excuse me, before we tested it. You can see the little
11 ridges left from the troweling operation.

12 (Slide.)

13 After testing we have a crack in the very
14 bottom, a slight crack over on the side, some other
15 cracks up on the top. The cracks would look worse in
16 the slide because we've accented those with felt-tip
17 magic marker type pens. This is the extent of the
18 damage that we would see when we would squeeze 30 inches
19 of pipe down to 27.

20 (Slide.)

21 The maximum loads that the pipes were taking
22 was about 12 Kips. We get small cracks about 3 Kips.
23 So we carried this pipe well into its plastic
24 deformation stage.

25 We also ran a torsion test on one two-foot

1 specimen, by welding it to a one inch thick plate on the
2 bottom, fixing up a loading apparatus onto the pipe.
3 What we were trying to approximate here is what happens
4 to one leg of a pipe as it goes into an elbow when the
5 other leg is moving and perhaps putting some bending or
6 torquing into it.

7 For this particular apparatus, we got quite a
8 bit of cracking in the lining itself, but it was all
9 where the cross piece ties into the pipe specimen. And
10 we consider that to be a problem with our loading
11 arrangement.

12 We carried this up until we actually failed
13 the weld in our loading frame over this particular
14 point. That was at about 60 Kips. Other than the
15 deformation associated with the loading points, there
16 was no major cracking. The pipe with our loading
17 arrangement; we were able to warp it about a quarter of
18 an inch.

19 (Slide.)

20 We took one long, 30-foot piece of pipe and we
21 subjected it to a bending test. Due to the size of the
22 specimen and the load we were putting on, we found it
23 was much easier to hold down the ends than to push up in
24 the middle, which is the opposite of what you would
25 normally do in a small test.

1 We had a 100-ton -- excuse me -- a 100-Kip
2 jack underneath. We ran the first load up to 80 Kips,
3 at which point we ran into a plastic buckling type
4 failure of the pipe at one of our support points and
5 that caused some spalling of the lining on the inside.

6 We put bigger pads on our support points,
7 rolled the pipe topside-down. This time we went up to
8 90 Kips. We had no spalling. We had only general
9 cracking running around the pipe. In essence, the
10 lining was relieving itself of any stress. And in this
11 particular one we took the steel up into its plastic
12 range.

13 We were able to deform the pipe enough so that
14 vertically it was compressing one inch and it was
15 expanding horizontally almost a half an inch.

16 (Slide.)

17 We then went into a series of impact or
18 missile drop tests where, from up to 40 feet high, we
19 dropped up to a 35-foot high. On the two-foot specimen,
20 when it would hit it would cause a dent in the steel.
21 This happens to be from a 14-foot drop.

22 (Slide.)

23 And only at 14 feet did we get any spalling of
24 the concrete or the mortar on the inside. As this
25 height progressively got up to 40, that spot got

1 progressively larger, but it was always a spalling
2 failure. We never got a lining to collapse.

3 (Slide.)

4 We also took the same bending test specimen
5 and subjected it to drops starting at one and working
6 our way up to ten feet. We could not get the lining to
7 fall in that pipe either, even though it had already
8 been tested and severely broken.

9 We tested our elbow again. Due to testing
10 constraints, it was easier for us to pull the elbow
11 together.

12 (Slide.)

13 We did so. During the test the elbow actually
14 came -- the two ends were pulled five inches closer to
15 each other. We wound up with a one and a half-inch
16 set. We were getting close to rated yield stress on
17 this particular area over here (Indicating).

18 We had no spalling, no cracking -- no
19 spalling, no major cracking of the lining inside the
20 elbow.

21 (Slide.)

22 We took our long, 40-foot diameter pipe,
23 buried it in the ground at one of our nuclear plants.
24 As you can see, we were scraping some dirt off it here
25 with a bulldozer. We had put three feet of dirt on it,

1 used a regular 400 vibratory compactor, subjecting it to
2 testing, to vibration; removed six inches of soil,
3 repeated the process; worked on down.

4 We could not get any cracks in this pipe
5 specimen until we had the vibrator sitting directly on
6 the bare pipe for over 15 minutes.

7 (Slide.)

8 Since our lining site was about 100 miles away
9 from our test site, we thought it would be prudent to
10 test it with accelerometers to see what kind of
11 transportation excitation it had received. It turned
12 out that for the pipes loaded on the lower portion of
13 the flatbed truck they received about six-tenths of a
14 g. For those loaded on the top portion they received
15 slightly over 2 g's of acceleration.

16 We performed the four-inch spectrum analysis
17 on the time histories we got. We found that the
18 frequencies ranged from zero to 100 hertz, slightly
19 richer than our typical earthquake, which would be in
20 the 5 to 10 hertz range.

21 On the basis of all of our testing, which was
22 on full-scale specimens, we saw that the lining showed
23 considerable flexibility and ductility. We think we put
24 the lining through paces more severe than what it would
25 encounter during our design earthquakes, and on the

1 basis of the testing the observed performance as well as
2 the historical performance that Chuck alluded to, we
3 believe that the pipe is fully qualified for seismic
4 events that it would see in our plants.

5 MR. EBERSOLE: Well, thank you.

6 I guess I only have one question about it.
7 That is, I guess I've seen too many WPA jobs with
8 reinforcing heaving concrete. I believe that some
9 heaving and spalling will occur over the years. But I
10 also gather that there is a surveillance program in
11 place that will detect any undue amounts of that. And I
12 have no further things with this, Mr. Chairman.

13 Does anyone else have any comment?

14 MR. MOELLER: We presume they also would have
15 filters in case --

16 MR. EBERSOLE: I don't know what the filter
17 logic is or whether it's been altered by this. I
18 suspect it has not.

19 MR. MOELLER: Could someone tell us?

20 MR. EBERSOLE: Have you altered any of your
21 filtration logic as a result of using this material?

22 MR. PIERCE: No, we have not altered any
23 filtration logic. We prefilter the water, not at the
24 pumps; but we have not altered any of the filter logic
25 used in the concrete lining.

1 MR. EBERSOLE: Thank you.

2 MR. SHEWMON: Find. The next speaker?

3 MR. EBERSOLE: The next topic is the problem
4 with the Westinghouse D3 steam generator. Ralph
5 Pierce.

6 MR. PIERCE: I am Ralph Pierce. I'm the
7 design and construction project manager for the Watts
8 Bar nuclear plant.

9 TVA became aware of the tube wear problem due
10 to flow-induced vibration in November of 1981. It
11 began working with Westinghouse relative to the Watts
12 Bar unit. The discovery of the tube wear problem was in
13 Ringhals Unit 3 in October 1981 in Sweden. Sweden has
14 since conducted two full-scale models of a portion of
15 the previous section of the Model D3 generator at its
16 hydraulics laboratory.

17 Only one of these test facilities is presently
18 being used. In March-April 1982, Westinghouse entered
19 into agreements with Sweden to have certain baseline and
20 confirmatory tests performed as a part of the
21 development of design modifications for the D2 and D3
22 generators. Test specifications, procedures, and
23 quality assurance requirements were prepared by
24 Westinghouse.

25 Operation of the model has been in Sweden.

1 Final data processing and evaluation has been performed
2 by Westinghouse here in the U.S.

3 During the week of June 1, 1982, the model was
4 in near readiness for starting baseline testing on the
5 existing D3 design when they had an overpressurization
6 event and caused substantial damage and delay. The
7 model was placed in equivalent full flow operation on
8 June 22, 1982.

9 Data collection and processing, including high
10 technology photography began. Based on evaluation in
11 the U.S. and at the site, initial baseline testing began
12 on January 5, 1982. While the evaluation of the design
13 of the modification was being performed, TVA began an
14 economic evaluation of the options of making the
15 modifications prior to fuel loading versus operating at
16 50 percent power level through the first refueling
17 outage, or scheduling an outage at some point in time to
18 do a modification.

19 It was determined that it would be to TVA's
20 economic advantage to delay fuel loading and to do the
21 modification prior to fuel loading, and specifically
22 prior to our hot functional testing, which we felt was
23 the best spot in the schedule to do this to approve the
24 system and get it back in operation.

25 Based on preliminary information from

1 Westinghouse, it was determined that we had a high
2 probability of obtaining an acceptable design, testing
3 and having the work performed by Westinghouse prior to
4 November the 3rd of 1982. The Watts Bar schedule was
5 adjusted to reflect this.

6 The progress to date on the Westinghouse test
7 is that the full flow test of the Model D3 first full
8 manifold design is complete. This establishes the
9 baseline for comparison purposes. These D3 design full
10 flow tests are to be rerun with force gauges in
11 approximately four of the tubes and will be done in
12 August of 1982.

13 Based on model testing and analytical work by
14 Westinghouse, they have a high level of confidence that
15 the optimized test manifold will become the production
16 model. Optimized manifold full flow test of the
17 production model is now scheduled to begin in
18 September. In your handout I said the week of September
19 30th, but Westinghouse informed me this morning that
20 they're a little ahead of schedule.

21 MR. SHEWMON: The one in Sweden -- there are
22 several of these slightly different models around. Is
23 yours identical to the one in Sweden?

24 MR. PIERCE: Ours is identical to the one in
25 Sweden.

1 MR. SHEWMON: Is the one in Spain, Maguire,
2 slightly different?

3 MR. PIERCE: It's slightly different, but it's
4 so close there's not much difference.

5 MR. SHEWMON: When you talk about this
6 manifold, what physically are you talking about?

7 MR. PIERCE: We're talking about a manifold
8 that would be put into the feedwater inlet nozzle, which
9 will disperse the flow of fluid such that velocity at
10 100 percent load will be dispersed like a shower head,
11 such that we will reduce the impingement on the rows of
12 tubes in the steam generator and cut out the vibration
13 that is causing the wear of the steam generator tubes.

14 MR. SHEWMON: This will give you somewhat more
15 pressure drop, but it will avoid the vibration?

16 MR. PIERCE: Westinghouse can address the
17 pressure drop, but nothing that will --

18 MR. SHULTHEIS: Joel Shultheis.
19 That's essentially correct.

20 MR. PIERCE: We've been working with
21 Westinghouse. It's hard to tie down what will become
22 the production model. They have recently informed us
23 that we will be finalizing the schedule hopefully by the
24 end of this month on Watts Bar. Also, TVA is working
25 with Duke and South Carolina Power on their two

1 reactors.

2 Watts Bar, Duke, and South Carolina at Sumner
3 will be the first three commercial units to get the
4 modifications. It has not been decided which will be
5 first, second and third. This will be worked out
6 mutually between the three utilities and Westinghouse.

7 So if there is any significant change in the
8 Westinghouse schedule for the final modification, we
9 will make another economic evaluation and note the place
10 in the schedule where we will make this modification.

11 MR. SHEWMON: Fine.

12 What is the support plate material in your
13 steam generators?

14 MR. PIERCE: I will let Westinghouse address
15 this, the technical people.

16 MR. SHULTHEIS: This is Joel Shultheis from
17 Westinghouse.

18 The support plate material in the D3 steam
19 generator is carbon steel.

20 MR. SHEWMON: So they haven't caught that one
21 yet. It's old-fashioned that way.

22 What about the condenser? What is your tubing
23 material?

24 MR. PIERCE: Our tubing material for the main
25 condenser?

1 MR. SHEWMON: Yes.

2 MR. PIERCE: Help me on this over here. It's
3 copper bearing Admiralty, isn't it?

4 MR. COTTLE: This is Bill Cottle.

5 It's 90-10 copper tubing.

6 MR. SHEWMON: Where are you with regard to
7 accepting the steam generator owners group criteria
8 about operating procedures for when you start getting
9 out of spec in the water, as you would with leaks in
10 your condenser, or oxygen control or other things like
11 that?

12 MR. COTTLE: Right now the present specs in
13 the operation are very close to the Westinghouse owners
14 group. There may be some slight difference.

15 MR. SHEWMON: I'm not talking about the
16 Westinghouse owners group. There has been a steam
17 generator group -- I didn't think that was only
18 Westinghouse, but maybe it was -- that EPRI is
19 managing.

20 MR. COTTLE: It's at EPRI, but the
21 specifications are being written for Westinghouse steam
22 generators and each of the other major classifications.

23 We are very, very close to that.

24 MR. SHEWMON: What will you do with oxygen,
25 for example? Will you have procedures or inspection and

1 control on that?

2 MR. COTTLE: We have procedures. We have an
3 alert level, I believe, for leakage of 5 Cfm, and we
4 have an action level which basically would involve
5 plants that have to gain concurrence from higher level
6 management to continue operation above 10 Cfm.

7 MR. SHEWMON: This is consistent with what the
8 Westinghouse owners group is saying?

9 MR. COTTLE: That's fairly consistent, I
10 believe, with the guidelines that are evolving there,
11 yes.

12 MR. SHEWMON: Have you had a chance to react
13 to what the NRC Staff put out on the 29th of last month
14 as requirements on that, or do you know where you are
15 relative to their checkpoints?

16 MR. COTTLE: I haven't seen those checkpoints
17 yet.

18 MR. SHEWMON: You might look.
19
20
21
22
23
24
25

1 MR. PIERCE: We are doing additional
2 modifications in the way of improving water chemistry.
3 We are taking the copper out of the main feedwater
4 heater, the condenser, we are modifying the
5 demineralizer. We will be using some nitrogen bubbling
6 through the condensate storage tank. So we have several
7 modifications that have been factored into our schedule
8 in water chemistry.

9 MR. SHEWMON: These are modified since
10 Sequoyah or will you make those at Sequoyah 2?

11 MR. PIERCE: We will make them at Sequoyah 2.
12 Some will be done during the outage as the need arises.

13 MR. ETHERINGTON: Do you have a deaerating
14 heater?

15 MR. PIERCE: No. One of our long-range
16 products is to look at the aeration of condensate. But
17 that is long range. Right now we are --

18 MR. EBERSOLE: Ralph, do you have any plans
19 that you could identify that would preclude your having
20 to do some unfortunate things with steam generators 15
21 or 20 years from now like having to take them out and
22 throw them away?

23 MR. PIERCE: That is what this is all about,
24 the control of the water chemistry to take care of the
25 steam generator denting. So this is the long-range

1 program we have here. We get the vibration modification
2 in. We control the water chemistry which has the
3 denting which has occurred on those that have had the
4 steam generator problems. So we are well aware that we
5 must control this aspect of it.

6 MR. EBERSOLE: Let me ask one more question
7 about the matter of the tubing. On the component
8 coolant heat exchanger, what affects the tubing material?

9 MR. PIERCE: On the component coolant heat
10 exchanger?

11 MR. EBERSOLE: This is the one that rejects
12 the water to service water.

13 MR. PIERCE: I would have to get you an
14 answer. I think it is stainless-steel.

15 MR. EBERSOLE: Is this carbon-steel, the tubes
16 that reject heat to service water?

17 MR. MERRICK: Ed Merrick. I do not know.

18 MR. PIERCE: I think it is stainless-steel,
19 Jesse.

20 MR. EBERSOLE: The reason I bring it up is I
21 recall a flap at Westinghouse where they did not want to
22 put three or four moderate levels and draw service water
23 and predicted dire results for them to do this. And I
24 thought that we had carbon-steel tubing in these
25 component coolant heat exchangers next to all service

1 water. Well, I will not pursue this matter. It is a
2 matter of peripheral interest.

3 MR. KERR: Is there someone who can give me a
4 two-or-three-word explanation as to why this vibration
5 problem did not show up when Westinghouse initially
6 tested the steam generators?

7 MR. SHEWMON: I am not sure they ever did
8 initially test them, but maybe Westinghouse should try
9 that one. You mean with the economizers?

10 MR. CANADA: Fred Canada, Westinghouse. The
11 original scale-model test of the steam generator, I
12 guess the best way to describe it was that when you try
13 to scale-model something of the size of a full steam
14 generator, there are certain phenomena which you observe
15 when you run the scale models and certain scale models
16 that you do not observe. And most likely this
17 particular phenomena in the inlet for the preheater was
18 not preserved in the scale-model tests.

19 MR. KERR: May I translate that to mean you
20 did not test it correctly because you did not know how?

21 MR. CANADA: Quite frankly, I think the test
22 was aimed at understanding and investigating other parts
23 of the preheater and the steam generator as a whole and
24 was not tested in the vein of anticipating this problem
25 with the inlet configuration. And hence that part of

1 the flow phenomena was not preserved when the model was
2 scaled down to a laboratory size.

3 MR. SHEWMON: Would you put that thing back on
4 the stand so you are forced to be a little further away
5 from it?

6 Any other questions?

7 MR. KERR: I am afraid to ask another one.

8 (Laughter.)

9 MR. SHEWMON: Mechanical engineering just is
10 not the exact science that instrumentation and control
11 is.

12 (Laughter.)

13 MR. EBERSOLE: Mr. Chairman, the next topic
14 would require that we vacate the room or clear it
15 because of its nature.

16 Incidentally, I am a little surprised to see
17 that on there. I take it its origin is Dr. Mark?

18 MR. MARK: No.

19 MR. EBERSOLE: I am personally willing to
20 forego that topic unless members of the committee here
21 want to go into it.

22 MR. BEAL: I think it is on there so that you
23 can ask if there is anything that you should know.

24 MR. EBERSOLE: Is there interest within the
25 committee of wanting to take up the security problem or

1 not?

2 MR. SHEWMON: It is off as far as I am
3 concerned. Anybody want it on?

4 MR. MARK: You mean drop it?

5 MR. SHEWMON: Yes.

6 MR. MARK: Well, we could ask --

7 MR. EBERSOLE: You could ask general questions.

8 MR. MARK: I did not put it on. It seems to
9 me the question that we do not need to clear the room
10 for is possibly --

11 MR. KERR: I believe your reporter would like
12 us to hold your microphone a bit further --

13 MR. MARK: One I could direct to the Staff:
14 Have they looked at it? Are they content with what they
15 found? Is it as good as --

16 MR. KERR: Browns Ferry?

17 MR. MARK: -- other plants? Or we can ask
18 that question in open session.

19 MR. SHEWMON: Let us try something newer than
20 Browns Ferry.

21 MR. MARK: Or Clinton or anything else. Are
22 they up to snuff in this regard?

23 MR. KENYON: Sir, the Staff has just recently
24 completed their review of TVA's physical security plan.
25 And there was one item that they were objecting to. The

1 Staff has made a determination just recently, verbally
2 passed on to TVA, that we will probably be imposing a
3 licensing condition. Other than that, we are satisfied
4 with it.

5 MR. MARK: You are satisfied except for two or
6 three aspects, I suppose, a matter of procedures, a
7 matter of guarding personnel, a matter of physical
8 equipment, probably those are all different types of
9 things which one would ask about. They are deficient,
10 do you think, in one or another of those fields; that
11 is, the fences or closed-circuit TVs or other such
12 things, mechanical, are not as good as you believe they
13 should be, or arrangements for guards are less good, or
14 their arrangements for scheduling people and not
15 controlling them in and out?

16 Can you say in which field you have a worry?

17 MR. KENYON: Sir, all three plants have just
18 recently been reviewed, physical security plan, the
19 safeguards contingency plan and the plant guard
20 training and qualification plan.

21 All have been accepted with the one exception
22 that the physical security plan, TVA wanted to designate
23 the containment as a nonvital area during the refueling
24 or major maintenance. And the Staff at least at the
25 moment does not believe that it can be done so.

1 MR. SHEWMON: Is this a rather different
2 request than the request at Sequoyah?

3 MR. KENYON: TVA has a slightly unique
4 situation in which they present a generic plan and then
5 attach some site-specific addenda. They are in the
6 process -- correct me if I am wrong -- they are in the
7 process of updating their Sequoyah and Browns Ferry plan
8 as well as the Watts Bar plan. But it has been covered
9 on Watts Bar just particularly as part of the normal
10 licensing review.

11 MR. SHEWMON: Is it your expectation that they
12 will clear off this condition in all three cases?

13 MR. KENYON: I guess that is up to TVA to
14 answer.

15 MR. SHEWMON: I do not know what your answer
16 was, but I would have hoped you would say yes or no.
17 The question, as I understood it, was do they already
18 have that sort of a clearance at Sequoyah? Your answer
19 was yes or no?

20 MR. KENYON: No, sir, they do not.

21 MR. SHEWMON: Although your answer did say
22 they may be coming in for it, is that what you meant?

23 MR. KENYON: I believe they have come in for
24 it.

25 MR. MILLS: Dr. Shewmon, basically what he is

1 talking about and one thing I would like to clear up is
2 when we are talking about this vital area to nonvital
3 area, it was without fuel in the core. We really made
4 this request initially on Browns Ferry when we had a
5 major torus outage out there, and it was very lengthy,
6 several months. We asked to go in and declare a vital
7 area to a nonvital area, do all this work and so forth
8 so that we did not have to go through the security
9 precautions, inspect the plant, inspect all aspects of
10 it in a very similar exact manner as we did before we
11 loaded fuel initially and then declare it a vital area
12 again.

13 That is what is in our security plan now.
14 That is what I think the Staff is talking about in
15 putting a condition on our license. And in our security
16 plan that is stated, that it will not be allowed at
17 Sequoyah or Watts Bar. We do not know whether that will
18 cause a future problem or not. We are not expecting any
19 long outages with fuel out of the core, but if we did,
20 we are not through pursuing it yet. We would make that
21 request again probably if we had a similar type
22 situation.

23 MR. MARK: It would seem to me that there is
24 nothing we want to explore here.

25 MR. MILLS: It has nothing to do with

1 equipment, personnel, or anything like that.

2 MR. MARK: Or general positions. You have
3 protection?

4 MR. MILLS: No, sir.

5 MR. MARK: It is a matter of procedures under
6 special circumstances, they either change their
7 procedure or the Staff changes its requirements.

8 MR. SHEWMON: Let me ask a different question
9 of the Staff. Where are we with regard to separation
10 of vital functions? Now, I am thinking more with regard
11 to sabotage prevention. Is there a reg guide on this
12 now? If there is, did it catch this plant? Or did this
13 one come in before that?

14 MS. ANDENSAM: Dr. Shewmon, the Staff was not
15 really prepared to discuss the physical security plan
16 with the ACRS. We do not have anyone here who is very
17 knowledgable in the physical security planning and what
18 our guidance is.

19 MR. SHEWMON: I do not know that this has
20 anything to do with physical security. It has to do
21 with plant layout with an idea toward sabotage
22 prevention and protection of vital function. That is
23 design. That does not have anything to do with how much
24 you pay our policemen or what kind of guns they carry.
25 Now, if you are still not prepared to answer it, I guess

1 that is an answer I will have to accept for today at
2 least.

3 MR. NOVAK: That is correct, sir.

4 MR. SHEWMON: Would you get back to me on that
5 so I could be a little better informed on this?

6 MR. EBERSOLE: Mr. Chairman, I want to ask a
7 question. Who in TVA comes up here or gets in the
8 proper channel the classified documents that describe in
9 some detail the actual vulnerability of the typical
10 plants and maybe yours in particular? You know that
11 such documents exist, and people like plant
12 superintendents and others need very badly to read them
13 to understand where the problem really is.

14 Who in your organization maintains a
15 familiarity with that? For instance, does the safety
16 staff? Are they aware of the security documents which
17 are not widely distributed?

18 MR. SHEWMON: It may happen to have been
19 written by people at TVA at the time.

20 MR. EBERSOLE: In fact, that is the case.

21 MR. MARK: You are referring to the NRC Sandia
22 reports of 5 or so years ago?

23 MR. EBERSOLE: That is correct. The NRC
24 Sandia reports is what I am talking about.

25 MR. SHEWMON: I would still like to see if

1 they tried to do anything on this one.

2 MR. MILLS: Mr. Ebersole, are you talking in
3 particular perhaps about the Sandia work and so forth?

4 MR. EBERSOLE: Yes, indeed, I am.

5 MR. MILLS: Our design organization is aware
6 of the ingredients of that report.

7 MR. EBERSOLE: By what means do they keep
8 aware? Is there just someone assigned to this or a
9 group? Now, is it part of your safety assessment to
10 look at security?

11 MR. CULVER: We look at the security plans
12 involved at Sandia.

13 MR. EBERSOLE: Do you look at it in all
14 aspects? Does any member of your --

15 ME. CULVER: We look at the hardware. We look
16 at the training. We look at the administrative
17 controls. We look at all parts of the security program.

18 MR. EBERSOLE: So you are still aware of the
19 Sandia articles?

20 ME. CULVER: I do not know if the man who
21 looks at security, I do not know if you have seen the
22 Sandia report. I think he has.

23 MR. SHEWMON: What I am more concerned about
24 is the degree to which the designer is worried about
25 separation so that there were not critical points. What

1 I am not getting is any particular indication that that
2 was done, although I would hope that with the design
3 organization like TVA they would stay abreast of this
4 some.

5 MR. PIERCE: Yes, sir. I am Ralph Pierce. We
6 have addressed too the separation of our safety-related
7 systems the train assignments, train A, train B,
8 separation of vital systems. And we have addressed this
9 in our design.

10 MR. SHEWMON: And is that something the NRC
11 reviews?

12 MR. PIERCE: The NRC reviews separation.

13 MR. SHEWMON: Okay. Well, maybe the Staff
14 will find out about it and get back to us.

15 MR. EBERSOLE: However, is it not true that
16 that separation was not oriented towards the security
17 aspect? It just came about that separation for other
18 reasons gave you a measure of that.

19 MR. PIERCE: I think that would be a correct
20 assessment of it.

21 MR. SHEWMON: Whether it is a fire or a guy
22 with a bag of something, either way, it helps.

23 MR. MARK: Well, the layout of Watts Bar, the
24 plan drawings of where is this and where is that, when
25 was that probably done? 1972?

1 MR. PIERCE: That is correct. The plant
2 layouts were initially made around 1972-73. You must
3 realize, too, with this vintage plant we do not have as
4 good a separation as we would like to have, and that is
5 apparent with the review we have had with the Staff.
6 Our later plants, we do have much better separation as
7 far as these circuits go.

8 MR. MARK: Well, the studies which I believe
9 Jesse was referring to and we are all picking up on,
10 were in fact done in 1966 or 1967. The Sandia reports,
11 those are still classified and discuss what they
12 consider to be sensitive points.

13 MR. EBERSOLE: Are you correct about that, Dr.
14 Mark? I thought it would be nearer 1976. You said 1966.

15 MR. MARK: What did I say?

16 MR. EBERSOLE: 1966.

17 MR. MARK: I meant 1976-77. That is what I
18 meant. When this plan was done, it was done 5 years
19 before that.

20 MR. EBERSOLE: Sure. Right.

21 MR. PIERCE: The physical layout of our plant
22 was more or less settled in the 1972-73 time frame, and
23 by 1976 we essentially had finished off all the concrete
24 work.

25 MR. MARK: That was the point I was wanting to

1 bring out. The reports which might have changed one's
2 view of the plant layout --

3 MR. PIERCE: There have been a lot of things
4 that have changed our view on separation.

5 MR. SHEWMON: Jesse, did you have concluding
6 remarks?

7 MR. EBERSOLE: One question I could ask
8 Ralph. Ralph, when you lose all the power, do you hold
9 the locks open or the locks shut or should you reveal
10 that?

11 MR. PIERCE: I do not think we should discuss
12 that.

13 MR. EBERSOLE: That is my last comment.

14 MR. MOELLER: I had a few questions I have
15 been patiently waiting to ask.

16 MR. SHEWMON: Then by all means, begin.

17 MR. MOELLER: They will not take that long.
18 But at some time I do want an answer to my earlier
19 question on the differences in the flow rate of the pumps.

20 But let me ask a couple of questions. Who in
21 TVA particularly with respect to Watts Bar keeps up with
22 LERs?

23 MR. MILLS: Keeps up with categorizing it, Dr.
24 Moeller?

25 MR. MOELLER: How do they apply to the Watts

1 Bar plant? How can you use them to your advantage?

2 MR. MILLS: I will let Bill Cottle, the plant
3 superintendent, answer that.

4 MR. COTTLE: We have an experienced review
5 group in our division central office in Chattanooga who
6 receives the inputs on LERs from the various
7 publications, NSAC, INPO, information from NRC, et
8 cetera. They do a preliminary type screening evaluation
9 on LERs as well as other experience inputs, and then we
10 get two kinds of outputs from that process at the
11 plant. One would be a simple summation that this type
12 item was looked at, and from their basic knowledge, if
13 it is very clear-cut, it is clearly not applicable to
14 Watts Bar.

15

16

17

18

19

20

21

22

23

24

25

1 The other type of information we would receive
2 from them would be in the way of a directed assignment
3 either assigning the item to the plant or its apparent
4 applicability and examination. Or if it is for more
5 hardware generic type item, we receive information if it
6 had been assigned to a particular down section
7 electrical unit section.

8 MR. MOELLER: So there is a specific person
9 who makes these assignments?

10 MR. COTTLE: Yes, sir.

11 MR. MOELLER: And for instance, at Sequoyah as
12 well as at D.C. Cook you had problems with the freezing
13 of the doors in your ice condenser. What have you done
14 at Watts Bar to prevent the problem at Sequoyah?

15 MR. COTTLE: I might point out one other
16 thing: We get direct copies of all Sequoyah reports at
17 the plant. The freezing problem at Sequoyah has been
18 primarily one of a heat tracing failure on the
19 individual air handling defrost brains, a tracing
20 failure and, to some extent, inadequate insulation on
21 those brains.

22 We are in the process, or will be in the
23 process. We have had the ice condensers down in
24 temperature. We will have a little better inspection
25 process on initially placing that in service and I think

1 treat it with a little more care procedurewise than
2 Sequoyah did in the nuclear operation. We will come to
3 the same type of upgrading as they are in the process of
4 doing at Sequoyah now.

5 MR. MOELLER: Did you make changes at Watts
6 Bar to try to reduce the ice loss, the rate of loss of
7 ice?

8 MR. COTTLE: We have received -- we are
9 working with AEP and Duke Power Company on overall icing
10 problems. For an example, we just received within the
11 last month the latest comprehensive report on Sequoyah
12 based on their heat load studies and ice sublimation
13 rates. We factor it primarily into our preventive
14 maintenance program and our daily shift check.

15 MR. MOELLER: You have not made physical
16 changes?

17 MR. COTTLE: We have made some physical
18 changes in change-outs primarily on what I call solenoid
19 handling valves on the air handling units themselves.
20 Most of the changes have been in either maintenance
21 practices or operational checks. They have not been
22 physical equipment changes.

23 MR. MOELLER: I note in the SER that you are
24 going to use gaseous and particulate rad monitors to
25 measure the leakage or one of the ways to measure the

1 leakage from the reactor coolant pressure boundary. And
2 that I think I could understand.

3 But you also for the SER says on page 9-17
4 that you are going to by analyzing the air in the
5 containment you can determine the extent of core
6 damage. Could you tell me how you do that? This is
7 post-accident, obviously, but maybe if you cannot, the
8 Staff might tell us how you are going to do it.

9 MR. COTTLE: I do not have the details with me
10 right now.

11 MR. MOELLER: Could the Staff comment on that
12 on page 9-17? How do you use air analyses within
13 containment to determine the extent of core damage?

14 MR. KENYON: I am afraid we do not have
15 anybody from the Staff to answer that.

16 MR. SHEWMON: Just out of curiosity, is there
17 anybody else from the Staff except you three here today?

18 (No response.)

19 MR. KERR: I bet they do not have anybody on
20 the Staff anywhere that could answer that question.

21 (Laughter.)

22 MR. KERR: So I do not think it would help.

23 MR. MOELLER: Okay. Another item. On page
24 9-12 they quote you as assuring us that there are no
25 cross-connections between the potable or sanitary water

1 systems and potentially radioactive water within your
2 plant. And that is fine. I assume it is true and so
3 forth.

4 However, I also looked for similar assurance
5 that there is no connections, cross-connections, between
6 service air systems and those reserved for breathing.
7 Can you give me such an assurance? Because we have had
8 problems such as that at some other plants.

9 MR. COTTLE: For the most part, our systems
10 used for breathing air are based on using Scott Air Pack
11 type equipment where we actually have a refilling
12 station located separately in the plant that we use.

13 MR. MOELLER: But now many plants or some
14 plants have in the control room centralized source
15 manifold, as I recall.

16 MR. COTTLE: Our experience with using those
17 manifolds are that they are so large and so unwieldy
18 that we have found them pretty impractical to use.

19 MR. MOELLER: What does Watts Bar have?

20 MR. COTTLE: We use Scott Air Packs. We have
21 capability for manifolds, but it is not our intention to
22 use them.

23 MR. MOELLER: Can you assure me, or has
24 someone checked to be positive that the air supply for
25 the manifold can in no way get cross-connected so that

1 radioactive material could be released?

2 MR. PIERCE: I think I can answer that. I
3 think I can answer that with a reasonable assurance, but
4 we will check it and make sure. But I am fairly certain
5 that we do not have any cross-connections of those type.

6 MR. MOELLER: The ice condenser volume at
7 Watts Bar is 100 cubic feet less than for Sequoyah.
8 Why? I mean at least that is what the SER says.

9 MR. KERR: Watts Bar is further north.
10 (Laughter.)

11 MR. MOELLER: Everything is exactly the same
12 except the ice condenser which is 110,400 cubic feet
13 instead of 110,500.

14 MR. ETHERINGTON: It sounds like thermal
15 expansion.

16 (Laughter.)

17 MR. MOELLER: Yet the rate of the ice is the
18 same? It is not a typographical error because it
19 carries through to the totals and so forth.

20 MR. COTTE: I am sure we do not have anyone
21 who could address that right now. I have no idea.

22 MR. MOELLER: One last question because I know
23 the committee wants to get on to other things. The air
24 cleaning systems for the reactor building and the
25 control room emergency system are credited with 95

1 percent iodine removal.

2 Now, the emergency gas treatment system and
3 the aux building system, they are credited for 99
4 percent radiiodine removal. Can you tell me why the
5 difference or what that is based on? That is on page
6 6-36 of the SER.

7 Or could I ask the Staff, do you have
8 different requirements for those four systems?

9 ME. CULVER: If I remember correctly, the
10 emergency gas treatment system has two banks of carbon
11 trays in series. The other systems only have one.

12 MR. MOELLER: Then is the requirement for the
13 control room less than, say, for the standby gas
14 treatment system, being the 95 versus 99?

15 ME. CULVER: The two banks were put in to
16 reduce as much as possible the effluent going out, and
17 it was not necessary to meet the requirement in the
18 control building.

19 MR. MOELLER: Okay. Can the Staff tell me if
20 that is just some tech spec requirement that there is a
21 difference there?

22 MS. ANDENSAM: Dr. Moeller, Eleanor Adensam
23 from the Staff. Could you repeat your question again?

24 MR. MOELLER: For the reactor building and
25 the control room emergency air cleaning system, they

1 stipulate a 95 percent radioiodine removal. Then for
2 the emergency gas treatment system and the aux building
3 system they specify 99 percent iodine removal. I just
4 wondered. I wanted to be informed.

5 MS. ANDENSAM: As I understand it, based on my
6 past experience, which is getting a little old and
7 rusty, the efficiencies on the filter systems are based
8 on what the filter system looks like. Then the dose
9 analyses are done after that to determine whether or not
10 that is sufficient.

11 I know past practice has been that if that is
12 not, then we go back to the applicant and require them
13 to modify their filter system to improve filter
14 efficiency. The requirement, to the best of my
15 knowledge, is not on the efficiency of the filters so
16 much as the dose consequences.

17 MR. MOELLER: Well, if someone could obtain
18 answers to some of my questions and send the committee a
19 written note, it would be helpful. It need not be too
20 formal, but I would like to have answers.

21 I will close with this very interesting
22 sentence in the SER on page 6-6, where they found that
23 the rate of ice loss in the ice condenser at Sequoyah
24 was too high. They resolved it in the following
25 manner: "This high loss rate necessitated a reanalysis

1 of the DBA to permit a reduction in the requirement of
2 the plant's tech specs."

3 That is how you administratively repair the
4 problem.

5 MR. SHEWMON: Have you left your last question
6 now?

7 MR. EBERSOLE: Mr. Chairman, I will turn it
8 back to you. I would expect TVA would like to hear an
9 observation from the committee.

10 MR. SHEWMON: Okay. Is there someone here who
11 feels we could not or should not write a letter on Watts
12 Bar at this meeting?

13 (No response.)

14 MR. SHEWMON: Then I presume we will. Thank
15 you.

16 I would like at this point to take a short
17 break, 6-minute break, and clear the room. Then we will
18 come back and read the letter.

19 (Thereupon, at 5:25 p.m., the Subcommittee was
20 adjourned.)

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/268th General Meeting

Date of Proceeding: August 13, 1982

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Jane N. Beach

Official Reporter (Typed)

Jane N. Beach

Official Reporter (Signature)

L. M. MILLS ACRS SUBCOMMITTEE PRESENTATION

I am Larry Mills, Manager of Nuclear Licensing for TVA.

The Watts Bar Nuclear Plant, which consists of two identical units, was constructed and will be operated by TVA. These units employ pressurized water reactors furnished by Westinghouse. Each unit will operate at 3411 thermal megawatts with an electrical output of 1218 megawatts. Completion of these two units will provide TVA with 7 operating nuclear units, including those currently in operation at Sequoyah and Browns Ferry Nuclear Plants, with a nuclear generating capability of approximately 8 million kilowatts of electrical power.

The Watts Bar plant site is located in East Tennessee (Slide 1). This slide also shows the locations of Sequoyah and Browns Ferry. Watts Bar is approximately 31 miles North-North East of the Sequoyah Nuclear Plant and 45 miles North-North East of Chattanooga, Tennessee. The plant site consists of a tract of approximately 1770 acres in Rhea County on the West bank of the Tennessee River. The 1770 acre reservation is owned by the United States and is in the custody of TVA. Also located within the reservation are the Watts Bar Hydro-Electric Plant and Watts Bar Steam Plant.

The contract for Watts Bar NSSS was awarded to Westinghouse on August 27, 1970, and a construction permit was issued on January 23, 1973. TVA submitted a Final Safety Analysis Report on July 1, 1976 in support of an application for an operating license. This application was docketed by the NRC on October 4, 1976. The construction completion schedule of August 1983 for unit 1 and August 1984 for unit 2 remains the same as we specified during the last ACRS Subcommittee meeting in April. This schedule includes plant modifications as a result of TMI related requirements and modifications resulting from the Sequoyah licensing review. These modifications were included at Watts Bar because of the similarities between Sequoyah and Watts Bar.


Later today we will be providing more specific information on TVA organizations and training, but briefly: Staffing of the plant operating personnel was initiated with the appointment of a Plant Superintendent in July 1976. Since that time, the staff has grown to a present level of approximately 190 engineering and maintenance employees, 65 administrative and support employees, 7 senior reactor operators, 4 reactor operators and 100 auxiliary unit operators. By fuel loading for unit 1, 2 more senior reactor operators and 12 more reactor operators will be added.

The on-site operations personnel are currently involved in becoming familiar with plant systems and equipment and operating various systems and equipment during the plant's construction test program.

Total plant staff for operation of both units will be approximately 560 people, composed of about 130 operators, 315 engineering and maintenance personnel, 120 administrative and support employees. The remainder of the plant operations personnel are being trained by the Nuclear Training Branch in the Division of Nuclear Power. TVA's training program conforms to the requirements set forth in ANSI N18.1.

When we receive a license to operate Watts Bar, TVA will have accumulated approximately 31 reactor years of operating experience from operation of Sequoyah and Browns Ferry Nuclear Plants.

A discussion of the Sequoyah-Watts Bar comparison will be provided by David Ormsby.



DAVID P. ORMSBY

The Watts Bar and Sequoyah Nuclear Plants are similar in most respects. The cores are similar and each plant utilizes a free-standing steel vessel with an ice condenser and a reinforced concrete shield building. The plant's mechanical systems, containment systems, emergency core cooling systems, instrument and control systems, electric power systems, auxiliary systems, radioactive waste systems, and steam and power conversion systems are also very similar in design and materials. Most differences are either site specific or are the result of the fact that two to three years separate the design phases of Sequoyah and Watts Bar. Although the design philosophy was the same, there were some instances when more current technology was used for Watts Bar.

This vugraph provides a table showing design differences between Watts Bar and Sequoyah. As I stated previously, there is a two-to-three year difference in the design phases for Watts Bar and Sequoyah. During that time, some design changes were made for Watts Bar which increased the efficiency of the system. There are also some instances where equipment was upgraded or provided by a different manufacturer. Some examples are as follows:

Reactor Coolant Pumps (RCP)

SON - 6,000 Horsepower pump motor
WBN - 7,000 Horsepower pump motor

copy
This difference results in an increased primary system flow rate and therefore, difference in maximum heat flux. Because of the increase in RCS flow, there is a need for greater PORV relieving capacity for load mismatch and to accommodate a 50% load rejection. The PORVs for Watts Bar are provided by a different manufacturer than those for Sequoyah.

Electrical Output

You will also note that there is an increase in turbine generator and gross electrical output. These differences are due to increased equipment and system efficiency including different steam generators.

Steam Generators

SON - Model 51
WBN - Model D3

The steam generators for the Watts Bar and Sequoyah units are similar vertical shell and U-tube evaporators with integral moisture separating equipment. The reactor coolant flows through the inverted U-tubes, entering the leaving through the nozzles located in the hemispherical bottom head of the steam generators. Steam is generated in the shell side and flows upward through the moisture separators to the outlet nozzle at the top of the vessel.

The major difference between the steam generators is that Watts Bar utilizes Model D3 series generators and Sequoyah utilizes Model 51 series generators. Inherent with this model difference are the associated differences in the feedwater entrances (i.e., preheater for Model D3 series utilized in Watts Bar and feedring for Model 51 series utilized in Sequoyah), surface areas, and U-tube design. These differences result in a secondary steam flow rate.

WATTS BAR - SEQUOYAH DESIGN FEATURES

DESIGN FEATURES	WATTS BAR	SEQUOYAH
Containment design pressure, psig	15.0	12.0
Gross electrical output, MWe	1,171	1,128 (Unit 1) 1,148 (Unit 2)
Total reactor coolant flow-rate, lb/hr	140,300,00	138,100,00
Secondary steam flow-rate, lb/hr	15,140,000	14,250,000
Reactor vessel minimum cladding thickness, in.	1/8	5/32
Maximum heat flux Btu/hr-ft ²	440,300	424,600
Reactor coolant pump flowrate, gpm	101,000	88,500
Steam generator type	W Model D-3	W Model 51
PORV-relieving capacity, lb/hr	210,000	179,000
Turbine generator output, kW	1,218,000	1,185,000
Secondary steam pressure, psia	1,000	832
Secondary steam temperature, °F	544	522

STATUS OF WATTS BAR REVIEW

- SER ISSUED - JUNE 1982
- SER CONTAINED
 - 17 OPEN ITEMS
 - 41 CONFIRMATORY ITEMS
 - 37 LICENSE CONDITIONS
 - 16 NON-TMI
 - 21 TMI
- SSER SCHEDULED TO BE ISSUED - SEPTEMBER 1982

Kenyon
T2

OPEN ISSUES REMAINING

- (1) POTENTIAL FOR LIQUEFACTION BENEATH ERCW PIPELINES AND CLASS 1E ELECTRICAL CONDUIT
- (2) BUCKLING LOADS ON CLASS 2 AND 3 SUPPORTS
- (3) PRESERVICE AND INSERVICE PUMP AND VALVE TEST PROGRAM
- (4) SEISMIC AND ENVIRONMENTAL QUALIFICATION OF EQUIPMENT
- (5) PRESERVICE AND INSERVICE INSPECTION PROGRAM
- (6) PRESSURE-TEMPERATURE LIMITS FOR UNIT 2
- (7) MODEL D-3 STEAM GENERATOR PREHEATER TUBE DEGRADATION
- (8) BTP-CSB 6-4 AND CONTAINMENT ISOLATION DEPENDABILITY (II.E.4.2)
- (9) H₂ ANALYSIS REVIEW
- (10) SAFETY VALVE SIZING ANALYSIS (WCAP-7769)
- (11) COMPLIANCE OF PROPOSED DESIGN CHANGE TO THE OFFSITE POWER SYSTEM TO GDC 17 AND 18
- (12) FIRE PROTECTION PROGRAM
- (13) QUALITY CLASSIFICATION OF DIESEL GENERATOR AUXILIARY SYSTEM PIPING AND COMPONENTS
- (14) DIESEL GENERATOR AUXILIARY SYSTEMS DESIGN DEFICIENCIES
- (15) BORON DILUTION EVENT
- (16) Q-List

ISSUE CLOSED SINCE SER ISSUANCE

- (1) PHYSICAL SECURITY PLAN

9 POSITION: POWER PLANT SUPERINTENDENT

NAME: WILLIAM T. COTTLE

EXPERIENCE SUMMARY:

A. NAVAL NUCLEAR PROPULSION PROGRAM 4 YEARS

B. NUCLEAR EXPERIENCE

FARLEY NUCLEAR PLANT 5½ YEARS

PREOPERATIONAL TEST ENGINEER

STARTUP ENGINEER

ASSISTANT OPERATIONS SUPERVISOR

OPERATIONS SUPERVISOR

OPERATING SUPERINTENDENT

LICENSED AS SRO

SEQUOYAH NUCLEAR PLANT 1 YEAR

COMPLIANCE SUPERVISOR

ASSISTANT PLANT SUPERINTENDENT

WATTS BAR NUCLEAR PLANT

PLANT SUPERINTENDENT *1 YEAR

NUCLEAR REGULATORY COMMISSION 2 YEARS

PROJECT INSPECTOR

SENIOR RESIDENT INSPECTOR

13½ YEARS

*6 MONTHS AS WBN PLANT SUPERINTENDENT AND SON ASSISTANT PLANT SUPERINTENDENT

T2, T3

POSITION: ASSISTANT PLANT SUPERINTENDENT (OPERATIONS & ENGINEERING)

NAME: ROBERT L. LEWIS

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 10 YEARS

AUXILIARY OPERATOR
STUDENT OPERATOR
ASSISTANT UNIT OPERATOR
UNIT OPERATOR
SHIFT ENGINEER

B. NUCLEAR EXPERIENCE

EGCR 6 YEARS

TRAINING & PREOPERATIONAL DUTIES
SHIFT ENGINEER

BROWNS FERRY NUCLEAR PLANT 2 YEARS

SHIFT ENGINEER

SEQUOYAH NUCLEAR PLANT 6 YEARS

ASSISTANT OPERATIONS SUPERVISOR

LICENSED AS SRO

WATTS BAR NUCLEAR PLANT 6 YEARS

OPERATIONS SUPERVISOR
ASSISTANT PLANT SUPERINTENDENT

10 YEARS - FOSSIL
20 YEARS - NUCLEAR

POSITION: ASSISTANT PLANT SUPERINTENDENT (MAINTENANCE)

NAME: EDDIE R. ENNIS

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 13½ YEARS

ENGINEER TRAINEE

POWER PLANT MAINTENANCE SPECIALIST

ASSISTANT MECHANICAL MAINTENANCE SUPERVISOR

MECHANICAL MAINTENANCE SUPERVISOR

B. NUCLEAR EXPERIENCE

WATTS BAR NUCLEAR PLANT 5 YEARS

MECHANICAL MAINTENANCE SUPERVISOR

ASSISTANT PLANT SUPERINTENDENT

COMPLETED COLD LICENSE CERTIFICATION COURSE ON SEQUOYAH NUCLEAR PLANT

13½ YEARS - FOSSIL

5 YEARS - NUCLEAR

POSITION: FIELD SERVICES SUPERVISOR

NAME: RICHARD H. ECTOR

EXPERIENCE SUMMARY:

A. NAVAL NUCLEAR PROPULSION PROGRAM 5 YEARS

B. NUCLEAR EXPERIENCE

CLINTON NUCLEAR STATION 1 YEAR
MAINTENANCE ENGINEER

BROWNS FERRY NUCLEAR PLANT 1 YEAR
OUTAGE PLANNER

SEQUOYAH NUCLEAR PLANT 3 YEARS
ASSISTANT OUTAGE DIRECTOR

WATTS BAR NUCLEAR PLANT 1 YEAR
FIELD SERVICES SUPERVISOR

11 YEARS

POSITION: OPERATIONS SUPERVISOR

NAME: GUY T. DENTON

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 15 YEARS

MATERIAL TESTER

STUDENT OPERATOR

ASSISTANT UNIT OPERATOR

UNIT OPERATOR

ASSISTANT SHIFT ENGINEER

B. NUCLEAR EXPERIENCE

BROWNS FERRY NUCLEAR PLANT 8½ YEARS

ASSISTANT SHIFT ENGINEER

SHIFT ENGINEER

LICENSED AS SRO

WATTS BAR NUCLEAR PLANT 5½ YEARS

ASSISTANT OPERATIONS SUPERVISOR

OPERATIONS SUPERVISOR

15 YEARS - FOSSIL

14 YEARS - NUCLEAR

POSITION: ASSISTANT OPERATIONS SUPERVISOR

NAME: REDFORD NORMAN, JR.

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 7 YEARS

STUDENT OPERATOR
ASSISTANT UNIT OPERATOR
UNIT OPERATOR
ASSISTANT SHIFT ENGINEER

B. NUCLEAR EXPERIENCE

SEQUOYAH NUCLEAR PLANT 4 YEARS

ASSISTANT SHIFT ENGINEER
STUDENT INSTRUCTOR

WATTS BAR NUCLEAR PLANT 6 YEARS

SHIFT ENGINEER
ASSISTANT OPERATIONS SUPERVISOR

7 YEARS - FOSSIL
10 YEARS - NUCLEAR

POSITION: ASSISTANT OPERATIONS SUPERVISOR

NAME: RICHARD E. YARBROUGH, JR.

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 20 YEARS

STUDENT OPERATOR
ASSISTANT UNIT OPERATOR
UNIT OPERATOR
ASSISTANT SHIFT ENGINEER
SHIFT ENGINEER

B. NUCLEAR EXPERIENCE

SEQUOYAH NUCLEAR PLANT 10 YEARS

SHIFT ENGINEER

LICENSED AS SRO

WATTS BAR NUCLEAR PLANT 3 MONTHS

ASSISTANT OPERATIONS SUPERVISOR

20 YEARS - FOSSIL
10 YEARS - NUCLEAR

POSITION: SPECIAL PROJECTS SUPERVISOR

NAME: DANIEL J. RECORD, SR.

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 19 YEARS

AUXILIARY OPERATOR

STUDENT OPERATOR

ASSISTANT UNIT OPERATOR

UNIT OPERATOR

ASSISTANT SHIFT ENGINEER

B. NUCLEAR EXPERIENCE

SEQUOYAH NUCLEAR PLANT 10½ YEARS

SHIFT ENGINEER

SHIFT ENGINEER TRAINING

ASSISTANT OPERATIONS SUPERVISOR

OPERATIONS SUPERVISOR

LICENSED AS SRO

WATTS BAR NUCLEAR PLANT 6 MONTHS

SPECIAL PROJECTS SUPERVISOR

19 YEARS - FOSSIL

11 YEARS - NUCLEAR

SHIFT ENGINEERS

	<u>FOSSIL</u>	<u>OTHER NUCLEAR</u>	<u>VBNP</u>	<u>COMMENTS</u>
ROBERT E. BRADLEY	7 YRS.	2 YRS.	5 YRS.	NONE
C. RICHARD COOK	6 YRS.	5 YRS.	5 YRS.	SON/3747-1
GRADY R. DAVIS	3 YRS.	4 YRS.	4 YRS.	BFN/OP 4286
EDWARD O. GAMBILL	3 YRS.	2 YRS.	5 YRS.	NUCLEAR NAVY-6 YRS.
DAVID S. KING	8 YRS.	2 YRS.	5 YRS.	NONE
LACY PAULEY	5 YRS.	5 YRS.	5 YRS.	SON/SOP 3748-1
W. DOUGLAS STEVENS	3 YRS.	7 YRS.	5 YRS.	BFN/SOP 2807
HARRY J. VOILES	7 YRS.	4 YRS.	4 YRS.	SON/SOP 3858
CARL E. WALLACE	8 YRS.	2 YRS.	5 YRS.	SON/SOP 3880
LOUIS JENKINS	28 YRS.	----	3 MOS.	NONE

ASSISTANT SHIFT ENGINEERS

	<u>FOSSIL</u>	<u>OTHER NUCLEAR</u>	<u>WBNP</u>	<u>COMMENTS</u>
GLENN T. CARVER	5 YRS.	2 YRS.	5 YRS.	NONE
M. E. HASTINGS	1 YR.	4 YRS.	5 YRS.	NONE
LEWIS E. HOWARD	1 YR.	4 YRS.	5 YRS.	NONE
JAMES C. JOHNSON	4 YRS.	1 YR.	4 YRS.	NONE
JOHN A. JUSTUS	----	1 YR.	4 YRS.	SON/OP 5405
RICHARD L. KIMBROUGH	----	----	4 YRS.	NONE
J. PATRICK MCGINNIS	----	4 YRS.	3 YRS.	BFN/OP 4833
DAVID L. McCONNEL	4 YRS.	1 YR.	5 YRS.	NONE
WILLIAM V. RUSBRIDGE	4 YRS.	6 YRS.	4 YRS.	NONE
WESLEY T. STOCKDALE	8 YRS.	----	2 YRS.	NONE
RALPH E. SCHMOOK	----	1 YR.	4 YRS.	SON/OP 5405

UNIT OPERATORS

	<u>FOSSIL</u>	<u>OTHER NUCLEAR</u>	<u>WBNP</u>	<u>COMMENTS</u>
STEVE M. BAKER	----	----	4 YRS.	NONE
SHEILAH D. BAKER	----	----	3 YRS.	NONE
D. W. BARKER	----	----	4 YRS.	NONE
J. M. CHILDERS	----	4 YRS.	2 MOS.	SON/OP 5782
W. R. COLLINS	----	----	4 YRS.	NONE
C. M. DEBLONK	----	----	3 YRS.	NONE
R. H. EVANS	----	----	3 YRS.	NONE
R. F. GALLAHER	3 YRS.	----	5 YRS.	NONE
R. W. INGLE	----	----	3 YRS.	NONE
M. H. MUIRHEAD	----	----	3 YRS.	NONE
T. L. NEWMAN	----	----	4 YRS.	NONE
R. S. SCARLETT	----	----	3 YRS.	NONE
A. E. SHULTZ	----	----	4 YRS.	NONE
J. W. SMITH	----	----	3 YRS.	NONE
G. D. STONE	----	----	5 YRS.	NONE
T. E. TUCKIER	----	1 YR.	4 YRS.	SON/OP 5781
T. D. WALLACE	----	----	3 YRS.	NONE

POSITION: DIRECTOR OF NUCLEAR POWER

NAME: HARRY J. GREEN

EXPERIENCE SUMMARY:

A. NAVAL NUCLEAR PROPULSION PROGRAM 8 YEARS

B. FOSSIL EXPERIENCE 2 YEARS
ASSISTANT PLANT SUPERINTENDENT

C. NUCLEAR EXPERIENCE

EGCR 5 YEARS

ASSISTANT TO NUCLEAR PLANT SUPERINTENDENT

NUCLEAR PLANT SUPERINTENDENT

BROWNS FERRY NUCLEAR PLANT 9 YEARS

ASSISTANT PLANT SUPERINTENDENT

POWER PLANT SUPERINTENDENT
DIRECTED RECOVERY FROM CABLE FIRE

DIVISION OF POWER PRODUCTION 2 YEARS

CHIEF, NUCLEAR GENERATION BRANCH

POWER MANAGER'S OFFICE 1 YEAR

ASSISTANT MANAGER OF POWER OPERATIONS

DIRECTOR OF NUCLEAR POWER 2 YEARS

2 YEARS - FOSSIL

27 YEARS - NUCLEAR

POSITION: ASSISTANT DIRECTOR, NUCLEAR POWER

NAME: JAMES A. COFFEY

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 8 YEARS

ENGINEERING AIDE
MECHANICAL ENGINEER

B. NUCLEAR EXPERIENCE

EGCR 8 YEARS

NUCLEAR DEVELOPMENT ENGINEER
MECHANICAL ENGINEER

BROWNS FERRY NUCLEAR PLANT 3 YEARS

ASSISTANT PLANT RESULTS SUPERVISOR

DIVISION OF POWER PRODUCTION 3 YEARS

NUCLEAR ENGINEER

NUCLEAR GENERATION BRANCH 5 YEARS

ASSISTANT TO THE CHIEF
ASSISTANT CHIEF

DIVISION OF NUCLEAR POWER 3 YEARS

ASSISTANT DIRECTOR (MAINTENANCE & ENGINEERING)

8 YEARS - FOSSIL

22 YEARS - NUCLEAR

POSITION: MANAGER, NUCLEAR PRODUCTION

NAME: TOMMY G. CAMPBELL

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 6 YEARS
ENGINEERING AIDE

B. NUCLEAR EXPERIENCE

BROWNS FERRY NUCLEAR PLANT 8 YEARS
MECHANICAL ENGINEER (CONST)
OUTAGE DIRECTOR
NUCLEAR ENGINEER

DIVISION OF NUCLEAR POWER 3 YEARS
CHIEF, OUTAGE MANAGEMENT BRANCH
MANAGER, NUCLEAR PRODUCTION

6 YEARS - FOSSIL

11 YEARS - NUCLEAR

POSITION: ASSISTANT NUCLEAR PRODUCTION MANAGER

NAME: HERBERT L. ABERCROMBIE

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 17 YEARS

OPERATOR TRAINING
STUDENT OPERATOR
ASSISTANT UNIT OPERATOR
UNIT OPERATOR
ASSISTANT SHIFT ENGINEER
SHIFT ENGINEER
PERSONNEL OFFICER (GIVING EXAMS)
POWER PLANT OPERATIONS SPECIALIST

B. NUCLEAR EXPERIENCE

SEQUOYAH NUCLEAR PLANT 7 YEARS
OPERATIONS SUPERVISOR

BROWNS FERRY NUCLEAR PLANT 4 YEARS
ASSISTANT PLANT SUPERINTENDENT
PLANT SUPERINTENDENT

DIVISION OF NUCLEAR POWER 1 YEAR
ASSISTANT NUCLEAR PRODUCTION MANAGER

17 YEARS - FOSSIL

12 YEARS - NUCLEAR

POSITION: CHIEF, MECHANICAL BRANCH

NAME: THOMAS F. ZIEGLER

EXPERIENCE SUMMARY:

A. FOSSIL EXPERIENCE 2 YEARS
MECHANICAL ENGINEER TRAINEE

B. NUCLEAR EXPERIENCE

BROWNS FERRY NUCLEAR PLANT 1 YEAR
ASSISTANT OUTAGE DIRECTOR

DIVISION OF POWER PRODUCTION 6 YEARS
MECHANICAL ENGINEER
SUPERVISOR, REACTOR AND AUXILIARY SECTION

DIVISION OF NUCLEAR POWER 3 YEARS
CHIEF, NUCLEAR MAINTENANCE BRANCH
CHIEF, MECHANICAL BRANCH

2 YEARS - FOSSIL
10 YEARS - NUCLEAR

POSITION: CHIEF, REACTOR ENGINEERING BRANCH

NAME: THOMAS D. KNIGHT

EXPERIENCE SUMMARY:

A. NUCLEAR EXPERIENCE

WESTINGHOUSE - ELECTRIC CORPORATION 6 YEARS

NUCLEAR ENGINEER

TVA - DIVISION OF POWER PRODUCTION 7 YEARS

NUCLEAR ENGINEER

SUPERVISOR, NUCLEAR SECTION

SUPERVISOR, REACTOR ENGINEERING STAFF

DIVISION OF NUCLEAR POWER 3 YEARS

CHIEF, REACTOR ENGINEERING BRANCH

16 YEARS - NUCLEAR

POSITION: CHIEF, ELECTRICAL AND INSTRUMENT AND CONTROLS BRANCH

NAME: HUBERT B. BOUNDS

EXPERIENCE SUMMARY:

A. U. S. NAVY 4 YEARS

ELECTRONICS TECHNICIAN (RADAR)

B. HAYES INTERNATIONAL CORP - SPERRY RAND 7 YEARS

ENGINEERING TECHNICIAN AND PROGRAMMER

C. TVA - ENGINEERING DESIGN 8 YEARS

ELECTRICAL ENGINEER

D. NUCLEAR EXPERIENCE

DIVISION OF NUCLEAR POWER 2½ YEARS

ACTING CHIEF, NUCLEAR MAINTENANCE BRANCH

SUPERVISOR, ELECTRICAL EQUIPMENT GROUP

CHIEF, ELECTRICAL AND INSTRUMENT AND CONTROLS BRANCH

8 YEARS - DESIGN

2½ YEARS - NUCLEAR

POSITION: SENIOR ENGINEER

NAME: RICHARD A. SESSOMS

EXPERIENCE SUMMARY:

A. NUCLEAR EXPERIENCE

U. S. NAVY 2 YEARS

NUCLEAR MAINTENANCE, REPAIR AND RESEARCH

FLORIDA POWER & LIGHT 4 YEARS

PLANT ENGINEER

TVA - DIVISION OF POWER PRODUCTION 7 YEARS

INSTRUMENT ENGINEER

SUPERVISOR, CONTROLS SECTION

DIVISION OF NUCLEAR POWER 3 YEARS

CHIEF, CONTROLS AND TEST BRANCH

CHIEF, TECHNICAL SERVICES BRANCH

SENIOR ENGINEER

16 YEARS - NUCLEAR

NUCLEAR SAFETY REVIEW STAFF

DISCUSSION OF PROGRAM

Presented By
H. N. Culver
Director, NSRS

8/13/82

74

FOLLOWING TMI, TVA ESTABLISHED A TASK FORCE TO IDENTIFY ACTIONS THAT COULD BE TAKEN TO FURTHER STRENGTHEN AND IMPROVE THEIR OVERALL NUCLEAR PROGRAMS.

YOU ARE AWARE OF THE FINDINGS OF THIS TASK FORCE . . . ACTIONS RELATING TO DESIGN, OPERATIONS, ORGANIZATION.

ONE OF THE ACTIONS WAS TO CREATE THE TVA NUCLEAR SAFETY REVIEW STAFF. MY REMARKS ARE DIRECTED AT PROVIDING YOU WITH A BRIEF DESCRIPTION OF THE EXISTING STAFF AND WHAT WE HAVE BEEN DOING AND WHAT WE WILL BE DOING IN THE FUTURE.

THE FUNCTIONS OF THE STAFF ARE SHOWN IN THE FIRST VIEWGRAPH

VIEWGRAPH #1

YOU CAN SEE THE STAFF HAS THE RESPONSIBILITY TO BECOME INVOLVED WITH ALL ASPECTS OF THE TVA NUCLEAR PROGRAM. A LITTLE LATER IN THE PRESENTATION YOU WILL SEE WE DO IN FACT GET INVOLVED WITH MOST OF THESE ACTIVITIES.

AS A POINT OF CLARIFICATION, NSRS DOES NOT REPLACE ANY OF THE LINE FUNCTIONS IN TVA. RATHER, IT IS AN ADDITIONAL OVERVIEW FUNCTION BEYOND REGULATORY REQUIREMENTS --- OR SOME THINK OF US AS ANOTHER GROUP SIMILAR TO I&E, ONLY OPERATING WITHIN TVA.

THE NSRS DURING THE PAST 2-1/2 YEARS HAS BEEN INVOLVED WITH MANY OF THE FUNCTIONS I HAVE SHOWN. IN ORDER TO ACCOMPLISH THESE TASKS THE STAFF WAS ORGANIZED WITH TWO OBJECTIVES-- INDEPENDANCE AND BROAD EXPERTISE.

SOME FACTS REGARDING NSRS ARE SHOWN IN THE NEXT VIEWGRAPH.

VIEWGRAPH #2

NOW REGARDING WHAT OUR INVOLVEMENT HAS BEEN.

VIEWGRAPH #3

I WOULD LIKE TO AMPLIFY A LITTLE REGARDING OUR MANAGEMENT REVIEWS. AS INDICATED, WE HAVE MADE SEVERAL OF THESE. THE NEXT 2 VIEWGRAPHS INDICATE WHAT THESE CONSIST OF

VIEWGRAPH #4

VIEWGRAPH #5

I WANT TO NOW INDICATE WHAT WE DO WITH OUR REPORTS AND HOW WE FIT IN WITH THE TVA ORGANIZATION.

ALL OF OUR REPORTS DEALING WITH THE LINE ORGANIZATION ARE PROVIDED TO LINE MANAGEMENT INDICATING OUR FINDINGS AND RECOMMENDATIONS. THESE REPORTS REQUIRE A RESPONSE--USUALLY IN 30 DAYS. THESE ITEMS ARE FOLLOWED UNTIL THERE IS CLOSEOUT.

OUR REPORTS MAY ALSO GO TO THE GM AND/OR THE BOARD EITHER BY COPY OF THE ORIGINAL OR IN SOME CONDENSED FORM.

THE GM AND BOARD ARE WELL AWARE OF OUR ACTIVITIES, FINDINGS, AND THE DEGREE OF RESOLUTION OF PROBLEMS. THE GM AND BOARD ARE SUPPORTIVE AND MORE INVOLVED IN THE NUCLEAR PROGRAM AS A RESULT OF THE NSRS PROGRAM.

WHAT I HAVE TALKED ABOUT UP UNTIL NOW BASICALLY RELATES TO THE NSRS ACTIVITIES ADDRESSING THE REVIEW AND EVALUATION OF THE PERFORMANCE OF THE LINE ORGANIZATION. OTHER FUNCTIONS ASSIGNED TO NSRS HAVE BEEN LIMITED DURING THE PAST TWO YEARS.

CHANGES ALREADY UNDERWAY WITHIN TVA WILL RESULT IN LESS NEED FOR DETAILED REVIEWS OF THE TYPE I HAVE PREVIOUSLY DESCRIBED. FUTURE ACTIVITIES WILL BE DIRECTED TOWARD UNRESOLVED SAFETY ISSUES, PRA, AND SAFETY POLICY DEVELOPMENT.

THIS CONCLUDES MY STATEMENTS REGARDING OUR PROGRAMS AND OUR INVOLVEMENT WITH SAFETY ISSUES WITHIN TVA.

KEEP4:R

FUNCTIONS OF THE NSRS

- INDEPENDENT REVIEW OF NUCLEAR PLANT DESIGN
- INDEPENDENT MONITORING OF NUCLEAR PLANT CONSTRUCTION
- INDEPENDENT MONITORING OF NUCLEAR PLANT OPERATIONS
- REVIEW OF NUCLEAR PLANT EMPLOYEE TRAINING
- REVIEW OF RADIOLOGICAL EMERGENCY PLANS
- REVIEW AND AUDIT OF RADIATION PROTECTION
- INVESTIGATION AND REVIEW OF OPERATING EVENTS OR INCIDENTS
AT TVA PLANTS OR OTHER PLANTS
- RECEIPT AND INVESTIGATION OF EMPLOYEE CONCERNS ABOUT
SAFETY ISSUES NOT ADEQUATELY ADDRESSED BY LINE
MANAGEMENT

NSRS TECHNICAL STAFF BACKGROUND

STAFF RECRUITED FROM

Outside TVA - 12	Within TVA - 9
● NRC 6	● EN DES 2
● DOE 2	● CONST 3
● Utilities 3	● NUC PR 3
● Other 1	● PSS 1

STAFF NUCLEAR EXPERIENCE

<u>Staff No.</u>	<u>Years</u>
1	0-5
4	6-10
8	11-15
4	16-20
2	21-25
2	26-30
Avg.	14.7
Total Man-Years	= 308
Number of Technical Staff	= 21

EXPERIENCE BACKGROUND (Man-Years)

● DESIGN	57
● CONSTRUCTION	26
● OPERATION	117
● REGULATORY/AUDIT	108

NSRS REVIEWS COMPLETED 1980-1982

MANAGEMENT REVIEWS

OFFICE OF POWER (BFN)	1
OFFICE OF HEALTH AND SAFETY (BFN)	1
DIVISION OF PURCHASING (BLN)	1
OFFICE OF ENGINEERING DESIGN AND CONSTRUCTION	2
PUBLIC SAFETY SERVICE	1
QUALITY ASSURANCE PROGRAMS	<u>1</u>
TOTAL	7

ROUTINE OR SPECIAL REVIEWS


OPERATIONS

● STARTUP PROGRAM	2
● TRAINING	2
● SECURITY	2
● EMERGENCY PLANNING	3
● ROUTINE	16
● EMPLOYEE CONCERNS	2
● OTHER SPECIAL REVIEWS	<u>10</u>
TOTAL	37

DESIGN/CONSTRUCTION

● PIPE HANGERS AND SUPPORTS	3
● QA PROGRAM REVIEWS	2
● INTERFACE CONTROLS	2
● SPECIAL REVIEWS	3
● EMPLOYEE CONCERNS	<u>2</u>
TOTAL	11

MANAGEMENT EVALUATION TREE



FUNCTIONAL AREAS REVIEWED DURING
MANAGEMENT REVIEW OF OEDC

- MANAGEMENT CONTROLS
- QUALITY ASSURANCE
- TRAINING AND QUALIFICATIONS OF PERSONNEL
- INTERFACE CONTROLS
- DESIGN PRCESS CONTROLS
- CONFIGURATION CONTROL
- CORRECTIVE ACTION
- RECORDS AND DOCUMENT CONTROL
- PROCUREMENT
- SCHEDULING OF CONSTRUCTION ACTIVITIES
- ASME SECTION III QA PROGRAM
- SPECIAL PROCESS CONTROLS
- EQUIPMENT AND FACILITIES CONTROL

NSRS PROGRAM ELEMENTS

<u>PROGRAM ELEMENT</u>	<u>%</u>
INTERFACE PROGRAM WITH EXTERNAL SAFETY ORGAN	13
GENERIC & UNRESOLVED SAFETY ISSUES	15
REGULATORY REQUIREMENTS	13
PROBABILISTIC RISK ASSESSMENT	13
EMPLOYEE CONCERN PROGRAM	4
INVESTIGATION PROGRAM	32
NUCLEAR SAFETY RELATIONS PROGRAM	4
TRAINING	6

IDENTIFIED PROBLEMS

- PRIOR TO 1980

- 1980 - 1981 TIMEFRAME

- HVAC

- WELDING

- TRANSFER TO OPERATOR

- MORALE

Beasley
T5

STEPS TAKEN TO CORRECT

- EACH IDENTIFIED DEFICIENCY CORRECTED
- PROCEDURES
- REINSPECTIONS
- REWORK AND NCRs

CURRENT STATUS

- QA PROGRAM BACK ON TRACK

- SOME CORRECTIVE ACTION STILL BEING FORMULATED

- SOME CORRECTIVE ACTION STILL BEING IMPLEMENTED

- RECENT NCRs ON ANALYSES

- 1982 QUALITY ACTION PLAN

- FEEL THAT WE HAVE IDENTIFIED ALL THE HOLES IN OUR PROGRAM

INDEPENDENT REVIEW

- NSRS REVIEWS
- NSRS RECOMMENDATION
- REGION II RECOMMENDATION
- ARRANGING FOR INDEPENDENT REVIEW
 - OBJECTIVE TO ENABLE TVA MANAGEMENT TO CONCLUDE DESIGNED AND CONSTRUCTED IN ACCORDANCE WITH LICENSE APPLICATION
 - REVIEW AND FINDINGS AVAILABLE TO NRC
 - SCOPE
 - COMPLETE BY END OF YEAR

COMPARISON WITH OTHER TVA PLANTS

- NOT THAT DIFFERENT

- EXCEPTIONS

 - HVAC

 - MORALE - MANAGEMENT CONTROL

- COMPARISON OF NSRS REPORTS

CONCLUSIONS

- QA PROGRAM IS ON A COURSE OF ACTION THAT WILL PROVIDE AND DOCUMENT SATISFACTORY PLANT
- HAVE A LOT OF WORK TO DO
- OEDC CONFIDENT
 - HAVE AN EXCELLENT PLANT
 - QUALITY PROBLEMS ARE BEING RESOLVED
 - INDEPENDENT REVIEW WILL CONFIRM DESIGN - CONSTRUCTION PROCESS

SEISMIC QUALIFICATION

- ALL SAFETY-RELATED ELECTRICAL AND MECHANICAL EQUIPMENT HAS BEEN SEISMICALLY QUALIFIED TO LEVELS WHICH ENVELOPE CONDITIONS DEFINED FOR ITS "AS-INSTALLED" CONFIGURATION.
- TVA'S EQUIPMENT SEISMIC QUALIFICATION PROGRAM IS IN FULL COMPLIANCE WITH NRC AND INDUSTRY RECOMMENDED PROCEDURES, GUIDES, CODES, AND STANDARDS--AND GOOD ENGINEERING PRACTICE.
- EQUIPMENT QUALIFICATION REPORTS PROVIDE A CONSERVATIVE DEMONSTRATION THAT THE EQUIPMENT IS CAPABLE OF WITHSTANDING ITS PRESCRIBED SEISMIC CONDITIONS.
- THE CURRENT PHILOSOPHY REGARDING SEISMIC QUALIFICATION THROUGHOUT THE INDUSTRY, TVA'S PROGRAM AS TYPICAL, DOES NOT REQUIRE THAT THE EFFORT BE EXTENDED TO DETERMINE HOW MUCH BETTER THE EQUIPMENT IS THAN IT NEEDS TO BE; NOR DOES THE QUALIFICATION DATA LEND ITSELF TO THE EXTRACTION OF SUCH INFORMATION.
- THE SEISMIC QUALIFICATION PROGRAM AS WE KNOW IT CANNOT BE TRANSFORMED INTO AN EQUIPMENT RELIABILITY PROGRAM. REEVALUATION EFFORT WOULD PROVIDE INDICATIONS OF MARGINS OF CONSERVATISM IN QUALIFICATION OF SPECIFIC ITEMS OF EQUIPMENT.

TJ Williams

SEISMIC MARGIN OF CONSERVATISM

TVA PROGRAMS

- SEQUOYAH NUCLEAR PLANT - REEVALUATION OF EQUIPMENT QUALIFICATION AGAINST THE HIGHER SEISMIC LEVELS OF THE SITE SPECIFIC SPECTRA DEMONSTRATED THAT QUALIFICATION HAD BEEN ACCOMPLISHED WITH A FACTOR OF CONSERVATISM OF AT LEAST 1.5.
- BROWNS FERRY NUCLEAR PLANT - PROBABILISTIC RISK ASSESSMENT STUDY INCLUDED THE CONSIDERATION OF EQUIPMENT SEISMIC QUALIFICATION. STUDY FOUND THAT MOST EQUIPMENT REFLECTED LARGE MARGINS OF CONSERVATISM BEYOND THE PRESCRIBED SEISMIC CONDITIONS; THE WEAKEST LINK IS RELAY CHATTER IN ELECTRICAL EQUIPMENT.
- WATTS BAR NUCLEAR PLANT - PROBABILISTIC RISK ASSESSMENT TO BE ACCOMPLISHED-- CURRENT SCHEDULE, TARGET COMPLETION DATE MAY 1984.

MINIMUM FACTORS OF CONSERVATISM OF BROWNS FERRY EQUIPMENT

<u>COMPONENT</u>	<u>FACTOR OF CONSERVATISM***</u>
250 VDC CIRCUIT BREAKER BOARD	1.4*/5.45**
REACTOR PRESSURE VESSEL INTERNALS	2.45
DIESEL GENERATOR TRANSFORMERS	2.5
CONTROL ROD DRIVE HOUSING	3.85
.	
.	LARGER
.	

*RELAY CHATTER

**BREAKER TRIP

***FACTOR OF CONSERVATISM = $FC_E \cdot FR_S \cdot FR_E$

WHERE:

FC_E = EQUIPMENT CAPACITY FACTOR = STRENGTH/LOAD

FR_S = STRUCTURAL RESPONSE FACTOR = TEST RESPONSE/ACTUAL RESPONSE

FR_E = EQUIPMENT RESPONSE FACTOR = DESIGN FLOOR SPECTRA/ANTICIPATED ACTUAL SPECTRA

SEISMIC MARGIN OF CONSERVATISM (CONTINUED)

GENERIC PROGRAMS

- SEISMIC SAFETY MARGIN RESEARCH PROGRAM, SSMRP, LAWRENCE LIVERMORE LABORATORY (NUREG/CR-2405) - EXTENSIVE RESEARCH PROGRAM INCLUDED CONSIDERATION OF EQUIPMENT FRAGILITIES.

AN IMPORTANT OBSERVATION . . . IS THAT MOST MECHANICAL AND ELECTRICAL EQUIPMENT IS INHERENTLY RUGGED AND WILL SURVIVE ACCELERATION LEVELS FAR IN EXCESS OF BUILDING RESPONSES ASSOCIATED WITH THE SAFE SHUTDOWN EARTHQUAKE.

- SEISMIC DESIGN MARGINS OF PUMPS, VALVES, AND PIPING (NUREG/CR-2137) - STUDY TO ESTABLISH MARGIN OF CONSERVATISM INHERENT IN CODE DESIGN OF FLUID SYSTEM COMPONENTS--MARGINS LISTED INDICATE LOWER BOUND.

MINIMUM FRAGILITY VALUES OF ZION* EQUIPMENT

<u>COMPONENT</u>	<u>FACTOR OF CONSERVATISM</u>
125 VAC DISTRIBUTION PANEL	3.5
SERVICE WATER PUMPS	3.7
4160 V SWITCHGEAR	4.2
.	
.	LARGER
.	

*REFERENCE PLANT FOR SSMRP

DESIGN MARGINS OF PUMPS, VALVES, AND PIPING
(NUREG/CR-2137)

NOMINAL MARGINS

FAILURE CRITERIA	ASME CODE, FOR PRESSURE BOUNDARY INTEGRITY		AISC MANUAL, FOR SUPPORTS	
	OBE	SSE	BASIC	SEISMIC
BREAK	3.0 TO 10.4	1.43 TO 5.2	2.6 TO 3.1	2.0 TO 2.3
YIELD	1.1 TO 4.8	0.55 TO 2.4* 1.1 TO 4.8**	1.67	1.25

*NORMAL MARGINS FOR PRESSURE BOUNDARY INTEGRITY ONLY--SERVICE LEVEL D

**NORMAL MARGINS FOR OPERABILITY ASSURANCE--SERVICE LEVEL B

NOMINAL MARGIN ON YIELDING = S_Y/S_A

NOMINAL MARGIN ON BREAKING = S_U/S_A

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2

ACRS PRESENTATION

by C. F. Bowman

Cement Mortar Lining

of the

Essential Raw Cooling Water System

Yard Piping

1.0 History

1.1 Problem Definition

While preoperational testing the emergency equipment cooling water (EECW) system at Browns Ferry Nuclear Plant during the summer of 1976, certain heat exchangers were found to be receiving inadequate cooling water flow due to a buildup of corrosion products in the interior of the carbon steel piping servicing the equipment. Since carbon steel piping was extensively used in both safety-related and nonsafety-related piping systems at other TVA nuclear plants, a study was undertaken to determine the pervasiveness of this problem in the TVA system and to develop recommended practices to mitigate its effects.

T9

1.2 Sampling Program

Approximately 50 sections of carbon steel raw water piping were removed from nine different TVA steam plants. Both normally stagnant and normally flowing piping systems, as well as both vertical and horizontal runs of pipe, were sampled.

In virtually every case, the primary mechanism was found to be corrosion of the steel piping by aerated river water and redeposition of the corrosion products. The problem was found to a significant degree at all plants that were sampled. The result is random pitting in the pipe wall and the formation of a tubercle over each pit.

The equivalent average diameter reduction as a result of corrosion products buildup as a function of years of service is shown on Figure 1. The deposit in each sample was removed and analyzed for various constituents. In virtually every case, it was found to be principally iron oxide.

1.3 Pressure Drop Tests

Tests were performed at the Widows Creek, Kingston, and Gallatin steam plants to evaluate the effects of corrosion product buildup on pressure drop. The sites were selected to cover a range of ages as well as a variety of water sources. Samples removed from

each test line were analyzed to determine the percent volume reduction of the pipe interior due to the corrosion product buildup. The corresponding diameter reduction for each test line was then used with the pressure drop test data to develop appropriate equations for pressure drop.

Several figures were generated in an attempt to find a correlation between diameter reduction and Hazen-Williams C. Values of C were assumed and corresponding values of diameter were calculated for each test. A dimensionless parameter, d^* , was defined for use in correlating the above calculated value of d with the measured value of diameter reduction.

$$d^* = \frac{(d_{NOM} - d_{CALC})}{\Delta d_{MEAS}}$$

$$= \frac{\text{Calculated Diameter Reduction}}{\text{Measured Diameter Reduction}}$$

Using this relationship for each of the three pressure drop tests conducted as shown in Figure 2, good agreement was discovered for values of $d^* = 2$ and $C = 57$. We have adopted a slightly more conservative value of $C = 55$ as our design value. The result is a modified Hazen-Williams equation

$$h_L = \frac{0.63Q^{1.85}}{(d_{NOM} - 2 \times \Delta d_{MEAS})^{4.8655}}$$

Figure 3 shows the comparison between the predictive model and actual test data taken on a 3-inch line at Widows Creek. Note also the head loss predicted by the normally used Hazen-Williams

C = 100. Similar comparisons are presented for the tests conducted at Kingston and Gallatin and are shown on Figures 4 and 5, respectively.

1.4 Corrective Action

TVA is now using this equation to evaluate the heat rejection system, fire protection system, raw cooling water system, and raw service water system at Watts Bar Nuclear Plant. Most significantly, however, we have completed our evaluation of the Watts Bar ERCW system, and the remainder of this presentation discusses results of that evaluation.

The analysis of the ERCW system determined that delivery of design flow rate to system users over plant life could not be guaranteed with the original design. Consequently, changes were defined to bring the system within the 40-year design basis. Figure 6 shows the changes being made in the ERCW system. They include

1. Replacement of selected segments of carbon steel piping within the buildings with stainless steel.
2. Requalifying certain system users to a lower ERCW flow rate by refinement of the heat transfer design calculations.

3. Applying a cement mortar lining to existing carbon steel piping in the yard in situ.

2.0 Experience with Cement Mortar

Before making the final decision to cement mortar line the ERCW system yard piping, a telephone survey was conducted to determine how well it has performed in service. Table I shows a total of 11 other utilities, 2 A-E's, and 5 municipal water systems which have cement mortar lined piping in service and which were canvassed. Although a few problems were reported, in general the experience reported was very good. All of the problems identified could be attributed to either the pipe being out of round or a failure to properly protect the pipe joints. In one instance lined pipe went through the San Fernando earthquake of 1971 which leveled buildings but only caused damage to the cement mortar lining where the pipe itself was plastically deformed.

3.0 Installation of Cement Mortar

The procedure for applying the cement mortar lining requires that the piping first be cleaned by scraping off existing tubercles.

Thereafter, the mortar is centrifugally applied from a spinning head and immediately troweled onto the inside surfaces using a machine which is pulled through from one end. Closure pieces and certain elbows are thereafter hand mortared to complete the process. The closure weld-affected region is hand lined from inside the pipe.

Humidity is carefully controlled after application to ensure proper curing, and each foot of piping is carefully inspected prior to plant operation.

TVA specified the necessary level of quality assurance on the lining process, and a number of nonconformances to the specifications have occurred. These have included:

- High and low mortar slump
- High mortar temperature
- Low mortar compressive strength
- Low relative humidity
- Surface cracks
- Mortar applied too thin
- End caps not replaced
- Pipe damage
- Exterior coating damage

Where appropriate, repairs have been made in accordance with approved procedures.


4.0 Surveillance of Cement Mortar Lining

Very good experience has been reported with cement mortar lining by other utilities. However, since this is the first application by TVA and since the ERCW system is a Safety Class 3 system, provision is being made in the design to facilitate periodic inspection of a portion of the system after it has been placed in service.

FIGURE I
 AVERAGE DIAMETER REDUCTION
 VERSUS
 SERVICE LIFE FOR FLOWING
 AND STAGNANT SAMPLES

DECREASE IN DIAMETER, INCHES

* SAMPLE TAKEN FROM A
 NORMALLY STAGNANT LINE



d#, CALCULATED DIAMETER REDUCTION / MEASURED DIAMETER REDUCTION







FIGURE -2
CORRELATION OF PARAMETERS
FOR USE IN
HAZEN-WILLIAMS EQUATION







CORRECTIVE ACTIONS:

- 1. STAINLESS STEEL**
- 2. LOWER FLOWRATE**
- 3. CEMENT MORTAR LINING**

FIGURE 6

TABLE I

Survey of Operating Experience for Cement Mortar Lining

Utilities

Consolidated Edison¹
Potomac Electric Power
Long Island Power
Cincinnati Gas and Electric²
Southern California Edison³
Florida Power and Light²
Sacramento Municipal Utility
Carolina Power and Light¹
Los Angeles Water and Power⁴
Pacific Power and Light
Pacific Gas and Electric

A and E

Bechtel
Ebasco

Municipal Water Systems

City of Pasadena
City of Norfolk
City of Newport News
City of San Francisco
Seattle Water Department

1. Carbon steel pipe prelined with cement mortar using brackish water failed at uncoated welded joints or uncoated flanged joints.
2. Cement mortar lining in 9-foot CCW failed in a transition section and a severely out-of-round section of pipe.
3. Extremely old section of riveted pipe had lining failure after 25 years in some out-of-round sections.
4. During 1971 earthquake, cement mortar lining failed only where piping suffered plastic deformation.

STEAM GENERATOR VIBRATION MODIFICATIONS

D-3 MODEL - WBNP

TVA became aware of the tube wear problem due to flow induced vibration in November 1981 and began working with Westinghouse relative to the WBN units.

The discovery of tube wear problem was at Ringhals Unit 3 in October 1981 in Sweden. Sweden has since constructed two full scale models of a portion of preheater section of Model D-3 generator at its Hydraulics Laboratory.

In March-April 1982, Westinghouse entered into agreements with Sweden to have certain baseline and confirmatory tests performed as a part of development of design modification for D-2, D-3 generators. Test specifications, procedures, and quality assurance requirements were prepared by Westinghouse. Operation of the model has been by Sweden. Final data processing and evaluation has been performed by Westinghouse in the U.S.

During week of June 1, 1982, the model was in near readiness for starting baseline testing of existing D-3 design, when an overpressure event caused substantial damage and delay.

The model was placed in equivalent full-flow operation on June 22, 1982. Data collection and processing, including high speed photography, began.

Based on evaluation in U.S. and at site, initial baseline testing began on June 25, 1982.

While the evaluation of the design of the modification was being performed, TVA began an economic evaluation of the options of making the modifications prior to fuel loading versus operating at 50% power level through the first refueling outage. It was determined that it would be to TVA's economic advantage to delay fuel loading and do the modification prior to fuel loading and specifically prior to hot functional testing. Based on preliminary information from Westinghouse, it was determined that we had a high probability of obtaining an acceptable design, testing, and performing the work by Westinghouse prior to November 3, 1982. The WBN schedule was adjusted to reflect this.

PROGRESS TO DATE

1. Full flow test of model D-3 first full manifold design is complete. This establishes a baseline for comparison purposes.
2. D-3 design full flow test to be rerun with force gauges in approximately four tubes in August 1982.
3. Based on model testing and analytical work W has a high level of confidence that the optimized test manifold design will be the production model.
4. Optimized manifold full flow test of the production model is now scheduled to begin the week of September 30, 1982.

5. W has informed TVA that the testing and installation schedule for Watts Bar will be finalized by August 30, 1982.

If there is any significant change in the Westinghouse schedule for a final modification, TVA will make another economic evaluation relative to the place in the schedule that the modification should be made.

TVA is working with Duke and South Carolina Power on the optimum time that the modifications could be made at the first three domestic plants.

TVA and Westinghouse will keep the NRC staff informed on the developments.

FULL SCALE TESTING
AND QUALIFICATION
OF
CEMENT—MOTAR LINED
CARBON STEEL PIPE

CEB 82-8

T10-Hand







FIG. 1 LINING SEQUENCE AND DIRECTION




#24 - 30" Pipe lining machine -
front view




#38 - Elbow lining




#116 - Three-edge bearing test -
loading machine set up



#158 - Three-edge bearing test -
30" Pipe, after loading,
fully cured (11 days)




#160 - Three-edge bearing test -
30" Pipe, before loading,
fully cured (16 days)




#164 - Three-edge bearing test -
30" Pipe, after loading,
fully cured (16 days)




#299 - Torsion test - Initial
setup



#325 - Bending test on the 30'
pipe - Initial setup




#241 - Impact test - Missile drop
in progress



#253 - Impact test - 30" Pipe -
14' Drop




#255 - Impact test - 30" Pipe -
14' Drop




#329 - Drop test - 30' Pipe



#333 - Tests on elbow - Initial
setup



#403 - Field test - Loading
6th cut



#117 - Installation of
accelerometer on pipe





FIG. 2 ACCELERATION TIME HISTORIES AND FOURIER AMPLITUDE SPECTRA



(Earthquake Engineering Research Laboratory, California Institute of Technology, "Analysis of Strong Motion Earthquake Accelerograms, Vol. IV-Fourier Amplitude Spectra," August 1972)

FIG. 10 FOURIER AMPLITUDE SPECTRUM CALCULATED FROM TYPICAL EARTHQUAKE ACCELERATION TIME HISTORY