



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

August 11, 1982

1CAN088202

Director of Nuclear Reactor Regulation
ATTN: Mr. J. F. Stoltz, Chief
Operating Reactors Branch #4
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Questions on the Emergency
Feedwater System Upgrade
Reliability Analysis

Gentlemen:

Your letter of April 21, 1982, (1CNA048212) requested additional information pertaining to the report "Emergency Feedwater (EFW) System Upgrade Reliability Analysis for Arkansas Nuclear One, Unit No. 1". In AP&L's letter of May 26, 1982, (1CAN058211) we proposed to submit the requested information by August 15, 1982. Therefore, attached is our response.

Very truly yours,

A handwritten signature in black ink that reads "John R. Marshall".

John R. Marshall
Manager, Licensing

A001
1/20

Apex. Dist

JRM:MCS:sc
MM

Attachments

8208170129 820811
PDR ADDOCK 05000313
P PDR

ADDITIONAL INFORMATION
CONCERNING
EMERGENCY FEEDWATER UPDRAGE RELIABILITY ANALYSIS
FOR
ARKANSAS NUCLEAR ONE, UNIT NO. 1
DOCKET NO. 50-313

Question 1

"The report's results are not presented in a manner that lends itself to a "NUREG-0611-type" comparison. For example, unavailability given LOOP is not tabulated. LOOP appears as a basic event on the fault tree; was this entered as the probability of LOOP given LMFW? How was this handled?"

Response 1

The presentation of these results in the format of NUREG-0611 does not imply that comparisons to NUREG-0611 are appropriate. Because the scope and assumptions of the analysis are different than for the NUREG-0611 analysis; there is no common basis for comparison. For example, the assumptions used for power availability illustrate the differences. NUREG-0611 assumed perfect DC power (i.e., failure probability of 0.0) for all cases, and one of two perfect diesel generators for this LOOP case. The analysis of ANO-1 EFW reliability evaluated power reliability in detail and assumed realistic probabilities for DC power and diesel generator failure.

The attached figure 1.1 "Reliability of ANO-1 EFW System" supplies the results of the report "Emergency Feedwater System Upgrade Reliability Analysis for the Arkansas Nuclear One Nuclear Generating Station Unit No. 1, April 1981" in the format of NUREG-0611. The attached table (Figure 1.2) "Unavailabilities for ANO-1 EFW" supplies the numerical results broken down into the three cases; loss of main feedwater (LMFW), loss of offsite power (LOOP), and loss of AC power (LOAC).

Question 2

"A narrative description of cut sets was provided, but no quantitative details were given. What were the contributions from the dominant cut sets?"

Response 2

The attached pages A-1 through A-3 explain the code used for the cut sets. The attached pages B-1 through B-36 supply the computer listing of

dominant cut sets for all of the analyzed cases. Each 8 letter code describes a basic event which can be found on the fault trees in Appendix B of the April 1981 Reliability Report.

Question 3

"Failure data were not given. What are they?"

Response 3

The attached pages C-1 through C-4 provide the basic event failure data used in the computer analysis of ANO-1 EFW Reliability.

Question 4

"The following questions pertain to the scenario discussed in point 4 of Section 3.2.1."

- a. "At the bottom of p. 3-1, it is stated that "...AC powered valves CV-X2 and CV-X3 will not open." (Fig. D-7 seems to indicate that CV-X3 is DC-powered. Is this correct?) In paragraph D.2.3 (p. D-3), it is stated that "The flow of EFW to each SG is controlled by redundant normally-open modulating solenoid motor operated control valves in parallel paths." The fact that loss of AC fails the control valves closed suggests that they are normally closed, but the subsequent discussion says that they are normally open. What are the normal positions of all valves in the four discharge paths? In this scenario, why were they presumed closed?"
- b. "Section 3.2.1.4 also talks about the opening of recirculation valves CV-2815 and CV-2816 during the loss-of-all AC power event which causes portion of turbine driven pump flow bypassing to the condensate storage tank. The ANO report recommends that an analysis be done to determine if adequate flow will be available to the SGs with this bypass flow. Has the analysis been performed? How serious is the bypass in degrading the total flow to the SGs?"

Response 4a

Attached figure 4 is the latest P&ID for the EFW System, this figure will be referenced in response to the remaining questions. Figure 4 indicates that four modulating control valves are normally open and fail open on loss of control signal or motive power. The four motor operated isolation valves are also normally open and fail "as is".

Response 4b

The recirculation piping will be changed to that shown on figure 4. This will eliminate the common recirculation flow path and resolve the concerns expressed in this question. The analysis will therefore not be done. The recirculation flow will not significantly degrade flow to the SG. This is due to the automatic nature of the recirculation valves to

be installed versus the constant flow nature of the existing design. Pump recirculation will occur only during periods of low total flow, and was considered in pump capacity calculations.

Question 5

"What physical measurement(s) actually regulate the recirculation valves: (CV-2815 and CV-2816)? According to the text (p. D-3, paragraph D.2.5), flow elements upstream of the control valves are used to decide whether flow is being demanded from each pump; however, the diagram suggests that the positions of the control valves (CV-X2 and CV-X3) are sensed."

Response 5

The recirculation flow piping will be changed according to figure 4. All valves in the recirculation flow path will be normally open and recirculation flow controlled by FW10A and FW10B. FW10A & B use pump flow to regulate recirculation flow. These valves consist of a set of interlocked check valves. One check valve is in the discharge path to the OTSG, the other is in the recirculation path. When the discharge path check valves closes due to reduced flow, the interlock will open the check valve in the recirculation line. This method does not require electric measurement and interlocks to establish recirculation and by design eliminates common (P7A and B) recirculation flow control.

Question 6

"If actual flow is the parameter to determine the recirculation then a simple failure of the EMD pump will also cause the recirculation in the TD pump flow (to increase) during the loss of main feed pump event. This failure mode should be included in the fault tree."

Response 6

This question no longer applies because the new recirculation control valves and piping design make pump recirculation flow independent of each other.

Question 7

"Pump Trip: Under what conditions do the pumps trip? Are there trips which are supposed to operate during a test but not during an emergency?"

"The fault tree takes credit for operator recovery of suction source in the event that it had been inappropriately left valved off after maintenance? How much time was assumed to be available for this before pump damage occurred?"

Response 7

The electric pump trips on overcurrent.

The turbine pump trips on overspeed.

There are no trip functions which are bypassed during an emergency.

Recovery of the suction source was assumed to occur before pump damage occurred.

Question 8

"What valves are closed for pump maintenance? Are any of the discharge valves disabled for this purpose?"

"What action is taken to isolate steam from the turbine driven pump during maintenance."

Response 8

During maintenance activities all suction and discharge valves are closed and tagged out of service per ANO procedures. In addition the steam inlet valves to the turbine pump are closed and the circuit breaker for the electric pump is opened and tagged out of service.

Question 9

"Providing steam to the turbine pump: One "steam unavailable" scenario involves the following: One of the valves in the pressure reducing station fails open, and one or the other of the relief valves fails to reseat. According to the fault tree, the relief capacity is such that there is insufficient pressure to drive the turbine if a relief valve is stuck open. It seems likely that given a wide-open control valve, the relief valve will cycle open and closed, so that even a small cyclic failure probability will lead to a substantial overall failure probability as the valve is repetitively cycled. Doesn't this scenario therefore have essentially the probability of either of the control valves failing high?"

Response 9

As part of the EFW upgrade project, the existing turbine is being replaced with a high pressure model. This eliminates the need for pressure reducing and safety valves.

Question 10

- a. "Isolation of the discharge paths: Are there single failures in the vector logic that can isolate both discharge paths from a given pump? Example: Channel D logic can isolate both discharge paths from the turbine driven pump. Are there failures in Channel D (e.g., power failures) that isolate both paths?"
- b. "Are these valves commanded open by vector logic given a simple LMFW, or does the logic assume that they are already open as they are supposed to be?"

Response 10a

It is possible for a channel, in this case Channel C, to fail. It is conceivable that such a failure could isolate both discharge paths from the turbine driven EFW pump. However, the single failure criterion as applied to the EFW system requires that at least one pump be able to supply EFW to at least one steam generator. Isolation of the turbine driven pump would require the following additional failures before the EFW system would be inoperable:

1. Loss of offsite power (LOOP)
2. Loss of both Diesel Generators (LOAC)


Thus the single failure of channel C would not render EFW inoperable.

Response 10b

These valves are normally open and commanded open by the vector logic. This is due to the system requirement that these valves must be closed during pump testing. An EFW initiation during a test will open these valves and close the test isolation valves, thus terminating the test and providing proper EFW system alignment.

The EFW vector logic commands the valves closed in the event of steam generator overfill or main steam isolation.

RELIABILITY OF ANO-1 EFW SYSTEM



NOTE: ASSUMPTIONS AND SCOPE FOR THIS ANALYSIS ARE DIFFERENT THAN THOSE USED IN NUREG-0611 AND COMPARISON WITH NUREG-0611 RESULTS IS INAPPROPRIATE.

* NOTE: THE SCALE FOR THIS EVENT IS NOT THE SAME AS THAT FOR THE LMFW AND LMFW/LOOP.

UNAVAILABILITIES FOR ANO-1 EFW

	Case 1 LMFW	Case 2 LOOP	Case 3 LOAC
<u>EFW Initiate</u> includes failure to initiate EFW due to fluid system failure, spurious isolation by FOGG or overfill protection, and EFIC initiation failure.			
Fully automatic initiation Includes operator corrective action within 20 minutes.	3.6×10^{-4} 1.4×10^{-5}	5.2×10^{-4} 9.1×10^{-5}	1.4×10^{-2} 5.7×10^{-3}
<u>EFIC Control</u>			
Fully Automatic control Includes operator corrective action within 20 minutes.	8.0×10^{-3} 1.3×10^{-6}	8.0×10^{-3} 1.3×10^{-6}	9.7×10^{-3} 2.6×10^{-6}
<u>FOGG</u>			
A > 600 psi B < 600 psi (feed only A)	3.8×10^{-4}	3.8×10^{-4}	3.8×10^{-4}
A < 600 psi B > 600 psi (feed only B)	3.8×10^{-4}	3.8×10^{-4}	3.8×10^{-4}
A < 600 psi B < 600 psi A 150 psi > B (feed only A)	1.5×10^{-3}	1.5×10^{-3}	1.5×10^{-3}
A < 600 psi B < 600 psi B 150 psi > A (feed only B)	1.5×10^{-3}	1.5×10^{-3}	1.5×10^{-3}
<u>EFW Overfill Protection</u>	6.2×10^{-4}	6.2×10^{-4}	3.1×10^{-3}

Babcock & Wilcox

a McDermott company

Nuclear Power Generation Division

PDS-21037-1 (9-81)

GENERAL CALCULATIONS

BASIC EVENT IDENTIFICATION CODE

XXYYYYYFM

XX - Component Identification Code

YYYY - Unique Component Identifier

FM - Failure Mode

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. A-1

COMPONENT IDENTIFICATION CODE

COMPONENT	CODE
Buffler amp or battery (batteries have numbers, e.g., BAD07)	BA
Breaker	BR
Cabinet main circuit breaker	CB
Charger	CH
Controller	CN
Pressure sensor, delta P	DP
FOGG module	FC
FOGG module	FG
Inverter	IN
Level sensor	LS
Level transmitter	LT
Valve or human operator	OP
Proportioner	PR
Resistor	RE
Rate follower	RF
Relay	RY
Setpoint signal	SP
Sensor power supply transformer	SFT
Subtractor	SU
Trip cabinet	TC
Timer circuit	TI
Valve stem	VS

COMPONENT FAILURE MODES
IDENTIFICATION CODE

FAILURE MODE	CODE
All Modes	AM
Catastrophic Failure	CF
Erroneously Trips	ET
Flow Blockage	FB
Fails Closed	FC
Fails to Energize	FE
Fails to Reinitialize	FI
Fails Low	FL
Fails Open	FO
Fails to Run	FR
Fails to Start	FS
Fails to Switch	FW
Indicates Trip	IT
Left Closed	LC
Left Open	LO
Mechanical Failure	MF
Miscalibrated High	MH
Miscalibrated Low	ML
No Signal	NS
In Preventive Maintenance	PM
Fails to Reseat	RS
Spuriously Closes	SC
Shorts	SH
Spurious Signal	SS
Fails to Close	TC
Fails to Detect Trip	TD
Fails to Open	TO
In Test	TS
Unable to Trip	UT

GENERAL CALCULATIONS

DOMINANT CUT SETS

FOR

ANO-1 EFW UNAVAILABILITY

for

LMFW: Loss of Main Feedwater

LOOP: Loss of Offsite Power

LOAC: Loss of AC Power

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. <u>8-1</u>

GENERAL CALCULATIONS

LMFW
Initiate
Automatic

P7AZZZFS	P7BZZZFR	
.4100000E-02	.3460000E-03	
P7AZZZFS	P7BZZZFS	
.4100000E-02	.5300000E-03	
CST412AM	SWSUCTION	
.2000000E-05	.1000000E+01	
CS98ZZFB	SWSUCTION	
.1100000E-03	.1000000E+01	
CS99ZZFB	SWSUCTION	
.1100000E-03	.1000000E+01	
P7AZZZFR	P7BRECCA	P7BRECLO
.3460000E-03	.1000000E+01	.3300000E-02
P7AZZZ+S	P7BRECCA	P7BRECLO
.4100000E-02	.1000000E+01	.3300000E-02
P7AZZZPM	P7BRECCA	P7BRECLO
.7590000E-03	.1000000E+01	.3300000E-02
P7ARECCA	P7ARECLO	P7BZZZFR
.1000000E+01	.3300000E-02	.3460000E-03
P7ARECCA	P7ARECLO	P7BZZZFS
.1000000E+01	.3300000E-02	.5300000E-03
P7AZZZFS	P7BRECOP	P7BZZZTS
.4100000E-02	.1000000E+01	.1390000E-02
CV2802LC	CV2802RE	P7BZZZFR
.3300000E-02	.1000000E+01	.3460000E-03
CV2802LC	CV2802RE	P7BZZZFS
.3300000E-02	.1000000E+01	.5300000E-03
CV2800LC	CV2800RE	P7AZZZFR
.3300000E-02	.1000000E+01	.3460000E-03
CV2800LC	CV2800RE	P7AZZZFS
.3300000E-02	.1000000E+01	.4100000E-02

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-2

GENERAL CALCULATIONS

CV2800LC	CV2800RE	P7AZZZPM	
.3300000E-02	.1000000E+01	.7590000E-03	
P7ARECCA	P7ARECLO	P7BRECCA	P7BRECLO
.1000000E+01	.3300000E-02	.1000000E+01	.3300000E-02
P7ARECOP	P7AZZZTS	P7BRECCA	P7BRECLO
.1000000E+01	.1390000E-02	.1000000E+01	.3300000E-02
P7ARECCA	P7ARECLO	P7BRECOP	P7BZZZTS
.1000000E+01	.3300000E-02	.1000000E+01	.1390000E-02
CV2802LC	CV2802RE	P7BRECCA	P7BRECLO
.3300000E-02	.1000000E+01	.1000000E+01	.3300000E-02
CV2802LC	CV2802RE	P7BRECOP	P7BZZZTS
.3300000E-02	.1000000E+01	.1000000E+01	.1390000E-02
CSVSGARS	CSVSGBRS	P7BRECCA	P7BRECLO
.1840000E-01	.1840000E-01	.1000000E+01	.3300000E-02
CV2800LC	CV2800RE	P7ARECCA	P7ARECLO
.3300000E-02	.1000000E+01	.1000000E+01	.3300000E-02
CV2800LC	CV2800RE	P7ARECOP	P7AZZZTS
.3300000E-02	.1000000E+01	.1000000E+01	.1390000E-02
CV2800LC	CV2800RE	CV2802LC	CV2802RE
.3300000E-02	.1000000E+01	.3300000E-02	.1000000E+01
CSVSGARS	CSVSGBRS	CV2800LC	CV2800RE
.1840000E-01	.1840000E-01	.3300000E-02	.1000000E+01

PREPARED BY _____

DATE _____

DOC. NO. _____

REVIEWED BY _____

DATE _____

PAGE NO. _____

B-3

GENERAL CALCULATIONS

LMFW
Initiate
with operator Corrective Action

P7AZZZFR	P7BZZZFR	
.3460000E-03	.3460000E-03	
P7AZZZFS	P7BZZZFR	
.4100000E-02	.3460000E-03	
P7AZZZPM	P7BZZZFR	
.7590000E-03	.3460000E-03	
P7AZZZFR	P7BZZZFS	
.3460000E-03	.5300000E-03	
P7AZZZFS	P7BZZZFS	
.4100000E-02	.5300000E-03	
P7AZZZPM	P7BZZZFS	
.7590000E-03	.5300000E-03	
FW10AZFB	P7AZZZFS	
.1100000E-03	.4100000E-02	
CS98ZZFB	SWSUCTOP	
.1100000E-03	.4000000E-01	
CS99ZZFB	SWSUCTOP	
.1100000E-03	.4000000E-01	
CSVSGARS	CSVSGBRS	P7BZZZFR
.1840000E-01	.1840000E-01	.3460000E-03
CSVSGARS	CSVSGBRS	P7BZZZFS
.1840000E-01	.1840000E-01	.5300000E-03
CV2800LC	CV2800RE	P7AZZZFS
.3300000E-02	.1900000E-01	.4100000E-02

Babcock & Wilcox

* McDermott company

Nuclear Power Generation Division

PDS-21037.1 (9-81)

GENERAL CALCULATIONS

LMFW
Control
Automatic

OPEM02X1	OPFAILPT
.2000000E-02	.1000000E+01
OPEM02X2	OPFAILPT
.2000000E-02	.1000000E+01
OPEM02X3	OPFAILPT
.2000000E-02	.1000000E+01
OPEM02X4	OPFAILPT
.2000000E-02	.1000000E+01

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____
B-5		

GENERAL CALCULATIONS

LMFW
Control
with operator corrective action

OPEM02X1	OPFAILPT
.2000000E-02	.1500000E-03
OPEM02X2	OPFAILPT
.2000000E-02	.1500000E-03
OPEM02X3	OPFAILPT
.2000000E-02	.1500000E-03
OPEM02X4	OPFAILPT
.2000000E-02	.1500000E-03
BA02X1FL	OPFAILPT
.9100000E-04	.1500000E-03
BA02X2FL	OPFAILPT
.9100000E-04	.1500000E-03
BA02X3FL	OPFAILPT
.9100000E-04	.1500000E-03
BA02X4FL	OPFAILPT
.9100000E-04	.1500000E-03

GENERAL CALCULATIONS

LMFW
F068
A<600 B>600

DPATCBFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPBTCBFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCAFL	DPBTCDFL
.5500000E-02	.5500000E-02
BIDPAAML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPAAML	DPBTCDFL
.2800000E-02	.5500000E-02
BIDPABML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPABML	DPBTCCFL
.2800000E-02	.5500000E-02
BIDPACML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPACML	DPBTCBFL
.2800000E-02	.5500000E-02
BIDPABML	BIDPACML
.2800000E-02	.2800000E-02
BIDPADML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPADML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPAAML	BIDPADML
.2800000E-02	.2800000E-02

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____
B-7		

Babcock & Wilcox

a McDermott company

Nuclear Power Generation Division

PDS-21037-1 (9-81)

GENERAL CALCULATIONSLMFW
FOSS

A<600, B<600, B150>A

DPATCAFH	DPATCBFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCBFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCBFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCCFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPBTCAFL	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCCFL
.5500000E-02	.5500000E-02

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-8

GENERAL CALCULATIONS

DPBTAFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPBTBFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTAFL	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTBFL	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCCFL	DPBTCDFL
.5500000E-02	.5500000E-02
BIA7BAML	DPATCDFH
.2800000E-02	.5500000E-02
BIA7BAML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BBML	DPATCCFH
.2800000E-02	.5500000E-02
BIA7BCML	DPBTCCFL
.2800000E-02	.5500000E-02
BIA7BCML	DPATCBFH
.2800000E-02	.5500000E-02
BIA7BBML	BIA7BCML
.2800000E-02	.2800000E-02
BIA7BDML	DPATCAFH
.2800000E-02	.5500000E-02
BIA7BAML	DPBTCAFL
.2800000E-02	.5500000E-02
BIA7BAML	CIA7BDML
.2800000E-02	.2800000E-02
BIB7AAMH	DPATCDFH
.2800000E-02	.5500000E-02
BIB7AAMH	DPBTCDFL

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____
B-9		

GENERAL CALCULATIONS

.2800000E-02	.5500000E-02
<hr/>	
BIA7BML	BIB7AAMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7ABMH	DPATCCFH
.2800000E-02	.5500000E-02
<hr/>	
BIB7ABMH	DPBTCCFL
.2800000E-02	.5500000E-02
<hr/>	
EIA7ECML	BIB7ABMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7ACMH	DPATCBFH
.2800000E-02	.5500000E-02
<hr/>	
BIB7ACMH	DPBTCBFH
.2800000E-02	.5500000E-02
<hr/>	
BIA7BBML	BIB7ACMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7ABMH	BIB7ACMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7ADMH	DPATCAFH
.2800000E-02	.5500000E-02
<hr/>	
BIB7ADMH	DPBTCAFH
.2800000E-02	.5500000E-02
<hr/>	
BIA7BAML	BIB7ADMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7AAMH	BIB7ADMH
.2800000E-02	.2800000E-02
<hr/>	
BIDPAAML	DPATCBFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPATCCFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPATCDFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPBTCBFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPBTCCFL
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPBTCDFL
.2800000E-02	.5500000E-02
<hr/>	
BIA7BML	BIDPAAML
.2800000E-02	.2800000E-02

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-10

GENERAL CALCULATIONS

BIB7ADMH	BIDPAAML
.2800000E-02	.2800000E-02
BIDPABML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPABML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPABML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPABML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPABML	DPBTCCFL
.2800000E-02	.5500000E-02
BIDPABML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BCML	BIDPABML
.2800000E-02	.2800000E-02
BIB7ACMH	BIDPABML
.2800000E-02	.2800000E-02
BIDPAAML	BIDPABML
.2800000E-02	.2800000E-02
BIDPACML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPACML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPACML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPACML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPACML	DPBTCBFL
.2800000E-02	.5500000E-02
BIDPACML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BBML	BIDPACML
.2800000E-02	.2800000E-02
BIB7ABMH	BIDPACML
.2800000E-02	.2800000E-02
BIDPAAML	BIDPACML
.2800000E-02	.2800000E-02
BIDPABML	BIDPACML

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____
B-11		

GENERAL CALCULATIONS

.2800000E-02 .2800000E-02

BIDPADML DPATCAFH
.2800000E-02 .5500000E-02

BIDPADML DPATCBFH
.2800000E-02 .5500000E-02

BIDPADML DPATCCFH
.2800000E-02 .5500000E-02

BIDPADML DPBTCAFL
.2800000E-02 .5500000E-02

BIDPADML DPBTCBFL
.2800000E-02 .5500000E-02

BIDPADML DPBTCCFL
.2800000E-02 .5500000E-02

BIA7BAML BIDPADML
.2800000E-02 .2800000E-02

BIB7AAMH BIDPADML
.2800000E-02 .2800000E-02

BIDPAAML BIDPADML
.2800000E-02 .2800000E-02

BIDPABML BIDPADML
.2800000E-02 .2800000E-02

BIDPACML BIDPADML
.2800000E-02 .2800000E-02

GENERAL CALCULATIONS**LMFW - Overfill Protection**DPOFABXX
 5.5×10^{-3} DPOFDBFL
 5.5×10^{-3} BAOFABXX
 9.1×10^{-5} DPOFDBFL
 5.5×10^{-3} BIOFABMH
 2×10^{-3} DPOFDBFL
 5.5×10^{-3} DPOFABXX
 5.5×10^{-3} BIOFDBMH
 2×10^{-3} BAOFABXX
 9.1×10^{-5} BIOFDBMH
 2×10^{-3} BIOFABMH
 2×10^{-3} BIOFDBMH
 2×10^{-3}

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____

B-13

GENERAL CALCULATIONS

LOOP
Initiate
Automatic

P7AZZZFS	P7BZZZFR	
.4100000E-02	.3460000E-03	
P7AZZZFS	P7BZZZFS	
.4100000E-02	.5300000E-03	
DG1ZZZFS	P7AZZZFR	
.1340000E-01	.3460000E-03	
DG1ZZZFS	P7AZZZFS	
.1340000E-01	.4100000E-02	
DG1ZZZFS	P7AZZZPM	
.1340000E-01	.7590000E-03	
DG1ZZZFS	FW10BZFB	
.1340000E-01	.1100000E-03	
CST41ZAM	SWSUCTOP	
.2000000E-05	.1000000E+01	
CS98ZZFB	SWSUCTOP	
.1100000E-03	.1000000E+01	
CS99ZZFB	SWSUCTOP	
.1100000E-03	.1000000E+01	
P7AZZZFR	P7BRECCA	P7BRECCLO
.3460000E-03	.1000000E+01	.3300000E-02
P7AZZZFS	P7BRECCA	P7BRECCLO
.4100000E-02	.1000000E+01	.3300000E-02
P7AZZZPM	P7BRECCA	P7BRECCLO
.7590000E-03	.1000000E+01	.3300000E-02
P7ARECCA	P7ARECCLO	P7BZZZFR
.1000000E+01	.3300000E-02	.3460000E-03
P7ARECCA	P7ARECCLO	P7BZZZFS
.1000000E+01	.3300000E-02	.5300000E-03
P7AZZZFS	P7BRECOP	P7BZZZTS
.4100000E-02	.1000000E+01	.1390000E-02

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-14

GENERAL CALCULATIONS

CV2802LC	CV2802RE	P7BZZZFR	
.3300000E-02	.1000000E+01	.3460000E-03	
CV2802LC	CV2802RE	P7BZZZFS	
.3300000E-02	.1000000E+01	.5300000E-03	
DG1ZZZFS	P7ARECCA	P7ARECLO	
.1340000E-01	.1000000E+01	.3300000E-02	
DG1ZZZFS	P7ARECOP	P7AZZZTS	
.1340000E-01	.1000000E+01	.1390000E-02	
CV2802LC	CV2802RE	DG1ZZZFS	
.3300000E-02	.1000000E+01	.1340000E-01	
CSVSGARS	CSVSGBRs	DG1ZZZFS	
.1840000E-01	.1840000E-01	.1340000E-01	
CV2800LC	CV2800RE	P7AZZZFR	
.3300000E-02	.1000000E+01	.3460000E-03	
CV2800LC	CV2800RE	P7AZZZFS	
.3300000E-02	.1000000E+01	.4100000E-02	
CV2800LC	CV2800RE	P7AZZZPM	
.3300000E-02	.1000000E+01	.7590000E-03	
P7ARECCA	P7ARECLO	P7BRECCA	
.1000000E+01	.3300000E-02	.1000000E+01	.3300000E-02
P7ARECOP	P7AZZZTS	P7BRECCA	P7BRECLO
.1000000E+01	.1390000E-02	.1000000E+01	.3300000E-02
P7ARECCA	P7ARECLO	P7BRECOP	P7BZZZTS
.1000000E+01	.3300000E-02	.1000000E+01	.1390000E-02
CV2802LC	CV2802RE	P7BRECCA	P7BRECLO
.3300000E-02	.1000000E+01	.1000000E+01	.3300000E-02
CV2802LC	CV2802RE	P7BRECOP	P7BZZZTS
.3300000E-02	.1000000E+01	.1000000E+01	.1390000E-02
CSVSGARS	CSVSGBRs	P7BRECCA	P7BRECLO
.1840000E-01	.1840000E-01	.1000000E+01	.3300000E-02
CV2800LC	CV2800RE	P7ARECCA	P7ARECLO
.3300000E-02	.1000000E+01	.1000000E+01	.3300000E-02
CV2800LC	CV2800RE	P7ARECOP	P7AZZZTS
.3300000E-02	.1000000E+01	.1000000E+01	.1390000E-02
CV2800LC	CV2800RE	CV2802LC	CV2802RE
.3300000E-02	.1000000E+01	.3300000E-02	.1000000E+01
CSVSGARS	CSVSGBRs	CV2800LC	CV2800RE
.1840000E-01	.1840000E-01	.3300000E-02	.1000000E+01

PREPARED BY _____

DATE _____

DOC. NO. _____

REVIEWED BY _____

DATE _____

PAGE NO. _____

B-15

GENERAL CALCULATIONS

LOOP
Initiate
with operator corrective action

P7AZZZFR	P7BZZZFR	
.3460000E-03	.3460000E-03	
P7AZZZFS	P7BZZZFR	
.4100000E-02	.3460000E-03	
P7AZZZPM	P7BZZZFR	
.7590000E-03	.3460000E-03	
P7AZZZFR	P7BZZZFS	
.3460000E-03	.5300000E-03	
P7AZZZFS	P7BZZZFS	
.4100000E-02	.5300000E-03	
P7AZZZPM	P7BZZZFS	
.7590000E-03	.5300000E-03	
DG1ZZZFS	P7AZZZFR	
.1340000E-01	.3460000E-03	
DG1ZZZFS	P7AZZZFS	
.1340000E-01	.4100000E-02	
DG1ZZZFS	P7AZZZPM	
.1340000E-01	.7590000E-03	
FW10AZFB	P7AZZZFS	
.1100000E-03	.4100000E-02	
DG1ZZZFS	FW10BZFB	
.1340000E-01	.1100000E-03	
CS98ZZFB	SWSUCTION	
.1100000E-03	.4000000E-01	
CS99ZZFB	SWSUCTION	
.1100000E-03	.4000000E-01	
CV2802LC	CV2802RE	DG1ZZZFS
.3300000E-02	.1100000E-01	.1340000E-01
CSVSGARS	CSVSGBRS	P7BZZZFR
.1840000E-01	.1840000E-01	.3460000E-03
CSVSGARS	CSVSGBRS	P7BZZZFS
.1840000E-01	.1840000E-01	.5300000E-03
CSVSGARS	CSVSGBRS	DG1ZZZFS
.1840000E-01	.1840000E-01	.1340000E-01
CV2800LC	CV2800RE	P7AZZZFS
.3300000E-02	.1900000E-01	.4100000E-02

1

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____

B-16

GENERAL CALCULATIONS

Loop
Control
Automatic

OPEM20X1	OPFAILPT
.2000000E-02	.1000000E+01
OPEM20X2	OPFAILPT
.2000000E-02	.1000000E+01
OPEM20X3	OPFAILPT
.2000000E-02	.1000000E+01
OPEM20X4	OPFAILPT
.2000000E-02	.1000000E+01

PREPARED BY _____ DATE _____
REVIEWED BY _____ DATE _____

DOC. NO. _____
PAGE NO. _____ B-17

GENERAL CALCULATIONS

LOOP
Control
with operator corrective action

LS20X4NS	OPFAILPT
.8700000E-04	.1500000E-03
OPEM20X1	OPFAILPT
.2000000E-02	.1500000E-03
OPEM20X2	OPFAILPT
.2000000E-02	.1500000E-03
OPEM20X3	OPFAILPT
.2000000E-02	.1500000E-03
OPEM20X4	OPFAILPT
.2000000E-02	.1500000E-03
OPESEL28	OPFAILPT
.1000000E-03	.1500000E-03
LS20X1NS	OPFAILPT
.8700000E-04	.1500000E-03
LS20X2NS	OPFAILPT
.8700000E-04	.1500000E-03
LS20X3NS	OPFAILPT
.8700000E-04	.1500000E-03
BA20X1FL	OPFAILPT
.9100000E-04	.1500000E-03
BA20X2FL	OPFAILPT
.9100000E-04	.1500000E-03
BA20X3FL	OPFAILPT
.9100000E-04	.1500000E-03
BA20X4FL	OPFAILPT
.9100000E-04	.1500000E-03

PREPARED BY _____

DATE _____

DOC. NO. _____

REVIEWED BY _____

DATE _____

PAGE NO. _____

B-18

Babcock & Wilcox

a McDermott company

Nuclear Power Generation Division

PDS-21037.1 (9-81)

GENERAL CALCULATIONS

LOOP
F066
A<600, B>600

DPATCBFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPBTCBFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCAFL	DPBTCDFL
.5500000E-02	.5500000E-02
BIDPAAML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPAAML	DPBTCDFL
.2800000E-02	.5500000E-02
BIDPABML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPABML	DPBTCCFL
.2800000E-02	.5500000E-02
BIDPACML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPACML	DPBTCBFL
.2800000E-02	.5500000E-02
BIDPABML	BIDPACML
.2800000E-02	.2800000E-02
BIDPADML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPADML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPAAML	BIDPADML
.2800000E-02	.2800000E-02

PREPARED BY

DATE

DOC NO.

REVIEWED BY

DATE

PAGE NO.

B-19

GENERAL CALCULATIONS

LOOP

F06 G

A<600, B<600, B 150> A

DPATCAFH	DPATCBFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCBFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCBFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCCFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPBTCAFL	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCCFL
.5500000E-02	.5500000E-02

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-20

GENERAL CALCULATIONS

DPBTCAFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPBTCBFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCAFL	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCBFL	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCCFL	DPBTCDFL
.5500000E-02	.5500000E-02
BIA7BAML	DPATCDFH
.2800000E-02	.5500000E-02
BIA7BAML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BBML	DPATCCFH
.2800000E-02	.5500000E-02
BIA7B9ML	DPBTCCFL
.2800000E-02	.5500000E-02
BIA7BCML	DPATCBFH
.2800000E-02	.5500000E-02
BIA7BCML	DPBTCBFL
.2800000E-02	.5500000E-02
BIA7BBML	BIA7BCML
.2800000E-02	.2800000E-02
BIA7BDML	DPATCAFH
.2800000E-02	.5500000E-02
BIA7BDML	DPBTCAFL
.2800000E-02	.5500000E-02
BIA7BAMI	BIA7BDML
.2800000E-02	.2800000E-02
EIB7AAMH	DPATCDFH
.2800000E-02	.5500000E-02
EIB7AAMH	DPBTCDFL

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____

B-21

GENERAL CALCULATIONS

.2800000E-02	.5500000E-02
BIB7EDML	BIB7AAMH
.2800000E-02	.2800000E-02
BIB7ABMH	DPATCCFH
.2800000E-02	.5500000E-02
BIB7ABMH	DPBTTCCFL
.2800000E-02	.5500000E-02
BIA7BCML	BIB7ABMH
.2800000E-02	.2800000E-02
BIB7ACMH	DPATCBFH
.2800000E-02	.5500000E-02
BIB7ACMH	DPBTTCBFL
.2800000E-02	.5500000E-02
BIA7BBML	BIB7ACMH
.2800000E-02	.2800000E-02
BIB7ABMH	BIB7ACMH
.2800000E-02	.2800000E-02
BIB7ADMH	DPATCAFH
.2800000E-02	.5500000E-02
BIB7ADMH	DPBTTCAF
.2800000E-02	.5500000E-02
BIA7BAML	BIB7ADMH
.2800000E-02	.2800000E-02
BIB7AAMH	BIB7ADMH
.2800000E-02	.2800000E-02
BIDPAAML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPAAML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPAAML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPAAML	DPBTTCBFL
.2800000E-02	.5500000E-02
BIDPAAML	DPBTTCCFL
.2800000E-02	.5500000E-02
BIDPAAML	DPBTTCDFL
.2800000E-02	.5500000E-02
BIA7BDML	BIDPAAML
.2800000E-02	.2800000E-02

PREPARED BY _____	DATE _____
REVIEWED BY _____	DATE _____

DOC. NO. _____	B-22
PAGE NO. _____	

GENERAL CALCULATIONS

BIB7ADMH	BIDPAAML
.2800000E-02	.2800000E-02
BIDPABML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPABML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPABML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPABML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPABML	DPBTCCFL
.2800000E-02	.5500000E-02
BIDPABML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BCML	BIDPAEML
.2800000E-02	.2800000E-02
BIB7ACMH	BIDPABML
.2800000E-02	.2800000E-02
BIDPAAML	BIDPABML
.2800000E-02	.2800000E-02
BIDPACML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPACML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPACML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPACML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPACML	DPBTCBFL
.2800000E-02	.5500000E-02
BIDPACML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BBML	BIDPACML
.2800000E-02	.2800000E-02
BIB7ABMH	BIDPACML
.2800000E-02	.2800000E-02
BIDPAAML	BIDPACML
.2800000E-02	.2800000E-02
BIDPABML	BIUPACML

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____

B-23

GENERAL CALCULATIONS

.2800000E-02	.2800000E-02
BIDPADML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPADML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPADML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPADML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPADML	DPBTCBFL
.2800000E-02	.5500000E-02
BIDPADML	DPBTCCFL
.2800000E-02	.5500000E-02
BIA7BAML	BIDPADML
.2800000E-02	.2800000E-02
BIB7AAMH	BIDPADML
.2800000E-02	.2800000E-02
BIDPAAML	BIDPADML
.2800000E-02	.2800000E-02
BIDPABML	BIDPADML
.2800000E-02	.2800000E-02
BIDPACML	BIDPADML
.2800000E-02	.2800000E-02

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. <u>B-24</u>

GENERAL CALCULATIONS*LOOP - overfill protection*DPOFABXX
 5.5×10^{-3} DPOFDBFL
 5.5×10^{-3} BAOFABXX
 9.1×10^{-5} DPOFDBFL
 5.5×10^{-3} BIOFABMH
 2×10^{-3} DPOFDBFL
 5.5×10^{-3} DPOFABXX
 5.5×10^{-3} BIOFDBMH
 2×10^{-3} BAOFABXX
 9.1×10^{-5} BIOFDBMH
 2×10^{-3} BIOFABMH
 2×10^{-3} BIOFDBMH
 2×10^{-3}

GENERAL CALCULATIONS

LOAC
Initiate
Automatic

P7AZZZFR		
.3460000E-03		
P7AZZZFS		
.4100000E-02		
P7AZZZPM		
.7590000E-03		
FWTUBZFB		
.1100000E-03		
P7ARECCA	P7ARECLO	
.1000000E+01	.3300000E-02	
P7ARECOP	P7AZZZTS	
.1000000E+01	.1390000E-02	
CV2802LC	CV2802RE	
.3300000E-02	.1000000E+01	
CST41ZAM	SWSUCTOP	
.2000000E-05	.1000000E+01	
CSVSGARS	W6ZZZZFB	
.1840000E-01	.1100000E-03	
CSVSGBRS	W5ZZZZFB	
.1840000E-01	.1100000E-03	
CSVSGARS	CSVSGBRS	
.1840000E-01	.1840000E-01	
CS98ZZFB	SWSUCTOP	
.1100000E-03	.1000000E+01	
CS99ZZFB	SWSUCTOP	
.1100000E-03	.1000000E+01	
BAD06ZAM	CV2802LC	
.8460000E-03	.3300000E-02	
CVY1Y20P	CVY1ZZT0	CVY2ZZT0
.1000000E+01	.4000000E-02	.4000000E-02
BAD06ZAM	CVY1Y20P	CVY2ZZT0
.8460000E-03	.1000000E+01	.4000000E-02
BAD07ZAM	CVY1Y20P	CVY1ZZT0
.8460000E-03	.1000000E+01	.4000000E-02

GENERAL CALCULATIONS

LOAC

Initiate , with operator corrective
action

P7AZZZFR	
.3460000E-03	
P7AZZZFS	
.4100000E-02	
P7AZZZFM	
.7590000E-03	
FWTUBZFB	
.1100000E-03	
P7ARECCA	P7ARECLO
.2100000E-02	.3300000E-02
P7ARECOP	P7AZZZTS
.4000000E-02	.1390000E-02
CV2802LC	CV2802RE
.3300000E-02	.1100000E-01
CSVSGARS	W6ZZZZFB
.1840000E-01	.1100000E-03
CSVSGBRS	W5ZZZZFB
.1840000E-01	.1100000E-03
CSVSGARS	CSVGBRS
.1840000E-01	.1840000E-01
CS98ZZFB	SWSUCTOP
.1100000E-03	.4000000E-01
CS98ZZFB	CV2806MF
.1100000E-03	.4000000E-02
CS98ZZFB	CV3851MF
.1100000E-03	.4000000E-02
CS99ZZFB	SWSUCTOP
.1100000E-03	.4000000E-01
CS99ZZFB	CV2806MF
.1100000E-03	.4000000E-02
CS99Z. 3	CV3851MF
.1100000E-03	.4000000E-02
CVY3ZZFH	PV6601RS
.2070000E-03	.2300000E-02
CVY3ZZFH	PV6602RS
.2070000E-03	.2300000E-02
CVY4ZZFH	PV6601RS
.2070000E-03	.2300000E-02
CVY4ZZFH	PV6602RS
.2070000E-03	.2300000E-02
BAD06ZAM	CV2802LC
.8460000E-03	.3300000E-02

GENERAL CALCULATIONS

LOAC
Control
Automatic

OPEM20X1	OPFAILPT
.2000000E-02	.1000000E+01
OPEM20X2	OPFAILPT
.2000000E-02	.1000000E+01
OPEM20X3	OPFAILPT
.2000000E-02	.1000000E+01
OPEM20X4	OPFAILPT
.2000000E-02	.1000000E+01
BAD06ZAM	OPFAILPH
.8460000E-03	.1000000E+01
BAD07ZAM	OPFAILPH
.8460000E-03	.1000000E+01

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-28

Babcock & Wilcox

a McDermott company

Nuclear Power Generation Division

GENERAL CALCULATIONS

LOAC
Control
with operator corrective action

<u>LS20X4NS</u>	<u>OPFAILPT</u>
.8700000E-04	.1500000E-03
<u>OPEM20X1</u>	<u>OPFAILPT</u>
.2000000E-02	.1500000E-03
<u>OPEM20X2</u>	<u>OPFAILPT</u>
.2000000E-02	.1500000E-03
<u>OPEM20X3</u>	<u>OPFAILPT</u>
.2000000E-02	.1500000E-03
<u>OPEM20X4</u>	<u>OPFAILPT</u>
.2000000E-02	.1500000E-03
<u>OPESEL28</u>	<u>OPFAILPT</u>
.1000000E-03	.1500000E-03
<u>LS20X1NS</u>	<u>OPFAILPT</u>
.8700000E-04	.1500000E-03
<u>LS20X2NS</u>	<u>OPFAILPT</u>
.8700000E-04	.1500000E-03
<u>LS20X3NS</u>	<u>OPFAILPT</u>
.8700000E-04	.1500000E-03
<u>BAD06ZAM</u>	<u>OPFAILPH</u>
.8460000E-03	.7500000E-03
<u>BAD07ZAM</u>	<u>OPFAILPH</u>
.8460000E-03	.7500000E-03
<u>BA20X1FL</u>	<u>OPFAILPT</u>
.9100000E-04	.1500000E-03
<u>BA20X2FL</u>	<u>OPFAILPT</u>
.9100000E-04	.1500000E-03
<u>BA20X3FL</u>	<u>OPFAILPT</u>
.9100000E-04	.1500000E-03
<u>BA20X4FL</u>	<u>OPFAILPT</u>
.9100000E-04	.1500000E-03

PREPARED BY _____ DATE _____
 REVIEWED BY _____ DATE _____

DOC NO.
PAGE NO.

B-29

GENERAL CALCULATIONS

LOAD
FOGG
A < 600, B > 600

DPATCBFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPBTCBFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCAFL	DPBTCDFL
.5500000E-02	.5500000E-02
BIDPAAML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPAAML	DPBTCDFL
.2800000E-02	.5500000E-02
BIDPAEML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPABML	DPBTCCFL
.2800000E-02	.5500000E-02
BIDPACML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPACML	DPBTCBFL
.2800000E-02	.5500000E-02
BIDPABML	BIDPACML
.2800000E-02	.2800000E-02
BIDPADML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPADML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPAAML	BIDPADML
.2800000E-02	.2800000E-02

GENERAL CALCULATIONS

LOAC

FO66

A<600, B<600, B 150>A

DPATCAFH	DPATCBFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCBFH	DPATCCFH
.5500000E-02	.5500000E-02
DPATCAFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCBFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCCFH	DPATCDFH
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCAFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCBFL
.5500000E-02	.5500000E-02
DPBTCAFL	DPBTCBFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCDFH	DPBTCCFL
.5500000E-02	.5500000E-02

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-31

GENERAL CALCULATIONS

DPBTAFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPBTCBFL	DPBTCCFL
.5500000E-02	.5500000E-02
DPATCAFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPATCBFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPATCCFH	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTAFL	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCBFL	DPBTCDFL
.5500000E-02	.5500000E-02
DPBTCCFL	DPBTCDFL
.5500000E-02	.5500000E-02
BIA7BAML	DPATCDFH
.2800000E-02	.5500000E-02
BIA7BAML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BBML	DPATCCFH
.2800000E-02	.5500000E-02
BIA7BBML	DPBTCCFL
.2800000E-02	.5500000E-02
BIA7BCML	DPATCBFH
.2800000E-02	.5500000E-02
BIA7BCML	DPBTCBFL
.2800000E-02	.5500000E-02
BIA7BBML	BIA7BCML
.2800000E-02	.2800000E-02
BIA7BDML	DPATCAFH
.2800000E-02	.5500000E-02
BIA7BDML	DPBTAFL
.2800000E-02	.5500000E-02
BIA7BAML	BIA7BDML
.2800000E-02	.2800000E-02
BIB7AAMH	DPATCDFH
.2800000E-02	.5500000E-02
BIB7AAMH	DPETCDFL

PREPARED BY _____ DATE _____
REVIEWED BY _____ DATE _____

DOC NO. _____
PAGE NO. B-32

GENERAL CALCULATIONS

.2800000E-02	.5500000E-02
<hr/>	
BIB7BDML	BIB7AAMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7AEMH	DPATCCFH
.2800000E-02	.5500000E-02
<hr/>	
BIB7ABMH	DPBYCCFL
.2800000E-02	.5500000E-02
<hr/>	
BIA7BCML	BIB7ABMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7ACMH	DPATCBFH
.2800000E-02	.5500000E-02
<hr/>	
BIB7ACMH	DPBTCBFL
.2800000E-02	.5500000E-02
<hr/>	
BIA7BBML	BIB7ACMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7ABMH	BIB7ACMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7ADMH	DPATCAFH
.2800000E-02	.5500000E-02
<hr/>	
BIB7ADMH	DPBTCAFL
.2800000E-02	.5500000E-02
<hr/>	
BIA7BAML	BIB7ADMH
.2800000E-02	.2800000E-02
<hr/>	
BIB7AAMH	BIB7ADMH
.2800000E-02	.2800000E-02
<hr/>	
BIDPAAML	DPATCBFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPATCCFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPATCDFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPAAML	DPBTCBFL
.2800000E-02	.5500000E-02
<hr/>	
BIDPAANL	DPBTCCFL
.2800000E-02	.5500000E-02
<hr/>	
BIDPAANL	DPBTCDFL
.2800000E-02	.5500000E-02
<hr/>	
BIA7BDML	BIDPAAML
.2800000E-02	.2800000E-02

PREPARED BY _____ DATE _____

DOC. NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

B-33

GENERAL CALCULATIONS

BIB7ADMH	BIDFACML
.2800000E-02	.2800000E-02
BIDPABML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPABML	DPATCCFH
.2800000E-02	.5500000E-02
BIDPAEML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPABML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPABML	DPBTCCFL
.2800000E-02	.5500000E-02
BIDPABML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BCML	BIDPABML
.2800000E-02	.2800000E-02
BIB7ACMH	BIDPABML
.2800000E-02	.2800000E-02
BIDPAAML	BIDPAEML
.2800000E-02	.2800000E-02
BIDPACML	DPATCAFH
.2800000E-02	.5500000E-02
BIDPACML	DPATCBFH
.2800000E-02	.5500000E-02
BIDPACML	DPATCDFH
.2800000E-02	.5500000E-02
BIDPACML	DPBTCAFL
.2800000E-02	.5500000E-02
BIDPACML	DPBTCBFL
.2800000E-02	.5500000E-02
BIDPACML	DPBTCDFL
.2800000E-02	.5500000E-02
BIA7BBML	BIDPACML
.2800000E-02	.2800000E-02
BIB7ABMH	BIDPACML
.2800000E-02	.2800000E-02
BIDPAANL	BIDPACML
.2800000E-02	.2800000E-02
BIDPABML	BIDFACML

GENERAL CALCULATIONS

.2800000E-02	.2800000E-02
<hr/>	
BIDPADML	DPATCAFH
.2800000E-02	.5000000E-02
<hr/>	
BIDPADML	DPATCBFH
.2800000E-02	.5E00000E-02
<hr/>	
BIDPADML	DPATCCFH
.2800000E-02	.5500000E-02
<hr/>	
BIDPADML	DPBYCAFL
.2800000E-02	.5500000E-02
<hr/>	
BIDPADML	DPBYCBFL
.2800000E-02	.5500000E-02
<hr/>	
BIDPADML	DPBYCCFL
.2800000E-02	.5500000E-02
<hr/>	
BIA7BAML	BIDPADML
.2800000E-02	.2800000E-02
<hr/>	
BIB7AAMH	BIDPADML
.2600000E-02	.2800000E-02
<hr/>	
BIDPAAML	BIDPADML
.2800000E-02	.2800000E-02
<hr/>	
BIDPABML	BIDPADML
.2800000E-02	.2800000E-02
<hr/>	
BIDPACML	BIDPADML
.2800000E-02	.2800000E-02
<hr/>	

GENERAL CALCULATIONS*LOAC - Overfill Protection*DPOFABXX
 5.5×10^{-3} DPOFDBFL
 5.5×10^{-3} BAOFABXX
 9.1×10^{-5} DPOFDBFL
 5.5×10^{-3} BIOFABMH
 2×10^{-3} DPOFDBFL
 5.5×10^{-3} DPOFABXX
 5.5×10^{-3} BIOFDBMH
 2×10^{-3} BAOFABXX
 9.1×10^{-5} BICFDBMH
 2×10^{-3} BIOFABMH
 2×10^{-3} BIOFDBMH
 2×10^{-3} BADO7ZAM
 8.46×10^{-4} DPOFDBFL
 5.5×10^{-3} BADO7ZAM
 8.46×10^{-4} BIOFDBMH
 2×10^{-3} BADO7ZAM
 8.46×10^{-4} DPOFDAFL
 5.5×10^{-3} BADO7ZAM
 8.46×10^{-4} BIOFDAMH
 2×10^{-3}

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____
B-36		

GENERAL CALCULATIONS

Basic Event Unavailabilities

AFWTRPOP	.100000E-02	BAARYAFO	.9100000E-04	BAARYBFO	.9100000E-04	BAARYCFO	.9100000E-04
BAARYBFO	.9100000E-04	BADJ6ZAM	.8460000E-03	BADD7ZAM	.8460000E-03	BAOFAFL	.9100000E-04
BAOFABFL	.9100000E-04	BAOFDAFL	.9100000E-04	BAOFDBFL	.9100000E-04	BAOFXFL	.9100000E-04
BAO2X1FL	.9100000E-04	BAO2XXFL	.9100000E-04	BAO2X3FL	.9100000E-J4	BAO2X4FL	.9100000E-04
BA20X1FL	.9100000E-04	BA20X2FL	.9100000E-04	BA20X3FL	.9100000E-04	BA20X4FL	.9100000E-04
BAIAZHAET	.2200000E-04	BAIA7BAML	.2800000E-02	BAIA7BBET	.2200000E-04	BAIA7BML	.2800000E-02
BAIA7BCEI	.2200000E-04	BAIA7BCML	.2800000E-02	BAIA7BDEI	.2200000E-04	BAIA7BDML	.2800000E-02
BIB7AAMH	.2800000E-02	BIB7AAUT	.8700000E-04	BIB7ABMH	.2800000E-02	BIB7ABUT	.8700000E-04
BIB7ACMH	.2800000E-02	BIB7ACUT	.8700000E-04	BIB7ADMH	.2800000E-02	BIB7ADUT	.8700000E-04
BIDPAAML	.2800000E-02	BIDPAAUT	.8700000E-04	BIDPABML	.2800000E-02	BIDPABUT	.8700000E-04
BIDPACML	.2800000E-02	BIDPACUT	.8700000E-04	BIDPADML	.2800000E-02	BIDPAUT	.8700000E-04
BIDPEAET	.2200000E-04	BIDPBAMH	.2800000E-02	BIDPBAML	.2800000E-02	BIDPBET	.2200000E-04
BIDPEBMH	.2800000E-02	BIDPBBML	.2800000E-02	BIDPBCEI	.2200000E-04	BIDPBCH	.2800000E-02
BIDFG6-ML	.2800000E-02	BIDPBET	.2200000E-04	BIDPBDMH	.2800000E-02	BIDPBDML	.2800000E-02
BI0FAAFL	.8700000E-04	BI0FAFL	.8700000E-04	BI0FDFL	.8700000E-04		

PREPARED BY _____ DATE _____

DOC NO. _____

REVIEWED BY _____ DATE _____

PAGE NO. _____

C-1

Babcock & Wilcox

a McDermott company

Nuclear Power Generation Division

PDS-21037.1 (9-81)

GENERAL CALCULATIONS

BR051ZFO	1720000E-06	BRB61ZFO	1720000E-06	BRD11HFO	1720000E-06
BRD01ZFO	1720000E-06	BRD02ZFO	1720000E-06	BRD03ZAM	4010000E-04
CHD04ZAM	1396000E-03	CNAMBRCO	1720000E-06	CNARYAC	7000000E-05
CNB3MERFO	1720000E-06	CNBRYATC	7000000E-05	CNBRYCTC	7000000E-05
CSFTSDAH	1200000E-04	CSFT12AH	2000000E-05	CSVSGARS	1840000E-01
CS982ZFB	1100000E-03	CS992ZFB	1100000E-03	CVX1EIFL	5490000E-05
CVX12ZSC	4560000E-06	CVX12ZFO	1540000E-04	CVX2EIFL	5490000E-05
CVX2VSFH	7600000E-05	CVX2ZSC	4560000E-06	CVX2ZFO	1540000E-04
CVX3INAH	1230000E-04	CVX3VSFH	7600000E-05	CVX3EFL	5490000E-05
CJX4EIFL	5490000E-05	CVX4VSFH	7600000E-05	CVX3ZSC	4560000E-06
CVT1RTFC	7000000E-05	CVT1Y2OF	4000000E-02	CVX4ZSC	4560000E-06
CVY2ZT10	4000000E-02	CVY32ZFH	2070000E-03	CVY1ZT10	4000000E-02
CV262ZFC	4560000E-06	CV262ZFC	4560000E-06	CVY2ZFH	2070000E-03
CV2800RE	1900000E-01	CV2800RE	1900000E-01	CV2802LC	4560000E-06
CV2802RE	1100000E-01	CV2803CA	4000000E-02	CV2803HS	1000000E-04
CV2803MF	4000000E-02	CV2806CA	4000000E-02	CV2806HS	1000000E-04
CV2806MF	4000000E-02	CV3850CA	4000000E-02	CV3850MF	1000000E-02
CV3851MF	4000000E-02	0612ZZFS	1340000E-01	DG22ZFS	1340000E-01
DPATCAFL	5500000E-02	DPATCBFH	5500000E-02	DPATCBFL	5500000E-02
DPATCCFL	5500000E-02	DPATCDFH	5500000E-02	DPATCDFL	5500000E-02
DPBTBCFL	5500000E-02	DPBTCCFL	5500000E-02	DPBTCDFL	5500000E-02
DP0FABFL	5500000E-02	DP0FABFL	5500000E-02	DP0FAFL	5500000E-02
FCCVX15S	1200000E-05	FCCVX25S	1200000E-05	FCCVX3FE	1200000E-05
FC2620SS	1200000E-05	FC2626SS	1200000E-05	FC2627FE	1200000E-05
FG0FAAFE	4700000E-05	FG0FABFE	4700000E-05	FG0FDAFE	4700000E-05
FW10AZFB	1100000E-03	FW10BZFB	1000000E-03	FW13AZFB	1100000E-03
TNCAPZAM	1230000E-04	INCOP2AH	1230000E-04	L520X2NS	8700000E-04
LFWLOOP	8450000E+00	LOOP2ZZ	15500000E+00	L520X1NS	8700000E-04
L520X3NS	8700000E-04	LS20X4NS	8700000E-04	LTCVX1FL	5500000E-02
LTCVX3FL	5500000E-02	LTCVX4FL	5500000E-02	OPEN02X1	2000000E-02
OPEN02X3	2000000E-02	OPEN02Y4	2000000E-02	OPEN02X1	2000000E-02
OPEN10X3	2000000E-02	OPEN20X4	2000000E-02	OPEN20X2	2000000E-02
OPFAILP1	1500000E-03	OPFAILSM	6100000E-02	OPESL28	1000000E-03
PRO2X3FL	1840000E-06	PRO2X4FL	1840000E-06	PRO2X1FL	1840000E-06
PR20X3FL	1840000E-06	PR20X4FL	1840000E-06	PR20X1FL	1840000E-06
P7ARECCA	2100000E-02	P7ARECLO	3300000E-02	P7ARECOF	4000000E-02
P7AZZZFS	4100000E-02	P7AZZZFM	7520000E-03	P7AZZZIS	1320000E-02
P7BRECLO	3300000E-02	P7BRECOP	4000000E-02	P7BZZFR	3460000E-03
P7BZZPM	2060000E-04	P7BZZTS	1390000E-02	PEARYASH	3000000E-07
REFRYASH	3000000E-07	REBRYASH	3000000E-07	REDPBASH	3000000E-07

PREPARED BY _____ DATE _____

DOC NO _____

REVIEWED BY _____ DATE _____

PAGE NO _____

C-2

Babcock & Wilcox

McDermott Company

Nuclear Power Generation Division

GENERAL CALCULATIONS

PDS-21037-1 (P-81)

REDFBCSH	.3000000E-07	REDFBDSH	.3000000E-07	REOFAASH	.3000000E-07	REOFABSH	.3000000E-07
RE02X2SH	.3000000E-07	RE0FDASH	.3000000E-07	RE0FDBSH	.3000000E-07	RE02X1SH	.3000000E-07
RE20X2SH	.3000000E-07	RE02X3SH	.3000000E-07	RE02X4SH	.3000000E-07	RE20X1SH	.3000000E-07
RYARYBTC	.7000000E-05	RYBRYATC	.7000000E-05	RYBRYBTC	.7000000E-05	RYARYATC	.7000000E-05
RYCVX2SS	.4200000E-07	RYCVX3EE	.7000000E-05	RYCVX4EE	.2000000E-05	RYCVX1SS	.4200000E-07
RYFGABFE	.7000000E-05	RYFGDAFE	.7000000E-05	RYFGDBFE	.7000000E-05	RYFGAAFE	.7000000E-05
RY1CBPTC	.7000000E-05	RY1P7ATC	.7000000E-05	RY2CAPTC	.7000000E-05	RY1CBPTC	.7000000E-05
RY2P7ATC	.7000000E-05	RY2620SS	.4200000E-07	RY2626SS	.4200000E-07	RY2CBPTC	.7000000E-05
RY2670FE	.7000000E-05	RY28X1AM	.4200000E-07	RY28X2AH	.4200000E-07	RY2627FE	.7000000E-05
RY28X4AM	.4200000E-07	SP02X1FH	.8900000E-07	SP02X2FH	.8900000E-07	RY28X3AM	.4200000E-07
SP02X4FH	.8900000E-07	SP20X1FH	.8900000E-07	SP20X2FH	.8900000E-07	SP02X3FH	.8900000E-07
SU02X4FH	.8900000E-07	SU02X1FL	.1840000E-06	SU02X2FL	.1840000E-06	SU02X3FH	.8900000E-07
SU02X4FL	.1840000E-06	SU20X1FL	.1840000E-06	SU20X2FL	.1840000E-06	SU02X3FL	.1840000E-06
SU20X4FL	.1840000E-06	SWSUCIOP	.4000000E-01	SW13Z2FB	.1100000E-03	TCAINZAH	.1230000E-04
TCAINRFO	.1720000E-06	TCA5PTAM	.1200000E-04	TCA15TAM	.1200000E-04	TCA48TAM	.1200000E-04
TCA5TRAM	.1200000E-04	TCBINZAM	.1230000E-04	TCBHBRFO	.1720000E-06	TCBSPTAM	.1200000E-04

TCB15TAM	.1200000E-04	TCB48TAM	.1200000E-04	TCB5TRAM	.1200000E-04	TCC1NZAM	.1230000E-04
TCCMORFO	.1720000E-06	TCC15TAM	.1200000E-04	TCC48TAM	.1200000E-04	TCC5TRAM	.1200000E-04
TCD1N7AM	.1230000E-04	TCDMBRFO	.1720000E-06	TCD15TAM	.1200000E-04	TCD48TAM	.1200000E-04
TCD5TRAM	.1200000E-04	T1RYX1SS	.4200000E-07	T1RYX2SS	.4200000E-07	T1RYX3SS	.4200000E-07
T1RYX1SS	.4200000E-07	W1ZZZZFB	.1100000E-03	W2ZZZZFB	.1100000E-03	W3ZZZZFB	.1100000E-03
W4ZZZZFB	.1100000E-03	W5ZZZZFB	.1100000E-03	W6ZZZZFB	.1100000E-03	W7ZZZZFB	.1100000E-03

PREPARED BY _____

DATE _____

DOC. NO. _____
PAGE NO. _____

C - 3

GENERAL CALCULATIONS

BAOFABXX	9.1×10^{-5}
BIOFABMH	2×10^{-3}
BIOFDBMH	2×10^{-3}
BRA120XX	1.72×10^{-7}
CSPTSAXX	1.2×10^{-5}
DPOFABXX	5.5×10^{-3}
DPOFDBFL	5.5×10^{-3}
INY11ZXX	1.23×10^{-5}

PREPARED BY _____	DATE _____	DOC. NO. _____
REVIEWED BY _____	DATE _____	PAGE NO. _____
C-4		