

Mr. Boyce H. Grier, Director
Office of Inspection & Enforcement, Region 1
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

No. 2-80-15/3L-1X

Dear Mr. Grier:

This L.E.R. concerns the failure of RCIC outboard steam supply isolation valve MO-2-13-16 to close during surveillance testing. The applicable Technical Specification is 3.7.D.1.

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 P A P B S 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
 7 8 9 14 15 25 26 57 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

0 1 REPORT SOURCE L 5 0 5 0 - 0 2 7 7 7 0 9 0 4 8 0 8 1 2 1 7 8 0 9
 60 61 68 69 74 75 80
 DOCKET NUMBER EVENT DATE REPORT DATE

0 2 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
 During surveillance testing of the RCIC steam line high flow switches

0 3 with the unit at full power, RCIC outboard steam supply isolation valve

0 4 MO-2-13-16 failed to close as required by Tech. Spec. 3.7.D.1. The

0 5 redundant inboard steam supply isolation valve was verified operable.

0 6

0 7

0 8

0 9 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
 9 10 11 12 13 14 15 16
 C E A V A L V O P A Z

0 1 LEI NO REPORT NUMBER 17 8 0 21 22
 23 24 25 26 27 28 29 30 31 32
 EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

0 2 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPR-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
 33 34 35 36 37 38 39 40 41 42 43 44 45
 E Z Z Z 0 0 0 0 N Y N L 2 0 0

0 3 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
 A limit switch on the limitorque operator for MO-2-13-16 did not function properly, which prevented automatic valve closure. A jumper was installed to restore valve closure from an isolation signal and was satisfactorily tested. During an outage on 11/15/80 the switch was readjusted, the jumper removed, and the valve was satisfactorily tested.

0 4 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
 47 48 49 50 51 52 53 54 55 56
 2 0 9 2 N/A B Operator Observation

0 5 ACTIVITY CONTENT AMOUNT OF ACTIVITY LOCATION OF RELEASE
 57 58 59 60
 Z Z N/A NA

0 6 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
 61 62 63 64
 0 0 0 Z NA

0 7 PERSONNEL INJURIES NUMBER DESCRIPTION
 65 66 67
 0 0 0 NA

0 8 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
 68 69 70
 Z NA

0 9 PUBLICITY ISSUE DESCRIPTION
 71 72 73
 N NA

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

NAME OF PREPARER: M. J. Cooney
 PHONE: (215) 841-5020
 8012290359