

GPU Nuclear

GPU Nuclear

P.O. Box 480
Middletown, Pennsylvania 17057
717-944-7621
Writer's Direct Dial Number:

August 9, 1982
4400-82-L-0133

Office of Inspection and Enforcement
Attn: Mr. Ronald C. Haynes, Director
Region I
US Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Licensee Event Report 82-024/03L-0

Attached please find Licensee Event Report 82-024/03L-0 concerning the inoperability of the Fuel Handling Building Ventilation System due to low exhaust flowrate on July 8, 1982.

This event concerns Section 3.9.12 and is considered reportable under Section 6.9.1.9(b) of the Interim Recovery Technical Specifications.

Sincerely,



B. K. Kanga
Director, TMI-2

BKK/SDC/jep

Attachment

CC: L. H. Barrett, Deputy Program Director - TMI Program Office
B. J. Snyder, Program Director - TMI Program Office
V. Stello, Deputy Executive Director

8208180054 820809
PDR ADOCK 05000320
S PDR

IE22