

APPENDIX A

NOTICE OF VIOLATION

Omaha Public Power District
Fort Calhoun Station

Docket: 50-285/82-12
License: DPR-40

Based on the results of an NRC inspection conducted during the period of June 1-30, 1982, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987, dated March 9, 1982, the following violation was identified:

Failure to Follow Procedures

Technical Specification 5.8.1 requires that "written procedures . . . be established, implemented, and maintained that meet or exceed the minimum requirements of Sections 5.1 and 5.3 of ANSI N18.7-1972, and Appendix A of USNRC Regulatory Guide 1.33"

Standing Order G-7 establishes the Operating Manual and states in Section 1.3 that "adherence to (the) Operating Manual is mandatory."

Section 2.10.1 of the Fort Calhoun Station Radiation Protection Manual, (volume VII of the Operating Manual) states that "all . . . instructions of Radiation Work Permits (RWP's) will be obeyed."

Contrary to the above, on June 17, 1982, a licensee representative failed to wear the appropriate clothing required by the RWP under which he entered the control area. As a result, the person and parts of his clothing became contaminated in excess of allowable limits for the unrestricted area.

This is a Severity Level IV Violation. (Supplement I.D.2) (285/8212-01)

Pursuant to the provisions of 10 CFR 2.201, Omaha Public Power District is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: _____

JUL 28 1982