

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
NRC

AUG 12 AM 11:52

SCE

REGION V

H. B. RAY
STATION MANAGER

August 6, 1982

TELEPHONE
(714) 492-7700

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-206
Installation of Radiation Monitors
Licensee Event Report No. 82-013
San Onofre Nuclear Generating Station, Unit 1

Reference: Letter, H. B. Ray (SCE) to R. H. Engelken (NRC),
Installation of Radiation Monitors,
dated June 11, 1982

In the reference we stated that the installation of radiation monitors in the release line of the Reheater Pit Sump and Oily Waste Sump would be completed by August 1, 1982.

As a result of unanticipated delays in performing the hydrostatic testing of the system piping and completing the system control circuitry, the work associated with monitor installation has not yet been completed. The entire installation effort will be concluded before the end of the current outage.

Pending the installation of these monitors, all effluent discharges will continue to be analyzed at the beginning, midpoint, and end of the release in accordance with Technical Specification 4.5.D(2).

8208180076 820806
PDR ADOCK 05000206
S PDR

IE-29

82-318


Mr. R. H. Engelker

-2-

August 6, 1982

If you have any questions or if we can provide additional information, please let me know.

Sincerely,

A handwritten signature in cursive script, appearing to read "A. S. Ray". The signature is written in dark ink and is positioned below the word "Sincerely,".

cc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission
Office of Management Information and Program Control

Institute of Nuclear Power Operations

L. F. Miller (USNRC Resident Inspector, San Onofre, Unit 1)