



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ENERGY OPERATIONS, INC.

SYSTEM ENERGY RESOURCES, INC.

SOUTH MISSISSIPPI ELECTRIC POWER ASSOCIATION

MISSISSIPPI POWER AND LIGHT COMPANY

DOCKET NO. 50-416

GRAND GULF NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 109
License No. NPF-29

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Operations, Inc. (the licensee) dated May 20, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-29 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 109, are hereby incorporated into this license. Entergy Operations, Inc. shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



William D. Beckner, Director
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the
Technical Specifications

Date of Issuance: December 13, 1993

ATTACHMENT TO LICENSE AMENDMENT NO. 109

FACILITY OPERATING LICENSE NO. NPF-29

DOCKET NO. 50-416

Replace the following pages of the Appendix A Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

REMOVE PAGES

3/4 3-1
3/4 3-2
3/4 3-5
3/4 3-6
3/4 3-7
3/4 3-8
3/4 3-53
3/4 3-54
3/4 3-55
3/4 3-55a
3/4 3-56
3/4 3-57
3/4 10-3
3/4 10-4

INSERT PAGES

3/4 3-1
3/4 3-2
3/4 3-5
3/4 3-6
3/4 3-7
3/4 3-8
3/4 3-53
3/4 3-54
3/4 3-55
3/4 3-55a
3/4 3-56
3/4 3-57
3/4 10-3
3/4 10-4

3/4.3 INSTRUMENTATION

3/4.3.1 REACTOR PROTECTION SYSTEM INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.1 As a minimum, the reactor protection system instrumentation channels shown in Table 3.3.1-1 shall be OPERABLE with the REACTOR PROTECTION SYSTEM RESPONSE TIME as shown in Table 3.3.1-2.

APPLICABILITY: As shown in Table 3.3.1-1.

ACTION:

- a. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for one trip system, place the inoperable channel and/or that trip system in the tripped condition* within twelve hours.
- b. With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip System requirement for both trip systems, place at least one trip system** in the tripped condition within one hour and take the ACTION required by Table 3.3.1-1.

SURVEILLANCE REQUIREMENTS

4.3.1.1 Each reactor protection system instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTIONAL TEST and CHANNEL CALIBRATION operations for the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.1.1-1.

4.3.1.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months.

4.3.1.3 The REACTOR PROTECTION SYSTEM RESPONSE TIME of each reactor trip functional unit shown in Table 3.3.1-2 shall be demonstrated to be within its limit at least once per 18 months. Each test shall include at least one channel per trip system such that all channels are tested at least once every N times 18 months where N is the total number of redundant channels in a specific reactor trip system.

4.3.1.4 The provisions of Specification 4.0.4 are not applicable to the Channel Functional Test surveillance for the Intermediate Range Monitors for entry into the applicable OPERATIONAL CONDITIONS (as specified in Table 4.3.1.1-1) from OPERATIONAL CONDITION 1, provided the surveillances are performed within 12 hours after such entry.

*An inoperable channel need not be placed in the tripped condition where this would cause the Trip Function to occur. In these cases, the inoperable channel shall be restored to OPERABLE status within 6 hours or the ACTION required by Table 3.3.1-1 for that Trip Function shall be taken.

**The trip system need not be placed in the tripped condition if this would cause the Trip Function to occur. When a trip system can be placed in the tripped condition without causing the Trip Function to occur, place the trip system with the most inoperable channels in the tripped condition; if both systems have the same number of inoperable channels, place either trip system in the tripped condition.

TABLE 3.3.1-1

REACTOR PROTECTION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (a)</u>	<u>ACTION</u>
1. Intermediate Range Monitors:			
a. Neutron Flux - High	2 5 ^{(b)(1)}	3 3	1 3
b. Inoperative	2 5 ⁽¹⁾	3 3	1 3
2. Average Power Range Monitor ^{(b)(c)} :			
a. Neutron Flux - High, Setdown	2	3	1
b. Flow Biased Simulated Thermal Power - High	1	3	4
c. Neutron Flux - High	1	3	4
d. Inoperative	1, 2	3	1
3. Reactor Vessel Steam Dome Pressure - High	1, 2 ^(d)	2	1
4. Reactor Vessel Water Level - Low, Level 3	1, 2	2	1
5. Reactor Vessel Water Level-High, Level 8	1 ^(e)	2	4
6. Main Steam Line Isolation Valve - Closure	1 ^(e)	4	4
7. Main Steam Line Radiation - High	1, 2 ^(d)	2	5
8. Drywell Pressure - High	1, 2 ^(f)	2	1

TABLE 3.3.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION

TABLE NOTATIONS

- (a) A channel may be placed in an inoperable status for up to 6 hours for required surveillance without placing the trip system in the tripped condition provided at least one OPERABLE channel in the same trip system is monitoring that parameter.
- (b) The "shorting links" shall be removed from the RPS circuitry prior to and during the time any control rod is withdrawn* per Specification 3.9.2 and shutdown margin demonstrations performed per Specification 3.10.3.
- (c) An APRM channel is inoperable if there are less than 2 LPRM inputs per level or less than 14 LPRM inputs to an APRM channel.
- (d) This function is not required to be OPERABLE when the reactor pressure vessel head is unbolted or removed per Specification 3.10.1.
- (e) This function shall be automatically bypassed when the reactor mode switch is not in the Run position.
- (f) This function is not required to be OPERABLE when DRYWELL INTEGRITY is not required.
- (g) With any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.
- (h) This function shall be automatically bypassed when operating below the appropriate turbine first stage pressure setpoint of:
 - (1) $\leq 26.9\%^{**}$ of the value of turbine first-stage pressure at valves wide open (VWO) steam flow when operating with rated feedwater temperature of greater than or equal to 420°F, or
 - (2) $\leq 22.5\%^{**}$ of the value of turbine first-stage pressure at VWO steam flow when operating with rated feedwater temperature between 370°F and 420°F.
- (i) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

* Not required for control rods removed per Specification 3.9.10.1 or 3.9.10.2.

** Allowable setpoint values of turbine first-stage pressure equivalent to THERMAL POWER less than 40% of RATED THERMAL POWER.

TABLE 3.3.1-2

REACTOR PROTECTION SYSTEM RESPONSE TIMES

<u>FUNCTIONAL UNIT</u>	<u>RESPONSE TIME (Seconds)</u>
1. Intermediate Range Monitors:	
a. Neutron Flux - High	NA
b. Inoperative	NA
2. Average Power Range Monitor*:	
a. Neutron Flux - High, Setdown	NA
b. Flow Biased Simulated Thermal Power - High	< 0.09**
c. Neutron Flux - High	< 0.09
d. Inoperative	NA
3. Reactor Vessel Steam Dome Pressure - High	< 0.35
4. Reactor Vessel Water Level - Low, Level 3	< 1.05
5. Reactor Vessel Water Level - High, Level 8	< 1.05
6. Main Steam Line Isolation Valve - Closure	< 0.06
7. Main Steam Line Radiation - High	NA
8. Drywell Pressure - High	NA
9. Scram Discharge Volume Water Level - High	NA
10. Turbine Stop Valve - Closure	< 0.10
11. Turbine Control Valve Fast Closure, Valve Trip System Oil Pressure - Low	< 0.10 [#]
12. Reactor Mode Switch Shutdown Position	NA
13. Manual Scram	NA

*Neutron detectors are exempt from response time testing. Response time shall be measured from the detector output or from the input of the first electronic component in the channel.

**Not including simulated thermal power time constant.

[#]Measured from start of turbine control valve fast closure.

TABLE 4.3.1.1-1

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. Intermediate Range Monitors:				
a. Neutron Flux - High	S/U, S, ^(b) S	S/U, W W	R R	2 5 ^(c)
b. Inoperative	NA	W	NA	2, 5 ^(c)
2. Average Power Range Monitor: ^(f)				
a. Neutron Flux - High, Setdown	S/U, S, ^(b)	S/U, W	SA	2
b. Flow Biased Simulated Thermal Power - High	S,	Q	W ^{(d)(e)} , SA, R ⁽¹⁾	1
c. Neutron Flux - High	S	Q	W ^(d) , SA	1
d. Inoperative	NA	Q	NA	1, 2
3. Reactor Vessel Steam Dome Pressure - High	S	Q	R ^(g)	1, 2 ^(j)
4. Reactor Vessel Water Level - Low, Level 3	S	Q	R ^(g)	1, 2
5. Reactor Vessel Water Level - High, Level 8	S	Q	R ^(g)	1
6. Main Steam Line Isolation Valve - Closure	NA	Q	R	1
7. Main Steam Line Radiation - High	S	Q	R	1, 2 ^(j)
8. Drywell Pressure - High	S	Q	R ^(g)	1, 2 ^(k)

TABLE 4.3.1.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
9. Scram Discharge Volume Water Level - High				
a. Transmitter/Trip Unit	S	Q	R ^(g)	1, 2, 5 ⁽¹⁾
b. Float Switch	NA	Q	R	1, 2, 5 ⁽¹⁾
10. Turbine Stop Valve - Closure	S	Q	R ^(g)	1
11. Turbine Control Valve Fast Closure Valve Trip System Oil Pressure - Low	S	Q	R ^(g)	1
12. Reactor Mode Switch Shutdown Position	NA	R	NA	1, 2, 3, 4, 5
13. Manual Scram	NA	W	NA	1, 2, 3, 4, 5

(a) Neutron detectors may be excluded from CHANNEL CALIBRATION.

(b) The IRM and SRM channels shall be determined to overlap for at least 1/2 decade during each startup after entering OPERATIONAL CONDITION 2 and the IRM and APRM channels shall be determined to overlap for at least 1/2 decade during each controlled shutdown, if not performed within the previous 7 days.

(c) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

(d) This calibration shall consist of the adjustment of the APRM channel to conform to the power values calculated by a heat balance during OPERATIONAL CONDITION 1 when THERMAL POWER 25% of RATED THERMAL POWER. Adjust the APRM channel if the absolute difference is greater than 2% of RATED THERMAL POWER.

(e) This calibration shall consist of the adjustment of the APRM flow biased channel to conform to a calibrated flow signal.

(f) The LPRMs shall be calibrated at least once per 1000 MWD/T using the TIP system.

(g) Calibrate trip unit at least once per 92 days.

(h) Deleted.

(i) This calibration shall consist of verifying the 6 ± 1 second simulated thermal power time constant.

(j) Not applicable when the reactor pressure vessel head is unbolted or removed per Specification 3.10.1.

(k) Not applicable when DRYWELL INTEGRITY is not required.

(l) Applicable with any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.

TABLE 3.3.6-1

CONTROL ROD BLOCK INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP FUNCTION</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
1. <u>ROD PATTERN CONTROL SYSTEM</u>			
a. Low Power Setpoint	2	1, 2	60
b. High Power Setpoint	2	1#	60
2. Deleted			
3. <u>SOURCE RANGE MONITORS</u>			
a. Detector not full in ^(a)	4	2##	61
	2**	5	62
b. Upscale ^(b)	4	2##	61
	2**	5	62
c. Inoperative ^(b)	4	2##	61
	2**	5	62
d. Downscale ^(c)	4	2##	61
	2**	5	62
4. Deleted			
5. <u>SCRAM DISCHARGE VOLUME</u>			
a. Water Level-High	2	1, 2, 5*	64
6. <u>REACTOR COOLANT SYSTEM RECIRCULATION FLOW</u>			
a. Upscale	3	1	64
7. <u>REACTOR MODE SWITCH SHUTDOWN POSITION</u>	2	3, 4	63

INSTRUMENTATION

TABLE 3.3.6-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION

ACTION

- ACTION 60 - Declare the RPCS inoperable and take the ACTION required by Specification 3.1.4.2.
- ACTION 61 - With the number of OPERABLE Channels:
- a. One less than required by the Minimum OPERABLE Channels per Trip Function requirement, restore the inoperable channel to OPERABLE status within 7 days or place the inoperable channel in the tripped condition within the next hour.
 - b. Two or more less than required by the Minimum OPERABLE Channels per Trip Function requirement, place at least one inoperable channel in the tripped condition within one hour.
- ACTION 62 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, place the inoperable channel in the tripped condition within one hour.
- ACTION 63 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, initiate a rod block.
- ACTION 64 - With the number of OPERABLE channels less than required by the Minimum OPERABLE Channels per Trip Function requirement, place the inoperable channel in the tripped condition within 12 hours.

NOTES

- * With more than one control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.
- ** OPERABLE channels must be associated with SRMs required OPERABLE per Specification 3.9.2.
- # With THERMAL POWER greater than the Low Power Setpoint.
- ## Whenever the related function is not bypassed as specified in notes (a) through (c).
- (a) This function shall be automatically bypassed if detector count rate is > 100 cps or the IRM channels are on range 3 or higher.
- (b) This function shall be automatically bypassed when the associated IRM channels are on range 8 or higher.
- (c) This function shall be automatically bypassed when the IRM channels are on range 3 or higher.
- (d) Deleted

TABLE 3.3.6-2

CONTROL ROD BLOCK INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. <u>ROD PATTERN CONTROL SYSTEM</u>		
a. Low Power Setpoint	20 + 15, -0% of RATED THERMAL POWER	20 + 15, -0% of RATED THERMAL POWER
b. High Power Setpoint	≤70% of RATED THERMAL POWER	≤70% of RATED THERMAL POWER
2. Deleted		
3. <u>SOURCE RANGE MONITORS</u>		
a. Detector not full in	NA	NA
b. Upscale		≤ 1 x 10 ⁵ cps ≤ 1.5 x 10 ⁵ cps
c. Inoperative	NA	NA
d. Downscale	≥ 0.7 cps	≥ 0.5 cps
4. Deleted		
5. <u>SCRAM DISCHARGE VOLUME</u>		
a. Water Level-High	≤ 32 inches	≤ 33.5 inches
6. <u>REACTOR COOLANT SYSTEM RECIRCULATION FLOW</u>		
a. Upscale	≤ 111% of rated flow	≤ 114% of rated flow
7. <u>REACTOR MODE SWITCH SHUTDOWN POSITION</u>		NANA

INSTRUMENTATION

TABLE 4.3.6-1 (Continued)

CONTROL ROD BLOCK INSTRUMENTATION SURVEILLANCE REQUIREMENTS

NOTES:

- a. Neutron detectors may be excluded from CHANNEL CALIBRATION.
- b. Within 7 days prior to startup.
- c. [Deleted]
- d. [Deleted]
- e. [Deleted]
- f. [Deleted]
- g. [Deleted]
- h. [Deleted]
- * With any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.10.1 or 3.9.10.2.
- ** With THERMAL POWER greater than the Low Power Setpoint.
- ## Whenever the related function is not bypassed as specified in Table 3.4.6-1 notes (a) through (c).

TABLE 4.3.6-1

CONTROL ROD BLOCK INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION^(*)</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>ROD PATTERN CONTROL SYSTEM</u>				
a. Low Power Setpoint	NA	S/U ^(b) , Q	Q	1, 2
b. High Power Setpoint	NA	S/U ^(b) , Q	Q	1**
2. Deleted				
3. <u>SOURCE RANGE MONITORS</u>				
a. Detector not full in	NA	S/U,W	NA	2##, 5
b. Upscale	NA	S/U,W	Q	2##, 5
c. Inoperative	NA	S/U,W	NA	2##, 5
d. Downscale	NA	S/U,W	Q	2##, 5
4. Deleted				
5. <u>SCRAM DISCHARGE VOLUME</u>				
a. Water Level-High	NA	Q	R	1, 2, 5*
6. <u>REACTOR COOLANT SYSTEM RECIRCULATION FLOW</u>				
a. Upscale	NA	Q	Q	1
7. <u>REACTOR MODE SWITCH SHUTDOWN POSITION</u>	NA	R	NA	3, 4

SPECIAL TEST EXCEPTIONS

3/4.10.3 SHUTDOWN MARGIN DEMONSTRATIONS

LIMITING CONDITION FOR OPERATION

3.10.3 The provisions of Specification 3.9.1, Specification 3.9.3 and Table 1.2 may be suspended to permit the reactor mode switch to be in the Startup position and to allow more than one control rod to be withdrawn for shutdown margin demonstration, provided that at least the following requirements are satisfied.

- a. The source range monitors are OPERABLE per Specification 3.9.2 with the RPS circuitry "shorting links" removed.
- b. The rod pattern control system is OPERABLE per Specification 3.1.4.2, or conformance with the shutdown margin demonstration procedure is verified by a second licensed operator or other technically qualified member of the unit technical staff.
- c. The "continuous withdrawal" control shall not be used during out-of-sequence movement of the control rods.
- d. No other CORE ALTERATIONS are in progress.
- e. The Average Power Range Monitors are OPERABLE per the requirements of Specification 3.3.1 for OPERATIONAL CONDITION 2.

APPLICABILITY: OPERATIONAL CONDITION 5, during shutdown margin demonstrations.

ACTION:

With the requirements of the above specification not satisfied, immediately place the reactor mode switch in the Shutdown or Refuel position.

SURVEILLANCE REQUIREMENTS

4.10.3 Within 30 minutes prior to and at least once per 12 hours during the performance of a shutdown margin demonstration, verify that;

- a. The source range monitors are OPERABLE per Specification 3.9.2 with the RPS circuitry "shorting links" removed.
- b. The rod pattern control system OPERABLE, or a second licensed operator or other technically qualified member of the unit technical staff is present and verifies compliance with the shutdown demonstration procedures, and
- c. No other CORE ALTERATIONS are in progress.

SPECIAL TEST EXCEPTIONS

3/4.10.4 RECIRCULATION LOOPS

LIMITING CONDITION FOR OPERATION

3.10.4 The requirements of Specifications 3.4.1.1 and 3.4.1.3 that recirculation loops be in operation may be suspended for up to 24 hours for the performance of:

- a. PHYSICS TESTS, provided that THERMAL POWER does not exceed 5% of RATED THERMAL POWER, or
- b. The Startup Test Program.

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2, during PHYSICS TESTS and the Startup Test Program.

ACTION:

- a. With the above specified time limit exceeded, insert all control rods.
- b. With the above specified THERMAL POWER limit exceeded during PHYSICS TESTS, immediately place the reactor mode switch in the Shutdown position.

SURVEILLANCE REQUIREMENTS

4.10.4.1 The time during which the above specified requirement has been suspended shall be verified to be less than 24 hours at least once per hour during PHYSICS TESTS and the Startup Test Program.

4.10.4.2 THERMAL POWER shall be determined to be less than 5% of RATED THERMAL POWER at least once per hour during PHYSICS TESTS.