



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

January 27, 1981

Docket Nos.: 50-266
and 50-301

Mr. Sol Burstein
Executive Vice President
Wisconsin Electric Power Co.
231 W. Michigan Street
Milwaukee, Wisconsin 53201



Dear Mr. Burstein:

Our letter of September 21, 1979 forwarded our requirements regarding the auxiliary feedwater system at Point Beach Nuclear Plant, Units 1 and 2. You provided responses to these requirements in letters dated October 29, 1979, December 17, 1979, February 4, 1980 and July 8, 1980.

Our evaluation of your responses is contained in the enclosed Safety Evaluation Report (SER).

The SER contains seven items for which our review is not complete:

1. Short Term Recommendation GS-1 - The licensee has not met our recommendation for revision to the Point Beach Technical Specifications for plant operation with inoperable AFW pumps in accordance with current Standard Technical Specifications.
2. Additional Short Term Recommendation 1 - The licensee has not provided sufficient information to assure that no inadvertent means exists for defeating the redundancy in the condensate storage tank level indication system or that adequate protection against such occurrences is provided.
3. Additional Short Term Recommendation 3 - The safety grade design (long term requirement) for auxiliary feedwater flow indication is under review. The evaluation will be contained in a supplement to this SER.
4. Long Term Recommendation GL-3 - The licensee has not met our long term recommendation for assuring AFW system flow independent of any AC power sources for two hours.
5. Long Term Recommendation GL-4 - The licensee has not met our long term recommendation for providing AFW pump protection for plants with unprotected normal AFW system water supplies.

Mr. Sol Burstein

- 2 -


6. Long Term Recommendation GL-5 - The safety grade design for auxiliary feedwater automatic initiation signals and circuits is under review. The evaluation will be contained in a supplement to this SER.
7. Recommendation (Enclosure 2) - The licensee has not provided a response to Enclosure 2 of our September 21, 1979 letter concerning a request for information on AFW system flow requirements.

You are requested to respond to the unresolved items within 60 days of your receipt of this letter.

Note for planning purposes that recommendations GS-1, GL-5 and additional short term recommendations 1 and 3 have a 7/1/81 implementation date and recommendations GL-3 and GL-4 have a 1/1/82 implementation date (i.e., NUREG-0737 II.E.1.1 and II.E.1.2).

Please contact us if you have any questions.

Sincerely,



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure: SER

cc: w/enclosure
See next page

Mr. Sol Burstein
Wisconsin Electric Power Company

cc: Mr. Bruce Churchill, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Mr. William Guldemon
USNRC Resident Inspectors Office
6612 Nuclear Road
Two Rivers, Wisconsin 54241

Joseph Mann Library
1516 Sixteenth Street
Two Rivers, Wisconsin 54241

Mr. Glenn A. Reed, Manager
Nuclear Operations
Wisconsin Electric Power Company
Point Beach Nuclear Plant
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha
Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Ms. Kathleen M. Falk
General Counsel
Wisconsin's Environmental Decade
302 E. Washington Avenue
Madison, Wisconsin 53703

Director, Criteria and Standards Division
Office of Radiation Programs (ANR-460)
U.S. Environmental Protection Agency
Washington, D.C. 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 S. Dearborn Street
Chicago, Illinois 60604

Chairman
Public Service Commission of Wisconsin
Hill Farms State Office Building
Madison, Wisconsin 53702