

Docket No: 99900774/82-01

AUG 06 1982

AIRCO Welding Products
Arcrods Plants
ATTN: Mr. J. J. Heidelmaier
Manager, Quality Assurance
P. O. Box 6686
Sparrows Point, MD 21219

Gentlemen:

This refers to the inspection conducted by Mr. J. T. Conway of this office on May 17-21, 1982, of your facility at Sparrows Point, Maryland, associated with the manufacture of nuclear welding products and to the discussion of our findings with you and members of your staff at the conclusion of the inspection.

This inspection was made as a result of a potential 10 CFR Part 50.55(e) notification which addresses coated stainless steel welding rods mislabeled as E-7018 carbon steel rods. The notification was made by Baldwin Associates at the Illinois Power Company Clinton Station site, Clinton, Illinois.

Areas examined and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

During the inspection it was found that the implementation of your QA program failed to meet certain NRC requirements. The specific findings and references to the pertinent requirements are identified in the enclosures to this letter.

The Notice of Violation is sent to you pursuant to the provisions of Section 206 of the Energy Reorganization Act of 1974. You are required to submit to this office within 30 days from the date of this letter, a written statement containing: (1) a description of steps that have been or will be taken to correct the items; (2) a description of steps that have been or will be taken to prevent recurrence; and (3) the dates your corrective actions and preventive measures were or will be completed. Consideration may be given to extending your response time for good cause shown.

You are also requested to submit a similar written statement for each item which appears in the enclosed Notice of Nonconformance.

8208190281 820806
PDR QA999 EMVAIRC
99900774 PDR

19:09

OFFICE	RIV CI:R&CPS JB	SC:R&CPS JB	BC:VPB JP	D:IES	RA:RIV		
NAME	JTConway/jr	IBarnes	UPotapovs	EHJohnson	JTCollins		
DATE	6/4/82	6/4/82	6/4/82	6/ /82	6/6/82		

FOR: OFFICIAL RECORD COPY

The responses directed by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request for withholding; and (b) submit within 25 days from the date of this letter a written application to this office to withhold such information. If your receipt of this letter has been delayed such that less than 7 days are available for your review, please notify this office promptly so that a new due date may be established. Consistent with Section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in the Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Uldis Potapovs, Chief
Vendor Programs Branch

Enclosures:

1. Appendix A - Notice of Violation
2. Appendix B - Notice of Nonconformance
3. Appendix C - Inspection Report No. 99900774/82-01
4. Appendix D - Inspection Data Sheets (6 pages)

bcc:

IE Files

AEOD

QAB

NRC:PDR

Reg. Administrators, I, II, III, IV, V

E. Johnson, RIV

ASME

OFFICE ► NBB & PVI

NAME ►

DATE ►