

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
EXH - CONTAINMENT POLAR CRANE

1.0 PURPOSE

To perform periodic Preventive Maintenance Inspections, tests and servicing on the Whiting 175/25 Ton Containment Polar Cranes (Serial Nos. 11245 and 11246).

2.0 REFERENCES

- 2.1 29CFR 1910.79; OSHA  
2.2 29CFR 1910.80; OSHA  
2.3 ANSI B30.2.0 - 1976; Overhead cranes  
2.4 CNM-1125.01.69; Whiting manual  
2.5 Station Directive 3.1.1; Safety Tags and Delineation Tags  
2.6 Station Directive 3.1.21; Oil Spill Prevention, Control and Counter-measure Plan.  
2.7 Hooks - Safety Inspection MP/0/B/7650/08  
2.8 Cranes and Hoists - Safety Inspection Procedure MP/0/B/7650/05

FOR INFORMATION ONLY

3.0 SPECIAL TOOLS/TEST EQUIPMENT (Record test equipment on Enclosure 7.4 and 7.5)

- |   |   |
|---|---|
| 3.1 General Shop/Hand Tools               | 3.10 Fine bristle brush 1-1½"                       |
| 3.2 Flashlight                            | 3.11 Hand Grease Gun w/Unirex N-2                   |
| 3.3 Wiping rags - lint free ½ lb.         | 3.12 Hand Grease Gun w/Ronex MP                     |
| 3.4 Micrometer 1-3 inch                   | 3.13 Lubricant Teresstic - 150                      |
| 3.5 Caliper with 12 inch scale            | 3.14 Hyraulic Fluid - Atlas 450<br>Super Heavy Duty |
| 3.6 Sheave gauges (see PM<br>Coordinator) | 3.15 Container for used oil, 10 gallons             |
| 3.7 Safety belts and hooks                | 3.16 Small Funnel                                   |

- 3.8 Multimeter - Simpson 260 or equal    3.17 Lubricant Nuto-H68  
3.9 500V megger    3.18 Lubricant Teresstic-68

#### 4.0 SAFETY CONSIDERATIONS

Record on Enclosures 7.4 and 7.5.

- 4.1 Warning signs posted as necessary to protect personnel under the crane.
- 4.2 If possible, move the crane to an area where the inspection work will cause minimum interference with other work.
- 4.3 Upon completion of the PM Inspection, insure that all guards and other safety devices are replaced and that all maintenance equipment is removed.
- 4.4 Insure crane operator and maintenance personnel are instructed in recognizing signs of heat stress and heat stroke and to act to prevent injury.
- 4.5 When specified in the procedure, electrical power shall be de-energized and tagged out. All electrical checks to be performed with equipment de-energized.
- 4.6 Oil must be checked for radiation contamination prior to disposal.
- 4.7 Radiation work permit issued (RWP or SRWP) as necessary.

#### 5.0 STATION/EQUIPMENT STATUS

- 5.1 Record on Enclosures 7.4 and 7.5.
- 5.2 Shutdown; crane must be out-of-service for PM inspection.

#### 6.0 PROCEDURE

Preventive Maintenance inspections, tests and servicing will be performed on a periodic basis by trained, qualified individuals as designated by Maintenance Sections.

Check each item on the inspection checklist, Enclosure 7.4 or 7.5, to indicate satisfactory or unsatisfactory conditions and initial. Explain all unsatisfactory items in "Remarks" section.

- 6.1 Yearly or before return to service (after 6 months); Mechanical Maintenance will perform Section 6.1 of this procedure, and complete Enclosure 7.4.
- 6.1.1 Have crane operator perform operational tests and verify all operating controls to be in proper adjustment and not interfering with proper operation. Perform the following:

- 6.1.1.1 The crane should be operated to all the limits of its travel without a load on the hook. Check proper release, coastdown, and holding of main hoist motor, and auxiliary hoist motor brakes.

**\*\*CAUTION\*\***

Each motion shall be inched into its limit or run in at slow speed. If a limit switch malfunctions, stop motion immediately.

- 6.1.1.2 Test the operation of all braking systems.
- 6.1.1.3 Check that bridge and trolley collector shoes do not arc.
- 6.1.1.4 Perform operational check of motion alarms.
- 6.1.1.5 Check that sheaves are all turning on main and auxiliary hoist operations.
- 6.1.1.6 Check that cables do not rub on framework or block housing and go into grooves properly.
- 6.1.2 Have each hoist hook lowered for inspection.
- 6.1.3 Have Operations deenergize and tag out crane for PM Inspection.
- 6.1.4 Inspect main bridge.
  - 6.1.4.1 Visually check overall general conditions, i.e., dust, dirt, oil, grease, loose or broken equipment or components.
  - 6.1.4.2 Check that gear case covers fit tight; check seals for leaks. Check/clean drip pan if supplied.
  - 6.1.4.3 Check couplings, pillow blocks and mounting brackets; they should not be loose, cracked or broken.
  - 6.1.4.4 Check oil level in bridge drive gear case, if low add Teresstic-150.
- 6.1.5 Inspect trolley in accordance with step 6.1.4.
- 6.1.6 Inspect main hoist in accordance with step 6.1.4.
- 6.1.7 Inspect auxiliary hoist in accordance with step 6.1.4.
- 6.1.8 Inspect gear motors on main and auxiliary hoists as follows:
  - 6.1.8.1 Inspect for oil leakage at seals, caps, plugs, pipe fittings, etc.

- 6.1.8.2 Check/clean oil breather with standard cleaning solution and blow dry.
- 6.1.8.3 Check bearing supports and bearings.
- 6.1.8.4 Clean oil, dirt, grime, grease from gearmotors.
- 6.1.8.5 Check oil level; if low, fill with Teresstic 150 to level recommended on lube plate attached to side of reducer.
- 6.1.9 Inspect the "Maxitorq" cluches and sprocket assemblies on the main and auxiliary hoists.
  - 6.1.9.1 Check for broken or missing nuts, fasteners, springs, keepers, etc.
  - 6.1.9.2 Inspect chain links for wear, cracks, broken or bent pins, etc.
  - 6.1.9.3 Check sprocket wheels for wear, cracks, missing or broken teeth.
- 6.1.10 Visually inspect each hoist drum for wear. Check grooves for wear and rope gouges.
- 6.1.11 Visually inspect the hook swivel assembly.
  - 6.1.11.1 Inspect condition of the V Belts; if cut, nicked, broken, etc., replace.
  - 6.1.11.2 Check oil level in gear case; if low, add Teresstic 150.
- 6.1.12 Visually inspect upper, lower and equalizing sheaves on main and auxiliary hoists.
  - 6.1.12.1 Check sheaves for excessive wear or breakage.
  - 6.1.12.2 Measure wear - use sheave gauge in accordance with Enclosure 7.2.
- 6.1.13 Inspect wire rope on main and auxiliary hoists. Record on Enclosure 7.4. The presence of any one of the following conditions requires that the wire rope be replaced.
  - 6.1.13.1 Measure the diameter of each rope above the block with a dial caliper or micrometer in accordance with Enclosure 7.2. Record the smallest measurement. The diameter for each main hoist wire rope should not be less than 1 1/16 (1.06) inches. The diameter for each auxiliary wire rope should not be less than 29/64 (0.453) inches.



- 6.1.13.2 Less than twelve (12) randomly distributed broken wires in one rope lay, or four (4) broken wires in one (1) strand of one (1) rope lay.
- 6.1.13.3 Wear of one-third (1/3) the original diameter of outside individual wires.
- 6.1.13.4 Kinking, crushing, bird-caging, or other damage resulting in distortion of rope structure.
- 6.1.13.5 Check end connector condition - must have at least two (wraps) of cable around the drum.
- 6.1.14 Inspect the hooks on main and auxiliary hoists in accordance with Enclosure 7.2. The presence of any of the following conditions requires that the hook be removed from service. Record on Enclosure 7.4.
  - 6.1.14.1 Evidence of damage from chemicals.
  - 6.1.14.2 Throat opening greater than 15% of original opening.
  - 6.1.14.3 More than 10 degree twist from the plane of unbent hook.
  - 6.1.14.4 Request QA perform Non-Destructive Examination (NDE) of the hooks. Attach the QA Report to Enclosure 7.3.
- 6.1.15 Check with I&E Technician to insure the Electrical PM Inspection has been completed. Have the I&E Technician sign this step on Enclosure 7.4.
- 6.1.16 Clean up area of rags and other debris. Insure all rags and waste are disposed of properly in accordance with Health Physics instructions.
- 6.1.17 Remove signs and rope from PM Inspection area.
- 6.1.18 Have Operations remove red tags, energize system (if applicable), and return crane to service.
- 6.1.19 Complete Enclosures 7.3 and 7.4. Insure all QA documents and other enclosures are completed, signed and attached.
- ✓ 6.2 Yearly or before return to service (after 6 months); I&E will perform Section 6.2 of this procedure and complete Enclosure 7.5.
  - 6.2.1 Check Operations has deenergized and tagged out the crane for PM Inspection. If this has not been done, check with the Maintenance Technician to verify that steps 6.1.1 and 6.1.2 have been completed.

- 6.2.2 Inspect each of the two (2) 15 HP bridge drive motors.
- 6.2.2.1 Check/clean exterior - remove oil, grease, dirt, grime, etc., as required.
- 6.2.2.2 Remove brush inspection cover and inspect brushes for cracks, chips, wear, and spring tension. Insure brushes are free to move.
- 6.2.2.3 Check that brush holders are tight. Commuter should be smooth with polished appearance.
- 6.2.2.4 Inspect motor coupling for misalignment, loose, or broken parts.
- 6.2.2.5 Perform an insulation resistance test of motors at the motor starter or maintenance disconnect and record on Enclosure 7.5.
- 6.2.2.6 The insulation resistance should not be less than that given by the formula:
- $$\text{Insulation Resistance (megohms)} = \frac{\text{Rated Motor Voltage} + 1000}{1000}$$
- 6.2.3 Inspect the 10 HP trolley drive motor in accordance with step 6.2.2.
- 6.2.4 Inspect the 50 HP auxiliary hoist motor in accordance with step 6.2.2.
- 6.2.5 Inspect the 3 HP auxiliary hoist slow speed motor in accordance with step 6.2.2.
- 6.2.6 Inspect the 60 HP main hoist motor in accordance with step 6.2.2.
- 6.2.7 Inspect the 5 HP main hoist slow speed motor in accordance with step 6.2.2.
- 6.2.8 Inspect the hook swivel motor in accordance with step 6.2.2.
- 6.2.9 Inspect the 1 HP trolley wheel lock motor.
- 6.2.9.1 Check the oil sump level - should be at second mark from top. If low, add NUTO H-68.
- 6.2.9.2 Check/clean the filler breather.
- 6.2.10 Inspect the 1 HP bridge wheel lock motor in accordance with step 6.2.9.
- 6.2.11 Inspect the Eddy current brakes on the main and auxiliary hoists as follows:

- 6.2.11.1 Check/clean exteriors.
- 6.2.11.2 Visually inspect for loose or missing parts, dents, etc.
- 6.2.11.3 Remove the intake screens and blow out with low pressure air (use the bristle brush to dislodge stubborn particles).
- 6.2.11.4 Clean screen and replace.
- 6.2.12 Inspect each of the "SESA" Electric bridge brakes (there are two) as follows:
  - 6.2.12.1 Remove the cover from each brake.
  - 6.2.12.2 Check for loose, missing or broken pins, nuts, retainers, springs, etc.
  - 6.2.12.3 Insure that a small clearance exists between the drum and lining. The shoes should not be dragging.
  - 6.2.12.4 Insure the brake lining is not less than 1/16" thick.
  - 6.2.12.5 Inspect the drum and lining for grease, glazing or grooves. Clean as necessary. Check brake mounting bolts.
  - 6.2.12.6 Check electrical connector is finger tight.
  - 6.2.12.7 Check fluid level in the solenoid, if low add Teresstic-68.
  - 6.2.12.8 Replace the covers.
- 6.2.13 Inspect the "SESA" Electric brakes (there are two) on the main and auxiliary hoists in accordance with step 6.2.12. Lubricate the ratchet teeth with Ronex MP.
- 6.2.14 Inspect the bridge, trolley, and hoist resistor banks for dirt, damaged or broken resistors, leads, etc.; clean as required.
- 6.2.15 Remove covers and inspect controllers, motor starters, disconnects, circuit breaker, etc. Check/adjust/tighten as required. Replace covers when completed.
- 6.2.16 Inspect the bridge and trolley conductor systems. Check each carbon shoe (brush) of each collector assembly for chips, cracks, wear, tension, etc. Ensure the brush pigtail is securely fastened.

- 6.2.17 Check with Maintenance Technician for clearance to obtain a temporary lift of red tags.

**\*\*CAUTION\*\***

Do not continue to the next step until the Maintenance Technician has been notified and is aware the electric brakes are to be tested. Both Maintenance and I&E must initial this caution on Enclosure 7.5.

- 6.2.18 Request a temporary lift of Red Tags from Operations to check brakes and lights.
- 6.2.19 Check operation of "SESA" electric brakes on the bridge, trolley, main and auxiliary hoists.
- 6.2.19.1 Observe if brake shoes clear drums with motor(s) engaged. Adjust if required.
- 6.2.19.2 Check that brake stops the motor movement when the controller button is released.
- 6.2.20 Check and replace burned out 1500 Watt crane light bulbs. Replace with Halophane #694-1500 Watt.
- 6.2.21 Notify Maintenance Technician when tests are completed.
- 6.2.22 If tests are satisfactory, request a permanent lift of Red Tags from Operations.
- 6.2.23 Clean up area of tools, rags and other debris. Insure all rags and waste are disposed of properly in accordance with Health Physics instructions.
- 6.2.24 Remove all signs and barricades from PM Inspection area.
- 6.2.25 Complete Enclosure 7.5 and attach to PM Standing Work Request.
- 6.3 Two year or before return to service (after 1 year); Mechanical Maintenance will perform Section 6.3 of this procedure and complete Enclosure 7.4.
- 6.3.1 Perform PM inspections and servicing, steps 6.1.1 through 6.1.15. Record on Enclosure 7.4.
- 6.3.2 Inspect walks and handrails for sound safe structural condition. Insure Operation's cab area, as well as other areas are free of grease, dirt, oil, oily rags, tools, loose equipment, etc.
- 6.3.3 Perform general inspection as follows:
- 6.3.3.1 Check runway structure and rails for loose bolts, rivets, welds, rust, chips, etc.

- 6.3.3.2 Check/clean rails and remove sand, dirt, oil, grease, metal shavings, and other foreign materials.
- 6.3.3.3 Check for loose bolts on end tracks and girder connections by tapping with a hammer.
- 6.3.3.4 Check girders and tracks for weld cracks, breaks, or other visual damage.
- 6.3.3.5 Inspect bridge and trolley wheels for flanging, wear, flat spots.
- 6.3.4 Lubricate bridge and trolley wheels with Unirex N-2. Use one (1) pump on the hand grease gun for each fitting.
- 6.3.5 Lubricate and inspect main bridge gear case (See Enclosure 7.1).
  - 6.3.5.1 Drain gear case, drain oil in suitable container.
  - 6.3.5.2 Remove inspection covers and check gears for excessive backlash, cracked, broken, or missing teeth. Check bearing races for cracks or breaks.
  - 6.3.5.3 Clean and replace drain plug and air breather.
  - 6.3.5.4 Refill with Teresstic 150.
  - 6.3.5.5 Insure oil is at level required on oil dipstick or gauge.
- 6.3.6 Lubricate and inspect main hoist gear case in accordance with step 6.3.5.
- 6.3.7 Lubricate and inspect auxiliary hoist gear case in accordance with step 6.3.5.
- 6.3.8 Lubricate the flexible couplings on main bridge drive motors.
  - 6.3.8.1 Rotate coupling until lube plugs are in horizontal positions.
  - 6.3.8.2 Remove both lube plugs; insert pressure gun in one hole leaving the other open.
  - 6.3.8.3 Fill the couplings with Ronex MP until it starts to come out the other hole.
  - 6.3.8.4 Replace both lube plugs.
- 6.3.9 Lubricate the flexible couplings on the trolley drive motor in accordance with step 6.3.8.



- 6.3.10 Lubricate the flexible couplings on the main hoist motor in accordance with step 6.3.8.
- 6.3.11 Lubricate the flexible couplings on the auxiliary hoist motor in accordance with step 6.3.8.
- 6.3.12 Change oil in main hoist gearmotor.
  - 6.3.12.1 Remove the drain plug and drain oil into a suitable container.
  - 6.3.12.2 Clean breather and drain plug before replacing.
  - 6.3.12.3 Refill gearmotor with Teresstic 150. Fill to level indicated on oil level indicating plate.
- 6.3.13 Change oil in auxiliary hoist gearmotor in accordance with step 6.3.12.
- 6.3.14 Change oil in hook swivel assembly gearmotor in accordance with step 6.3.12.
- 6.3.15 Lubricate main hoist sheaves with Unirex N-2. Use one (1) pump on the hand grease gun for each fitting as follows:
  - 6.3.15.1 Hook swivel block and sheaves.
  - 6.3.15.2 Equalize sheaves.
  - 6.3.15.3 Upper sheave nest.
- 6.3.16 Lubricate auxiliary hoist sheaves in accordance with step 6.3.15.
  - 6.3.16.1 Block and sheaves.
  - 6.3.16.2 Upper sheave nest.
- 6.3.17 Inspect control cab air conditioning unit as follows:
  - 6.3.17.1 Inspect and clean/change filters.
  - 6.3.17.2 Check/clean condenser coils - blow out with low pressure air, loosen stubborn dirt with brush.
  - 6.3.17.3 Grease compressor and fan motor bearings with Unirex N-2. Use one (1) pump on hand grease gun each fitting.
  - 6.3.17.4 Check refrigerant oil level (compressor must be warmed up before checking) level should be half-full on sight glass.


- 6.3.18 Inspect "Rescuematic" unit as follows:
  - 6.3.18.1 Remove metal cover and blow out dust accumulation.
  - 6.3.18.2 Check cable for wear - if worn it must be replaced immediately.
  - 6.3.18.3 Check operation by making a practice descent after inspection.
- 6.3.19 Clean up area of rags and other debris caused by inspection. Properly dispose of contaminated rags and debris in accordance with Health Physics instructions.
- 6.3.20 Dispose of used oil/greases/coolants as follows:
  - 6.3.20.1 Draw one (1) liter sample of used oil and send to Health Physics Counting Room.
  - 6.3.20.2 Dispose of oil in accordance with Health Physics instructions.
- 6.3.21 Check with the I&E Technician to insure that section 6.2 is completed. Have I&E Technician sign this step on Enclosure 7.4.
- 6.3.22 Remove ropes and signs used during inspection.
- 6.3.23 Have Operations remove red tags, energize system (if applicable), and return crane to service.
- 6.3.24 Complete Enclosure 7.3 and 7.4. Insure all QA Documents and other enclosures are completed, signed and attached.

## 7.0 ENCLOSURES

- 7.1 Lubrication Chart
- 7.2 Schematics, Drawings, Hook and Sheave Inspection
- 7.3 Inspection Cover Sheet
- 7.4 Mechanical - Inspection Guide
- 7.5 Electrical - Inspection Guide

# Operation and Maintenance Chart 1-D-R1


## Lubrication



Maintain Lubricant Levels As Required by Operating Conditions  
Change Lubricant at 2000 Hour or Six Month Intervals Unless Otherwise Noted  
All Lubrication Intervals Are Based On 8 HR. Per Day Industrial Service.


POINT	LUBRICANT	INSTRUCTIONS
1*	AMOCO RYKON #2EP	Lifetime Lubricated; Change every 5 Years
	Exxon Unirex N-2	When Crane is Supplied with Fittings, Bearings Should be Lubricated Sparingly With Pressure Gun.
2	Exxon Teresstic-150	Mobilfluid 350 Below 32° F. use: Shell Clavus Oil 33 Texaco Meropa Lubricant 1 (Approx. 200 Saybolt @ 100°)
3	Exxon Teresstic-150	Oil linkage.
4	Exxon Surett Fluid-4-K	Every 3 months for outdoor crane. Every 6 months for indoor crane. Apply sparingly.
5	Exxon Surett N-80-K	Every 6 months. Apply to each tooth.
6	Exxon Ronex MP	DO NOT OVERGREASE!
7	Exxon Ronex MP	All gear-type flexible couplings (if used).

\* Use Mobilplex 45 if a central greasing system is employed.



This illustration explains why worn sheaves will rapidly destroy wire rope. This sheave was originally grooved for 1 1/4" rope, but the 1 1/4" sheave gauge no longer fits the groove. In addition, the sheave is made of such soft material that it has become badly corrugated. Unless this sheave is repaired or replaced, subsequent ropes used on it will be badly pinched at the groove, and quickly worn out by the corrugations.

**HOW TO MEASURE WIRE ROPE**



**WIRE ROPE TOLERANCES**

**DIAMETER OF WIRE ROPE**

The components of a wire rope each has a small but definite size tolerance. Therefore, the rope itself must have a diameter tolerance. All wire rope is required to have a diameter at least equal to the nominal, or catalog, size . . . never smaller. Standard ropes may exceed the nominal diameter by the amounts shown below.






FIG. 4 INSPECTION OF CRANE HOOKS

1. NO VISIBLE TRANSVERSE CRACKS PERMITTED IN THE AREA SHOWN OR IN THE HOOK SHANK.
2. MEASURE (AA) BETWEEN PRICK PUNCH MARKS. REPLACE THE HOOK IF (AA) MEASURES MORE THAN  $1.15 \times$  ORIGINAL THROAT GAGE STAMPED ON HOOK.
3. IF HOOK IS TWISTED MORE THAN  $10^\circ$ , HOOK SHALL BE REPLACED.







MILL POWER SUPPLY CO. ORDER NO. C59984  
 DUKE POWER CO. ITEM NO. 1125.01-1

**CRANE DATA**

INSIDE SERVICE	
BRIDGE SPEED	50 F.P.M.
TROLLEY SPEED	50 F.P.M.
MAIN HOOK	4 F.P.M. @ 28 F.P.M.
AUX. HOOK	28 F.P.M. @ 1.4 F.P.M.
REQ. 65751 - CR. #	11245 - UNIT # 1
REQ. 65759 - CR. #	11246 - UNIT # 2

REPRO. FROM  
 U-65065


WHITING CORPORATION  
 MILLING DIVISION  
 68781 & 68789  
 GEN'L ASST. OF  
 TWO MOTOR BRIDGES

1	10-26-76	TEST PRESSURE WAS NOT SHOWN	2	2-24-77	5500 WAS NOT SHOWN
2	2-24-77	5500 WAS NOT SHOWN	3	2-25-77	1 WAS 57102
3	2-25-77	1 WAS 57102	4	5-2-77	1 WAS 11533
4	5-2-77	1 WAS 11533			

CRG-1500 WATT  
 MOUNT-30  
 JOBS (NO CURBS)  
 TRS.)


CONSTRUCTION  
 U-77457  
 U-77464  
 U-77485  
 61457  
 7003-10

EXCEPTIONS 'A-A' & 'B-B' SEE T-6107C



11243 UNIT 1 REQ 4.08762-84	MAIN STD.	66.18:1 +6.7:1	4	60	1200	444-TX V/LOWER	TWO WHITING 13" SEAS - ONE 13" TIME DELAY	1870G W/ALT.		
11244 UNIT 2 REQ 4.08762-84	MAIN DEC.	7.34	0.28	5	1200	444-TX V/UPPER	TWO WHITING 13" SEAS - ONE 13" TIME DELAY	1870G W/ALT.		
U-77020 T-01076	AUX. PREZ.	37.59:1	23	50	1200	405-TX	WHITING 13" SEAS	1870G W/ALT.	3/60/600 (575 V. MOTORS)	10-0225-C UPPER
	120-REV DRIVE	175.23:1	50	10	1200	280-TX	WHITING 13" SEAS WAGNER G-HM	1870G W/ALT.	LOOPEO CABLES CU GIRD. "A"	CR-118-E-C UPPER & LA
DRIVE LG & E2225 CA	UNIT	Q270	SPD FRM.	HP	220V	FRAME	SOLENOID & HYD. BRAKES.	EDDY CURRENT BRAKES	CURRENT CONDUCTORS	GENERAL ELECT HOIST LIM. SWITCHES





STATION: CATAWBA UNITS #1 & #2  
 DUKE POWER CO ITEM NO. 1125.01-1  
 MILL POWER SUPPLY ORDER NO. C39986  
 FILE NO. CN-1125.01 POLAR CRANE

FOR END ELEVATION SEE U-77010  
 FOR CAB ELEVATION SEE U-77011

INSIDE	ALUMITE HYD. FITTINGS ACCESSIBLE FROM DECK	134,000# TROLLEY 8000# CAB & SPACER	COVERS ON MAIN & AUX. PRECISION DRIVES - ALL BRAKES - REEL & LIMIT SWITCHES.
REAR CRANE			
SERVICE	LUBRICATION	EST. WT.	REMARKS

10-20-K

WHITING CORPORATION

MARKET DIVISION

NO. 68782-68790

GEN'L. 4226-CFA

D. 25-K-F

FIVE MOTOR TROLLEY

PLAN VIEW

Scale 3/4" = 1'-0"


App. GPC

App. 122

U-77009







30" DIA ROLLED STEEL WHEELS  
 RAIL SWEEPS S-4GG13-X  
 AUTOMATIC WHEEL LOCKS ON  
 EACH IDLER WHEEL DRG. U-77200

TOP OF 17" BRIDGE RAIL  
 ELEV. 679'-10"

16 PARTS 1/8" DIA. MONITOR "AA"  
 OR EQUAL WIRE CRANE ROPE (6x37) 1.4 W.C.  
 RIGHT REG. LAY - 1-PIECE 2190'-0" LG.  
 BREAKING STR. = 65.0 TONS  
 REEVE PER R-32739 AND SO THAT MOTOR  
 IS AWAY FROM WALL AS SHOWN.  
 LUBRICATE WITH TEXACO CRATER "A"


STATION # CATALISA U-7711  
 DUKE POWER CO. ITEM NO. 115.01-1  
 MILL POWER SUPPLY ORDER NO. C39124  
 FILE NO. CN-1125-C "POLAR CRANE"

FOR PLAN VIEW SEE U-77009  
 FOR CAR ELEVATION & CONTROL  
 LAYOUT SEE U-77011

REPRODUCED  
 FROM U-68182

WHITING CORPORATION	
<small>THIS DRAWING IS THE PROPERTY OF THE WHITING CORPORATION AND IS LOANED TO YOU FOR THE USE OF THE PROJECT TO WHICH IT IS APPLIED. IT IS NOT TO BE REPRODUCED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE WHITING CORPORATION. THIS DRAWING IS NOT TO BE USED FOR ANY OTHER PROJECT.</small>	
1	U-20-76
2	U-2371 1/2" dia.
<b>WHITING CORPORATION</b> <small>HARVEY BLYTHE</small>	
No. G8782 E 00	GEN'L ASST. OF R
D. 25 x 1	FIVE MOTOR TROLLEY
QV R. 1/4" DIA. 8"	- END ELEVATION -
End. 3/4" - DIA. R.	Capacity 15 TON
App. C-2	DUKE POWER CO.
App. U-77	U-77010
App. J	






- | NO. | DESCRIPTION   | NO. |
|-----|---|-----|
| 1   | WARNING BELL  |     |
| 2   | BRIDGE CONTROL  |     |
| 3   | TROLLEY CONTROL   |     |
| 4   | DEAD MAN FOOT SWITCH  |     |
| 5   | BELL FOOT SWITCH  |     |
| 6   | LINTERJ SIGNAL LIGHT  |     |
| 7   | BRAKE PEDAL   |     |
| 8   | MAIN HOIST CONTROL  |     |
| 9   | AUX. HOIST CONTROL  |     |
| 10  | FIXED FRONT & REAR WINDOWS<br>REMOVABLE LOWER FRONT WINDOW<br>FOR ACCESS TO SIGNAL LIGHT. |     |
| 11  | MAIN BLOCK ROTATION CW. & C.C.W.  |     |
| 12  | RESET FOR COMBINATION STARTER   |     |
| 13  | EMERGENCY STOP BUTTON   |     |
| 14  | KEY OPER. SW. - FOR WHEEL LOCK<br>OVER RIDE - BRIDGE & TROLLEY                            |     |


**VIEW "A-A"**

INSULATED CAB-CONTROL LAYOUT



COLOR CODING DIAGRAM  
BRIDGE MOTION BY CUSTOMER

ARROWS ON MASTER  
WILL CORRELATE WITH  
ON BRIDGE.



SECTION "B-B"


FOR PLAN VIEW SEE U-77009  
FOR END ELEVATION SEE U-77010

STATION CATAWBA UNITS #1 & #2  
DUKE POWER CO. ITEM NO. 1125.01-1  
MILL POWER SUPPLY ORDER NO. C39984  
FILE NO. CN-1125.01 POLAR CRANE



1	10-20-76	BY: [Signature]	DATE: 11-20-76
2	3-3-77	BY: [Signature]	DATE: [Blank]

WHITING CORPORATION  
WILLARD  
ONTARIO

Proj. G0782 & 90	Title: GEN'L ARRG'T. OF A
D. R. S. K. I.	FIVE MOTOR TROLLEY
Chk'd BY: [Signature]	- CAB ELEVATION -
Scale: 3/4" = 1' - One ft.	Contract: 175 TON MAIN, 25 TON & X
App: PC	1st: DUKE POWER CO.
App: VBA	CATAWBA NUCLEAR STATION #2
App: [Blank]	WESLEYAN, SANTA CAROLINA
U-77011	



FOR CAB ACCESS & CONTROL ARRGT.  
SEE TROLLEY GEN'L ARRGT.




SECTION C-C THRU TRUCK  
SHOWING UPKICK LUGS

VIEW FROM



**REF. DOC. LIST**

Trolley W/CAB U-77009, 10 #11  
 GIRDERS U-7035 # 37  
 TRUCK U-77440  
 END CONJ. T-5419B  
 DRIVE SUPPT. U-68064  
 END PLTFM. U-68191




**BRIDGE WEIGHTS**

GIRD. A'4, RAILING, DRIVE ETC.	105,900
GIRD. B	29,200
TRUCKS - 4 @ 2,500*	34,000
END CONJ. 2 @ 5,000*	10,000
MISC. PLTFM., LOADERS ETC.	12,000
<b>TOTAL</b>	<b>251,700*</b>

**TOP OF RUNWAY RAIL**

36" R.S. WHL'S. STR. TRD. EQUALIZING BOSSIE TUCKS  
 36" T 36" BRG. ASSEM. S-59440 # 572809  
 MAX. CONSTRUCTION WHEEL LOAD = 225,000#  
 BASED ON (A) 416 TON & (B) 512 TON LOADS 11'-0" FROM RAIL  
 THIS INCLUDES LIFTED LOAD AND DEAD  
 WGT. OF CONSTRUCTION TROLLEY.  
 MAX. NORMAL WHL. LOAD W/ 175 TON ON  
 HC. K = 152,000#



WIRING DIAGRAMS U-77457  
 U-27484  
 U-77485  
 T-61407  
 TROLLEY G.A. U-77009-10

MILL POWER SUPPLY CO. /  
 ORDER NO. C39984  
 DUKE POWER CO.  
 ITEM NO. 1125.01-1

68781 68789	REPAIR ALL CORNERS, REMOVE ALL BURRS ALL MACHINE DIMENS. AND WHERE TOLERANCES ARE NOT GIVEN SHALL BE HELD TO PLUS OR MINUS 1/64"
1 1-18-77	THIS DRAWING IS THE PROPERTY OF THE WRITING CORPORATION, AND IS ISSUED ONLY UNDER THE UNDERSTANDING THAT IT BE USED CONFIDENTIALLY AND DISAPPEARED, AND IN NO WAY TO THE DISADVANTAGE OR DETRIMENT OF THE WRITING CORPORATION. THIS DRAWING IS SUBJECT TO RECALL.
2 2-25-77, 10X 1/2	NOT SHOWN
<b>WHITING CORPORATION</b> HAVERTY WELLSVILLE ONTARIO TITLE GENL. ASST. OF <b>TWO MOTOR BRIDGES</b> - END ELEVATION - DATE 1-18-77 SCALE 3/8" = 1'-0" OVER APPROVED FOR [Signature] IN CHARGE <b>T-61026</b>	

U-77009

REPAIR FILE T-61026



DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
INSPECTION COVER SHEET

Inspected By:

Mech. Maint. Technician \_\_\_\_\_ Date \_\_\_\_\_  
I&E Maint. Technician \_\_\_\_\_ Date \_\_\_\_\_  
Lubricated By \_\_\_\_\_ Date \_\_\_\_\_  
NDE performed \_\_\_\_\_ (Attach Report) Date \_\_\_\_\_  
QA reviewed \_\_\_\_\_  
Reviewed (Maint. Supr.) \_\_\_\_\_ Date \_\_\_\_\_  
Crane Ready for Service \_\_\_\_\_ Date \_\_\_\_\_  
(PM Coordinator)

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
MECHANICAL

Equipment No. \_\_\_\_\_ SWR No. \_\_\_\_\_  
Date \_\_\_\_\_

Equipment Description: "Whiting" Containment Polar Crane

3.0 Test Equipment

<u>Type</u>	<u>CN No.</u>	<u>Cal. Due</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____

4.0 Safety Considerations: \_\_\_\_\_ / \_\_\_\_\_  
Initials Date

5.0 Station/Equipment Status: \_\_\_\_\_ / \_\_\_\_\_  
Initials Date

Step	Item	Sat.	Unsat.
<u>Annual</u>			
6.1.1	Crane operator perform operational checks	_____	_____
6.1.2	Lower Hook(s) for inspection	_____	_____
6.1.3	Operations Tag out Crane	_____	_____
6.1.4	Inspect Main Bridge	_____	_____
6.1.5	Inspect Trolley	_____	_____
6.1.6	Inspect Main Hoist	_____	_____
6.1.7	Inspect Auxiliary Hoist	_____	_____
6.1.8	Inspect Gear motors on Main & Aux. Hoists	_____	_____
6.1.9	Inspect "Maxitorque" clutches on Main and Auxiliary Hoists	_____	_____
6.1.10	Inspect Hoist Drums; Main & Auxiliary	_____	_____
6.1.11	Inspect Hook Swivel Assembly	_____	_____
6.1.12	Inspect Sheaves:		
	1. Main Hoist	Upper _____	Lower _____ Equalizing _____
	2. Aux. Hoist	Upper _____	Lower _____ Equalizing _____

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
MECHANICAL

Step	Item (Mechanical)	Sat.	Unsat.
6.1.13	Inspect Wire Rope		
	1. Main Hoist Rope Diameter _____ (must be greater than 1.06 inches)		
	2. Aux. Hoist Rope Diameter _____ (must be greater than 0.453 inches)		
	3. Randomly distributed broken wires	_____	_____
	4. Excessive wear of individual wires	_____	_____
	5. Structural damage of wire rope	_____	_____
	6. End connections	_____	_____
6.1.14	Inspect Hooks:		
	<u>Main Hoist</u>		
	1. Damage from chemicals	_____	_____
	2. Throat opening <15% above original	_____	_____
	3. Less than 10 degree twist	_____	_____
	4. Request QA perform NDE		
		_____ (Maintenance Technician Signature)	
	<u>Auxiliary Hoist</u>		
	1. Damage from chemicals	_____	_____
	2. Throat opening <15% above original	_____	_____
	3. Less than 10 degree twist	_____	_____
	4. Request QA perform NDE		
		_____ (Maintenance Technician Signature)	

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
MECHANICAL

Step	Item (Mechanical)	Sat.	Unsat.
6.1.15	Check with I&E Technician that Electrical PM Inspection is completed		
		(I&E Technician Signature)	
6.1.16	Clean up area	_____	_____
6.1.17	Remove signs and ropes	_____	_____
6.1.18	Operations Remove Red Tags	_____	_____
6.1.19	Insure all QA Documents, Enclosures, and Electrical Checklists are completed, signed and attached.	_____	_____

Two Years or After One Year

6.3.1	Perform yearly or after 6 months inspection Steps 6.1.1 through 6.1.15	_____	_____
6.3.2	Inspect walks and handrails	_____	_____
6.3.3	Inspect general condition of crane	_____	_____
6.3.4	Lubricate bridge and trolley wheels	_____	_____
6.3.5	Lubricate/inspect main bridge gear case	_____	_____
6.3.6	Lubricate/inspect aux. hoist gear case	_____	_____
6.3.7	Lubricate/inspect main hoist gear case	_____	_____
6.3.8	Lubricate flexible couplings main bridge drive motors	_____	_____
6.3.9	Lubricate flexible couplings trolley drive motor	_____	_____
6.3.10	Lubricate flexible couplings main hoist motor	_____	_____
6.3.11	Lubricate flexible couplings aux. hoist motor	_____	_____
6.3.12	Lubricate/inspect main hoist gearmotor	_____	_____

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
MECHANICAL

Step	Item (Mechanical)	Sat.	Unsat.
6.3.13	Lubricate/inspect aux. hoist gearmotor	_____	_____
6.3.14	Lubricate/inspect swivel assembly gear motor	_____	_____
6.3.15	Lubricate main hoist sheaves:		
	1. Hook swivel block and sheaves	_____	_____
	2. Equalizer sheaves	_____	_____
	3. Upper sheave nest	_____	_____
6.3.16	Lubricate auxiliary hoist sheaves:		
	1. Lower block and sheaves	_____	_____
	2. Equalizer sheaves	_____	_____
	3. Upper sheave nest	_____	_____
6.3.17	Inspect/check control cab air conditioner	_____	_____
6.3.18	Inspect/check "Rescuematic" Unit	_____	_____
6.3.19	Clean up area	_____	_____
6.3.20	Dispose of used oil/greases/coolants	_____	_____
6.3.21	Check with I&E Technician that Electrical PM Inspection is completed	_____	_____
		(I&E Technician Signature)	
6.3.22	Remove ropes and signs	_____	_____
6.3.23	Operations remove red tags	_____	_____
6.3.24	Insure Enclosure 7.3, 7.4, 7.5, QA Inspection documents and other Enclosures are completed, signed and attached.	_____	_____



DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
MECHANICAL

Comments, Action Taken: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Performed by \_\_\_\_\_ Date \_\_\_\_\_  
(Maintenance Technician)

Reviewed by \_\_\_\_\_ Date \_\_\_\_\_  
(PM Coordinator)

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
ELECTRICAL

Equipment No. \_\_\_\_\_ SWR No. \_\_\_\_\_  
Date \_\_\_\_\_

Equipment Description "Whiting" Containment Polar Crane

3.0 Test Equipment

<u>Type</u>	<u>CN I&amp;E No.</u>	<u>Cal. Due</u>
_____	_____	_____
_____	_____	_____
_____	_____	_____

4.0 Safety Considerations: \_\_\_\_\_ / \_\_\_\_\_  
Initials Date

5.0 Station/Equipment Status: \_\_\_\_\_ / \_\_\_\_\_  
Initials Date

Step	Item (I&E)	Sat.	Unsat.
------	------------	------	--------

Yearly or After 6 Months

6.2.1	Operations Tag Out Crane	_____	_____
6.2.2	Inspect Bridge Drive Motors	_____	_____
	Perform Insulation Resistance Test:		
	Bridge Motor #1: Phase X _____ Phase Y _____ Phase Z _____		
	Bridge Motor #2: Phase X _____ Phase Y _____ Phase Z _____		
6.2.3	Inspect Trolley Drive motor	_____	_____
	Perform Insulation Resistance Test:		
	Phase X _____ Phase Y _____ Phase Z _____		
6.2.4	Inspect Auxiliary Hoist Motor	_____	_____
	Perform Insulation Resistance Test:		
	Phase X _____ Phase Y _____ Phase Z _____		
6.2.5	Inspect Auxiliary Hoist Slow Speed Motor	_____	_____
	Perform Insulation Resistance Test:		
	Phase X _____ Phase Y _____ Phase Z _____		
6.2.6	Inspect Main Hoist Motor	_____	_____
	Perform Insulation Resistance Test:		
	Phase X _____ Phase Y _____ Phase Z _____		

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
ELECTRICAL

Step	Item (I&E)	Sat.	Unsat.
6.2.7	Inspect Main Hoist low Speed Motor	_____	_____
	Perform Insulation Resistance Test:		
	Phase X _____ Phase Y _____ Phase Z _____		
6.2.8	Inspect Hook Swivel Motor		
	Perform Insulation Resistance Test:		
	Phase X _____ Phase Y _____ Phase Z _____		
6.2.9	Inspect Trolley Wheel Lock Motor	_____	_____
6.2.10	Inspect Bridge Wheel Lock Motor	_____	_____
6.2.11	Inspect and Clean Eddy Current Brakes:		
	1. Main Hoist	_____	_____
	2. Auxiliary Hoist	_____	_____
6.2.12	Inspect/clean "SESA" Electric Bridge Brakes	_____	_____
6.2.13	Inspect/clean "SESA" Electric Hoist Brakes		
	1. Main Hoist	_____	_____
	2. Auxiliary Hoist	_____	_____
6.2.14	Inspect/clean Resistor Banks:	_____	_____
6.2.15	Inspect/clean controllers, motor starters, etc.	_____	_____
6.2.16	Inspect Bridge and Trolley Conductor Systems	_____	_____
6.2.17	Check with Maintenance Technician that Mechanical PM Inspection is completed		
		_____ (Maintenance Technician Signature)	
6.2.18	Request Temporary Lift of Red Tags	_____	_____
6.2.19	Check Operation of "SESA" Electric Brakes:		
	1. Bridge Brakes	_____	_____
	2. Trolley Brakes	_____	_____
	3. Main Hoist	_____	_____
	4. Auxiliary Hoist	_____	_____
6.2.20	Check/replace Burned Out 1500 Watt Bulbs	_____	_____

DUKE POWER COMPANY  
CATAWBA NUCLEAR STATION  
CONTAINMENT POLAR CRANE  
ELECTRICAL

Step	Item (I&E)	Sat.	Unsat.
6.2.21	Notify Maintenance Technician Tests Completed	_____	_____
6.2.22	Request Permanent Lift of Red Tags	_____	_____
6.2.23	Clean Up Area	_____	_____
6.2.24	Remove Signs and Barricades	_____	_____
6.2.25	Insure all Enclosures are Completed, Signed, and Attached to PM Work Request	_____	_____

Comments, Action Taken: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Performed by \_\_\_\_\_ Date \_\_\_\_\_  
(I&E Technician)

Reviewed by \_\_\_\_\_ Date \_\_\_\_\_  
(PM Coordinator)