UPDATE REPORT - PREVIOUS REPORT DATE November 2, 1981

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 CRTNP1 (2) 00-0000-00 (3) 4 1111 (4) (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 REPORT SOURCE L (6) 050-034 (7) 100381 (8) 120781 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 FAILURE OF AN INDICATING LAMP SOCKET RESULTED IN A BLOWN FUSE AND LOSS OF
03 DC CONTROL POWER TO THE WEST EMERGENCY DIESEL GENERATOR (EDG). THE EDG
04 WAS, THEREFORE, DECLARED INOPERABLE. THE PLANT WAS OPERATING IN A
05 DEGRADED MODE PERMITTED BY STS 3.8.1.1.
06
07
08

09 SYSTEM CODE EE (11) CAUSE CODE E (12) CAUSE SUBCODE A (13) COMPONENT CODE INSTRU (14) COMP. SUBCODE I (15) VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 024 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 1

ACTION TAKEN A (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0000 (22) ATTACHMENT SUBMITTED Y (23) NPRD-4 FORM SUB. N (24) PRIME COMP. SUPPLIER L (25) COMPONENT MANUFACTURER X999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE CAUSE OF THIS OCCURRENCE IS ATTRIBUTED TO THERMAL BREAKDOWN OF AN
11 INDICATING LAMP SOCKET, WHICH WAS THE RESULT OF CONTINUOUS OPERATION AT
12 ITS MAXIMUM DESIGN OPERATING VOLTAGE. THE LAMP, ITS SOCKET, AND THE DC
13 CIRCUIT FUSE WERE REPLACED. AN ENGINEERING EVALUATION IS BEING MADE
14 CONCERNING THE OVERVOLTAGE CONDITION.

15 FACILITY STATUS F (28) % POWER 100 (29) OTHER STATUS (30) NA — METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION (32) ANNUNCIATOR ACTUATION

16 ACTIVITY RELEASED Z (33) CONTENT OF RELEASE Z (34) AMOUNT OF ACTIVITY (35) NA — LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 000 (37) TYPE Z (38) DESCRIPTION (39) NA

PERSONNEL INJURIES
18 NUMBER 000 (40) DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY
19 TYPE Z (42) DESCRIPTION (43) NA

PUBLICITY
20 ISSUED N (44) DESCRIPTION (45) NA — NRC USE ONLY

NAME OF PREPARER M. L. Dawson (KLN) PHONE: 503/556-3713,xt.315

8112170070 811207
PDR ADOCK 05000344
S PDR