(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 201, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION

Brian C. McCle for Robert A. Capra, Director Project Directorate I-1

Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical Specifications

Date of Issuance: December 28, 1993

FACILITY OPERATING LICENSE NO. DPR-59 DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Page 80

Insert Page 80

JAFNPP

TABLE 4.2-2 (Cont'd)

MINIMUM TEST AND CALIBRATION FREQUENCY FOR CORE AND CONTAINMENT COOLING SYSTEMS

	Logic System Functional Test		Frequency
1)	Core Spray Subsystem	(7) (9)	Once/6 months
2)	Low Pressure Coolant Injection Subsystem	(7) (9)	Once/6 months
3)	Containment Cooling Subsystem		Once/6 months
4)	HPCI Subsystem	(7) (9)	Once/6 months
5)	HPCI Subsystem Auto Isolation	(7)	Once/6 months
6)	ADS Subsystem	(7) (9)	Once/6 months
7)	RCIC Subsystem Auto Isolation	(7)	Once/6 months
8)	ADS Relief Valve Ber on Pressure Switch	(7) (9)	Once/operating cycle

NOTE: See notes following Table 4.2-5.