

December 28, 1993

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M87689)

The Commission has issued the enclosed Amendment No. 71 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated September 10, 1993, as supplemented November 12, 1993.

The amendment changes the Technical Specifications to provide consistency with the guidance of Generic Letter 90-09 that relates to the revision of the surveillance requirements for snubbers.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 71 to DPR-21
- 2. Safety Evaluation

cc w/enclosures:

See next page

9401060278 931228
PDR ADOCK 05000245
P PDR

DISTRIBUTION:

Docket File	GHill (2)	NRC & Local PDRs	CGrimes
SVarga	JCalvo	ACRS (10)	
SNorris	OPA	JNorberg	
JAndersen	OC/LFDCB		
OGC	LDoerflein		
DHagan			

NRC FILE CENTER COPY

OFFICE	LA:PDI-4	PM:PDI-4	EMEB	D:PDI-4	OGC
NAME	SNorris	JAndersen	JNorberg	JStoriz	Utter
DATE	1/16/93	1/16/93	12/16/93	12/17/93	12/17/93

OFFICIAL RECORD COPY

Document Name: G:\ANDERSEN\87689

*embargoed in change
SER*
DFO

December 28, 1993

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M87689)

The Commission has issued the enclosed Amendment No. 71 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated September 10, 1993, as supplemented November 12, 1993.

The amendment changes the Technical Specifications to provide consistency with the guidance of Generic Letter 90-09 that relates to the revision of the surveillance requirements for snubbers.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 71 to DPR-21
2. Safety Evaluation

cc w/enclosures:

See next page

DISTRIBUTION:

Docket File	GHill (2)	NRC & Local PDRs	CGrimes
SVarga	JCalvo	ACRS (10)	
SNorris	OPA	JNorberg	
JAndersen	OC/LFDCB		
OGC	LDoerflein		
DHagan			

OFFICE	LA:PDI-4	PM:PDI-4	EMEB	DJPD-4	OGC
NAME	SNorris	JAndersen	JNorberg	Stoniz	Wtal
DATE	11/16/93	11/16/93	12/16/93	12/17/93	12/17/93

OFFICIAL RECORD COPY
Document Name: G:\ANDERSEN\87689

Handwritten notes: "12/17/93" and "SER" with a signature.



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

December 28, 1993

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M87689)

The Commission has issued the enclosed Amendment No. 71 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated September 10, 1993, as supplemented November 12, 1993.

The amendment changes the Technical Specifications to provide consistency with the guidance of Generic Letter 90-09 that relates to the revision of the surveillance requirements for snubbers.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in dark ink, appearing to be "JW Andersen", written over a circular stamp or mark.

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 71 to DPR-21
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 1

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

J. P. Stetz, Vice President
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
362 Injun Hollow Road
East Hampton, Connecticut 06424-3099

J. M. Solymossy, Director
Nuclear Quality and Assessment Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Post Office Box 5066
Hartford, Connecticut 06102-5066

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Vice President
Millstone Nuclear Power Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

P. D. Swetland, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 513
Niantic, Connecticut 06357

H. F. Haynes, Nuclear Unit Director
Millstone Unit No. 1
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502