



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

August 13, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Erroneous Reporting of Radgas
Sampling
Reference: LER 82-019/01 T-0
AECM-82/346

On July 29, 30, and 31, 1982, radgas samples from the fuel handling area ventilation were not taken. Shift Superintendents had initialed reports indicating that these samples had been taken. Attached is LER 82-019/01 T-0 with supplementary information.

Yours truly,

JPM:lm
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Document Control Desk (w/a)
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8208200059 820813
PDR ADOCK 05000416
S PDR

AE1N1

Member Middle South Utilities System

OFFICIAL COPY

IC 22