

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 CASO S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 _____ 5
 7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
 01 REPORT SOURCE L 6 0 5 0 0 0 2 0 6 7 0 7 0 6 8 2 8 0 8 0 6 8 2 9
 7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
 02 While the reactor was in Mode 5, particulate filter samples from the main stack
 03 taken in May and July 1982 were accidentally discarded before being analyzed
 04 for strontium-89 and -90. The particulate filter samples were mistaken for
 05 routinely disposed health physics air samples since they look alike and were
 06 kept together. No Technical Specifications or 10CFR20 discharge limits
 07 were exceeded and there was no adverse effect on public health and safety.
 08 _____

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 M B 11 A 12 D 13 Z Z Z Z Z Z 14 Z 15 Z 16
 7 8 9 10 11 12 13 18 19 20
 17 LER/RO REPORT NUMBER EVENT YEAR SHUTDOWN METHOD SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO
 8 2 - 0 1 8 - 0 3 L - 0
 21 22 23 24 26 27 28 29 30 31 32
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
 G 18 G 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 Z 25 Z 9 9 9 26
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
 10 Human error resulted in the disposal of the stack particulate samples.
 11 Similar appearance and common storage contributed to the error. As corrective
 12 action, the station procedure for gaseous radioactive waste release has been
 13 changed so that the main-stack particulate samples will be kept at a separate
 14 location, preventing accidental discarding of the stack particulate filter samples.

15 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32
 G 28 0 0 0 29 NA B 31 Routine Test for Strontium -89 and -90
 7 8 9 10 12 13 44 45 46 80
 16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
 Z 33 Z 34 NA 35 NA 36
 7 8 9 10 11 44 45 80
 17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
 0 0 0 37 Z 38 NA 39
 7 8 9 11 12 13 80
 18 PERSONNEL INJURIES NUMBER DESCRIPTION 41
 0 0 0 40 NA 41
 7 8 9 11 12 80
 19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43
 Z 42 NA 43
 7 8 9 10 80

20 PUBLICITY ISSUED DESCRIPTION 45 N 44 NA 45 _____ 80
 7 8 9 10 80
 8208200242 820806 PDR ADOCK 05000206 PDR

GPO 917-926