

# LICENSEE EVENT REPORT

*Unit 1*

CONTROL BLOCK: \_\_\_\_\_ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(01) | T | N | S | N | P | 1 | (2) | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | (3) | 4 | 1 | 1 | 1 | 1 | (4) | \_\_\_\_\_ | (5)  
7 8 9 14 15 25 26 30 37 CAT 50  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CONT

(01) | L | (6) | 0 | 5 | 0 | 0 | 0 | 3 | 2 | 7 | (7) | 1 | 1 | 1 | 0 | 8 | 1 | (8) | 1 | 2 | 10 | 8 | 18 | 1 | (9)  
7 8 60 61 68 69 74 75 80  
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

(02) | With Unit 1 in Mode 1 (100% power, 578 degrees F, 2235 psig) at 1955 CST on 11/10/81  
(03) | the auxiliary building ventilation radiation monitor was declared inoperable due to  
(04) | a defective motor. This event placed the unit in action statements 41, 42 and 44 of  
(05) | limiting condition for operation 3.3.3.10. There was no effect upon public health  
(06) | and safety. Previous occurrences - none.

(07) | \_\_\_\_\_

(08) | \_\_\_\_\_

(09) | M | B | (11) | E | (12) | A | (13) | M | O | T | O | R | X | (14) | E | (15) | Z | (16)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

(17) | 8 | 1 | 1 | (18) | A | (19) | Z | (20) | Z | (21) | 0 | 0 | 0 | 0 | (22) | N | (23) | N | (24) | L | (25) | G | 0 | 6 | 3 |  
21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44  
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM: UB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

(10) | Upon investigation the pump motor for radiation monitor 0-RM-90-101 was found to be  
(11) | burnt out due to normal wear. The General Atomic monitor was switched over to a  
(12) | redundant pump motor and returned to service at 2110 CST on 11/10/81. The defective  
(13) | motor will be repaired or replaced.

(14) | \_\_\_\_\_

(15) | E | (28) | 1 | 0 | 0 | (29) | NA | (30) | R | (31) | Operator observation (32)  
7 8 9 10 11 12 13 44 45 46  
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

(16) | Z | (33) | Z | (34) | NA | (35) | NA | (36)  
7 8 9 10 11 44 45  
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

(17) | 0 | 0 | 0 | (37) | Z | (38) | NA | (39)  
7 8 9 11 12 13  
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

(18) | 0 | 0 | 0 | (40) | NA | (41)  
7 8 9 11 12  
PERSONNEL INJURIES NUMBER DESCRIPTION

(19) | Z | (42) | NA | (43)  
7 8 9 10  
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

(20) | N | (44) | NA | (45) | 8112180365 811208 PDR ADOCK 05000327 S PDR  
7 8 9 10  
PUBLICITY ISSUED DESCRIPTION

NRC USE ONLY

Name of Preparer H. R. Rogers / M. R. Harding

Phone (615) 842-8317