

Docket No. 50-322

AUG 9 1982

Long Island Lighting Company  
ATTN: Mr. M. S. Pollock  
Vice President - Nuclear  
175 East Old Country Road  
Hicksville, New York 11801

Gentlemen:

Subject: Inspection 50-322/82-08

This refers to your letter dated June 25, 1982, in response to our letter dated May 27, 1982.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

We have reviewed the information provided in your letter dated June 25, 1982, regarding the classification of Item A.2 as a Violation. It is our position that integrated systems tests, such as the Reactor Pressure Boundary Leak Test require review and approval in accordance with commitments described in FSAR, Section 14.1 and the Startup Manual, Section 4.2. Based on our review, Item A.2 remains a Violation.

Based on discussions between Mr. E. Youngling of your staff and Mr. J. Higgins of our staff on July 27, 1982, we understand the following. Individual system tests will be performed using the appropriate type of test procedure such as preoperational test procedure, an acceptance test procedure or a Checkout and Initial Operations Test procedure. Individual system operation will be accomplished utilizing the Startup Interim Operating Instructions (IOIs) or the permanent Station Procedures. Additionally, significant integrated systems tests will be controlled using one of the above procedure types. The Joint Test Group will review planned integrated systems tests to determine if they are significant and as such require additional procedural coverage.

Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:

*[Handwritten Signature]*  
Richard W. Starostecki, Director  
Division of Project and Resident Programs

8208230125 820809  
PDR ADOCK 05000322  
Q PDR

IF81

OFFICE							
SURNAME							
DATE							

AUG 9 1982

cc:

J. L. Smith, Manager of Special Projects  
 Edward M. Barrett, Esq.  
 Jeffrey L. Futter, Esq.  
 T. F. Gerecke, Manager, QA Department  
 J. Rivello, Plant Manager  
 Public Document Room (PDR)  
 Local Public Document Room (LPDR)  
 Nuclear Safety Information Center (NSIC)  
 NRC Resident Inspector  
 State of New York

bcc:

Region I Docket Room (with concurrences)  
 R. Gilbert, DOL, NRR  
 G. Rhoads, SRI

OFFICE	RI: <i>[Handwritten]</i>	DPRP	DPRP	DPRP		
SURNAME	Higgins/jm	<i>[Handwritten]</i>	Brunner	Stangstedt		
DATE	8/6/82	8/10/82	8/6/82	<i>[Handwritten]</i>		