LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | W I K N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 0 5 (7) | 0 7 1 6 8 2 (8) | 0 8 1 3 8 2 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a document review it was discovered that the waste disposal liquid effluent
0 3 monitor was indicating low. Therefore, the possibility of not meeting T.S. 3.9.a.5.c.
0 4 existed, automatic closure of the waste discharge valve prior to exceeding the limits
0 5 of 10CFR Part 20, Appendix B, and is reportable per T.S. 6.9.2.b(2). Since samples
0 6 are analyzed and discharge permits must be issued before a release is made, there was
0 7 no effect on public safety or plant operation.
0 8

0 9 SYSTEM CODE M C (11) | CAUSE CODE E (12) | CAUSE SUBCODE F (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE E (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 2 5 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER H 0 6 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Low count indication on the waste disposal monitor was due to a weak detector tube.
1 1 Upon discovery no further discharges were made until the detector tube was replaced
1 2 and detector calibrated. No further action is required.
1 3
1 4

1 5 FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Review of Waste Discharge Permits

1 6 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

1 7 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

1 8 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

8208230172 820813
PDR ADOCK 05000305
S PDR

1 9 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

2 0 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER S. L. Bernhoft PHONE: (414) 388-2560 Ext. 340

GPO 917-924