

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

August 16, 1982

TVA-SQN-TS-35

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Denton:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

In accordance with 10 CFR Part 50.59, we are enclosing 40 copies of a requested amendment to the operating licenses DPR-77 and DPR-79 for a change to the Sequoyah Nuclear Plant units 1 and 2 technical specifications. The proposed changes to the technical specifications and justifications for the changes are provided in the following enclosures.

Enclosure 1 - Change No. 1, Deletion of Flow Rate Monitors from Tables 3.3-13 and 4.3-9

Enclosure 2 - Change No. 2, Maximum Isolation Time for Containment Isolation Valves

Enclosure 3 - Change No. 3 - Winter Flood Level for Flood Protection and Surveillance Requirements

Enclosure 4 - Change No. 4, Modification of Surveillance Requirements for Testing of Containment Penetration Protective Fuses

Enclosure 5 - Change No. 5, Rod Position Indication System Requirements

Enclosure 6 - Change No. 6, Clarification of Location of Capsules T and S in Table 4.4-5

In accordance with the provisions of 10 CFR Part 170.22, we have determined the proposed amendment to be Class IV for unit 1 and Class I for unit 2. This classification is based on the fact that the amendment involves

13021

8208230366 820816
PDR ADOCK 05000327
P PDR


Mr. Harold R. Denton, Director

August 16, 1982

several changes of the Class III type incorporated into this amendment and involves a second essentially identical unit at the same site. The remittance of \$12,700 is being wired to the Nuclear Regulatory Commission, Attention: Licensing Fee Management Branch.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 16th day of Aug. 1982

Bryant M. Lowery
Notary Public

My Commission Expires 4/8/86

Enclosures (40)

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303