

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-338VIRGINIA ELECTRIC AND POWER COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 41 to Facility Operating License No. NPF-4 issued to the Virginia Electric and Power Company (the licensee) for operation of the North Anna Power Station, Unit No. 1 (the facility) located in Louisa County, Virginia. The amendment was effective on July 16, 1982.

The amendment provides relief from Surveillance Requirement 4.4.7 (Table 4.4.3) which requires that reactor coolant system chemistry limits for chlorides and fluorides be sampled on a continuing 72 hour basis. The relief from Surveillance Requirement 4.4.7 (Table 4.4-3) is applicable when the reactor coolant system is drained below the reactor pressure nozzle and the internals and/or head are in place. The relief is only applicable in Mode 6 (Refueling).

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since this amendment does not involve a significant hazards consideration.

DESIGNATED ORIGINAL

Certified By \_\_\_\_\_


8208240 073

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated July 16, 1982; (2) the Commission's letter to the licensee dated July 16, 1982; (3) Amendment No. 41 to Facility Operating License No. NPF-4; and (4) the Commission's related Safety Evaluation. These items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C. 20555 and at the Board of Supervisor's Office, Louisa County Courthouse, Louisa, Virginia 23093 and at the Alderman Library, Manuscripts Department, University of Virginia, Charlottesville, Virginia 22901. A copy of items (2), (3) and (4) may be obtained upon request to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland this 4th day of August, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

  
Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing