## LICENSEE EVENT REPORT

| . CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)   |
|--|
| 0 1   C   0   F   S   V   1   2   0   0   -   0   0   0   0   -   0   0  |
| ON'T SOURCE SO 6 0 5 0 0 0 2 6 7 7 0 7 1 2 8 2 3 0 8 1 7 8 2 9   |
| EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)   |
| 0 2 On three occasions during the month of July, the emergency feedwater headers to the  |
| [0]3   helium circulator pelton wheel drives were isolated to perform maintenance on leaking   |
| [ ] [ header safety valves. With the reactor operating at approximately 70% power during   |
| [0] [each of these occasions, this constitutes a degraded mode of LCO 4.2.2(a) and is re-  |
| of portable per Fort St. Vrain Technical Specification AC 7.5.2(b)2. Similar occurrence  |
| 0 7 Lis RO 81-046. No affect on public health or safety.   |
| 03   |
| SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC |
| SEQUENTIAL OCCURRENCE REPORT REVISION /  |
| (17) REPORT   8 2   -   0 2 9   0 3   X   -   1  |
| ACTION FUTURE EFFECT SHUTDOWN HOURS (22) ATTACHMENT NPRO-4 PRIME COMP. COMPONENT TAKEN ACTION ON PLANT METHOD HOURS (22) SUBMITTED FORM SUB, SUPPLIER MANUFACTURER   |
| B 18 Z 19 Z 20 Z 20 Q 0 0 0 Q Y 23 N 24 N 25 D 2 4 3 26  |
| CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27  |
| [1] Repair of four Dresser 1500# Consolidated Safety Relief Valves, Model No. 1916-Gc/Pl, ]  |
| [1] Lrequired rework of the seats and discs to eliminate internal leakage through the  |
| [1] [valves, and thus, necessitated the isolation of the helium circulator pelton wheel  |
| [1] [drives. The valves were repaired, and pelton wheel drives returned to service within]   |
| [1]4 Ltime allowed by LCO 4.2.2. No further corrective action anticipated or required.   |
| FACILITY STATUS NOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  1 5 E 28 0 7 0 29 N/A A 31 Operator Observation  |
| 7 8 9 10 12 13 44 45 46 80  ACTIVITY CONTENT AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  |
| 1 6 Z 33 Z 34 N/A N/A N/A N/A N/A N/A  |
| PERSONNEL EXPOSURES. NUMBER TYPE DESCRIPTION (39)  |
| 7 3 9 11 12 13 N/A   |
| PERSONNEL INJURIES NUMBER DESCRIPTION (41)   |
| 1 8 0 0 0 0 0 N/A  T 8 9 11 12 12 N/A  LOSS OF DR DAMAGE TO FACILITY 43 820 8 24 0 0 79 5  |
| 1 9 Z 42 N/A   |
| PUBLICITY ISSUED DESCRIPTION 45  |
| 2 2 N (4) N/A  |
| NAME OF PREPARED Charles Lucle PHONE (303) 785-2224  |