



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

August 18, 1982

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTENTION DARRELL G EISENHUT DIRECTOR
DIVISION OF LICENSING
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON D C 20555

DOCKET 50-312
LICENSE NO. DPR-54
LICENSE TO RANCHO SECO AUXILIARY FEEDWATER MODIFICATION
TEST

In further clarification of the testing that we agreed to do in our letter dated August 17, 1982, a complete description of the test is as follows:

A hot flow demonstration test will be performed by simulating an AFW injection actuation with the Steam Generator pressure and temperature slightly above normal, hot, no load conditions. The purpose of this test is to verify that no feedwater hammer problems exist. An individual will be standing near each of the new AFW headers and risers during initiation. This test will also ensure that minimum AFW flow to the Steam Generators is provided.

John J. Mattimoe
Assistant General Manager
and Chief Engineer

A001

8208240379 820818
PDR ADOCK 05000312
P PDR