

Appendix B

NOTICE OF DEVIATION

Consumers Power Company

Docket No. 50-329

Docket No. 50-330

As a result of the inspection conducted on May 26-28, June 17, and 30 through July 2, 1982, the following was cited as a deviation.

During the May 28 and June 17, 1982, NRC exit meetings and during a conference call between the inspector and licensee representatives on June 18, 1982, the licensee committed to the use of approved installation/coordination forms during the installation of affected underpinning instrumentation.

Contrary to the above, it was determined on July 1, 1982 that unapproved installation/coordination forms were being used by construction personnel to document underpinning instrumentation installations.