



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

August 16, 1982
EQC 82-472

DIRECTOR OF NUCLEAR REACTOR REGULATION
ATTENTION JOHN F STOLZ CHIEF
OPERATING REACTORS BRANCH 4
U S NUCLEAR REGULATORY COMMISSION
WASHINGTON D C 20555

DOCKET 50-312
RANCHO SECO NUCLEAR GENERATING STATION UNIT NO. 1
AUXILIARY FEEDWATER HEADER REPAIR--ADDITIONAL INFORMATION

During a meeting held on August 13, 1982 in Washington, D. C., it was agreed that additional information regarding the cracks known to exist in the Internal Auxiliary Feedwater Headers at Rancho Seco would be provided to the NRC.

The enclosed analysis done by B&W provides this information.

A handwritten signature in cursive ink that reads "J. J. Mattimoe".

J. J. Mattimoe
Assistant General Manager
and Chief Engineer

Attachment

A handwritten mark consisting of the letters "A001" in a cursive style.

8208250303 820816
PDR ADOCK 05000312
P PDR

AN ELECTRIC SYSTEM SERVING MORE THAN 600,000 IN THE HEART OF CALIFORNIA

INTERNAL AFW HEADER

1. Stress Profiles With and Without Crack

These MSLB stresses for representative elements around the internal header are shown in Table 1. Figures 1, 2, and 3 show the element orientation. Of these elements, the maximum stress intensities (14.8 ksi without crack and 15.3 ksi with crack) occur at element 6 which is approximately 100° from the center of the crack. The ASME Section III allowable stress intensity for this condition is 42.0 ksi.

2. Circumferential Crack Growth

The largest loading on a corner weld is a moment about the tangential axis due to differential thermal expansion. If a through-wall crack were present this moment would be relieved, lowering the thermal stresses.

A critical crack length in the circumferential direction cannot be determined by Section XI fracture mechanics methods. However, a fatigue crack growth rate could be calculated using fracture mechanics methods if the proper material properties were known. This would be expected to show a longer life than the fatigue analysis already performed since the fracture analysis considers only the stress component driving the crack (2300 psi) while the fatigue analysis considers the total stress intensity (11,000 psi) which was conservatively calculated assuming no relief in the thermally induced stresses due to the presence of the through-wall crack. Therefore the existing fatigue analysis using a fatigue strength reduction factor of four is deemed adequate to demonstrate that the crack will not propagate.

GENERAL CALCULATIONS

SUMMARY OF SELECTED MID-ELEMENT EDGE STRESSES (HIT AND WITHOUT THE HELD CHECK) TABLE I NSL BRK PRELIM

EL. NO.	NEW CROSS SECN	S _x (PSI)	S _y (PSI)	S _{xy} (PSI)	S _{MAX} (PSI)	S _{MIN} (PSI)	APPROX. ANGLE S TO CENTER OF ELEM
6	No	-13,329.	-1645.	4568.	-71.	-14,903.	3.4°
	Yes	-13,587.	-1873.	4921.	-80.	-15,380.	
102	No	3354.	-325.	1925.	4104.	-1085.	80.6°
	Yes	3212.	-333.	1912.	4132.	-1153.	
198	No	-12,783.	-241.	843.	-185.	-12,839.	162.4°
	Yes	-13,014.	-143.	1204.	-31.	-13,126.	
262	No	2463.	791.	-3020.	4761.	-1507.	215.1°
	Yes	3911.	1464.	-3240.	6151.	-776.	
274	No	1768.	62.8	-1301.	2471.	-640.	240.9°
	Yes	-1206.	109.	-571.	322.	-1419.	
302	No	4977.	31.8	-1341.	5317.	-308.	247.3°
	Yes	2257.	895.	-1492.	3216.	-64.	
310	No	7330.	205.	-1484.	7627.	-92.	253.7°
	Yes	-6982.	-691.	-1882.	-171.	-7502.	

PER COMPUTER RUNS AEOACBG AND AEOACBN*

* WITH HELD CHECK

PREPARED BY	John R. Biddle	DATE	8-16-82	DOC. NO.	
REVIEWED BY		DATE		PAGE NO.	5-2

GENERAL CALCULATIONS



SUMMARY OF SELECTED MID-ELEM EDGE STRESSES - CONT'D
TABLE I NCL BCF PRESSURES

REF. COMP. RUNS AEGACBG AND AEGACBN

PREPARED BY	<u>John R. Blodgett</u>	DATE	<u>8-16-82</u>	DOC. NO.	
REVIEWED BY		DATE		PAGE NO.	<u>B-3</u>


GENERAL CALCULATIONS

LOCATION OF WELD CRACK IN HEADER MODEL FOR
SMUD POINT



NOTE: 3 ADDITIONAL NODES
HAVE BEEN ADDED TO THE
ORIGINAL HEADER ELEMENT
ELEMENT NUMBER - NODE
NO. 1805, 1806 AND 1807 -
AT THE LOCATION SHOWN TO
MODEL THE WELD CRACK.

GENERAL CALCULATIONS



NOTE: THE CIRCLED NOS. ARE ELEMENT NOS. - THE OTHER NOS. ARE NODE POINT NOS.

GENERAL CALCULATIONS

FIGURE 3

TOP VIEW OF HEADER (INNER WALL) SHOWING
CIRCUMFERENTIAL LOCATION OF TABULATED
ELEMENTS

