

APPENDIX A

Rockwell International Energy Systems Group 8900 DeSoto Avenue Canoga Park, California 91304

Docket No. 70-25 License No. SNM-21

NOTICE OF VIOLATION

Based on the results of the NRC inspection conducted on November 1-2, 1978, it appears that certain of your activities were not in full compliance with applicable NRC regulations and conditions of your license, as indicated below.

A. 10 CFR 73.50(c)(3) requires that "A picture badge identification system shall be used for all individuals who are authorized access to protected areas without escort."

Contrary to the above, the inspector observed on November 1, 1978 a security guard enter the protected area without escort and without a picture badge.

This is an infraction and a repeated item of noncompliance.

B. License Condition 9.A.3.7 requires that, "All non-moveable openings in material access area barriers, including openings to the roof, shall be protected to prevent unauthorized removal of SNM by closing permanently or by fastening material over such openings which provide sufficient strength to assure that the integrity of the barrier is not lessened and that removal of SNM through the opening is not possible."

Contrary to the above, the inspector observed three unattended carts within the MAA in hallway 11-H on which were numerous highly enriched uranium/aluminum fuel plates .051 inch thick x 6 inches wide x 4-1/2 feet long each containing approximately 60 grams U-235. Openings under doors at both ends of the hallway were 3/8 inches high (.375) x 3 feet wide and removal of SNM through the openings under the door was possible.

copy II of It cooise

This is an infraction.

CONTRACTOR OF THE OWNER

9401310266 930520 PDR FDIA SMITH92-576 PDR