

# LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N J S G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
 7 8 9 14 15 25 26 30 57 CAT 58

CON'T  
 01 REPORT SOURCE L 6 0 5 0 0 0 3 1 1 7 0 7 2 4 8 2 8 0 8 1 2 8 2 9  
 7 8 60 61 68 69 74 75 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On July 24, 1982, during routine operation, the Control Operator observed erratic  
 03 operation of No. 23 Reactor Coolant Pump (RCP) Flow Channel III. The channel was  
 04 declared inoperable, and Limiting Condition for Operation 3.3.1 Action 7 was entered.  
 05 All bistables associated with the channel were placed in the tripped condition. The  
 06 occurrence constituted operation in a degraded mode in accordance with Technical  
 07 Specification 6.9.1.9.b.  
 08 (81-131, 81-120, 81-102, 81-100, 81-077)

69 SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE G 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE T 15 VALVE SUBCODE Z 16  
 7 8 9 10 11 12 13 18 19 20  
 17 LER RO REPORT NUMBER 8 2 21 22 23 24 26 27 28 29 30 31 32 REVISION NO. 0  
 33 34 35 36 37 40 41 42 43 44 47  
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
 A 18 Z 19 Z 20 Z 21 0 0 0 0 Y 23 Y 24 A 25 F 1 2 0 26

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The erratic operation of No. 23 RCP Flow Channel III instrument was due to a failed  
 11 ferrite slug in the flow transmitter. The failed transmitter was replaced with a  
 12 spare and the channel was satisfactorily recalibrated. No. 23 RCP Flow Channel III  
 13 was declared operable, and the limiting condition for operation was terminated.  
 14

15 FACILITY STATUS E 28 0 8 2 29 NA OTHER STATUS 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION 32 Operator Observation  
 7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT Z 33 Z 34 NA AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
 7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE 2 38 DESCRIPTION 39 NA  
 7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION 41 NA  
 7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION 43 NA  
 7 8 9 10 80

20 PUBLICITY ISSUED N 44 DESCRIPTION 45 NA  
 7 8 9 10 80

NAME OF PREPARER R. Frahm

PHONE (609) 541-5900 629