



LER NO. 50-313/82-008/03L-0 (cont'd)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (cont'd)

solenoid valves for the actuator of valve CV-6202 and is a backup to assure valve closure upon loss of instrument air. The relay was repaired and reinstalled. Functional checks proved satisfactory. Valve CV-6202 was tested and proved operable. An engineering evaluation will be performed to determine long term corrective action to prevent recurrence.