



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

April 30, 1982

DIRECTOR OF NUCLEAR REACTOR REGULATION  
ATTENTION DARRELL G EISENHUT DIRECTOR  
DIVISION OF LICENSING  
US NUCLEAR REGULATORY COMMISSION  
WASHINGTON D C 20555



DOCKET 50-312  
RANCHO SECO NUCLEAR GENERATING STATION  
UNIT NO 1  
REQUIREMENT SCHEDULE

The Sacramento Municipal Utility District has received your letter of April 13, 1982, requesting schedule information for new requirements imposed on us by the Nuclear Regulatory Commission and other items of our own which affect our workload. Attached to this letter is the list of items taken from the January 31, 1982 listing in NUREG - 0748 and a listing of the Rancho Seco Engineering Change Notices which detail the work we have planned for the foreseeable future.

The attached lists specify whether or not a plant outage is required for the modification, provide a scheduled implementation date for each modification, and provide a priority for these items. For this listing we have used a priority level of 1 for items which are safety related or which have been imposed by the NRC. A level of 2 has been used for items which would improve plant reliability, and a level of 3 for all other items. We have been unable to completely specify priorities and schedules for all items at this time, but hope to have most items completed by our meeting on this subject, which we understand is presently scheduled for May 13, 1982.

At first glance some of the items on our list of Engineering Change Notices may appear to be smaller, less consequential tasks. However, we feel these items cannot be ignored since taken as a whole, they represent a significant portion of our workload. Another significant impact on our workload are intangibles which are not listed, such as technical specification required inspections and surveillance efforts. These activities significantly affect both the engineering and operating staff workloads.


Aool  
s  
/ll

8205040706 820430  
PDR ADOCK 05000312  
P PDR

April 30, 1982

Your letter included a list of IE Bulletins which have not yet been closed out on some plants. To the best of our knowledge all bulletins listed require no further action on our part and are therefore considered completed.

We sincerely hope that our meeting on May 13 will provide meaningful input to the methods you use to impose new requirements on the nuclear industry.



John J. Mattimoe  
Assistant General Manager  
and Chief Engineer

Enclosures

## MULTI-PLANT ACTIVE

TAC #	DESCRIPTION	OUTAGE	PRIORITY	SCHEDULE
12326	HELB and Consequential System Failure Rancho Seco			
12746	Adequacy of Station Electric Distribution Systems Voltages	Y		1/83
42126	Decay Heat Removal Capability Tech Specs			Complete
43042	Technical Specifications Defining Operability for Safety Systems			
43606	Snubber Inservice Surveillance Technical Specifications			Complete
43663	Seismic Qualification of the Auxiliary Feedwater System			Complete
46634	Monitoring of Fatigue Transient Limits for the Reactor Coolant System			
46855	PWR MSLB with cont'd Feedwater Addition			5/82
47077	Qualif of Insp, Exam, & Testing Personnel			Complete
47565	Qualifications: Insp, Exam, Test,			
43320	Fire Protection - Appendix R	Y		1/83
06710	Reactor Coolant System Overpressurization Protection	Y	1	?
11130	Appendix J - Containment Leak Testing			Complete
08612	Filter Tech Specs			Complete
08079	Control of Heavy Loads over Spent Fuel Pool (NUREG 0612)			1/84
10383	Loss of 125-V DC Bus Voltage with Loss of Annunciator System			
11288	Inservice Testing			
11284	Tendon Surveillance			
10816	10 CFR 50.55A(G) - Inservice Inspection - Generic			
08153	Appendix I Tech Spec Implementation Review			Complete

TAC #	DESCRIPTION	OUTAGE	PRIORITY	SCHEDULE
08602	Review of Asymmetric LOCA Loads Submittal			Complete
08605	Mechanical Snubber Surveillance			Complete
10968	Degraded Grid Voltage			Complete
08247	PWR Secondary Chemistry Monitoring Requirements - Generic			
42703	IE Bulletin 79-27, Loss of Non Class IE Inst & Constr. Power. Rev. & Eval			Complete
43264	B&W Accident induced Neutron Flux Errors (Multi-Plant Item B-64)			Complete
43938	Station Blackout Procedures & Training			Complete
42601	Long Term Review Containment Purge and Vent (B-24)		2	
47170	Natural Circulation Cooldown (Generic Ltr 81-21)			Complete
42918	Masonry Wall Design. Response to IE Bulletin 80-11		1	6/82
42507	Environmental Qualification of Safety Related Electrical Equipment (80-CLI-21)	Y	1	8/84
MULTI-PLANT TMI "COMPLETE"				
45188	NUREG-0737 II.K.2.10, Safety Grade Arts	Y	1	1/83
45195	NUREG-0737 II.K.2.11, Operator Training and Drilling			Complete
45222	NUREG-0737 II.K.2.17, Potential for Voiding in RCS			Complete
44123	NUREG-0737 I.A.1.3.1, Shift Manning Overtime Limits			Complete
47320	Correct Performance of Operating Activities (API.C.6)			Complete
44052	NUREG-0737 I.A.1.1 Sta Long Term Requirements			
42790	Confirmatory Order - ICS Reliability Analysis			Complete

MULTI PLANT TMI ACTIVE

TAC #	DESCRIPTION	OUTAGE	PRIORITY	SCHEDULE
44194	NUREG-0737 I.A.2.4, Upgrading of RO and SRO Training			Complete
44265	NUREG-0737 I.C.1.2.A, Inadequate Core Cooling Guidelines			Complete
44335	NUREG-0737 I.C.1.3A, Abnormal Transient Operator Guidelines	Y	1	1/83
44402	NUREG-0737 II.B.1, RCS High Point Vents	Y	1	1/83
44473	NUREG-0737 II.B.3.2, Post Accident Sampling Modifications	Y	1	1/83
44544	NUREG-0737 II.B.4.1, Training for Mitigation Core			Complete
44615	NUREG-0737 II.D.1.2, Relief and Safety Valve Testing		1	
44673	NUREG-0737 II.E.1.1, AFW System Evaluation	Y	1	1/83
44709	NUREG-0737 II.E.1.2.1, AFW Safety Grade Auto Initiation	Y	1	1/83
44755	NUREG-0737 II.E.1.2.2, AFW Safety Grade Flow Indication	Y	1	1/83
44812	NUREG-0737 II.E.4.1.2, Dedicated Hydrogen Penetrations	Y	1	1/83
44883	NUREG-0737 II.E.4.2, Containment Isolation Dependability			Complete
44954	NUREG-0737 II.E.1.1, Noble Gas Monitor	Y	1	1/83
45025	NUREG-0737 II.F.1.2, Iodine/Particulate Sampling	Y	1	1/83
45096	NUREG-0737 II.F.1.3, Containment High Range Monitor	Y	1	1/83
45166	NUREG-0737 II.F.2.3, Inadequate Core Cooling Instrumentation	Y	1	85
45202	NUREG-0737 II.K.2.13, Thermal-Mechanical Report		1	12/82
45209	NUREG-0737 II.K.2.14, Lift Frequency of PORV's and SV's			Complete
45216	NUREG-0737 II.K.2.16, RCP Seal Damage			Complete
45273	NUREG-0737 II.K.3.1, Auto PORV Isolation	Y	2	84
45319	NUREG-0737 II.K.3.2, Report on PORV Failures			Complete

TAC #	DESCRIPTION	OUTAGE	PRIORITY	SCHEDULE
45376	NUREG-0737 II.K.3.3, Report on RV/SV Failures			Complete
45440	NUREG-0737 II.K.3.5, Auto Trip of RCPS	Y	1	84
45662	NUREG-0737 II.K.3.17, ECC System Outages			Complete
45859	NUREG-0737 II.K.3.30, SB LOCA Outline		1	84
45978	NUREG-0737 III.A.1.2, Technical Support Center	Y	1	1/83
46049	NUREG-0737 III.A.1.2, Operational Support Center		1	1/83
46121	NUREG-0737 III.A.1.2, Emergency Operations Facility		1	
46193	NUREG-0737, III.A.1.2, Nuclear Data Link Data			Complete
46265	NUREG-0737, III.A.2.1, Emergency Plan Upgrade to meet Rule		1	6/82
46337	NUREG-0737, III.A.2.2, Meteorological Data Upgrade		1	84
46408	NUREG-0737, III.D.3.3, Inplant Radiation Monitoring		1	1/83
46477	NUREG-0737, III.D.3.4, Control Room Habitability		1	
46777	NUREG-0737, II.B.2- Plant Shielding Review		1	1/83
47703	NUREG-0737, Item II F1.5, Containment Water Level Monitor	Y	1	1/83
47774	NUREG-0737m Item II F1.6, Containment Hydrogen Monitor	Y	1	1/83
43427	Item II K.2.13, Thermal-Mech Effects of HPI on Vessel		1	12/83

PLANT SPECIFIC "COMPLETE"

TAC #	DESCRIPTION	OUTAGE	PRIORITY	SCHEDULE
43285	Miscellaneous Water Evaporator		2	
43702	Security Plan Amendments 7 & 8			Complete
46553	Physical Security Plan - Amendment 9		2	8/82
46692	HPI Pump Lube Oil Cooler Blockage			
47248	Feedback of Operating Experience (API.C.5)			Complete
46519	Tower Crane Use			Complete

PLANT SPECIFIC "ACTIVE"

13099	Seismic Assessment of Foothills Fault System			Complete
42049	LCO for DG Operability			
42850	Tech. Spech. Amendment 71 - Invertor Outage Duration			
42933	Atmospheric Dump Valve Circuitry Modification	Y	1	84
43190	Auxiliary Feedwater System Upgrade	Y	1	84
43460	IAEA Safeguards			
46778	Proposed Amendment 79, Administrative Reorganization			Complete
47445	Security Plan - Amendment 10 Info			
11128	TS for Hydraulic Snubbers			Complete
	RCP Seal Damage			Complete
	Control Rod Tech Specs			Complete



ACTIONS NOT YET DOCUMENTED

DESCRIPTIONS	OUTAGE	PRIORITY	SCHEDULE
Radwaste Storage Building			
Upgrade Construction Facilities			
Fire Training Facility			
Relocate South Fire Water Line			
Modify PAP Building Exit Area			
Spare S.V. Tfmr.			
Upgrade 12 KV Offsite Dist. System			
Vital Inverter Auto Transfer Sw.			
Upgrade "F" Battery			
Upgrade Cl. 1 Heat Trace System			



## LISTING OF ECN'S

NJMBR	WR	DESCRIPT	MODNO	GECOG	NUCOG	REG. FEQ.	OUTAGE	PRIORITY	SCHED.
A1710		CHANGE WASTE GAS RAD MONITOR R15005	N/A	STEPHENSON	N/A				
A1723		RAD WASTE SOLIDIF&COMPACTION REVAMP	N/A	N/A	LAWRENCE				
A1840		ADD OFF SEAL COL TANK & LOOP SEAL	N/A	N/A	WICHERT		Y		
A1869	065664	PROV AIRFLOW RATE IND/SURV TESTING	N/A	STEPHENSON	N/A				
A1869	031346	PROV AIRFLOW RATE IND/SURV TESTING	N/A	STEPHENSON	N/A				
A1869	063154	PROV AIRFLOW RATE IND/SURV TESTING	N/A	STEPHENSON	N/A				
A1871	051655	STEAM SAMPLING SYSTEM	035	ALVI	N/A				
A1871	056213	STEAM SAMPLING SYSTEM	035	ALVI	N/A				
A2010	040393	NUC SYS BUS 4A & 4B-COMMITMNT TO NRC	051	DANIELS	N/A		Y		1-1-83
A2010	040394	NUC SYS BUS 4A & 4B-COMMITMNT TO NRC	051	DANIELS	N/A		Y		1-1-83
A2067	036405	ADD TEMPERATURE INDICATORS	N/A	N/A	LOW				
A2067	053720	ADD TEMPERATURE INDICATORS	N/A	N/A	LOW				
A2218	051069	MISC WATER EVAPORATOR	010	ALVI	UHL				
A2218	051070	MISC WATER EVAPORATOR	010	ALVI	UHL				
A2218	051071	MISC WATER EVAPORATOR	010	ALVI	UHL				
A2218	066044	MISC WATER EVAPORATOR	010	ALVI	UHL				
A2218	051066	MISC WATER EVAPORATOR	010	ALVI	UHL				
A2268	051211	RPL ANCHOR BOLTS WITH CERTIFD ANCHOR	N/A	LEWIS	N/A		Y		
A2268	055822	COMPLETE GROUTING OF LETDOWN COOLER	N/A	LEWIS	N/A		Y		
A2271		ADD FLOWMETER WITH TOTALIZER	N/A	N/A	LAWRENCE				
A2313		POS HOLDOWN OF REG NEUTRAL SRC IN RX	N/A	N/A	JREN				
A2332		HVAC-EP-A-9	057	ALVI	N/A				
A2332A	066043	HVAC-EP-A-9, MECHANICAL & CIVIL	057	ALVI	WHITNEY				
A2338	058246	INSTALL GRID INDICATOR BAR FOR UPEND	N/A	N/A	WICHERT		Y		
A2374		PROVIDE PERM ELEC POWER TO A/WAREHSE	N/A	N/A	LINKHART				
A2387	037648	INSTALL AIR TANK REGULATR CHECK VALV	N/A	N/A	LOW		Y		
A2387		INSTALL AIR TANK REG. CHECK VALVE	N/A	N/A	PRICE				
A2394		MOD RX BLDG PURGE SUPPLY DAMPR CONTR	N/A	N/A	LINKHART				

NUMBR	WR	DESCRIPT	MODNO	GECDG	NUCOG	REG. REQ.	OUTAGE	PRIORITY	SCHED.
A2439	048163	MODIFY WASTE GAS HEADER DRAIN LINES	N/A	N/A	WICHERT		Y		
A2447	037832	PROVIDE PERM POWER FOR TEST EQUIPMEN	N/A	N/A	LINKHART				
A2457	062598	INSTALL CONTACTS FROM PUMP MONITOR	N/A	N/A	LOW				
A2457	062599	INSTALL CONTACTS FROM PUMP MONITOR	N/A	N/A	LOW				
A2457	062758	COMPLETE INSTRUMENTATION OF CONTACTS	N/A	N/A	LOW				
A2457	062759	COMPLETE INSTRUMENTATION OF CONTACTS	N/A	N/A	LOW				
A2457	062765	ELECT TIE IN AFTER WR62598	N/A	N/A	LOW				
A2457	062765	ELECT TIE IN AFTER WR62599	N/A	N/A	LOW				
A2460	040391	INST TERM CONTRL IN ADMIN COM ROOM	N/A	N/A	LINKHART				
A2486	051258	PROVIDE ADD SUPPORT IN DELAY HEAT S	N/A	N/A	STIVER		Y		
A2486	051259	PROVIDE ADD SUPPORT IN DELAY HEAT S	N/A	N/A	STIVER		Y		
A2497		REPLACE GLOBE VALVES WITH 1 1/2" VAL	N/A	N/A	LAWRENCE				
A2545	067841	ADD COMPONENTS TO SPND SYSTEM	N/A	N/A	WHITNEY				
A2578	048465	INSTALL PEDESTALS SUPPORT STEEL/VENT	N/A	N/A	LAWRENCE				
A2631	049692	SET RELIEF VALVE TO 11 +/- PSIG	N/A	N/A	WICHERT		Y		
A2638		ADD BYPASS TO REHEATER/MAIN/PEG VALV	N/A	N/A	WICHERT				
A2640	066055	FAB & ASSEMBLE PER DWGS N2601-108	N/A	N/A	KENEY				
A2640	066489	INSTALL SAFETY SWITCHES ON CRD	N/A	N/A	KENEY				
A2644	052089	RELOCATE GROUND WIRING FOR CT	N/A	N/A	LINKHART		Y		
A2644	052090	RELOCATE GROUND WIRING FOR CT	N/A	N/A	LINKHART		Y		
A2644	052091	RELOCATE GROUND WIRING FOR CT	N/A	N/A	LINKHART		Y		
A2644	052092	RELOCATE GROUND WIRING FOR CT	N/A	N/A	LINKHART		Y		
A2644	052093	RELOCATE GROUND WIRING FOR CT	N/A	N/A	LINKHART		Y		
A2670		RPL CONTROLLER FOR P-440	N/A	N/A	LINKHART				
A2676		RPL REACTOR VESSEL HD. RETAINING SCR	N/A	N/A	PRICE		Y		
A2683	051216	COMPLETE TELEPHONE MODS H64D	N/A	N/A	LINKHART				
A2704		COMPLETE SECURITY MODIFICATIONS		HODGES	N/A				
A2734		NO INFORMATION YET	N/A	HAZELETT	N/A				

NUMBR	WR	DESCRIPT	MODNO	GECOG	NUCOG	REG. PER.	OUTAGE	PRIORITY	SCHED.
A2792	047726	INST. CONDUIT/CABLE/INSTR/TUBING/ETC	013	DANIELS	N/A	II.K.2.10			
A2794		TRIP 4 RX COOLANT PUMP & 2 BUS BRKRS	N/A	DANIELS	N/A				
A2806		PROVIDE AUTO AUX FD PMP START LO STE	N/A	P JOHNSON	WICHERT				
A2806/		ADD INDICATORS TO AUX FD WATER PUMPS	N/A	P JOHNSON	N/A				
A2808		TIES BACK TO ECN A-1861	N/A	STEPHENSON	N/A				
A2809		ADD INTERCOM SYSTEM IN CONTROL ROOM	N/A	STEPHENSON	N/A				
A2827		PERMANENT MANWAY COVERS	N/A	FIELD	N/A				
A2889		GENER PROTECTION, SWTCHYRD DCB PROJE	N/A	N/A	LINKHART				
A2894		COMPLETE MODS TO AUX HEATING AND VEN	025	COX	N/A	II.B.3.2	Y		1-1-83
A2895	045881	INSTALL POST ACCIDENT SAMPLING SYSTM	025	COX	N/A	II.B.3.2	Y		1-1-83
A2912		NEW INSTR TO MONITOR COND TANK LEVEL	001	STEPHENSON	N/A	II.E.1.1			1-1-83
A2916	065019	REPLACE TURBINE CONTROLLER	N/A	LOW	N/A		Y		
A2916	065020	REPLACE TURBINE CONTROLLER	N/A	LOW	N/A		Y		
A2924		FUSE PROT FOR CKYS LEAVING ICC	N/A	STEPHENSON	N/A				
A2931	052012	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052013	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052014	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052023	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052024	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052025	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052026	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052030	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052031	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052036	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931	052037	REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2931		REPLACE BOLTING MATERIAL ON ANCHR VA	N/A	N/A	WICHERT				
A2932		UPGRADE TSAT METER	002	D JOHNSON	LOW	II.F.2	Y		1-1-83
A2934		INSTALL HOT LEG VENTS AND SOL VALVES	041	JONES	N/A	II.E.1	Y		1-1-83

NUMBR	WR	DESCRIPT	MOONO	GECDG	NUCOG	SEG. SER.	OMTAGE	PRIORITY	SHED.
A2936		CLASS 1 INDICATION OF CONTAINMENT PR	055	CONKLIN	N/A	II, F, 1, 4	Y		1-1-83
A293E		CLASS 1 INDIC OF HYDROGEN CONCENTRAT	021	CONKLIN	N/A	II, F, 1, 6	Y		1-1-83
A2946		CLASS 1 NARW/WIDE RNG CONTAINMNT LEV	012	CONKLIN	N/A	II, F, 1, 5	Y		1-1-83
A2945	052071	REMOVE DEHUMIDIFIER IN RX BUILDING	N/A	FIELD	N/A		Y		
A2972		RPL MANL VLVES FOR LETOWN FILT BCKFL	033	FIELD	N/A		Y		1-1-83
A2973		STEEL SHIELD AROUND RADWASTE FILTERS	033	FIELD	KENEY				1-1-83
A2974		PER ALARA CHG RAD FILTERS	033	FIELD	KENEY		Y		1-1-83
A2975		REDUCE EXP. WHOLE CHG RAD FILTERS	033	FIELD	KENEY				1-1-83
A2976		NO INFORMATION YET	033	FIELD	N/A				
A2977		NO INFORMATION YET	033	FIELD	N/A				
A297E		NO INFORMATION YET	033	FIELD	N/A				
A2975		NO INFORMATION YET	N/A	FIELD	N/A				
A298C	052847	NSEB	047	JURKOVICH	N/A	0737			1-1-83
A298C	058171	NSEB	047	JURKOVICH	N/A				
A298C	053715	NSEB	047	JURKOVICH	N/A				
A298C	055517	NSEB	047	JURKOVICH	N/A				
A298C	056225	NSEB	047	JURKOVICH	N/A				
A298C	058147	NSEB	047	JURKOVICH	N/A				
A298E	058187	NSEB	047	JURKOVICH	N/A				
A298C	062238	NSEB	047	JURKOVICH	N/A				
A2982	064751	UPGRADE THE EXISTING SEISMIC MONITOR	015	DILTS	N/A		Y		1-1-83
A2982	062594	UPGRADE THE EXISTING SEISMIC MONITOR	015	DILTS	N/A		Y		1-1-83
A2984		INSTALL ELECTRICAL PENETRATIONS	052	JONES	N/A	0737	Y		1-1-83
A3011		CORE FLOOD LINE BREAK - CPT DISCHARG	N/A	DILTS	N/A				
A3021		SAMPLE VALVE TO SAMPLE FROM T887A&B	N/A	N/A	STIVER				
A3051	048144	FUEL SYSTEM CARRIAGE STOPS	N/A	N/A	WICHERT		Y		
A3062		REPLACE INPULSE STEAM TRAP @ AUX PUM	N/A	N/A	LAWRENCE				
A3065	066057	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A	0737	Y		1-1-83

NUMBR	W#	DESCRIPT	MODNO	GECDG	NUCDG	FEQ. FEQ.	OUTSIDE	PRIORITY	DATE
A3065	062807	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A	0737			1-1-83
A3065	062841	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A		Y		
A3065	062815	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A				
A3065	062844	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A				
A3065	066052	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A				
A3065	062842	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A				
A3065	065696	CABLE RACEWAY IN/OUTSIDE CONTAINMENT	N/A	JONES	N/A	Y	Y		Y
A3082	063000	ADD TEMP INDICATION CHARCOAL FILTER	N/A	DILTS	N/A				
A3082	063001	ADD TEMP INDICATION CHARCOAL FILTER	N/A	DILTS	N/A				
A3092		CKT FROM COMM INVERTER TO PT&T RACK	N/A	N/A	LINKHART				
A3094		AUZ FW SYS RELIABILITY IMPROVEMEN(FV 31835)	001	FIELD	WICHERT	II.E.1.1	Y		1-1-83
A3097		REMOTE OP OF DH5001 AND DH5002	054	THORPE	LINKHART	II.B.2	Y		1-1-83
A3101		ADDITION OF SAMPLING SYSTEMS	025	COX	N/A	II.B.3.2	Y		1-1-83
A3105	062589	RPL METEOROLOGICAL SENSORS W/EQUIP	016	DILTS	N/A	III.A.2.2			
A3107		ADD H2 SEAL OIL DRAIN HI-LEVEL ALARM	N/A	STEPHENSON	N/A				
A3131		ADD SEALS TO ALL AFFECT PENETRATIONS	N/A	FIELD	N/A				
A3152	065176	PROV SAMPLE PTS FRM VENTILATION SYS	N/A	N/A	LAWRENCE				
A3155		CHG DWG TO SHOW NEW WIRING FROM P462	N/A	N/A	LINKHART				
A316E		ABILITY TO REMOVE FL TUBES FOR INSP	N/A	N/A	WICHERT				
A3172	063416	COMPLETE TEST OF GRND FAULT DETECTOR	N/A	N/A	LINKHART				
A3172	053652	COMPLETE TEST OF GRND FAULT DETECTOR	N/A	N/A	LINKHART				
A3175		THERMOCP L COOLING UNITS FOR TEMP IND	N/A	N/A	DANIELS				
A318C	053704	ID LEAK FROM S PUMP TO RODWASTE BOX	N/A	N/A	LINKHART				
A318C	053705	ID LEAK FROM S PUMP TO RODWASTE BOX	N/A	N/A	LINKHART				
A3181		ELIM BLACK BOX IN LEAK FROM ACID S	N/A	N/A	PRICE				
A3182	053624	MINIMIZE BLOCK BOX IN LEAKAGE	N/A	N/A	PRICE		Y		
A3182	055473	MINIMIZE BLOCK BOX IN LEAKAGE	N/A	N/A	PRICE		Y		

NUMBR	WR	DESCRIPT	CDND	GECOG	NUCDG	REG. REQ.	INTASK	PRIORITY	DATE
A3184	053699	480V WELDING OUTLETS AT AUX-20 LEVEL	N/A	N/A	LINKHART				
A3190		DRAIN FOR CONDENSATION IN RY BLDG EM	N/A	N/A	WHITNEY				
A3196		UPGRADE LINE 25000 W/NEW SITE GLASS	N/A	N/A	WICHERT				
A3215	065008	STORAGE FOR CASK IN SPND SYSTEM	N/A	N/A	KENEY				
A3215	065017	STORAGE FOR CASK IN SPND SYSTEM	N/A	N/A	KENEY		Y		
A3216		ELEC SERVICE ADJACENT TO NSEB	N/A	HODGES	N/A				
A3219	053810	INS RCP SEAL RET TEMPS TO RECORDER	N/A	N/A	FRASER				
A3219	055805	INS RCP SEAL RET TEMPS TO RECORDER	N/A	N/A	FRASER				
A3219		INS RCP SEAL RET TEMPS TO RECORDER	N/A	N/A	FRASER				
A3223	066040	MONITOR OPERATION OF MAIN STEAM	N/A	DILTS	N/A				
A3224	049840	CONDUIT FOR FUTURE FIRE WATER VL POS	N/A	JONES	N/A				
A3231		TIE BETWEEN RCS LOOP DR & PRESS SAMP		COX	N/A	II.B.3.2	Y		1-1-83
A3237		INST SHUTOFF VL BETWEEN T-9936DMW013	N/A	N/A	LAWRENCE				
A3239	056554	SUPPLY N2 OFF OF LINE 74380-1"	N/A	N/A	LDW				
A3239	058262	SUPPLY N2 OFF OF LINE 74380-1"	N/A	N/A	LDW				
A3247		INSTALL ISOLATION VALVE IN DRAIN LN	N/A	FIELD	N/A				
A3251	055113	INIT CHANGES PER NCR 5-1878 TO PANEL	N/A	N/A	FRASER				
A3254	051647	RELOCATE FIRE PROTECT DELUGE PIPING	N/A	N/A	WELLSFRY		Y		
A3255	059024	NEW LIGHTING AT AUX BLDG WEST DBL DR	N/A	N/A	LINKHART				
A3263	059025	NEW 115VAC NEAR FEEDWATER FLOW TRANS	N/A	N/A	LINKHART				
A3266		ADD ISOLATION VALVE ON LINE 69420	N/A	N/A	PRICE				
A3284	053706	ADD ROOT VALVES FOR "D" MSR	N/A	N/A	PRICE		Y		
A3285		TIE N2 TO INSTR AIR HD ON GR LEVEL	N/A	N/A	WICHERT				
A3298		RPR CT ON THE LINER PLATE IN RY BLDG	031	ALVI	N/A		Y		
A3299		COAT PIPING OF NUC SERV COOL WATER	N/A	ALVI	N/A		Y		
A3302	055524	MACHINE ON TORQUE TUBE UNCOUP TOOL	N/A	N/A	STIVER				
A3308		700 NEW POINTS FOR CRT ANNUNCIATOR	006	STEPHENSON	N/A		Y		
A3312	062778	EH FLUID CIRCULATION WITHIN RESERVOR	N/A	N/A	PRICE				



NUMBR Y	WR	DESCRIPT	DDNO	GECOG	NUCOG	FEQ. REQ.	DATE	PRIORITY	OTHER
A3315	053660	RELOCATE TEMP INDICATOR	N/A	N/A	CARMICHAEL			Y	
A3318	053772	INSTALL EXHAUST FAN IN CHLOR ROOM	N/A	N/A	WELLSFRY				
A3318	063153	INSTALL EXHAUST FAN IN CHLOR ROOM	N/A	N/A	WELLSFRY				
A3319		RPL MANIFOLD SNUBBERS IN 5 SYSTEMS	N/A	N/A	STIVER				
A3320		LIGHT ABOVE MAIN LUBE OIL CENTRIFUGE	N/A	N/A	LINKHART				
A3325		INST AUTO NOTIF SYS ON RY BLDG PURGE	019	DILTS	SHEEHAN	S.B. 1184		Y	1-1-73
A3328	064826	480V WELD OUTLETS ON MEZZ & TURB LE	N/A	N/A	LINKHART				
A3335		REPLACE COATING ON RX BLDG ROOF AREA	N/A	ALVI	N/A				
A3336		METAL BLDG SOUTH OF L & D BUILDING	N/A	GILLIS	N/A				
A3343		STEAM SAMPLE SYSTEM MODULE HOUSING	035	ALVI	N/A				
A3356	059580	PA SPKR IN HP OFFICE & -27 TANK FARM	N/A	N/A	LINKHART				
A3359	051637	SWITCH ON SOURCE ROOM AREA MONITOR	N/A	N/A	CARMICHAEL				
A3360	065018	PERM LIGHTS NEAR PCW PUMPS	N/A	N/A	LINKHART				
A3364	066058	CONSTRUCT ROTOR STORAGE BUILDING	N/A	GILLIS	N/A				
A3364	066059	CONSTRUCT ROTOR STORAGE BUILDING	N/A	GILLIS	N/A				
A3374		ADD 2 PERSONNEL EXPLOSIVE DET IN PAP	N/A	STEPHENSON	N/A				
A3375		ADD XRAY MACHINE IN PAP	N/A	STEPHENSON	N/A				
A3393	053401	PENETRATIONS OF AUX BUILDING	N/A	JURKOVICH	N/A				
A3393	062812	PENETRATIONS OF AUX BUILDING	N/A	JURKOVICH	N/A				
A3393	062810	PENETRATIONS OF AUX BUILDING	N/A	JURKOVICH	N/A				
A3393	058188	PENETRATIONS OF AUX BUILDING	N/A	JURKOVICH	N/A				
A3398	051215	MOD UNDERVOLT RELAY ON LISTED BREAKR	N/A	PHIPPS	N/A				
A3400		PROVIDE LIFTING LUGS FOR A-532	N/A	LAWRENCE	N/A			Y	
A3417	068183	CABLE TO LOG TYPER FROM H4CPD-1	N/A	N/A	LINKHART				
A3420	065005	PROVIDE TIME SIG/START/WORK/QUIT,ETC	N/A	N/A	LINKHART				
A3431		REDESIGN CONT ROD MAST ON MAIN FH BR	N/A	N/A	WICHERT				
A3438		ADD SUPPORTS AND DRAIN TANK FLAME	030	FIELD	N/A	APP. 8.		Y	1-1-73
A3441	066045	INSTALL DEWPOINT MONITOR	N/A	N/A	CARMICHAEL				



NUMBR	WR	DESCRIPT	DDNO	GECOG	NUCOG	REG. REF.	OT/ASE	PRIORITY	DATE
A3442	065022	RELOCATE FT22013	N/A	N/A	LOW			Y	
A3442	065023	RELOCATE FT22013	N/A	N/A	LOW			Y	
A3452		INST CABLE TO NRC RED PH IN CONT RM	N/A	N/A	LINKHART				
A3453	059022	INSTALL NEW THERMOSTATS FOR Z7 & Z1	N/A	N/A	SHEEHAN				
A3458		RANCHO SEC0 COMMUNICATION SYSTEM	009	FERU/CONKL	N/A	II.A.1.2			1-1-83
A3465	056551	REM JUMPER FROM TROLLEY FESTOON JBOX	N/A	N/A	PHIPPS				
A3466		I & O UNIONS TO HPI-A PUMP RM COOLER	N/A	N/A	WELLSFRY				
A3477		REWIRE INV OUTPUT VOLT/FREQ METERS	N/A	N/A	LINKHART				
A3480	068186	RED NOISE ON ANALOG INP TO BAILEY TM	N/A	CONKLIN	N/A			Y	
A3483	065679	JOG CONTROL MOD SFV25003	N/A	N/A	FRASER				
A3483	065680	JOG CONTROL MOD SFV25004	N/A	N/A	FRASER				
A3485		HOT LINE PHONE IN HP AND TSC OFFICES	N/A	CONKLIN	N/A	*			
A3490	062784	REWIRE PROTECT TRIP FOR RCP BREAKERS	N/A	N/A	LINKHART			Y	
A3490	062785	REWIRE PROTECT TRIP FOR RCP BREAKERS	N/A	N/A	LINKHART			Y	
A3494	058274	REWIR MOD TO CVA 7	N/A	N/A	SHEEHAN				
A3497		JIB CRANE ADDITION TO REACTOR BLDG	001	FIELD	THOMAS				
A3500		PROX SENSOR TO RPL MECH POS SW FPW	N/A	FIELD	N/A				
A3505	067702	REWIRE SFAS MOD 880 BUFFER AMPS	N/A	N/A	LOW				
A3506		POST ACCIDENT SAMPLING SYSTEM	025	COX	N/A	II.B.3.2		Y	1-1-83
A3509	059593	ADD PHONE TO DESK NEAR RAD-WASTE PNL	N/A	CONKLIN	N/A				
A3512		TEST JACKS ON RPI POWER SUPPLY PANEL	N/A	N/A	CARMICHAEL				
A3528		RPL WESTINGHOUSE TRANSMITTERS	N/A	STEPHENSON	N/A				
A3528		RPL WESTINGHOUSE TRANSMITTERS	N/A	STEPHENSON	DROCK				
A3533	068445	VARIAC AUTO TRANSMIT ON IE & IF BU	N/A	N/A	LINKHART				
A3533	068444	VARIAC AUTO TRANSMIT ON IE & IF BU	N/A	N/A	LINKHART				
A3535		METER TO MONITOR CHARCOAL OPER HOURS	N/A	N/A	SHEEHAN				
A3537		H2 CONTROL SYSTEM MOD FOR LOCA	020	SMITH	N/A	II.C.3.2		Y	1-1-84
A3543		REPAIR LIMITORQUE OPERATOR	N/A	N/A	WELLSFRY				

NUMBR	Y	WR	DESCRIPT	DDNO	GECOG	NUCOG	REQ. REQ.	DATE	STATUS	COMPL.
A3546		065345	INSTALL 8 HR BATTERY PWR EMERGCY LIG	N/A	PILAPIL	N/A	APP. R.			
A3546		063149	INSTALL 8 HR BATTERY PWR EMERGCY LIG	N/A	PILAPIL	N/A				
A3546A		063150	INST EMERG PWR SUPPLY IN MAIN STREAM	N/A	THORPE	BROCK				
A3546B			INST EMERG PWR SUPPLY IN CONTROL RM	N/A	THORPE	BROCK				
A3646C			INST EMERG PWR SUPPLY/FIRE PROTECTIO	N/A	PILAPIL	BROCK				
A3548			EMER CONTROL OF VI AREA DRS @ CON RM	N/A	DILTS	N/A				
A3553			INSTR SHOP AREA MADE AVAIL FOR MOD	003	STEPHENSON	N/A	III.A.1.2			1-1-83
A3553A		068193	CIVIL CHGS FOR IC SHOP TO BE TSC	003	GILLIS	FRASER				
A3553A		068194	CIVIL CHGS FOR IC SHOP TO BE TSC	003	GILLIS	FRASER				
A3553B		063132	REMOVAL OF HVAC DUCTING	N/A	FIELD	THOMAS				
A3562		068104	INST LIGHTS AT PROPANE FILLING STATS	N/A	N/A	LINKHART				
A3565		059005	MAINTAIN 9FT WATER OVER FUEL ASSY	N/A	N/A	LOW				
A3566			ADD Y STRAINER TO RAD MONITOR 15017	N/A	N/A	LAWRENCE				
A3577		068182	INSTALL ELECT FOR DEGAS SUMP PUMP	N/A	N/A	LAWRENCE				
A3577		059006	INSTALL ELECT FOR DEGAS SUMP PUMP	N/A	N/A	LAWRENCE				
A3579			CHNGE ALARM ANNUNCIAT FOR DIESEL GEN	N/A	N/A	PHIPPS				
A3581			CONSTRUCT RECORDS AND TRAINING BLDG	037	JURKOVICH	N/A				
A3583			REPLACE PIPING NEAR LETDOWN ORIFICE	N/A	N/A	STIVER				
A3584			REVERSE SAMPLE FLOW THROUGH R15020	N/A	N/A	LAWRENCE				
A3585			INST PLTFORM FOR PINNING STRING HANG	N/A	N/A	LAWRENCE				
A3586			REPLACE SNUBBER ISW291.25-9A	N/A	N/A	STIVER				
A3587			ALLOW MANUAL CONTROL OF HV20001	N/A	DILTS	N/A				
A3589		062794	REMOVE RET BASIN ALARM FROM HZCHR-28	N/A	N/A	LINKHART				
A3600			PLACE TEST STAT PRIOR TO FIRE STAT 4	N/A	FIELD	N/A				
A3601			INCREASE SPENT FUEL CAPABILITIES	039	COX	N/A				
A3602		062782	REPLACE FV36030 AND 36543	N/A	N/A	WELLSFRY				1-1-84
A3602		062783	REPLACE FV36030 AND 36543	N/A	N/A	WELLSFRY				

NUMBR	WR	DESCRIPT	IODNO	GECOG	NUCOG	REG. REQ.	DATE	PRIORITY	COMET
A3614	065007	REMOVE CABLES IN2D01A/E & 122D201A	N/A	N/A	PHIPPS				
A3615	062798	INSTALL LOUD SPEAKER IN RET BASIN	N/A	N/A	PHIPPS				
A3618		CHANGE PCV74380 SET PT TO 5+/-P" I	N/A	N/A	CARMICHAEL				
A3620		INSTALL NEW PHOLYTHELENE TANK	N/A	N/A	WELLSFRY				
A3521		PROVIDE CONTAINMENT TEMP INDICATION	023	M ROSS	BROCK		Y		8-1-84
A3622		CHANGE TO AUX FW SYSTEM (FLOW)	001	TZOUROS	WICHERT	W.E.I.2.2.C	Y		1-1-83
A3626	063142	MODIFY DECON RM#134 & ULTRASON DECON	N/A	N/A	UHL				
A3626	063143	MODIFY DECON RM#134 & ULTRASON DECON	N/A	N/A	UHL				
A3628	066047	CK MOUNTING STUD RUNOUT FOR FILTERS	N/A	N/A	UHL				
A3630	056250	RAISE TOP OF ELEC MANHLS	N/A	JURKOVICH	N/A				
A3632	051370	INSTALL BRACKET IN FUEL TRANSF CANAL	N/A	N/A	WHITNEY				
A3632	051371	INSTALL BRACKET IN FUEL TRANSF CANAL	N/A	N/A	WHITNEY				
A3635	062761	RELOCATE PSH2200566 TO LOWER RAD ARE	N/A	FIELD	N/A				
A3635	062760	RELOCATE PSH2200566 TO LOWER RAD ARE	N/A	FIELD	N/A				
A3636		CHANGE DRAINS IN AUX FEED SYSTEM	N/A	N/A	WELLSFRY				
A3637	065670	MODIFY HZES FOR NCR S-2149	N/A	KELSO	N/A				
A3639		UPGRADE EXISTING MODCOMP (BK-UP) COM	007	WILLIAMS	FRASER	0737			1-1-83
A3640		NO INFORMATION YET	N/A	WILLIAMS	N/A				
A3642		TO ALLOW TEST OF BFPT CONTROL SYSTEM	N/A	N/A	CARMICHAEL				
A3646		CONSTRUCT WASTE STORAGE SHIELD	N/A	GILLIS	N/A				
A3650	062786	REMOVE AGASTAT RELAY	N/A	KNIERIEM	FRASER				
A3650	062787	REMOVE AGASTAT RELAY	N/A	KNIERIEM	FRASER				
A3651		UPGRADE IE EQUIPMENT FOR IE 79-01B	011	KNIERIEM	FRASER	79-01B	Y		1-1-83
A3652			011	KNIERIEM	FRASER				
A3653		MOD RX BLDG *B* SPRAY FOR IE 79-01B	011	THORPE	WICHERT				
A3654		MODIFY RCS CHANNEL B FOR IE 79-01B	011	KNIERIEM	FRASER				
A3655		MODIFY RCS CHANNEL B FOR IE 79-01B	011	KNIERIEM	N/A				

NUMBR	WR	DESCRIPT	DDNO	GECOG	NUCOG	REG. REQ.	OUTAGE	PRIORITY	SCHED.
A3656		MOD SEAL INJ & MAKEUP *A* FOR IE7901	011	THORPE	FRASER	79-01B	Y		1-1-83
A3657		MOD SEAL INJ & MAKEUP *B* FOR IE7901	011	KNIERIEM	N/A				
A3658		MOD NUC SERV WATER *A* FOR IE 79-01B	011	KNIERIEM	N/A				
A3659		MOD NUC SERV WATER *B* FOR IE 79-01B	011	KNIERIEM	N/A	Y	Y		
A3660		MODIFY FEEDWATER *A* FOR IE 79-01B	040	THORPE	FRASER				
A3661		MODIFY HVAC *A* FOR IE 79-01B	040	THORPE	FRASER				
A3662		MODIFY RAD WASTE *A* FOR IE 79-01B	040	THORPE	FRASER				
A3663		MODIFY CCW *A* FOR IE 79-01B	040	THORPE	FRASER				
A3664		EQUIPMENT FOR NEW DIESEL GENERATORS	N/A	APPEL	THOMAS				
A3667		CHANGE RADIATION MONITOR LVL IN HVAC	005	DILTS	N/A	II, F, I			1-1-83
A3671		INSTRUMENT ENCLOSURES	N/A	STEPHENSON	N/A				
A3672		ENCLOSURE TO PROTECT PT 26502	N/A	STEPHENSON	N/A				
A3673		ALARM FOR P318 WHEN FW PUMP TRIPPED	N/A	STEPHENSON	N/A				
A3683		NEW POST ACCIDENT RAD MONITOR SYSTEM	005	DILTS	CARMICHAEL	I, F, I			1-1-83
A3684	062591	NEW FLOW DRAIN TRAP - N2 LINE 743801	N/A	N/A	STIVER				
A3689		NO INFORMATION YET	N/A	RIGALADO	N/A				
A3691		REMOVE ABNORMAL TAGS 531/532	N/A	N/A	PHIPPS				
A3692	068224	MOD FOR L5LL46508/LSH446507/LSHL465	N/A	N/A	LOW				
A3696		NO INFORMATION YET	N/A	COJAYON	N/A				
A3697	063144	UPDATE SECURITY COMPUTER	N/A	CONKLIN	FRASER				
A3697	063145	UPDATE SECURITY COMPUTER	N/A	CONKLIN	FRASER				
A3698		ADD GATE VALVE & AUTO VAL TO AUX STE	053	FIELD	N/A	79-01B			1-1-83
A3700		NO INFORMATION YET	N/A	COJAYON	N/A				
A3708		INSTALL NEW WASTE COMPACTOR	N/A	N/A	FAUBLE				
A3710		ADD BACKUP PUMP	058	APPEL	WICHERT				
A3711		MOVE VARIOUS CABLES AND SHIELDS	N/A	N/A	CARMICHAEL				
A3724		RELOCATE FLOW ORIFICE	N/A	N/A	LOW				
A3725		CHGS TO FIRE DET SYS NSEP/DSL/GEN/AU	N/A	FIELD	N/A	0757			

NUMBR	WR	DESCRIPT	MODNO	GECOG	NUCOG	REG REQ.	OFFICE	PROPERTY	SCHED.
A3726	058098	DOM H2O & SEWER UNDERGROUND TO I & C	N/A	JURKOVICH	N/A				
A3728		REPLACE CABLE 112N 150F	N/A	N/A	SHEEHAN				
A3728		REPLACE CABLE 112N 150F	N/A	N/A	SHEEHAN				
A3729		RPL FUSE LINK DAMPER RELEASE DEVICE	N/A	N/A	FRASER				
A3732		REPLACE SWITCH FOR NCR S-1073	N/A	J JONES	SHEEHAN				
A3733		REPLACE SWITCH FOR NCR S-1073	N/A	J JONES	SHEEHAN				
A3734		REPLACE SWITCH FOR NCR S-1073	N/A	J JONES	SHEEHAN				
A3736		MODCOMP BACKUP COMPUTER EXPANSION	007	DILTS	FRASER	0737			1-1-82
A3739		COOL FOR PENETRAT IN MAI' STREAM LN	N/A	FIELD	N/A				
A3745		IMPROVE SEWAGE TREATMENT QUALITY	N/A	N/A	FAUBLE				
A3748		NO INFORMATION YET	N/A	BREGGAR	N/A				
A3749		WIRING TO ALLOW LOCAL TRIP RESET	N/A	N/A	PHIPPS				
A3753		INSTALL PUMP & TANK IN AUX STEAM SYS	N/A	ALVI	UHL				
A3759	062764	MOD 68901 HEG LINE FOR ACID ADD PT	N/A	N/A	PRICE				
A3760		ADD CARD READERS AT ASSEMBLY POINTS	N/A	ROGERS	BROCK				
A3761	063160	NEW PIPE FITTINGS FOR PSBL75804	N/A	N/A	STIVER				
A3762	063010	PERM PIPE FROM T689A/B TO D691	N/A	N/A	STIVER				
A3764		SONALERT ON RX BLDG HATCH	N/A	DILTS	BROCK				
A3768		RECEPTICLE IN ADMIN BUILDING LIBRARY	N/A	N/A	PHIPPS				
A3769		ADD CONTACT RAD MONITOR	005	DILTS	N/A				
A3770	062762	UPGRADE BORIC ACID FEED PUMPS	N/A	N/A	PRICE				
A3770	062763	UPGRADE BORIC ACID FEED PUMPS	N/A	N/A	PRICE				
A3773	063141	PLATFORM FOR COND PUMP MOTOR	N/A	N/A	WHITNEY				
A3774		INST ELECT OUTLET AT 40+ LV AUX BLDG	N/A	N/A	LINKHART				
A3777		FILTER FOR DECON ROOM SINK	N/A	N/A	KENEY				
A3778		UPGRADE RCP VIR MONITOR SYSTEM	N/A	N/A	LOW				
A3781		NEW PRESSURE TRANSMITTERS	N/A	TZOUROS	N/A				
A3782	063133	AUX BUILDING STACK FILTER HOLDER	N/A	N/A	THOMAS				

NUMBR	WR	DESCRIPT	MUDNO	GECOG	NUCOG	REG, FEQ	OUTAGE	PRIORITY	SCHED.
A3785	068225	INST MON SYS FOR STM COIL TUBE FAIL	N/A	N/A	FRASER				
A3785	068285	INST MON SYS FOR STM COIL TUBE FAIL	N/A	N/A	FRASER				
A3790		COMBINE COMPUTER SYS FOR HP FUNCTION	N/A	L CONKLIN	N/A				
A3792		EMERGENCY OPERATIONS FACILITY	004	DEGUCHI	FRASER	III, A, 1, 2			1-1-83
A3795		RPL MAKEUP PUMP LUBE OIL COOL/E-237B	N/A	N/A	R THOMAS				
A3795A		REPLACE E-237B	N/A	N/A	R THOMAS				
A3795E		ADD DIFF PRESS INSTRU TO E-273A	N/A	N/A	R THOMAS				
A3795C		REPLACE E-239C	N/A	N/A	R THOMAS				
A3795E		ADD DIFF PRESS INSTRU TO E-239A	N/A	N/A	R THOMAS				
A3795E		REPLACE E-239D	N/A	N/A	R THOMAS				
A3795F		ADD DIFF PRESS INSTRU TO E-239B	N/A	N/A	R THOMAS				
A3796		ADD SHOWER IN CHEM RAD LAB	N/A	N/A	S WELLSFRY				
A3799		DISCONNECT LOW ALARM SYSTEM	N/A	N/A	R FRASER				
A3806		SPEAKERS FOR SPRAY PONDS FOR EVAC	N/A	N/A	LINKHART				
A3808	062797	REMOVE WIRES FROM HVS DRY CLEANER	N/A	N/A	SHEEHAN				
A3809		ANNUNCIATE POWER LOSS OF HZES WINDOW	N/A	N/A	SHEEHAN				
A3810		AMENDMENT 9 SECURITY CHANGES	N/A	B DILTS	BROCK				
A3810E		REMOVE DEFENSIVE PORTIONS PER AMED	N/A	B DILTS	BROCK				
A3810C		CONTROL ACCESS TO POWER BLOCK	N/A	B DILTS	BROCK				
A3818	063002	ADD ENCL WASTE RELIEF VL TO PSV99607	N/A	FIELD	WICHERT				
A3819		FIRE PROTECTION WATER SYSTEM	N/A	FIELD	WICHERT				
A3822		INST NFW H2O SYS IN SECONDARY LAB	N/A	N/A	KENEY				
A3830	063008	REROUT OF CO2 FIRE PROTECT SP CABLES	N/A	N/A	PHIPPS				
A3834		REMOUNT RELAYS - EGS	N/A	N/A	SHEEHAN				
A3835		INSTALL PA IN CAS	N/A	N/A	PHIPPS				
A3840		INSTALL PHONE IN AUX BLDG TOOL ROOM	N/A	N/A	LINKHART				
A3841		PULL CABLES PER NU REG 0660, 0737	N/A	J JONES	FRASER	0737			
A3842		FUEL INSPECTION PIT	N/A	N/A	KENEY				



NUMBR	WR	DESCRIPT	MODNO	GECDG	NUCDG	REQ. REQ	OUTAGE	PRIORITY	DATE
A3846		ADD TWO STANDBY DIESEL GENERATORS		J FIELD	R THOMAS	0737			7-1-84
A3846A		ENGINE/AUX SKID INSTALLATION		J FIELD	R THOMAS				
A3846E		AIR STARTING SYSTEM		J FIELD	R THOMAS				
A3846C		INTAKE & EXHAUST AIR SYSTEMS		J FIELD	R THOMAS				
A3846E		COOLING SYSTEM		J FIELD	R THOMAS				
A3347		REMOVAL OF CAMERA ON FH BRIDGE	N/A	N/A	KENEY				
A3851		ANNUNCIATOR H2ES WINDOWS 7 & 24	N/A	N/A	LINKHART				
A3852		CABLE TRAYS IN FIRE ZONE	N/A	P KELSO	F SHEEHAN				
A3853	063139	GAUGE INSTALLATION TO CLEAR TAGS	N/A	N/A	R LOW				
A3853	063140	GAUGE INSTALLATION TO CLEAR TAGS	N/A	N/A	R LOW				
A3854		INSTALL TRAY 743B5	N/A	R WHITE	SHEEHAN				
A3865		INST HI/LO SWITCH IN CONDEN DRAIN TK	N/A	N/A	R LOW				
A3867		EMERGENCY LIGHT FOR N5EB	N/A	K HARTLEY	LINKHART	0737			1-1-83
A3868		CHANGE LOAD SETT ON OUTSIDE WAREHSE	N/A	N/A	LINKHART				
A3869	063003	REPLACE FLOW TRANSMITTERS	N/A	N/A	R LOW				
A3869	063004	REPLACE FLOW TRANSMITTERS	N/A	N/A	R LOW				
A3871		AS BUILT DOC FOR CONTAINMENT RAD MON	N/A	N/A	R THOMAS				
A3872		FENCE LAYDOWN AREA AT OFFSITE WAREHS	N/A	S BOENZI	WICHERT				
A3881		ALARM CIRCUITS FOR DIESEL GENERATOR	N/A	N/A	F SHEEHAN				
A3881A		ALARM CIRCUITS FOR DIESEL GENERATORS	N/A	N/A	F SHEEHAN				
A3883		CHANGE TRIP SET ON SWITCHYARD FEEDER	N/A	N/A	LINKHART				
A3886		REPLACE FLOW SENSORS IN RCP	N/A	N/A	R LOW				
A3888	063176	ADD DOM H2O PIPING TO EMFAC EYEW STA	N/A	G SELGER	WELLSFRY				
A3889		PROV HARDWARE TO SUPPORT SEAL RING	046	R DEGUCHI	MEYERS				1-1-83
A3892		ADDITIONAL PIPING FOR SSW	N/A	FIELD	LAWRENCE				
A3893		REPLACE PERIM UNDERGRND LIGHTNG CABL	N/A	KELSO	LINKHART				
A3893		REPLACE PERIM UNDERGRND LIGHTNG CABL	N/A	KELSO	LINKHART				
A3893A		REPAIR PERIM UNDERGRND LIGHTING CABL	N/A	KELSO	LINKHART				



NUMBR	WR	DESCRIPT	MODNO	GECOG	NUCOG	FEED REQ	DTAGE	PRIORITY	SCHED.
A3894		INSTALL PHONE CABLE TO L & D	N/A	N/A	LINKHART				
A3897		REPLACE THERMOCOUPLE IN RX CONTAINME	N/A	ROBERTS	FRASER				
A389E		CHANGE TOP ON TRANSFORMER	N/A	N/A	LINKHART				
A389S		MOD PLANT CCTV	N/A	N/A	PHIPPS				
A390C		UPGRADE FEED PUMPS	N/A	N/A	PRICE				
A390I		DOCUMENT INSTALL. OF DESABLE SWITCHE	N/A	N/A	LINKHART				
A3904		RELOCATE RCS CHANNEL TRANSMITTER	N/A	TZOURDS	CARMICHAEL				
A3906		REPLCE TEMP SWITCH IN AUX LUBE OIL C	N/A	N/A	LOW				
A3907		REQUIREMENTS FOR NUREG 0696 (SFD3)	060	PROSCH	FRASER	0676			
A3908		FLOW PATH FOR DTSG	N/A	N/A	COLEMAN				
A3911		NUREG 0612 - SPT FUEL POOL GATE	017	HANSON	WICHERT	0612			
A3912	063137	REPLACE METEOROLOGICAL TOWER CABLE	N/A	DILTS	SHEEHAN				
A3913		MODIFY INCORE JIB CRANE	065	APPEL	STIVER	0612			1-1-80
A3915		DISCONNECT AUTO SYNC PUSHBUTTON	N/A	N/A	SHEEHAN				
A3917		ADD PIPING FOR HYDROGEN RECOMBINER	N/A	HANSEN	THOMAS	50,44			1-1-80
A3918		REPLACE MULTIPLEXER SYSTEM	N/A	N/A	LOW				
A391S		ELECT WORK FOR AUX STEAM REDUC STATI	N/A	TZOUROZ	LOW				
A392C		CHGS REQRD BY NUREG0660 FOR TSC	052	FIELD	THOMAS	JUL.D.3.4.2	Y		7-1-87
A392I		INSTALL MONITORS TO Y-933	N/A	N/A	LOW				
A392J		INSTALL VENT TIME ON SUMP CONTROL SW	N/A	N/A	CARMICHAEL				
A392E	063182	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				
A392E	063183	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				
A392E	063184	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				
A392E	063185	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				
A392E	063186	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				
A392E	063187	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				
A392E	063188	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				
A392E	063189	REPLACE MAIN FEED PUMP DISCH SWITCHE	N/A	N/A	LOW				

NUMBR	WR	DESCRIPT	MODNO	GECOG	NUCOG	REG. REQ.	OUTAGE	PRIORITY	SCHED.
A3929		FLOW PATH FOR MAIN STEAM LINE	N/A	N/A	COLEMAN				
A3930		INSTALL TELEPHONE NEAR FEEDWATER VAL	N/A	N/A	LINKHART				
A3936		ADD RELAY TO H28 ANUN PANEL	N/A	N/A	CARMICHAEL				
A3938		MODIFY CONTROLS FOR AUX STEAM SUP	N/A	N/A	LOW				
A3938		MODIFY CONTROLS FOR AUX STEAM SUP	N/A	N/A	LOW				
A3942		ADD AUX RELAY TO ICS GENERATOR	N/A	N/A	LOW				
A3946		RELCTE POLSH AMON TNK & ACID DAY TNK	N/A	N/A	STIVER				
A3947		ADD VARIABLE SPEED CHART	N/A	N/A	RAINEY				
A3948		CONTROL ROOM CONSOLES AND PANELS	008	ROSS	N/A	0737	Y		1-1-83
A3948A		ADD NEW COMPTX DRIVEN TREND RECOR	007	ROSS	N/A				
A3948B		ADD PNLS FOR DIESEL GEN. & ELECT DIS	008	ROSS	N/A				
A3948C		DELETE AUX BOILR & AUX STM CONTROLS	007	ROSS	N/A				
A3948D		ADD SPDS/ATOG KEYBOARD TO CR CONSOLE	008	ROSS	N/A				
A3948E		CONTROL RM VRTCL PANEL H2SF CHNL A	008	ROSS	N/A				
A3948F		CONTROL RM VRTCL PANEL H2SF CHNL B	008	ROSS	N/A				
A3948G		RELOCATION OF LOG TYPER IN CNTRL RM	008	ROSS	N/A				
A3948H		CONTROL RM CONSOLE ADD KEYBOARD	008	ROSS	N/A				
A3948I		RELOCATE TV MONITOR	008	ROSS	N/A	7	Y		
A3951		INSTALL TELEPHONE EXT IN DEMIN SHACK	N/A	N/A	LINKHART				
A3952		REPLCE THERMAL SLEEVE ON COLD LEG A	N/A	N/A	UHL				
A3965		INSTALL TEST JACKET ON METERO STATID	N/A	N/A	LOW				
A3966		ADD DEWPOINT MEASURES TO BAILEY-855	N/A	N/A	LOW				
A3967		INSTALL CHLORINE ANALYZER FOR CLG TW	N/A	N/A	CARMICHAEL				
A3968		INSTL PRES INDCTR ON SG DRN BOSTR PM	N/A	N/A	LOW				
A3971		REPLACE THERMAL SLEEVE ON COLD LEG B	N/A	N/A	UHL				
A3976		RELOCATE PIPING IN NEW DIESEL GEN RD	N/A	FIELD	WICHERT				
A3977		ADD TEMP INDICATOR IN AIR EJECTOR	N/A	N/A	LOW				
A3981		INSTL PHONE CBLES FOR OFSTE WAREHSE	N/A	KELSO	LINKHART				

NUMBR	DESCRIPT	MODNO	GECOG	NUCOG	REG. PER.	OUTAGE	REMARKS	DATE
A3984	NO INFORMATION	N/A	N/A	WELLSFRY				
A3988	RCS CONNECT TEST EQUIP FOR CALIBRATN	N/A	N/A	LDW				
A3989	INSTL PIPING & SUPPORT FOR PLNT UPGR	N/A	TZOURDS	N/A	0737	Y		1-1-83
A3990	INSTL PHONE KEY SYSTEM IN ADMIN	N/A	N/A	LINKHART				