

Docket 70-1100
License SNM-1067
Amendment 30

JAN 25 1994

Mr. Robert E. Sheeran, Facilities Manager
Windsor Nuclear Fuel Manufacturing
Combustion Engineering, Inc.
1000 Prospect Hill Road
Windsor, Connecticut 06095-0500

Dear Mr. Sheeran:

SUBJECT: EXEMPTION TO 10 CFR 70.24 (A)(1) (TAC NO. L30636)

In accordance with your application dated January 7, 1994, and pursuant to Part 70 to Title 10 of the Code of Federal Regulations, Materials License SNM-1067 is hereby amended to exempt Buildings 6, 17, and 21 from the requirements of 10 CFR 70.24(a)(1) for criticality detection. Accordingly, Condition S-1 has been revised to include the date of January 7, 1994.

In accordance with your application dated January 7, 1994, and pursuant to part 70 to Title 10 of the Code of Federal Regulations, Materials License SNM-1067 is hereby amended to exempt Buildings 6, 17 and 21 from the requirements of 10 CFR 70.24(a)(1) for criticality detection. Accordingly, Condition S-1 has been revised to include the date of January 7, 1994.

All other conditions of your license shall remain the same.

Enclosed is a copy of the revised Materials License SNM-1067 and the Safety Evaluation Report, which includes the Categorical Exclusion determination.

Sincerely,

Original Signed By
Elizabeth Q. TenEyck, Deputy Director
Division of Fuel Cycle Safety
and Safeguards, NMSS

Enclosures:

- 1. Materials License SNM-1067
- 2. Safety Evaluation Report

cc w/encls:

Mr. J. F. Conant, Manager
Nuclear Materials Licensing

010010

Distribution: w/encls. (Control No. 6A0S)

Docket No. 70-1100 PDR NRC File Center HZibulsky, FRIB
NMSS R/F FCSS R/F FCLS2 R/F
FCLB R/F JRoth, FCOB Region I
JNoggle, RI SHO MMessier, LFDCB

OFC	FCLB	<i>pk</i>	FCLB	<i>EE</i>	FCLB	<i>EZ</i>	FCLB	<i>K1</i>
NAME	SSoong	<i>SS</i>	VTharpe		MAdams		MK1	<i>ky</i>
DATE	1/21/94		1/21/94		1/24/94		1/23/94	
OFC	FCLB	<i>E</i>	FCLB		DD:FCSS			
NAME	MPokar		RPierson		ETenEyck			
DATE	1/24/94		1/24/94		1/25/94			

9402070059 940125
PDR ADOCK 07001100
PDR
C

NFB
1/11