



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-361

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 109
License No. NPF-10

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern California Edison Company, et al. (SCE or the licensee) dated November 25, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-10 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 109, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 1, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 109 TO FACILITY OPERATING LICENSE NO. NPF-10

DOCKET NO. 50-361

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by the captioned amendment number and contains marginal lines indicating the areas of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 7-28

INSERT

3/4 7-28

PLANT SYSTEMSSURVEILLANCE REQUIREMENTS

4.7.8.1.1 The fire suppression water system shall be demonstrated OPERABLE:

- a. At least once per 7 days by verifying the contained water supply volume.
- b. At least once per 31 days on a STAGGERED TEST BASIS by starting each electric motor driven pump and operating it for at least 15 minutes on recirculation flow.
- c. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path is in its correct position.
- d. At least once per 12 months by cycling each testable valve in the flow path through at least one complete cycle of full travel.
- e. At least once per 18 months by performing a system functional test which includes simulated automatic actuation of the system throughout its operating sequence, and:
 1. Verifying performance of the fire pumps as follows:
 - a. Diesel engine drive pump develops at least 2500 gpm at a system head of 283 feet.
 - b. Electric motor driven pumps each develop at least 1500 gpm at a system head of 289 ft.
 2. Cycling each valve in the flow path that is not testable during plant operation through at least one complete cycle of full travel,* and
 3. Verifying that each fire suppression pump starts (sequentially) to maintain the fire suppression water system pressure greater than or equal to 95 psig.
- f. At least once per 3 years by performance of a system flush.

*Refueling interval for those plant areas that are inaccessible during non-refueling operations.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 98
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern California Edison Company, et al. (SCE or the licensee) dated November 25, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-15 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 98, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and must be fully implemented no later than 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Theodore R. Quay
Theodore R. Quay, Director
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 1, 1994

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 98 TO FACILITY OPERATING LICENSE NO. NPF-15

DOCKET NO. 50-362

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by the captioned amendment number and contains marginal lines indicating the areas of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 7-28

INSERT

3/4 7-28

PLANT SYSTEMS

3/4.7.8 FIRE SUPPRESSION SYSTEMS

FIRE SUPPRESSION WATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.8.1 The fire suppression water system shall be OPERABLE with:

- a. Two electric motor-driven fire pumps, each with a capacity of 1500 gpm and one diesel-driven fire pump with a capacity of 2500 gpm, with their discharge aligned to the fire suppression header,
- b. Two separate water supplies, each with a minimum contained volume of 300,000 gallons, and
- c. An OPERABLE flow path capable of taking suction from each water supply and transferring the water through distribution piping with OPERABLE sectionalizing control or isolation valves to the yard hydrant curb valves, the first valve upstream of the water flow alarm device on each spray and/or sprinkler or fire hose station required to be OPERABLE per Specifications 3.7.8.2 and 3.7.8.3.

APPLICABILITY: At all times.

ACTION:

- a. With one required electric motor-driven/diesel-driven pump and/or one water supply inoperable, restore the inoperable equipment to OPERABLE status within 7 days or provide an alternate backup pump or supply. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.
- b. With the fire suppression water system otherwise inoperable, establish a backup fire suppression water system within 24 hours.

SURVEILLANCE REQUIREMENTS

4.7.8.1.1 The fire suppression water system shall be demonstrated OPERABLE:

- a. At least once per 7 days by verifying the contained water supply volume.
- b. At least once per 31 days on a STAGGERED TEST BASIS by starting each electric motor-driven pump and operating it for at least 15 minutes on recirculation flow.
- c. At least once per 31 days by verifying that each valve (manual, power-operated or automatic) in the flow path is in its correct position.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- d. At least once per 12 months by cycling each testable valve in the flow path through at least one complete cycle of full travel.
 - e. At least once per 18 months by performing a system functional test which includes simulated automatic actuation of the system throughout its operating sequence, and:
 - 1. Verifying performance of the fire pumps as follows:
 - a. Diesel engine-driven pump develops at least 2500 gpm at a system head of 283 feet.
 - b. Electric motor-driven pumps each develop at least 1500 gpm at a system head of 289 ft.
 - 2. Cycling each valve in the flow path that is not testable during plant operation through at least one complete cycle of full travel,* and
 - 3. Verifying that each fire suppression pump starts (sequentially) to maintain the fire suppression water system pressure greater than or equal to 95 psig.
 - f. At least once per 3 years by performance of a system flush.
 - g. At least once per 3 years by performing a flow test of the system in accordance with Chapter 5, Section 11 of the Fire Protection Handbook, 14th Edition, published by the National Fire Protection Association.
- 4.7.8.1.2 The fire pump diesel engine shall be demonstrated OPERABLE:
- a. At least once per 31 days by verifying:
 - 1. The diesel fuel oil day storage tank contains at least 225 gallons of fuel, and
 - 2. The diesel starts from ambient conditions and operates for at least 30 minutes on recirculation flow.
 - b. At least once per 92 days by verifying that a sample of diesel fuel from the fuel storage tank, obtained in accordance with ASTM-D270-1975, is within the acceptable limits specified in Table 1 of ASTM D975-1977 when checked for viscosity, water and sediment.
 - c. At least once per 18 months by subjecting the diesel to an inspection in accordance with procedures prepared in conjunction with its manufacturer's recommendations for the class of service.

**Refueling interval for those plant areas that are inaccessible during non-refueling operations.