

| WORK & JOB FUNCTION | NUMBER OF PERSONNEL (>100 nrem) | | | TOTAL MAN-REM | | |
|--|---------------------------------|-------------------|-----------------------------|-------------------|-------------------|-----------------------------|
| | STATION EMPLOYEES | UTILITY EMPLOYEES | CONTRACT WORKERS AND OTHERS | STATION EMPLOYEES | UTILITY EMPLOYEES | CONTRACT WORKERS AND OTHERS |
| <u>REACTOR OPERATIONS AND SURVEILLANCE</u> | | | | | | |
| OPERATING PERSONNEL | 47 | 0 | 2 | 36.804 | 0 | .043 |
| HEALTH PHYSICS PERSONNEL | 21 | 0 | 32 | 10.062 | 0 | 5.058 |
| SUPERVISORY & ENGR. PERSONNEL | 25 | 15 | 48 | 4.838 | .766 | 4.872 |
| INSTRUMENT & CONTROLS PERSONNEL | 10 | 1 | 0 | 4.621 | .114 | 0 |
| SECURITY PERSONNEL | 0 | 0 | 0 | 0 | 0 | 0 |
| MAINTENANCE PERSONNEL | 42 | 41 | 246 | 11.799 | 1.697 | 19.058 |
| <u>ROUTINE MAINTENANCE</u> | | | | | | |
| OPERATING PERSONNEL | 32 | 0 | 0 | 1.751 | 0 | 0 |
| HEALTH PHYSIC PERSONNEL | 10 | 0 | 13 | .415 | 0 | 1.330 |
| SUPERVISORY & ENGR. PERSONNEL | 21 | 13 | 49 | 1.705 | .565 | 3.544 |
| INSTRUMENT & CONTROLS PERSONNEL | 9 | 0 | 0 | 1.222 | 0 | 0 |
| MAINTENANCE PERSONNEL | 50 | 107 | 393 | 18.223 | 12.121 | 50.503 |
| <u>*SPECIAL MAINTENANCE</u> | | | | | | |
| OPERATING PERSONNEL | 44 | 0 | 0 | 22.613 | 0 | 0 |
| HEALTH PHYSIC PERSONNEL | 21 | 0 | 38 | 3.881 | 0 | 26.965 |
| SUPERVISORY & ENGR. PERSONNEL | 22 | 24 | 110 | 7.514 | 10.948 | 89.295 |
| INSTRUMENT & CONTROLS PERSONNEL | 10 | 0 | 0 | 4.981 | 0 | 0 |
| MAINTENANCE PERSONNEL | 45 | 110 | 605 | 20.209 | 49.508 | 521.463 |
| <u>1-1 WASTE PROCESSING</u> | | | | | | |
| OPERATING PERSONNEL | 27 | 0 | 2 | 2.558 | 0 | 2.285 |
| HEALTH PHYSICS PERSONNEL | 9 | 0 | 1 | 1.023 | 0 | .045 |
| SUPERVISORY & ENGR. PERSONNEL | 2 | 0 | 3 | .014 | 0 | .102 |
| MAINTENANCE PERSONNEL | 23 | 0 | 5 | 1.005 | 0 | .524 |
| <u>REFUELING</u> | | | | | | |
| OPERATING PERSONNEL | 45 | 0 | 0 | 4.516 | 0 | 0 |
| HEALTH PHYSICS PERSONNEL | 0 | 0 | 2 | 0 | 0 | .503 |
| SUPERVISORY & ENGR. PERSONNEL | 5 | 1 | 19 | .334 | .109 | 4.881 |
| INSTRUMENT & CONTROLS PERSONNEL | 1 | 0 | 0 | .009 | 0 | 0 |
| MAINTENANCE PERSONNEL | 21 | 33 | 11 | 1.142 | 1.740 | .690 |
| <u>INSERVICE INSPECTION</u> | | | | | | |
| SUPERVISORY & ENGR. PERSONNEL | 8 | 4 | 18 | .125 | 3.507 | 13.222 |
| MAINTENANCE PERSONNEL | 10 | 16 | 18 | .804 | 1.254 | 2.556 |
| <u>**TOTAL</u> | | | | | | |
| OPERATING PERSONNEL | 195 | 0 | 4 | 68.242 | 0 | 2.323 |
| HEALTH PHYSICS PERSONNEL | 61 | 0 | 86 | 15.381 | 0 | 33.901 |
| SUPERVISORY & ENGR. PERSONNEL | 83 | 57 | 244 | 14.530 | 15.895 | 115.916 |
| INSTRUMENT & CONTROLS PERSONNEL | 30 | 1 | 0 | 10.833 | .114 | 0 |
| SECURITY PERSONNEL | 0 | 0 | 0 | 0 | 0 | 0 |
| MAINTENANCE PERSONNEL | 191 | 307 | 1278 | 53.182 | 66.320 | 594.794 |
| GRAND TOTAL: | 560 | 365 | 1615 | 162.168 | 82.329 | 746.939 |

8208270648 820713
 PDR FOIA
 UDELL82-285 PDR

*DESCRIPTION: 1. Maintenance performed in Primary Containment during plant shutdown.

2. Fire Penetration Upgrade.

3. Torus Modification.

4. Feedwater Sparger Modification

991

**INDIVIDUALS MAY BE LISTED UNDER MORE THAN ONE WORK AND JOB FUNCTION.

5. Core Spray Pipe Modification

6. Reactor Cell Hx. Leak