

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

M S G G S I ② 0 0 - 0 0 0 0 0 - 0 0 ③ 4 1 1 1 1 ④ _____ ⑤
 7 8 9 14 15 25 26 57 58

CON'T
 L ⑥ 0 5 0 0 0 4 1 6 ⑦ 0 7 2 5 8 2 ⑧ 0 8 2 3 8 2 ⑨
 7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

On July 25 the smoke detector above the steam tunnel area zone 2-08,
 alarmed where no fire existed and would not reset. The smoke detector
 was declared inoperable and an hourly fire watch was established as
 required by T.S.3.3.7.9. The event is being reported pursuant to T.S.6.9.1.13.b.

A B ⑪ X ⑫ Z ⑬ I N S T R U ⑭ E ⑮ Z ⑯
 7 8 9 10 11 12 13 18 19 20

⑰ LER/RO REPORT NUMBER _____
 EVENT YEAR ⑱ 8 2 _____
 SEQUENTIAL REPORT NO. _____
 OCCURRENCE CODE _____
 REPORT TYPE _____
 REVISION NO. _____

ACTION TAKEN _____ FUTURE ACTION _____ EFFECT ON PLANT _____ SHUTDOWN METHOD _____ HOURS ⑳ 0 0 0 0 _____
 ATTACHMENT SUBMITTED _____ NPRD-4 FORM SUB. _____ PRIME COMP. SUPPLIER _____ COMPONENT MANUFACTURER _____
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉑

upon inspection on July 27 the manual pull station was found initiated.
 The system was restored at 1930 and the hourly fire watch discontinued.
 This is considered a final report.

H ㉒ 0 0 0 ㉓ NA ㉔ A ㉕ Audio and Visual Alarm
 7 8 9 10 12 13 44 45 46 80

Z ㉖ Z ㉗ NA _____ LOCATION OF RELEASE ㉘ _____
 7 8 9 10 11 44 45 80

0 0 0 ㉙ Z ㉚ NA _____
 7 8 9 11 12 13 80

0 0 0 ㉛ _____ NA _____
 7 8 9 11 12 80

Z ㉜ _____ NA _____
 7 8 9 10 80

N ㉝ _____ NA _____
 7 8 9 10 80

8208300107 820823
 PDR ADOCK 05000416
 S PDR

NRC USE ONLY

 68 69 80

ORIGINAL SIGNED BY: RON BYRD
 NAME OF PREPARER _____

PHONE: _____