

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | A | Y | K | R | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
 0 1 | R | E | P | O | R | T | S | O | U | R | C | E | L | 6 | 0 | 5 | 0 | 0 | 0 | 0 | 2 | 9 | 7 | 0 | 6 | 0 | 4 | 8 | 2 | 8 | 0 | 7 | 0 | 2 | 8 | 2 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation in Mode 1 the indicating lights for SI-MOV-517 w
 0 3 | ere found off. Investigation by Maintenance personnel determined the bre
 0 4 | aker was open. The breaker was open from approximately 1200 to 1330. T.S
 0 5 | . 4.5.2.b.5 requires power to the valve operator be available. Valve SI-
 0 6 | MOV-516, installed in parallel with SI-MOV-517, was available and energi
 0 7 | zed in accordance with T.S. 4.5.2.b.5; therefore there were no adverse e
 0 8 | ffects to the public health or safety.

0 9 | S | F | 11 | A | 12 | E | 13 | C | K | T | B | R | K | 14 | A | 15 | Z | 16
7 8 9 10 11 12 13 18 19 20

17 | L | E | T | T | E | R | / | R | O | R | E | P | O | R | T | N | U | M | B | E | R | 8 | 2 | 21 22 | - | 23 | 0 | 1 | 1 | 5 | 24 26 | / | 27 | 0 | 3 | 28 29 | L | 30 | - | 31 | 0 | 32

ACTION TAKEN (18) | FUTURE ACTION (19) | EFFECT ON PLANT (20) | SHUTDOWN METHOD (21) | HOURS (22) | ATTACHMENT SUBMITTED (23) | NPRD-4 FORM SUB. (24) | PRIME COMP. SUPPLIER (25) | COMPONENT MANUFACTURER (26)
 X | Z | Z | Z | 0000 | N | N | L | W | 1 | 1 | 2 | 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this event has not been determined. No problem was found w
 1 1 | ith the breaker. Construction work was in progress in the area so it is
 1 2 | assumed the breaker was accidentally knocked open. The breaker was closed
 1 3 | and the lights and breaker satisfactorily tested. To prevent recurrence
 1 4 | personnel were reinstructed in precautions to take when working in area.

1 5 | E | 28 | 1 | 0 | 0 | 0 | 29 | NA | 30 | A | 31 | Operator Observation | 32
7 8 9 10 12 13 44 45 46 80

1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 44 45 80

1 7 | 0 | 0 | 0 | 37 | NA | 38 | NA | 39
7 8 9 11 12 13 80

1 8 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 11 12 80

1 9 | Z | 42 | NA | 43
7 8 9 10 80

2 0 | N | 44 | NA | 45
7 8 9 10 80

820713027B 820702
 PDR ADOCK 05000029
 S PDR

NRC USE ONLY

68 69 80

NAME OF PREPARER L. D. French PHONE (413) 625-6140