

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NYIP S 2 00 - 000000 - 00 41111 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

01 L 05000247 7 053082 8 062982 9
7 8 REPORT SOURCE 60 61 DOCKET NUMBER 63 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

07 During routine start-up conditions, one of the No. 21 Steam Generator
03 Level Indicators slowly drifted upscale. The associated bi-stables of
04 the reactor protection system input were placed in the trip condition
05 in accordance with T.S.3.5. thus fully meeting the instrument's
06 required safety functions. The health and safety of the public were
07 unaffected by this event.

09 I A 11 E 12 A 13 I N S T R U 14 T 15 Z 16
7 8 SYSTEM CODE 9 10 CAUSE CODE 11 12 CAUSE SUBCODE 13 14 COMPONENT CODE 15 16 COMP. SUBCODE 17 18 VALVE SUBCODE 19 20

17 LER/RO REPORT NUMBER 82 025 03 L 0
21 22 23 24 25 26 27 28 29 30 31 32
18 X 19 C 20 Z 21 Z 22 0000 N 23 N 24 N 25 E 18 0
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
ACTION TAKEN 33 FUTURE ACTION 34 EFFECT ON PLANT 35 SHUTDOWN METHOD 36 HOURS 37 ATTACHMENT SUBMITTED 38 NPPD-4 FORM SUB. 39 PRIME COMP. SUPPLIER 40 COMPONENT MANUFACTURER 41

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Level indicator drifted upscale due to transmitter failure. Repair and
11 further investigation must await a plant shutdown. Until then the
12 bi-stables will remain tripped as discussed above. Instrument
13 data: Foxboro Co. Level transmitter 417C.

15 C 040 NA A Control Room Instrumentation
7 8 9 FACILITY STATUS 10 11 % POWER 12 13 OTHER STATUS 30 44 45 METHOD OF DISCOVERY 31 46 47 DISCOVERY DESCRIPTION 32 80

16 Z Z NA NA NA
7 8 9 ACTIVITY CONTENT 10 11 RELEASED OF RELEASE 12 13 AMOUNT OF ACTIVITY 35 44 45 LOCATION OF RELEASE 36 80

17 000 Z NA
7 8 9 PERSONNEL EXPOSURES 10 11 NUMBER 12 13 TYPE 14 15 DESCRIPTION 30 80

18 000 NA S
7 8 9 PERSONNEL INJURIES 10 11 NUMBER 12 13 DESCRIPTION 41 80

19 Z NA
7 8 9 LOSS OF OIL DAMAGE TO FACILITY 10 11 TYPE 12 13 DESCRIPTION 43 80

20 N NA
7 8 9 PUBLICITY 10 11 ISSUED 12 13 DESCRIPTION 35 80
8207130303 820629
PDR ADDCK 05000247
PDR