

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I | A | D | A | C | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
01 | L | 6 | 0 | 1 | 5 | 0 | 1 | 0 | 0 | 3 | 3 | 1 | 7 | 0 | 6 | 1 | 1 | 0 | 8 | 2 | 9 | 0 | 1 | 7 | 1 | 0 | 6 | 8 | 2 | 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 | During cold shutdown while performing surveillance testing, suppression
03 | chamber to drywell vacuum breaker valve CV-4327D was opened and failed t
04 | o close completely. Since the reactor was already in cold shutdown, the
05 | requirements of Technical Specification 3.7.A.4 were already met. There
06 | have been two previous similar occurrences. (See RO 81-21 and 82-25).
07 |
08 |

09 | SYSTEM CODE: S A 11 | CAUSE CODE: E 12 | CAUSE SUBCODE: B 13 | COMPONENT CODE: V A L V I O P 14 | COMP SUBCODE: D 15 | VALVE SUBCODE: 7 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 | LER/RO REPORT NUMBER: 8 2 21 | SEQUENTIAL REPORT NO.: 0 3 8 24 | OCCURRENCE CODE: 0 3 28 | REPORT TYPE: L 30 | REVISION NO.: 0 32
18 | ACTION TAKEN: B 18 | FUTURE ACTION: Z 19 | EFFECT ON PLANT: Z 20 | SHUTDOWN METHOD: Z 21 | HOURS: 0 0 0 0 22 | ATTACHMENT SUBMITTED: N 23 | NPRO-4 FORM 308: N 24 | PRIME COMP. SUPPLIER: A 25 | COMPONENT MANUFACTURER: G 1 1 2 26
21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 | Valve failed because pneumatic cylinder was stuck in mid-position due to
11 | crud accumulation. Pneumatic operator disassembled, cleaned, and lubed.
12 | New o-rings, seals, gaskets installed. Valve op. tested sat. Valve is Ge
13 | neral Precision Systems model LS-240-208. Valves CV-4327 B to H rebuilt.
14 | Pneumatic operators to be added to preventive maintenance schedule.

15 | FACILITY STATUS: Z 28 | % POWER: 0 0 0 0 29 | OTHER STATUS: NA 30 | METHOD OF DISCOVERY: B 31 | DISCOVERY DESCRIPTION: Surveillance Test 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

16 | ACTIVITY CONTENT RELEASED OF RELEASE: Z 33 | AMOUNT OF ACTIVITY: NA 34 | LOCATION OF RELEASE: NA 35
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

17 | PERSONNEL EXPOSURES NUMBER: 0 0 0 37 | TYPE: Z 38 | DESCRIPTION: NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

14 | PERSONNEL INJURIES NUMBER: 0 0 0 40 | DESCRIPTION: NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z 42 | DESCRIPTION: NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

20 | PUBLICITY ISSUED DESCRIPTION: N 44 | DESCRIPTION: NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
ISSUED DESCRIPTION: 8207130304 820706 PDR ADOCK 05000331 S PDR
NAME OF PREPARER: Kimuel L. Hill
PHONE: 319-851-5611
NRC USE ONLY