LICENSEE EVENT REPORT

	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	M TIB R P1 200 0 -0 0 0 0 - 0 0 3 4 11 11 0 5 57 CAT 58
O 1	SOURCE L 6 0 5 0 - 0 1 5 5 7 0 8 0 1 8 2 8 0 8 1 9 8 2 6 6 8 EVENT DATE 74 75 REPORT DATE 80
0 2	During a monthly test operation of a back-up core spray valve (MO7071), the
03	valve opening stroke was found to be about one-half of the normal full
04	stroke, but still adequate for core cooling requirements. The valve was
0 6	made inoperable to make repairs during a 1 hour period on 8/1/82 and a
06	125 hour period for vendor inspection on 8/9/82. The primary core spray
0 7	system was operable and no hazard to the public occurred. Reportable
08	based on T.S. 6.9.2.b(2).
0 9	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBCODE SUBCODE SUBCODE SUBCODE SUBCODE SUBCODE
7 8	SEQUENTIAL OCCURRENCE REPORT REVISION
	TO REPORT NUMBER 21 22 23 23 CODE TYPE NO.
	ACTION PUTURE EFFECT SHUTDOWN HOURS (22) ATTACHMENT NPRO-4 PRIME COMP. COMPONENT SUBMITTED FORM SUB. SUPPLIER MANUFACTURER
	18 X (19) B (20) B (21) O O O O O O O O O O O O O O O O O O O
10	Investigation indicates that a slip clutch in the positioning mechanism
TT.	was marginal in operation. An adjustment was made. The precise cause is
1 2	not yet identified and a report is expected from the vendor with details
13	from his inspection. Incident may be related to previous LER 82-17 and
-	LER 82-21.
	ACILITY NOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION (32)
7 8	E (28) 0 8 7 (39) NA B (31) Review of routine test
1 6	LEASED OF RELEASE AMOUNT OF ACTIVITY (35) Z (33) [Z (34) NA NA NA
, .	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
1 7	0 0 0 3 Z 3 NA PERSONNEL INJURIES 13 00 80
V 8	NUMBER DESCRIPTION (1) O O O (40) NA
8	OSS OF OR DAMAGE TO FACILITY 43
1 9	Z 42 NA
2101	PUBLICITY SUED DESCRIPTION 45 NRC USE ONLY N 44 NA
	10 8208300288 820819 PDR ADDCK 05000155
	S PDR