

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

January 31, 1994

Docket No. 50-155

Mr. Patrick M. Donnelly, Plant Manager Big Rock Point Plant Consumers Power Company 10269 U.S. 31 North Charlevoix, Michigan 49201

Dear Mr. Donnelly:

SUBJECT: BIG ROCK POINT PLANT - GENERIC LETTER 89-10, SUPPLEMENT 5, "INACCURACY OF MOTOR-OPERATED VALVE DIAGNOSTIC EQUIPMENT" (TAC M87918)

On June 28, 1993, the NRC staff issued Supplement 5, "Inaccuracy of Motor-Operated Valve Diagnostic Equipment," to Generic Letter (GL) 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance," requesting nuclear power plant licensees and construction permit holders (1) to re-examine their MOV programs and to identify measures taken to account for uncertainties in properly setting valve operating thrust to ensure operability, and (2) to evaluate the schedule necessary to consider the new information on MOV diagnostic equipment inaccuracy and to take appropriate action in response to that information. Within 90 days of receipt of Supplement 5 to GL 89-10, licensees were required (1) to notify the NRC staff of the diagnostic equipment used to confirm the proper size, or to establish settings, for safety-related MOVs, and (2) to report whether they had taken actions or planned to take actions (including schedule) to address the new information on the accuracy of MOV diagnostic equipment.

The staff has reviewed the responses, and has found that, for the most part, licensees and permit holders have been actively addressing the uncertainties regarding the accuracy of MOV diagnostic equipment. The increased inaccuracy of MOV diagnostic equipment can raise questions regarding (1) the adequacy of torque switch settings to provide sufficient thrust while not exceeding thrust or torque structural limits and (2) the capability of actuator motors at current settings. In their responses, licensees and permit holders indicated that many MOVs had the potential for underthrusting or overthrusting as a result of the higher than expected inaccuracy of MOV diagnostic equipment. Consequently, some licensees reported that MOVs have been retested, adjusted, or modified to resolve the concerns regarding the accuracy of MOV diagnostic equipment.

In your response dated September 27, 1993, you stated that Consumers Power (CPCo) uses Liberty Technologies' VGTES equipment for MOV diagnostic testing. You also stated that 12 MOVs were affected by the Liberty Technologies' Part 21 notice, dated October 2, 1992, and that CPCo had determined four MOVs to exceed their thrust rating, but no immediate action was required. You stated that, of those four MOVs, one had its actuator replaced and torque switch reset, and another had its torque switch reset. You stated that the 9402100134 540131 PDR ADOCK 05000155 P DR DDCK 05000155 P DR DDCK 05000155

Mr. Patrick M. Donnelly

January 31, 1994

remaining two MOVs were only 2% and 3% overthrust. During a future inspection, the NRC staff will discuss CPCo's resolution of the MOV diagnostic equipment accuracy issue. Particularly, the staff will discuss (1) CPCo's basis for determining that no immediate action was required for the four actuators, and (2) whether CPCo addressed the thrust/torque structural and motor capability limits.

This completes all efforts on TAC M87918. If you have any questions regarding this issue, please call me at (301) 504-3018.

Sincerely,

Original signed by

Leonard N. Olshan, Project Manager Project Directorate III-1 Division of Reactor Projects - III/IV/V Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION Docket File NRC & LPDRs JZwolinski LMarsh ARBlough LOlshan CJamerson OGC ACRS(10) BJorgensen, RIII AHensen TScarbrough 7/E/23

| NAME CJamerson LOIshan:jkd ARBlough | FICE | LA: PD31 | PM:PD31 | (A)D:PD31 |
|-------------------------------------|------|-------------|-------------|------------|
| and I should be some a state | AME | CJamerson / | LOIshan:jkd | ARBlough D |
| DATE 1/1/94 1/25/94 1/0/9 | ATE | 1/17/94 | 1 128/94 | - 188/94 |

FILENAME: G:\WPDOCS\BIGROCK\BR87918.GL

Mr. Patrick M. Donnelly, Plant Manager cc:

Mr. Thomas A. McNish, Secretary Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201

Judd L. Bacon, Esquire Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201

Jane E. Brannon, County Clerk County Building Annex 203 Antrim Street Charlevoix, Michigan 49720

Office of the Governor Room 1 - Capitol Building Lansing, Michigan 48913

Regional Administrator, Region III U.S. Nuclear Regulatory Commission 8G1 Warrenville Road Lisle, Illinois 60532-4351

Nuclear Facilities and Environmental Monitoring Section Office Division of Radiological Health Department of Public Health 3423 N. Logan Street P. O. Box 30195 Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission Resident Inspector Office Big Rock Point Plant 10253 U.S. 31 North Charlevoix, Michigan 49720

Mr. David P. Hoffman, Vice President Nuclear Operations Big Rock Point Plant Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201 Big Rock Point Nuclear Plant