APPENDIX A

NOTICE OF VIOLATION

Kansas Gas and Electric Company Wolf Creek Generating Station Docket: 50-482/82-07 License: CPPR-147

Based on the results of an NRC inspection conducted during the period of April 1-30, 1982, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987, dated March 9, 1982, the following violation was identified:

Additional Work on Nonconforming Material

10 CFR Part 50, Appendix B, Criterion XV requires that nonconforming materials be controlled to prevent their inadvertent use or installation.

The SNUPPS Quality Assurance Programs for Design and Construction Manual requires, in paragraph 17B.1.15.d of the Wolf Creek Site Addendum section, "Segregation, if practicable, of nonconforming items from acceptable items and identification as discrepant until properly dispositioned for use. Access to the items will be controlled."

Daniel International Corporation (DIC) requires, in their Construction Administrative Procedure No. AP-VI-02, Revision 13, paragraph 3.6, a "Conditional Release" to install or perform additional work on material found to be nonconforming during the course of construction activities.

Contrary to the above, welding of attachments beyond the scope of Deficiency Reports 1SD8484MW and 1SD8485MW had been performed on Piping Hangers BG01-R007 and BG01-R008, without a conditional release being issued for the work accomplished.

This is a Severity Level IV violation. (Supplement II) (50-482/8207-01)

Pursuant to the provisions of 10 CFR Part 2.201, Kansas Gas and Electric Company is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: June 17, 1982