

JUN 28 1982

Docket: 99900505/82-02

Ebasco Services, Inc.
ATTN: Mr. B. E. Tenzer, Vice President
Materials Engineering and Quality Assurance
Two World Trade Center
New York, NY 10048

Gentlemen:

This refers to the inspection conducted by Mr. D. F. Fox of this office on April 26-30, 1982, of your facility at New York, New York, and to the discussions of our findings with Mr. Louis J. Sas and members of the Ebasco staff at the conclusion of the inspection.

This inspection was made as a result of a Louisiana Power and Light 10 CFR Part 50.55(e) report that valves in the suction lines to the low pressure safety injection pumps for Waterford Unit 3 were not procured to withstand the high differential pressure to which they would be subjected during the shutdown cooling mode of operation.

Areas examined during this inspection and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

During this inspection it was found that you failed to meet certain NRC requirements. The specific findings and references to the pertinent requirements are identified in the enclosures to this letter. However, since corrective action and preventive measures were completed during the inspection, no written response to Appendix A of this letter is required.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request for withholding; and (b) submit within 25 days from the date of this letter a written application to this office to withhold such information. If your receipt of this letter has been delayed such that less than 7 days are available for your review, please notify

RIV

CI:RSS
DFFox/r
6/15/82

SC:RSS
CJHale
6/21/82

BC:VPB
UPotapov
6/21/82

D:IES
EHJohnson
6/22/82

ABD
f-RA:RIV
JTCollins
6/25/82

Tr:09

8207130592 820628
PDR QA999 EECEBAS
99900505 PDR

NRC

Ebasco Services, Inc.

-2-

this office promptly so that a new due date may be established. Consistent with Section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in the Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Uldis Potapovs, Chief
Vendor Programs Branch

Enclosures:

1. Appendix A - Notice of Nonconformance
2. Appendix B - Inspection Report No. 99900505/82-02
3. Appendix C - Inspection Data Sheets (6 Pages)

bcc:
IE Files
AEOD
NMSS
NRC:PDR
QAB
Reg. Administrators I, II, III, IV & V
EHJohnson, RIV