LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M D C C N 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 7 (7) | 0 5 2 6 8 1 (8) | 0 6 0 9 8 1 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Bay water sample for April 1981 analyzed for H-3 Environmental Tech-
03 nical Specification Appendix B, Section 3.2 showed 1549 ± pCi/l at
04 the "Plant Outfall Area" (location 7) compared to ≤121 pCi/l at the
05 Plant Intake Area (location 8). Since the outfall mixes rapidly with
06 the ambient Bay water and is not used for drinking purposes, no signif-
07 icant impact of any consequence to the health and safety of the public
08 is expected.

09 | SYSTEM CODE Z Z (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 1 | — | SEQUENTIAL REPORT NO. 0 3 8 | / | OCCURRENCE CODE 0 4 | REPORT TYPE T | — | REVISION NO. 0

ACTION TAKEN Z (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This incident is reported as required by ETS 5.6.2.b because the meas-
11 ured concentration of the sample is greater than ten times the back-
12 ground. No exceedance of effluent limits was involved and no corrective
13 action is currently deemed necessary.
14

15 | FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Routine Sample

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 | NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 | NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE Z (42) | DESCRIPTION NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) 8208310036 810609 PDR ADOCK 05000317 S PDR | NRC USE ONLY

Ahmad Rafi/G. E. Brobst (301) 234-5575/269-4729
NAME OF PREPARER — PHONE