

T-1116

NUCLEAR REGULATORY COMMISSION

In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

RECEIVED
ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS, U.S.N.R.C.

267TH GENERAL MEETING

JUL 10 1982
7, 8, 9, 10, 11, 12, 1, 2, 3, 4, 5, 6
AM PM

DATE: July 9, 1982 PAGES: 308 - 482

AT: Washington, D. C.

TR04
Delete B. White

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8207130661 820709
PDR ACRS
T-1116 PDR

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
4 267TH GENERAL MEETING

5 - - -

6 Nuclear Regulatory Commission
7 1717 H Street, N.W., Room 1046
8 Washington, D.C.

9 Friday, July 9, 1982

10 The Committee convened, pursuant to recess,
11 at 8:30 a.m.

12 PRESENT FOR THE ACRS:

13 PAUL G. SHEWMON, Chairman
14 JEREMIAH J. RAY, Member
15 J. CARSON MARK, Member
16 MILTON S. PLESSET, Member
17 CHESTER P. SIESS, Member
18 ROBERT C. AXTMANN, Member
19 MAX W. CARBON, Member
20 WILLIAM M. MATHIS, Member
21 DAVID A. WARD, Member
22 JESSE C. EBERSOLE, Member
23 DAVID OKRENT, Member

24 DESIGNATED FEDERAL EMPLOYEE:

25 RAYMOND FRALEY

1 ALSO PRESENT:

2 MR. CHECK
MR. MORRIS
3 MR. LONGENECKER
MR. PIPER
4 MR. HULMAN
MR. CLARE
5 MR. KNIGHT
MR. LEE
6 MR. ABRAHAM
MR. STRAND
7 MR. GOODWIN
MR. THOMAS
8 MR. STARK
MR. RUMBLE
9 MR. GOESER
MR. KNIEL
10 MR. MARCHESE
MR. BERRY

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

P R O C E E D I N G S

(8:30 a.m.)

1
2
3 MR. SHEWMON: Could we begin?

4 This is the second day of the 267th meeting of
5 the ACRS. During today's meeting the Committee will
6 hear reports and discuss the following: discussion of
7 the NPC report on the site suitability of for the Clinch
8 River Breeder Reactor and ACRS Subcommittee report on
9 the proposed NRC rule on high level waste disposal;
10 discussion of the NRC Task Action Plan 845; evaluation
11 of alternate decay heat removal systems; continued
12 discussion on the proposed Committee report on the
13 fiscal year 1984-85 NRC research budget; and
14 miscellaneous subcommittee reports and activities.

15 The items scheduled for discussion on Saturday
16 are listed in the schedule for the meeting which is
17 posted on the bulletin board in the back of the room.

18 The meeting is being conducted in accordance
19 with the provisions of the Federal Advisory Committee
20 and Government in the Sunshine Act. Mr. Paul Boenert on
21 my right is the designated Federal employee for the
22 meeting.

23 A transcript is being kept and we would
24 appreciate your help in allowing the transcriptress to
25 hear you. We have received no written statements or

1 requests to make oral statements from members of the
2 general public for today's meeting.

3 The first item has to do with the Clinch River
4 Breeder Reactor, and Dr. Max Carbon will handle that.

5 MR. CARBON: Thank you, Mr. Chairman.

6 We have got a rather full agenda, so I will
7 give only a brief report and then open it for questions.

8 I would like to begin by stating what we are
9 to cover this morning and what we will not from the
10 standpoint that the Staff is drawing some distinctions
11 in here which seem worthwhile.

12 This is a meeting to review NUREG-0786, which
13 is the site suitability report in the matter of the
14 Clinch River Breeder Reactor plant, and to consider the
15 suitability of the CRBR site for such a plant. You will
16 recall that the Full Committee decided several weeks ago
17 that we wanted to be involved in the consideration of
18 the CRBR site. And further, I am sure that we will hear
19 from the Staff this morning that they do want us to
20 write a letter on this topic.

21 At this point I would try and get into a
22 distinction here that the Staff is making that is a
23 rather important one for our discussion this morning.
24 The Staff has discussed this with the ASLB and is asking
25 us to review the proposed site as "a suitability

1 location for a reactor of the general size and type as
2 CRBR." And that is the end of the quotation.

3 The Staff concluded in 1977 and has
4 reconfirmed that it does indeed consider the site
5 suitable for the general size and type as the CRBR. It
6 has no concluded at this time that the CRBR plant as it
7 is currently designed can be located there. In fact,
8 the Staff won't complete its safety evaluation and issue
9 an SER until next March.

10 I guess in theory that leaves open the
11 question of whether the CRBR could ever be placed there,
12 although in practice the Staff has stated its belief
13 that if the present CRBR design doesn't fit for some
14 reason, that the design could be modified in a
15 reasonable fashion such that the modified plant could be
16 placed there. That is their belief at this time.

17 Examples there are the present design might
18 have to be beefed up to handle greater seismic loads of
19 higher energetics or some such thing. I am just
20 grabbing something out of the air. But the Staff
21 believes that if modifications are necessary along those
22 lines or any other, they could be done in some fashion.

23 So the Staff is asking us today to review the
24 site for the CRBR-type plant, and it specifically is
25 asking us not to review the safety aspects of the CRBR

1 as it is currently designed.

2 Some of the major topics that will come up in
3 today's meeting include the following. One is certainly
4 what is the Staff's understanding of the general hazards
5 of a plant of this size and type, what is the basis for
6 that understanding. The second topic is how does one
7 compare the safety of an LMFBR with that of an LWR. The
8 third topic is what is the basis for selecting the site
9 suitability source term, which is equivalent to that of
10 an LWR, with an addition. The term for an LWR, as you
11 recall, is 100 percent of the noble gases, effectively
12 25 percent of the halogens and 1 percent of the fission
13 products.

14 Then for the CRBR they add 1 percent of the
15 transuranics. This is sometimes stated as 1 percent of
16 the plutonium, but it is quite sure it is 1 percent of
17 the transuranics. As part of this question, the basis
18 for selecting the site suitability source term and
19 associated question of what role, if any, does a
20 potential for core disruptive accidents play in the
21 definition of the source term will be taken up.

22 A fourth topic concerns the assumptions made
23 in estimating the effects of an upstream dam failure.
24 Specifically, what is the basis for assuming a partial
25 failure rather than a total collapse, and what is the

1 significance of it?

2 A fifth topic has to do with the level of the
3 SSE that is appropriate. The value actually chosen for
4 the CRBR is .25 g acceleration. Dr. Trifunac, who is a
5 consultant on our Subcommittee, has estimated that there
6 is something like one chance in 30 of exceeding that
7 value over a 50-year lifetime. This gives a return
8 period, then, of 1640 years.

9 The Applicant sent us a letter a day or two
10 ago which you all have, and if I interpret it correctly,
11 it estimates a return period of 5000 to 10,000 years,
12 which if my arithmetic is correct, is six to ten times
13 as long. I believe the Staff will concentrate on what
14 is a reasonable level for an SSE value rather than for
15 the design of the CRBR for a .25 g.

16 This meeting today follows the site
17 suitability meeting held June 24, and it was attended by
18 several people, if I remember correctly, Mr. Bender, Mr.
19 Ebersole, Kerr, Mark, Moeller, Okrent and Ray. This
20 review that we are undertaking of site suitability is
21 unusual but not unique. Paul Boenert has pointed out
22 that the ACRS has reviewed a half-dozen or so sites in
23 the past. And further, if the U.S. were to establish a
24 bank of pre-approved sites, as has been sometimes
25 suggested, we might do a lot more such reviewing in the

1 future.

2 I would add for background information that
3 several safety review meetings have also been held on
4 topics such as HCDA containment and so on. I would
5 like to turn from the site suitability discussion as
6 such to the topic of the letter from Dr. Cochran of the
7 Natural Resources Defense Council which arrived the day
8 before yesterday, of which you have copies, I am sure.

9 There are two or three points I would like to
10 inform you of. First, I called Cochran yesterday
11 morning simply to discuss the letter. He was out to a
12 meeting. I left a message for him to call me but he has
13 not done so yet.

14 A second point. I am somewhat puzzled by the
15 letter. Dr. Cochran is fully aware, I am sure, from his
16 personal experience from Federal Register notices that
17 both written and oral statements may be made by members
18 of the public at our meetings, and yet, although he says
19 he has attended four such meetings, we have had no
20 communication from him of any kind that I am aware of
21 except now when it is really quite late in our schedule
22 to factor his concerns into our evaluation.

23 He presumably, surely is aware that it has not
24 been our policy to seek out comment from potential
25 public groups, and yet he has not come forth prior to

1 this time.

2 With regard to his specific points, I would
3 state that the Subcommittee was not aware of any of the
4 NRDC contentions. He states to the contrary in citing a
5 reference in one of the transcripts, but all that
6 transcript reference actually says is that there are
7 intervenors. It doesn't say who they are or anything
8 like that. Actually, we had heard that NRDC was an
9 intervenor, but we had no specific knowledge.

10 On the second point, that Staff and Applicant
11 have made strikingly different presentations in the ACRS
12 than to the Licensing Board, I cannot offer any comment
13 now. Paul Boenert is assembling the transcripts and
14 depositions, but it seems to come to something like 1000
15 pages, I guess, and it will take some time to assemble
16 and some time to scan. So we have no information.

17 I guess I would say that since the letter was
18 really addressed to the Full Committee rather than the
19 Subcommittee and not me as chairman, I will stop there.
20 I am sure, though, that the Staff will be prepared to
21 present more information on the NRDC contentions this
22 morning if you would like to hear them.

23 On this point -- let me go back a minute --
24 that the Staff and the Applicant made different
25 presentations to us than to the Licensing Board, I was

1 informed this morning that an appeal was being made on
2 that. I am not much more acquainted with or aware of
3 exactly what is going on further than that.

4 Let me at this time ask other members who were
5 present at the June 24 meeting for comments which they
6 would like to add, and then perhaps we could have any
7 questions that anyone might wish to raise.

8 Carson?

9 MR. MARK: I have nothing to add.

10 MR. CARBON: Dave, do you have anything to add?

11 MR. OKRENT: Nothing.

12 MR. CARBON: Jerry, were you there?

13 MR. RAY: I wasn't there.

14 MR. CARBON: You were at one of the other
15 meetings.

16 Are there any questions that anyone would like
17 to raise before we follow the agenda in turning to the
18 Staff?

19 MR. MARK: When you said that the Staff is not
20 prepared to say yet that the site is suitable for what
21 is is presently designed for, this is separate from the
22 fact that there might be features in the design which
23 might suggest further thought. This tangles, surely,
24 head on with the request for an LWA-1, which if at all,
25 will be acted on before the summer is over, or before

1 the fall is over.

2 MR. CARBON: I think the Staff would say that
3 any activities undertaken by the Applicant prior to
4 issuance of the construction permit is strictly and
5 solely at their risk. I expect they will address that.

6 If there are no further questions, then let me
7 go ahead and turn to Mr. Check of the Staff.

8 Paul.

9 MR. STARK: Paul, before you start, maybe I
10 would like to make a minor adjustment -- this is Richard
11 Stark, by the way -- to the agenda. In addition to what
12 is on the agenda, we have a consultant, Ed Rumble, who
13 will assist Mr. Morris on II.C, Comparability to LWRS.
14 In addition to that, under Geology and Seismology, Bob
15 Rothman will be available to assist Jim Knight if
16 required.

17 I would like to make a recommendation that
18 after we complete Item II.C, Comparability to LWRs, that
19 we then discuss source term. I think they follow each
20 other. In addition, we have a slide that addresses the
21 admitted contentions. If the Full Committee would like
22 to address that, we could attempt to do that.

23 With that, I would like to turn the meeting
24 over to Paul Check, who is the Director of the Clinch
25 River Breeder Reactor Program. Thank you.

1 MR. CHECK: Thank you.

2 As you see, Richard Stark, Project Manager, is
3 directing traffic for the Staff. He will continue to do
4 so.

5 There isn't too much that I can add to what
6 Dr. Carbon has said and to what Mr. Stark has said by
7 way of introduction. But because there are some
8 important distinctions to be made, it is probably worth
9 repeating things just a bit.

10 We are here today to consider the suitability
11 of the Clinch River site, not the acceptability of the
12 Clinch River reactor. The distinction is important and,
13 judging by the Subcommittee meeting, apparently somewhat
14 elusive. I ask that you bear the distinction in mind,
15 however, as we proceed through this morning's agenda.

16 You will hear more in a moment from Cecil
17 Thomas regarding what specifically in our view is
18 germane to site suitability.

19 The reason we are considering the site in this
20 manner is because the Applicants have exercised the
21 right they have in law to request a limited work
22 authorization, LWA. That is, they seek to begin certain
23 site preparation activities prior to receipt of a
24 construction permit. A construction permit, as you
25 know, would authorize them to construct the plant proper

1 as well as to undertake any site preparation.

2 I want to stress at this point that the
3 limited work that would be authorized does not include
4 any safety-related systems or structures. While limited
5 work authorizations are not uncommon, approximately 30
6 of them have been granted. They are usually granted at
7 a point in the licensing process well beyond that at
8 which the ACRS has reviewed the case. Thus, since the
9 ACRS review had already been completed for each of those
10 cases, there was never a need for the Committee to
11 distinguish between the site and the plant.

12 MR. MARK: When you use the word
13 "safety-related" in the statement you just made, is that
14 the same use of the word we have meant before where some
15 valves and pumps and pipes aren't safety-related?

16 MR. CHECK: It's a standard definition.

17 MR. MARK: So they could really build the aux
18 building and quite a few things that aren't
19 safety-related.

20 MR. CHECK: That may in fact be true, but that
21 test is not before us. What is being requested is less
22 than anything that we could agree is the plant proper.
23 The law, that is, the NRC regulations contemplate such
24 request for partial permission and prescribes in 10 CFR
25 Part 50 conditions to be met. Briefly, they are that

1 the ASLB find: one, that the NEPA or environmental
2 review has been completed with a salutary conclusion;
3 and they must find also that the proposed site is a
4 suitable location for a reactor of the general size and
5 type proposed.

6 Notice that the traditional finding of
7 reasonable assurance on safety of the reactor is
8 absent. That conclusion is a natural end point for the
9 safety review, which in this case is not scheduled for
10 completion until next year.

11 Now, as Dr. Carbon has mentioned, the Atomic
12 Safety and Licensing Board has defined the issue for the
13 limited work authorization hearing and has promulgated a
14 schedule for its accomplishment. Our delineation of the
15 site suitability issues, some of which are to be
16 discussed here today more than others, is consistent
17 with the Board's definition of the scope of the LWA
18 hearing.

19 Okay, that concludes my orientation. And as I
20 say, some of it is repetition, but I hope it is helpful.

21 Before I turn, then, to Cecil Thomas for a
22 more careful description of the Staff's site suitability
23 process, let me say again, as Dr. Carbon has said, we
24 are requesting that the Committee give its opinion on
25 the matter of the suitability of the site, the Clinch

1 River site, in a letter in order that we might proceed
2 to hearing in August.

3 Unless there are questions, I would invite
4 Cecil Thomas to come up and discuss the process. As I
5 said, following Cecil, Bill Morris and our consultant,
6 Ed Rumble, who has already been noticed to you, will
7 discuss the matter of comparability which arose in the
8 Subcommittee meeting.

9 MR. OKRENT: Excuse me. Where in the agenda
10 are you going to tell us about the contentions, and also
11 where will you comment on the statement that was made in
12 the letter by Dr. Cochran that there was a difference in
13 what was presented to the ACRS and to other groups?

14 MR. CHECK: I can do some now and some under
15 Cecil Thomas. Cecil Thomas is prepared to deal with the
16 contentions. I hadn't expected that we were going to be
17 asked to respond to the letter impropriety by
18 impropriety, but I will.

19 It is, of course, difficult -- without having
20 Tom Cochran here -- to know precisely what that second
21 point of his really meant. I think at the top of that
22 paragraph he says something about the Staff has not been
23 candid with the ACRS regarding how it has been dealing
24 with the Board, or vice-versa. In any case, I think
25 that is an error because if we looked at the transcript

1 of the Subcommittee meeting, I think you would find that
2 I was rather explicit in stating that the delineation of
3 issues that we had before us with the Subcommittee and
4 the full Committee was the outgrowth of discussions we
5 had had with the ASLB.

6 So I believe in terms of scope of discussions,
7 scope of issues, definition of what we think needs to be
8 accomplished, we are telling the same story to both
9 groups.

10 I believe toward the end of that paragraph he
11 says something more on this point, and I would only
12 offer as a possible explanation that Mr. Cochran sees
13 that the entire spectrum of discussions we have had with
14 the Committee, the Subcommittee, primarily, are fit and
15 proper things and within the scope of what the Board has
16 decided is the LWA hearing. I would say that that is
17 not true.

18 What we have been talking about with the
19 Subcommittee is much broader. It includes the safety
20 matters. Most of our discussion has been on safety
21 matters. Only two meetings, today and the previous
22 Subcommittee meeting, had to do with the question of
23 site suitability per se, and it is the content of those
24 two meetings that would be what would map on the
25 conversations or discussions we have had with the ASLB.

1 Now, as I say, the question of contentions
2 will be taken up by Cecil Thomas in his discussion.

3 MR. CARBON: Will you or will someone else be
4 saying anything more about the schedule? And
5 particularly I would welcome --

6 MR. CHECK: I could show the slide I showed at
7 the Subcommittee? We have a rather packed agenda --

8 MR. CARBON: Would you address whether or not
9 you consider it important that we try to act at this
10 meeting?

11 MR. CHECK: I'm sorry. I mentioned that the
12 hearing is scheduled for August. A letter in July
13 leaves the Staff with its traditional time to respond to
14 that. We have that analog of an SER out there, which is
15 the site suitability report, in this case. The
16 Committee, as you know, write letters and then the Staff
17 supplements its report prior to going to hearing. So
18 some time is needed, and I think the time we have asked
19 for is not undue. So a letter in July conforms to
20 reasonable and traditional assumptions about scheduling.

21 MR. CARBON: If we were to delay for some
22 period of time, would that cause any sort of delay
23 farther down the road in the other aspects?

24 MR. CHECK: Well, there is no specific
25 requirement for the letter in law that I am aware of, so

1 we could proceed without it. I would have expected that
2 the letter would have been the natural interim end point
3 for this part of the Committee's deliberation. The
4 Committee did ask to review the site suitability matter,
5 and we have been assuming that they meant to unburden
6 themselves of an opinion on that question.

7 Much of what we have said to the Committee has
8 been interesting and stimulating, there has been a lot
9 of good discussion. It is somewhat of an open record
10 now, an open book, a book without a conclusion, a
11 symphony without a final movement. Without the letter,
12 it would give us a very interesting hearing to face
13 without being able to point to something that
14 represented some consensus view of the Committee.

15 MR. CARBON: If we delayed a month, would that
16 delay the opening of the ASLB hearing?

17 MR. CHECK: It would be awfully close. I
18 can't promise that it would, but it would, as I say,
19 leave us virtually no time to amend our basic testimony
20 document.

21 MR. CARBON: Fine.

22

23

24

25

1 MR. OKRENT: One more question. Can you tell
2 me what the status or significance is of the criteria,
3 the things called Clinch River Breeder Reactor plant
4 design criteria given in Appendix A of NUREG-0786?

5 MR. CHECK: I will start by observing that in
6 the preface, we have a paragraph from which I will
7 quote. "Because the staff has not completed its safety
8 review of CRBR, a process which may lead to changes in
9 design or design criteria, descriptions of specific CRBR
10 design features in this report are presented only as
11 representative of a facility of the general size and
12 type as CRBRP. Similarly, CRBRP design criteria in
13 Appendix A are included only as representative design
14 criteria for such a facility."

15 MR. OKRENT: What does that statement mean?

16 MR. CHECK: It means that we are not prepared
17 today to say that they are the design acceptance
18 criteria for the Clinch River reactor. I recall that in
19 an early subcommittee meeting we went over the question
20 of the development of design criteria at some length.
21 Dr. Morris, who is here with us, can review some of
22 that. We can if there is time in the schedule.

23 MR. OKRENT: I don't want to go over the
24 criteria blow by blow today.

25 MR. CHECK: I am talking about the process.

1 MR. OKRENT: I am trying to see whether the
2 staff treats these as plausible design criteria,
3 acceptable design criteria. You use this word
4 "representative", which suggests some degree of
5 applicability in the staff's mind.

6 MR. CHECK: There is. I simply want to
7 reserve, we are not finished. The scheme that we have
8 outlined to the subcommittee regarding the development
9 and establishment of design criteria is one that
10 proceeds in parallel with the safety review itself, and
11 that is why the conclusion of the safety review will be
12 the time when we will be able to announce, these are the
13 criteria. These are the criteria we would be prepared
14 to defend as applicable, suitable and applicable for
15 this plant, and then, of course, measure the plant
16 against them.

17 So it is our plan that we proceed with the
18 safety review, bearing in mind and testing continually
19 the design against these initial statements, initial
20 derivations from the general design criteria, but that
21 we remain flexible and prepared if necessary to change
22 the design criteria.

23 MR. OKRENT: Well, I couldn't tell my students
24 what you meant, if I can use a common calibrator, but
25 let's let it go at that.

1 MR. CHECK: Cecil Thomas.

2 MR. OKRENT: I might note in passing while he
3 is getting ready, I don't feel that I am willing to
4 accept many of the design criteria written in that
5 appendix. That is why I raised the question. I don't
6 know about the rest of the subcommittee.

7 MR. THOMAS: Good morning. My name is Cecil
8 Thomas. I am section leader of the licensing section
9 for the Clinch River Breeder Reactor project office.

10 (Slide.)

11 MR. THOMAS: This morning, I will give you an
12 overview of the staff's site suitability review. I will
13 briefly review some of the important features of an
14 LWA-1. I will give you a list of the site preparation
15 activities that the applicant proposes to conduct under
16 the LWA-1. I will describe our approach to the site
17 suitability review, and I will conclude with a few words
18 on our site suitability report.

19 (Slide.)

20 MR. THOMAS: LWA-1's are governed by 10 CFR
21 50.10E. An LWA-1 authorizes the conduct of non-safety
22 related site preparation activities. An LWA-1 requires
23 the completion of the environmental and site suitability
24 reviews, and the completion of public hearings on both
25 environmental and site suitability matters. Any

1 activities undertaken by the applicant that are
2 authorized by the LWA-1 are undertaken solely at the
3 applicant's own risk. The issuance of an LWA-1 has no
4 bearing on any subsequent issuance of a construction
5 permit.

6 The finding that must be made before an LWA-1
7 is issued is that based upon the available information
8 and review to date, there is reasonable assurance that
9 the proposed site is a suitable location for a reactor
10 of the general size and type proposed from the
11 standpoint of radiological health and safety
12 considerations.

13 And finally, we have obtained a more accurate
14 account since Paul indicated, we have now issued 27
15 LWA-1's since they were first established in 1974.

16 (Slide.)

17 MR. THOMAS: This is the first of two slides
18 that show in detail or at least list the site
19 preparation activities that are proposed by the
20 applicants should they get an LWA-1. I will not burden
21 you by reading the specific activities. They are in
22 your handouts. They basically fall into four general
23 categories, the first of which is general site clearing
24 and grading. The second, excavation. Thirdly,
25 installation of temporary construction facilities.

1 (Slide.)

2 MR. THOMAS: And fourthly, other miscellaneous
3 activities. We believe these activities are allowable
4 under 10 CFR 50.10E, and we believe that none of these
5 activities are safety related.

6 (Slide.)

7 MR. THOMAS: I have attempted to depict
8 pictorally in this slide our approach towards site
9 suitability review. We begin by defining the facility
10 of the general size and type proposed. We define this
11 by a limited set of characteristics that are relevant to
12 a determination of site suitability. These
13 characteristics are based on proposed CRBR plant design
14 features, our experience with LWR plants, and our
15 experience with other types of plants.

16 These bases also provide us with reasonable
17 assurance that the characteristics and parameters
18 assumed for a facility of the general size and type
19 proposed are feasible, and finally, we assess the
20 compatibility of the characteristics of the parameters
21 of the facility of a general size and type with those of
22 the proposed site. The characteristics of the proposed
23 site are those normally found in Chapter 2 of the safety
24 evaluation report or the PSAR. They generally consist of
25 the ologies, geology, demography, foundation

1 engineering, and consideration of emergency planning.

2 So, as Dr. Carbon pointed out this morning,
3 once we have defined a facility of the general size and
4 type, we in effect conduct an early site review, as you
5 are all familiar with, under the standardization
6 policy. We compare the characteristics of the facility
7 with those of the proposed site, and make a conclusion
8 as to a facility of the general size and type's
9 suitability.

10 (Slide.)

11 MR. THOMAS: Our site suitability report for
12 the Clinch River Breeder Reactor plant is NUREG-0786.
13 That report documents the results of the staff's
14 evaluation of the suitability of the Clinch River site
15 for a facility of the general size and type as the
16 proposed Clinch River Breeder Reactor plant. We
17 conclude in that report that based upon the available
18 information and review to date, there is reasonable
19 assurance that the Clinch River site is a suitable
20 location for a facility of the general size and type of
21 the proposed Clinch River Breeder Reactor plant from the
22 standpoint of radiological health and safety
23 considerations.

24 This concludes my presentation on the site
25 suitability review. If the Committee would like, I

1 would be happy to address the contentions that are
2 admitted into the proceeding, and specifically those
3 contentions that we feel are related to the question of
4 site suitability.

5 MR. CARBON: Yes, please do.

6 MR. MARK: A question. We know better some
7 1,300 megawatt electric plants, more about its design
8 than you do at this moment let's say about the final
9 details of the CRBR, so would this be a site suitable
10 for such a plant?

11 MR. THOMAS: If those characteristics of the
12 1,300 megawatt plant --

13 MR. MARK: I am just referring to any standard
14 type plant.

15 MR. THOMAS: I am, too. I am will try to be
16 general in my answer. If the characteristics that are
17 relevant to the site suitability match up with the
18 parameters of the site in a way that we have looked at
19 site suitability in the past in our acceptance criteria
20 for site suitability, yes.

21 MR. MARK: "If" they did.

22 MR. THOMAS: Yes. We would have to evaluate
23 the specific characteristics.

24 MR. MARK: Well, the ground is firm enough to
25 hold the plant. The water is generous enough. And the

1 only thing that might come into the way would be what
2 should the SSE value be, and how does it stand with
3 respect to floods.

4 MR. THOMAS: By and large my answer is yes, we
5 would have to look at the details just to assure
6 ourselves; but I see no reason, based on our review,
7 there is no reason why you couldn't site any plant.

8 MR. SHEWMON: Is that the way you normally
9 answer questions, or are you just being evasive? I
10 cannot really tell.

11 MR. THOMAS: Dr. Mark asked a fairly general
12 question. I tried to answer --

13 MR. SHEWMON: You are giving very general and
14 vague answers, depending on your viewpoint. I take it
15 the answer was yes. Is that roughly correct?

16 MR. MARK: Look, there are a couple of things
17 that have to be looked at. The demography probably is
18 okay. The soil is okay, probably. Water.

19 MR. THOMAS: There is no overriding
20 consideration that would preclude licensing a larger
21 plant at that site that we are aware of.

22 MR. AXTMANN: What actually happened when you
23 updated the NUREG-0786 for the site suitability report
24 of 1977?

25 MR. THOMAS: The changes in that report from

1 the earlier report are indicated by lines in the
2 margin. Basically, we updated it to reflect additional
3 information that was provided by the applicants over the
4 years, modifications to the design, for example,
5 changing a homogeneous core to a heterogeneous core. It
6 was updated to reflect later meteorology, which accounts
7 for more data. It is more statistically significant, if
8 you would. To note, for example, that FFTF is now in
9 operation, and we have begun to receive operating
10 experience from that, things of that nature.

11 The changes were not overwhelming. There were
12 a limited number of them, and it was clearly
13 characterized as an update.

14 MR. SHEWMON: Get on with the contentions, if
15 you would.

16 (Slide.)

17 MR. THOMAS: You have been given a copy of the
18 complete set of contentions that have been admitted to
19 the proceeding. These contentions cover both the site
20 suitability portion of the hearing and the construction
21 permit portion of the hearing. The Board, as I am sure
22 you have heard by now, has ruled on which of these
23 contentions or which parts of the contentions are
24 admissible for the site suitability part of the
25 hearing. I have not attempted to mark those, because it

1 is not easy. I would say that the Board has parsed
2 those contentions, if you would, both vertically and
3 horizontally.

4 Certain of the contentions have been ruled
5 appropriate for the CP part, but others only portions of
6 the contentions have been ruled appropriate for the LWA
7 or site suitability portion of the hearing. For
8 example, Contentions 1, 2, and 3, as I have indicated
9 here, deal with inclusion of the core disruptive
10 accident and the design basis accident spectrum, and
11 hence -- the Board has sliced these three horizontally,
12 and have limited consideration of those contentions to
13 the feasibility of designing the plant in such a way
14 that the CDA's, the probability of the core disruptive
15 accidents could be made so low that they could be
16 excluded from the design basis accident spectrum.

17 So, to give you the complete set of
18 contentions that have been admitted to date, you have
19 that package. This slide pulls out from that list those
20 contentions or the portions of those contentions that we
21 believe are relevant to site suitability. Those are
22 1(a), 2, 3(b) and (d), which, as I indicated, have been
23 limited as to the extent that the Board will allow
24 inquiry at the hearing. The general subject matter is
25 whether the CDA should be included in the spectrum of

1 design basis accidents and hence in the site suitability
2 source term.

3 Contention 5(a) I have included in here for
4 conservatism, if you would. It is really more related
5 to the NEPA review of alternative sites. It has to do
6 with the adequacy of the meteorology and population
7 density at the Clinch River site versus the alternate
8 sites.

9 MR. SHEWMON: Would you read from the vu-graph
10 back there so that we can, too?

11 MR. THOMAS: Contention 5(b) relates to the
12 effects of long-term evacuation of nearby facilities,
13 specifically, the facilities at Oak Ridge, X10 Y12, K25
14 and the proposed synfuels plant. We have discussed this
15 matter in some of the subcommittee meetings. Item
16 11(d)(1) has to do with 10 CFR 100.11, organ dose
17 equivalent limits.

18 Without attempting to characterize the various
19 positions of the parties at the hearing, I have
20 attempted to be as objective as I could in summarizing
21 what our understanding of the issues in controversy are.

22 MR. OKRENT: On 5(b), what is the staff
23 position, that this will not occur, or that even if it
24 occurred it wouldn't be an unacceptable loss to the
25 nation? Or just how do you respond to that?

1 MR. THOMAS: To begin with, we normally do not
2 look at the effects of evacuation of nearby industrial
3 facilities during the course of our review
4 specifically. Let me elaborate on that. We do a review
5 to assess the radiological health and safety
6 consequences for various distances out from the site.
7 We make a judgment as to the acceptability of those
8 consequences.

9 During the operating license phase of our
10 review, and to some extent during the construction
11 permit stage, we work with the applicant in developing
12 an emergency plan that is an integrated plan that
13 considers a number of things, not only --

14 MR. OKRENT: You are really asking a different
15 question, because that is not the question raised in the
16 contention.

17 MR. THOMAS: I am getting -- let me get to
18 that.

19 MR. OKRENT: Get directly to it.

20 MR. THOMAS: The Department of Energy is
21 responsible for those facilities. They know the
22 activities that go on at those facilities, both in terms
23 of national defense and energy. It is really ultimately
24 their responsibility to make the decision whether they
25 want to site a nuclear plant near those facilities.

1 During the OL stage, we will be sure that there is an
2 emergency plan, but that falls within the Department of
3 Energy.

4 MR. OKRENT: So the decision with regard to
5 Contention 5(b) is that it is not offering an opinion?
6 Is that what you are saying?

7 MR. THOMAS: The bottom line is that, yes.
8 Any further questions?

9 (No response.)

10 MR. THOMAS: Thank you very much.

11 MR. AXTMANN: On that point, is the applicant
12 the best judge of such matters? It sounds like this is
13 a --

14 MR. THOMAS: The applicant is the Department
15 of Energy.

16 MR. AXTMANN: Yes, but it is the Department of
17 Energy who makes the statement is the section that we
18 are discussing, 11(3)(b).

19 MR. CARBON: 5(b).

20 MR. AXTMANN: 5(b).

21 MR. THOMAS: These are the contentions of the
22 intervenor. These are the intervenors' contentions.

23 MR. AXTMANN: Based on what you have said, I
24 find that they have merit.

25 MR. THOMAS: I didn't mean to imply that at

1 all.

2 MR. AXTMANN: I know.

3 MR. THOMAS: You see, these contentions, there
4 are three parties to the proceeding, the applicant, the
5 staff, and the intervenors. The staff and the applicant
6 at this point in the proceeding have no contentions. It
7 is only the intervenor. The intervenor is saying, hey,
8 look, there may be a problem here. It is the applicant,
9 specifically the DOE portion of the applicant, that has
10 to make the decision as to whether or not it is prudent
11 to locate the Clinch River Breeder Reactor plant within
12 the proximity of those other facilities.

13 MR. OKRENT: With regard to Contentions 3(b0,
14 (d), you will address those when you address the site
15 suitability source term?

16 MR. THOMAS: We could go into that more.

17 MR. OKRENT: Would you include that in your
18 presentation, fit it in at the appropriate time so that
19 it is not just --

20 MR. THOMAS: For clarification, are you
21 referring to the general subject of whether the CDA's
22 can be made -- there is reasonable assurance that they
23 can be made sufficiently improbable that they don't have
24 to be included in the spectrum of design basis accidents?

25 MR. OKRENT: That is one of them. I think you

1 should comment on it. If you have no comment, you can
2 say you are not going to address it or whatever it is.
3 Similarly, under (c), (b), (d), and so forth, if you
4 would just include that, it would be helpful.

5 MR. THOMAS: I would just note that in the
6 many meetings we have been having with the
7 subcommittees, and I think once before the full
8 committee, we have made it clear that it is our position
9 that the core disruptive accidents are sufficiently
10 improbable or could be made sufficiently improbable that
11 they do not have to be considered in the spectrum of
12 design basis accidents since the site suitability source
13 term bounds the sources of that spectrum of accident so
14 that it is not appropriate to include.

15 MR. CARBON: Why don't you tie that in more
16 with the discussion at the time?

17 MR. THOMAS: We will do that during the source
18 term discussion.

19 MR. CHECK: Let me address that briefly while
20 Bill Morris is moving up. I believe Dr. Mark asked the
21 question, could we put down a 1,000 megawatt E
22 light-water reactor on this site, and would it be a
23 suitable location for such a reactor. I think if you
24 will accept the short answer that I would give is
25 "probably."

1 MR. MARK: I recognize there are questions you
2 would have to go into.

3 MR. CHECK: What keeps us from making a fuller
4 answer and a more affirmative positive answer is that we
5 know we probably have to put cooling towers down there.
6 There are the environmental considerations, and raising
7 the power by three probably means the exclusion distance
8 may be a little tight; we might have to go out a
9 little. But I am almost certain that it could be made
10 suitable by a combination of things.

11 MR. SHEWMON: Mr. Longenecker, do you wish to
12 make a statement at this time?

13 MR. LONGENECKER: Yes, Mr. Chairman.

14 MR. SHEWMON: I really don't want to get into
15 the Natural Resources Defense Council letter. If that
16 is what you are mainly there for, I wish you would make
17 it extremely brief. What is it you wish to --

18 MR. LONGENECKER: Mr. Chairman, I have a few
19 remarks to make. I would like to discuss the
20 presentation we are going to make today. I would like
21 to make a brief, as in about ten seconds, statement on
22 our position on the NRDC contention, and I would like to
23 make a statement --

24 MR. SHEWMON: Fine. If you take more than ten
25 seconds we will cut you off.

1 MR. LONGENECKER: My name is John Longenecker,
2 from the Department of Energy. We are the applicants.
3 We will be presenting today information on the site and
4 clean up some of the issues that were left over from the
5 June 24th meeting. I would like to introduce the
6 presenters for you, but before that, I would like to
7 thank Dr. Carbon for the opportunity to present
8 information on the CRBR project over the last six months.

9 With regard to the action that the full
10 committee is considering here today, I would like to
11 state that we believe, based on the information that we
12 have submitted, that we have adequately assessed in all
13 regards the potential environmental impacts of the CRBR
14 site. The request made by Paul Check previously that
15 the full committee take a position and report favorably
16 on their report, we support that.

17 With regard to the NRDC letter, which speaks
18 to the appropriateness and consistency of our
19 presentations to the ASLB and the ACRS subcommittee
20 today, I would just like to say that in our opinion our
21 presentations have been totally consistent, both
22 technically and factually, and a key difference, as I
23 believe was pointed out in Cecil Thomas's presentation,
24 is in the scope of the contentions and the detail at
25 this point in the process with which the Atomic Safety

1 and Licensing Board has ruled that we should review.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 In other words, we have presented exactly the
2 same information bottom line with the information that
3 is contained in the Staff site suitability report, which
4 is representative of that we have presented. We will as
5 a point of final clarification be presenting information
6 at the hearings which will begin in August on each of
7 those contentions, and the intervenors will also be
8 providing their testimony, and each of those that the
9 Board has admitted will be discussed and litigated to
10 the extent the Board has allowed.

11 So as a final point to introduce the people
12 who will be presenting, today we have an assortment of
13 people both from the Department of Energy, from the
14 Project Management Corporation and the Tennessee Valley
15 Authority. We are co-applicants with our utility
16 partners in this matter.

17 For the first presentation on the overall
18 description of the site will be Henry Piper, who is from
19 the Project Office Licensing Branch. Following that on
20 the site suitability source term George Clare who is
21 from the Westinghouse Licensing Division will review
22 both that and he will be discussing a comparison of
23 source terms with other countries, principally focusing
24 on source terms used by the U.K. and the Japanese.
25 George will also discuss the open item from the last

1 meeting, and that is the assessment of the consequences
2 of a release of non-radioactive sodium on site and other
3 potential impact of sodium aerosols with LMFBR reactor
4 system design.

5 On the last agenda item, hydrology, we have
6 some people here from TVA. Namely, Ray Lee, who is an
7 expert hydrologist with TVA, will discuss the analysis
8 of Clinch River floods which could impact the site. He
9 will be followed by Tom Abraham, who is the head civil
10 engineer of the hydrostructural design for TVA, and he
11 will discuss the Norris dam failure.

12 For the last discussion, Henry Piper will
13 summarize the effects and potential impacts on
14 groundwater due to the hypothetical core melt.

15 In addition, we have with us from TVA Joe
16 Hunt, principal engineer of the geotechnical and
17 earthquake engineering staff of TVA; and and Jim Domer,
18 the TVA supervisor for BWR licensing. They will address
19 any issues any of you may refer to.

20 Unless there are further questions, I would
21 turn it over to Bill Morris, who will continue. We will
22 be prepared to do the site suitability in the order that
23 you discuss.

24 MR. MORRIS: At the recent joint meetings of
25 the CRBR Siting Subcommittees, a question arose with

1 regard to the Staff statement in its site suitability
2 report about our objective that the risks at Clinch
3 River would be comparable to those for light-water
4 reactors and what that meant, and a more general
5 question, I believe, arose with regard to a general
6 characterization of the hazards that could be related to
7 a plant such as Clinch River or a general LMFBR.

8 I am going to try to clarify some of these
9 points today and just point out to you that when we talk
10 about comparability of risk of Clinch River to LWRs, we
11 are talking about the current generation of LWRs
12 undergoing licensing today. That is modern LWRs.

13 We are not talking about an average LWR, I
14 think. We are talking about risk in terms of both the
15 probabilities and frequencies of accidents. More, we
16 have that risk as a product of frequency in mind.
17 However, I want to make it clear that we believe it
18 would be too restrictive a concept to think of this only
19 in numerical terms. We believe that the capabilities of
20 current probabilistic risk assessment methodology are
21 such that the uncertainties are still too large to try
22 to make a numerical comparison of this type and to rely
23 only on that as a basis for making this judgment.

24 In addition to this, we have a number of more
25 deterministic criteria that we apply in making judgments

1 about the comparability of the different kinds of
2 reactors. Of course, the CRBR will be expected to meet
3 all the applicable LWR criteria, and there are a number
4 of these, from the Standard Review Plan, the Code of
5 Federal Regulations, the ASME and IEEE code standards
6 that would apply to systems such as, for instance,
7 protection systems, which we believe will ensure
8 comparability between the light-water reactor and those
9 for Clinch River.

10 There are, of course, specific examples where
11 there must be special criteria developed for the
12 sodium-cooled reactor. Those will be applied also. But
13 there in general we are talking about deterministic
14 criteria and the application of those to assure low risk.

15 Another point is the consequences of design
16 basis accident, including a bounding site suitability
17 source term to adequately bound all the design basis
18 accidents, will be required to meet the 10 CFR Part 100
19 guidelines.

20 Now, remember that the site suitability source
21 term we are using here for Clinch River is a
22 non-mechanistic postulated release of radioisotopes into
23 containment followed by design basis leakage from
24 containment but with no containment failure. That
25 source term includes some contribution from core melting

1 that could only realistically be considered to be
2 associated with some core disruption. But the source
3 term does not include -- is not based on an attempt to
4 bound all postulated CDAs that one might consider. And
5 in the non-mechanistic way that it is treated, we don't
6 anticipate that it really is closely related to CDA
7 analysis.

8 We have required in previous communications
9 with the Applicant that certain design measures will be
10 imposed on the Clinch River design to assure that severe
11 accidents such as CDAs will be improbable and hence are
12 beyond the design basis spectrum.

13 MR. OKRENT: Are you able to quantify for me
14 "very improbable"?

15 MR. MORRIS: We don't have a specific
16 threshold that we apply to decide whether an accident is
17 within or beyond the design basis. We can characterize
18 the probability and make estimates of what the
19 probabilities may be, but I would not want you to
20 believe that that was being used as a threshold
21 discriminator for design basis versus nondesign basis
22 accidents.

23 So I think that I could not give you a
24 numerical value for what this probability threshold
25 might be. We do have a judgment that there are

1 sufficient design measures that can be imposed to assure
2 that the accidents will be sufficiently low in frequency
3 that they need not be considered as part of the design
4 basis.

5 MR. SHEWMON: When you talk about a CDA, is
6 that defined as when the core might disrupt or when the
7 accident might get out of the pressure vessel?

8 MR. MORRIS: The core might disrupt. We are
9 talking about a core disruption.

10 MR. SHEWMON: So it has nothing to do with the
11 energetics of what that would be or the strength of the
12 head or anything that would be there to contain it?

13 MR. MORRIS: Once you postulate that there
14 might be core disruption, you have to consider the
15 possibility that there would possibly be some damage
16 done to the primary system, either mechanical or
17 thermal.

18 MR. SHEWMON: I am aware that such things are
19 sometimes done with my present position. That was why I
20 asked the question. The question has to do with when
21 you talk about a probability, is it the initial core
22 disruption or are you including in that some of these
23 other considerations?

24 MR. MORRIS: When we talk about a judgment
25 that the probability of a CDA is sufficiently low to

1 exclude it from the design basis, we are talking about
2 the initiation and the core disruption but not the
3 subsequent failures of the primary system and/or
4 containment that might occur.

5 MR. SHEWMON: Thank you.

6 MR. OKRENT: Excuse me. Suppose before the
7 time that you get to the point where a hearing board is
8 reviewing a construction permit and arriving at some
9 decision with regard to CRBR, the Commission arrives at
10 some position with regard to severe accident rulemaking
11 for LWRs and says that certain measures need to be dealt
12 with for light-water reactors.

13 It already has said that you have to deal with
14 substantial amounts of hydrogen. Would that in some way
15 affect what you are telling us now? I am trying to
16 understand how you relate what you have just said about
17 CRBR to this halfway position that the Commission is
18 already in, and in fact it is sort of a five-eighths
19 position with regard to near-term CPs, which this is not
20 quite.

21 Do you understand my question?

22 MR. MORRIS: I think I understand. Even
23 before Three Mile Island and the current interest in
24 degraded cores, the Staff and the Applicant were
25 considering how to go about accommodating severe

1 accidents.

2 Two points. First, you take measures to
3 assure that the accidents are very improbable. But then
4 the Staff further said in its letter of May 6, 1976 that
5 the design should be capable of accommodating severe
6 accident. The word "accommodate" here should be
7 distinguished from "mitigate." We use "accommodate" to
8 mean that there should be in the design sufficient
9 measures to assure that containment will survive for a
10 long enough time that the consequences will be
11 acceptably low.

12 What that translates to in terms of design
13 features and what has been proposed by the Applicant are
14 measures to cool the steel between the annulus and the
15 outer building subsequent to a core melt, measures to
16 vent through filters and to purge the system to control
17 hydrogen subsequent to a core melt, and in general I
18 would say there is already in the Clinch River design
19 and in our licensing proceedings measures taken to take
20 into consideration the consequences of severe
21 accidents. We don't just say we want to make it very
22 low. We go beyond that to say we want to make sure they
23 won't result in severe consequences.

24 We are looking at a design that will
25 accommodate core melt-throughs and the pressures and

1 temperatures that could occur in containment and assure
2 that they do not cause early containment failure.

3 MR. OKRENT: Why don't you go on.

4 MR. MORRIS: Again, one point that wasn't
5 clear. This does include a consideration of hydrogen
6 that could be generated from sodium-concrete reaction,
7 and we take that into account.

8 Well, all these more deterministic criteria
9 have been discussed. We have gone recently through an
10 exercise to come up with a preliminary evaluation of the
11 risk that could be associated with the CRBR. This is in
12 relationship to the work to issue an update to the final
13 environmental statement. It is similar to the analyses
14 performed for other recent environmental statements in
15 conformance with the policy statement made by the
16 Commission to take into account the consequences of a
17 Class 9 accident.

18 We do not propose to you that this is a PRA.
19 This is not anything but a preliminary scoping analysis
20 of accidents and their consequences that might occur.
21 Subsequently, however, to further confirm that the risks
22 from CRBR will be low and will be somewhat comparable to
23 light-water reactors, there will be a probabilistic risk
24 assessment performed by the Applicant to confirm that
25 the safety goal will be met for Clinch River.

1 MR. CARBON: Do you believe that that last one
2 truly will ever be met?

3 MR. MORRIS: Do I believe the safety goal will
4 be met?

5 MR. CARBON: No, that the PRA will confirm
6 that the CRBR meets the safety goal.

7 MR. MORRIS: To the extent we understand the
8 way the implementation of the safety goal may proceed,
9 this is, again, somewhat preliminary because the actual
10 implementation plans are just being discussed and
11 developed. But we believe the PRA will be a large part
12 of how we deal with the implementation of the safety
13 goal. We believe that to the extent the PRA can be used
14 for dealing with the safety goal for light-water
15 reactors, that it can also be applied to Clinch River.

16 It is in that sense that we make this
17 statement about how this PRA will be used. I have to
18 qualify it to say that only to the extent we have become
19 confident that PRA methodology is sufficient for that
20 purpose would I believe that we could do it.

21 MR. OKRENT: I guess if I were a member of the
22 public and said what did he just tell me by the
23 statement that the Staff is going to try to make the
24 risks comparable to those of a light-water reactor, I
25 would say, well, he didn't tell me how low a probability

1 accident had to be before I didn't consider it in the
2 design basis. He didn't tell me how low in probability
3 the core melt accident needed to be. He did tell me he
4 didn't know how to quantify the risk from light-water
5 reactors or from LMFBRs. So what did he tell me when he
6 said he was going to try to make them comparable? I
7 guess I couldn't even explain it to my children. Am I
8 wrong?

9 MR. MORRIS: I think I said that there are a
10 number of deterministic criteria that, when applied,
11 will assure us that the risk will be acceptably low. We
12 can do probabilistic assessments to try to come up with
13 numerical values for what those risks might be, but
14 because of the uncertainties inherent in risk
15 methodology, I think one would have to be cautious about
16 interpreting those values. So that is the reason I
17 don't want to be very specific about the use of
18 numerical values in making these decisions. I don't
19 think it has been generally accepted that the
20 methodology is yet sufficient for its use in that way.

21 MR. OKRENT: Well, let me suggest you could
22 have a non-acceptance limit, if the core melt
23 probability was 1 in 10 per year, that that should be a
24 design basis. If it were 1 in 100 per year, I would
25 expect you would have to find that it was included in

1 the design basis.

2 MR. MORRIS: If I found that, it wouldn't be
3 an acceptable design.

4 MR. OKRENT: Well, they might have a way of
5 dealing with it, that it was so good that the reactor
6 was still safe. So whatever. I said core melt, but you
7 take your choice. A leak in the hot leg. Okay? There
8 is some probability when it becomes a design basis, and
9 there is some when it is not. There is a threshold in
10 your mind.

11 MR. SHEWMON: You made the point. Let's go
12 on. Are you through?

13 MR. MORRIS: I now want to introduce Ed
14 Rumble, who is Corporate Vice President for SAI. We
15 have asked Dr. Rumble to assist us in evaluating the
16 hazards and risks of Clinch River and in performing this
17 analysis for incorporation into our final environmental
18 statement. He has had considerable experience in
19 probabilistic risk assessment, and will be involved in
20 our review of the applicants PRA.

21 The most significant experience he has, to our
22 way of thinking, is the work that he has done in
23 evaluating the risks for the SNR-300 reactor, which is a
24 reactor very similar to the Clinch River design in
25 concept, and he has been involved in evaluating certain

1 significant accident sequences all the way from
2 inception through the release fractions.

3 MR. CARBON: One question before you leave.
4 If he is going to talk primarily about PRA, you have
5 used the word "deterministic," but doesn't it really
6 come down to it is going to be your engineering
7 judgment?

8 MR. MORRIS: I think it is a consensus
9 judgment based on the continued acceptability of these
10 deterministic criteria. There are some specific cases
11 where we will have to look at very detailed acceptance
12 criteria related to those that we will have to make a
13 judgment that they have been met, ultimately.

14 MR. CARBON: Well, in the final analysis it is
15 going to be your engineering judgment.

16 MR. MORRIS: I think it would evolve down to a
17 judgment, but it is not one individual's judgment but it
18 is a consensus judgment about what is an accepted
19 practice for designing a reactor.

20 MR. OKRENT: Before you take that microphone
21 off, one of the recent light-water reactor PRAs, Zion,
22 and I guess again Indian Point, makes the claim that
23 with their design for certain families of core melts,
24 they don't have any loss of containment integrity. It
25 is not just that there is a delayed loss. They say they

1 will not have any loss.

2 They also argue that the probability of a loss
3 of containment integrity, again, not a delayed loss, is
4 very low and you integrate it over the family of more
5 probable core melts.

6 Now, have you considered whether that should
7 be the kind of criterion you should have for a CRBR
8 rather than the one which you expressed in the May 19
9 something --

10 MR. MORRIS: 1976. .

11 MR. OKRENT: -- '1976, was it, letter, where
12 you, if I understand it correctly, requested that there
13 be an ability to maintain containment integrity for an
14 extended period of time like 24 hours? But if I recall
15 correctly after that, sort of the building could fall
16 down and everything could get out, according to the
17 letter.

18 MR. MORRIS: We have recently discussed with
19 the Subcommittee a new set of criteria that we think
20 will prefer to that 24-hour criteria. It relates to the
21 fact that in this design there will be a possible
22 venting of the material inside containment subsequent to
23 a core melt accident. We believe such venting should
24 not result in consequences greater than 10 CFR Part 100
25 even though those guidelines are not designed for that

1 purpose. It is to assure that venting will not be a
2 severe health hazard compared to, say, the subsequent
3 failure.

4 We believe we want to see a high probability
5 that the containment will survive and that there will
6 not be a precipitous failure. That is, it will not fall
7 apart. So we think that is too narrow a criterion and
8 we are changing to some slightly broader criterion.

9 MR. OKRENT: At the Subcommittee meeting when
10 I asked this question, the only statement I was given at
11 that time, and the committee meeting continued after I
12 left, but you just said, look at the May 6th or whatever
13 it is letter, and you did not qualify it.

14 MR. MORRIS: I think it was the inadequacy of
15 that response that prompted us to come back today and
16 give you a better discussion, but that was what we had
17 said at that time.

18 MR. OKRENT: Is there something in writing
19 that modifies the position taken in that letter?

20 MR. MORRIS: We have said in the site
21 suitability report that that is under review, that
22 24-hour criterion is under review, and in the
23 subcommittee meeting on containment when we discussed
24 core melt accidents, I presented the new criteria we
25 would hope to impose. We are still evaluating those

1 criteria to determine whether we find them acceptable or
2 not.

3 MR. OKRENT: Are you telling us you are not
4 prepared to tell the ACRS today what your criterion in
5 this regard is? You are evaluating it?

6 MR. MORRIS: To recapitulate what I said
7 before at that earlier meeting, if that is what you
8 would like, if there is time to do that --

9 MR. OKRENT: It is what you would like. I am
10 trying to understand just what the Staff position is. I
11 just heard of a change which is different from what I
12 heard at the Subcommittee meeting which was held, I
13 think, only last week or the week before.

14 MR. MORRIS: I believe in the Subcommittee
15 meeting I was trying to say without I think referring
16 specifically to the 24 hours in my discussion, that we
17 would like for containment to be capable of retaining
18 radioisotopes for a sufficiently long period of time
19 subsequent to a core melt that the risk would be
20 acceptably low. We believe if that is done it will be
21 comparable with light-water reactors.

22 The specific time is what I think is the
23 problem here. The 24-hour number that was chosen and
24 was published in the May 6th letter of 1976 was based on
25 a judgment coming from WASH-1400 studies in which

1 containment failures occurred both before and after 24
2 hours and that was taken as a mean value to be used as a
3 target.

4 I think that there is somewhat of an
5 insensitivity of the consequences to the exact time of a
6 release provided the release is held up for a
7 sufficiently long period of time.

8 MR. SHEWMON: Could we leave it at that?

9 MR. MORRIS: So we have a criterion, but it is
10 not a very specific one such as 24 hours anymore.

11 MR. OKRENT: Well, Mr. Chairman, I am
12 confused. I think it is somewhat relevant to know what
13 their criterion in this regard is.

14 MR. SHEWMON: You may ask him to send it to
15 you. I am not sure asking him several more times today
16 is going to help.

17 MR. OKRENT: Well, you may find it hard to
18 write a letter when what we really heard is it is under
19 review.

20 MR. MORRIS: I would just point out that it
21 would be in the transcript of the Subcommittee meeting
22 on containment in which we discussed the core melt
23 accidents. Those criteria were spelled out there.

24 MR. CARBON: Mr. Chairman, I think it would be
25 worthwhile to ask him once more to try to be more

1 specific. Can't you be a little more precise in
2 answering Dr. Okrent's question? Forget what you said
3 in the past.

4 MR. MORRIS: Okay. Let me see if I can --
5 What I will have to do is recapitulate what those
6 criteria that we are proposing to use would be.

7 MR. OKRENT: Look, if you want to sit down and
8 tell us in an hour, that would be perfectly fine as far
9 as I am concerned. Collect your thoughts.

10 MR. SHEWMON: If you have got it written
11 someplace, that would be a little more authoritative
12 than you repeating what you think you said while on your
13 feet.

14 MR. MORRIS: I will address it later.

15 MR. SHEWMON: Now we get to discuss PRA? Is
16 that right? Mr. Stark, you are responsible for the
17 agenda here and to be a traffic cop, I was told. We
18 have now increased by 50 percent the number of people
19 who are on this agenda and the time is going up
20 appropriately. I hope you are a good traffic cop before
21 the day is over.

22 MR. STARK: Well, we have some provisions for
23 shortening some of the sessions later on if necessary.

24 MR. RUMBLE: My name is Ed Rumble, and in the
25 context of risk comparability, I am going to briefly

1 review a quick scoping analysis that was done, a short
2 scoping analysis that was done for input to the final
3 environmental statement regarding quantifying frequency
4 and consequences of some accident sequences for CRBRP.

5 There are a couple of things you should keep
6 in mind before I get started with the presentation. It
7 will be pretty short. I am talking about the CRBPP
8 design. There are some assumptions regarding
9 procedures, human interactions, things like that that
10 are comparable with LWR procedures and human
11 interactions -- These things are not available right now
12 -- and also that the plant is built the way it is
13 supposed to be built and maintained and operated the way
14 it is supposed to be.

15 On the other hand, in this analysis I did note
16 that there is a wealth of information, I guess a wealth
17 of analysis as background material that is available.
18 The accident delineation study at Sandia. There was a
19 PRA that was done earlier. CRBRP-1 is the name of the
20 report. There are a number of topical studies that have
21 been done. So there is quite a lot of information
22 available on this facility to start with.

23

24

25

1 (Slide.)

2 Basically, performing this analysis for the
3 FES. We had to start somewhere. Some of the basic
4 assumptions are on the first slide. The basic
5 considerations. First of all, as in an LWR, the
6 dominant risk associated with the facility comes from
7 the core. Secondly, the core inventories are comparable
8 on a megawatt basis. Plutonium is roughly a factor of 3
9 higher, but otherwise, it's roughly comparable -- the
10 core inventories are roughly comparable.

11 Thirdly, the starting point for looking at
12 core disruptive accidents -- the severe accidents are
13 the ones we're going to be talking about today -- is,
14 again, the heat imbalance problem, the heat generation
15 versus heat removal.

16 One can start from that point and fairly
17 logically deduce initiators that can get you into these
18 conditions and then try to quantify the frequency of
19 such initiators.

20 The types of accidents that could occur at
21 this facility are broken into three categories; internal
22 plant failures, external forces and sabotages. This is
23 a fairly important here that I am going to be discussing
24 in internal plant failures, and I have not done any work
25 directly, in a PRA-oriented vein, on external forces or

1 sabotage at this point. This is just the internal plant
2 failures.

3 There are really three phases to the
4 analysis. One is the initiation phase, then one looks
5 at the primary system and how that can be challenged;
6 and thirdly, one looks at the containment and how that
7 can be challenged.

8 In the initiation phase, as I mentioned
9 before, if you start with the heat imbalance and
10 logically proceed from there to look at the ways you can
11 get this heat imbalance, you come up with several
12 classes of accident initiators. On the second slide I
13 have these classes listed.

14 (Slide.)

15 They are fairly familiar. LOCA, flow
16 blockage, et cetera. The transients include here --
17 these transients mean that the scram system is demanded,
18 and in the transient category we include cases where the
19 scram systems do not work.

20 When you look at the internal plant failures
21 and you try and analyze their impact, you have to look
22 at the safety systems engineered in the plant and see
23 how they respond, such as decay heat removal systems and
24 the scram system. And this was done.

25 In addition, one other important point I

1 forgot to mention and a very large part of any kind of
2 analysis like this is you want to look at common
3 connections between initiators and containment failures
4 and primary system failures, things that can cause all
5 three to fail at one time. That is also part of the
6 thinking here.

7 Going on to the primary coolant system, once
8 we have the initiation of a core disruptive accident,
9 then we look at the ways the primary system can fail.
10 There are thermal failures, mechanical failures that are
11 considered. In the case of CRBRP there is a potential
12 for head releases after energetic CDAs, and also for the
13 bottom vessel head to fail from a melt-through type
14 situation.

15 There are some accident sequences that could
16 end at the point of a head release and no thermal vessel
17 failure if the vessel could retain the degraded core.
18 If the vessel does fail, then we have both a potential
19 head release and the dumping of the sodium, a million
20 pounds or more of sodium, plus the core inventory and
21 steel into the reactor cavity.

22 The next part of the analysis is the
23 containment response. The containment response is both
24 the thermal dynamic response and the integrity response.

25 (Slide.)

1 When you compare containment of the CRBRP to
2 the LWR, there are important differences. First of all,
3 in the design of the CRBRP, of course, we have sodium
4 which is many, many degrees below its boiling point. We
5 do not have the blowdown forces associated with LWRs
6 initially.

7 Additionally, we have the potential for a
8 relatively large amount of sodium aerosols to be in the
9 containment environment, which can play an important
10 role in fission product behavior. These aspects have to
11 be taken into account when looking at containment
12 behavior.

13 As far as containment failure modes are
14 concerned, there are the typical containment systems, as
15 are in LWRs. There's a containment isolation system,
16 for example. In addition, it has a filtered venting
17 system specifically for the severe accidents in which
18 the containment environment can be scrubbed and filtered
19 and vented out of the containment to maintain
20 containment integrity.

21 There is also the potential for prompt
22 failures in the containment due to, at this point,
23 hypothetically postulated type instances of very large
24 energetics or a very large sodium spray fire. These are
25 the aspects of the scoping analysis that were considered.

1 As I mentioned before, you have to look at
2 things that connect all three of these aspects together
3 that could all of them to fail at once.

4 (Slide.)

5 An important one that one has to consider is,
6 for example, loss of all off-site electric power. In
7 this case, electric power could supply power to both the
8 containment systems and to the engineering safeguard
9 systems, and this has to be looked at and it was looked
10 at in this analysis.

11 The point here is that there are a number of
12 systems that are available for decay heat removal, which
13 is a primary concern in this case. However, they all
14 require electrical power, and what may seem to be
15 totally diverse systems may not turn out to be when one
16 looks at the service systems needed to power these
17 systems. So in the case of the loss of all off-site
18 electrical power, electrical power plays a predominant
19 role at the site in this accident sequence.

20 So, one has to analyze the emergency power
21 supplies, the diesel generators and the batteries to
22 come up with frequencies for this type of an event.

23 Basically, these considerations were taken
24 into account and we came up with a set of accident
25 sequences which were then supplied for analysis so far

1 as consequence goes.

2 (Slide.)

3 I should mention the work I was involved with
4 was to develop frequency estimates and release fraction
5 estimates for typical accident sequences that could
6 occur at the site. This matrix sort of slide here shows
7 four types of accident sequences that were analyzed
8 using the COMIX code. It was considering both small and
9 large head releases and the various type of containment
10 failures one could have.

11 I guess at this point, if there are no
12 questions or further discussion, I want to turn it over
13 to Mr. Hulman who will discuss the risk numbers that we
14 got for these accident sequences.

15 MR. OKRENT: Just one easy question. What are
16 the weak points, would you say, in what you have done?
17 In other words, where do you feel that you may have made
18 poorly-based assumptions or you ignored things of
19 necessity, or whatever?

20 MR. RUMBLE: First of all, the completeness
21 question is certainly a weak point. This was a scoping
22 study to look at typical accident sequences. This is
23 not a fullblown PRA. Therefore, I have no confidence
24 that this is a complete study, although I did look at it.

25 For example, we looked for accident sequences

1 such as an interfacing system LOCA type of accident that
2 could occur in an LWR. A situation where you could
3 bypass the containment.

4 We spent some amount of time looking for it
5 with some information. There could be more time spent
6 in looking for these types of sequences. So the
7 completeness point is one area. Again, we're not
8 considering any external events or sabotage, but
9 certainly it should be pointed out as a very important
10 part of any PRA analysis and that was not done at this
11 point.

12 The human interaction area, of course, is
13 another area. Because we are looking at a paper plant
14 at this point, we don't know specifically how the human
15 is going to interface with this system.

16 MR. EBERSOLE: May I ask a question?

17 MR. RUMBLE: Those are some of the
18 weaknesses. I could go on.

19 MR. EBERSOLE: For the numerical values you
20 used, this containment uses a design which envisions
21 large flow ventilation and large purge valves
22 hypothesized to close under such pressure pulses and
23 release rates as one might get during an accident. What
24 reliability did you use to estimate the closure of the
25 containment in the mechanical context?

1 MR. RUMBLE: Yes. The containment isolation
2 system used a frequency of 10^{-2} per demand. We think
3 that is achievable for a containment isolation system to
4 be designed and operated and maintained at 10^{-2} per
5 demand or less. Typical LWR values I think are in the
6 10^{-3} to 10^{-2} range, 3×10^{-3} comes to mind as a
7 number for WASH-1400. And I think, reviewing the system
8 quickly, the number of valves 24 inch inlet and outlet
9 on that system, and the redundancy in the electronics
10 and things, I think that's achievable at 10^{-2} or less
11 for that system under accident conditions in the
12 environment for that system.

13 MR. SHEWMON: Thank you.

14 MR. HULMAN: Good morning, my name is Jerry
15 Hulman, I am Chief of the Accident Analysis Branch in
16 NRR. I want to talk about four interrelated subjects.
17 In the interest of brevity, I am going to do it quickly.

18 The first thing I'm going to talk about is the
19 risk of a beyond design basis accident. Secondly, I
20 want to talk about site suitability source term.
21 Thirdly, dose guidelines for site acceptability. And
22 last, the design basis accident enveloping event that we
23 have used for site suitability.

24 Ed Rumble has just told you about the accident
25 sequences and the consideration of probability and

1 release fractions. We have used that information in the
2 same manner that we would use it for a lightwater
3 reactor to evaluate the consequences and risks of severe
4 accidents for beyond design basis events, for
5 environmental impact statements.

6 Our conclusions are that the risks are
7 generally comparable. They are not only comparable for
8 a lightwater reactor of similar size, but they are also
9 comparable for a contemporary reactor of 1000 or 1200
10 megawatts.

11 With regard to site suitability source term,
12 we have presented to the subcommittee on two occasions
13 our conclusion that we can use a non-mechanistic event
14 that is analogous to what is used for lightwater
15 reactors and postulate the release of 100 percent of the
16 noble gases, 50 percent of the halogens, 1 percent of
17 the solids and 1 percent of plutonium in a design basis,
18 limiting kind of accident for site suitability.

19 The only difference between this array of
20 activity and what we use for lightwater reactors is the
21 addition of plutonium. Plutonium being a significant
22 potential dose contributor.

23 Questions were raised at the subcommittee
24 meetings about whether plutonium is the only actinide
25 that we've considered. I will try to address that

1 quickly by saying that we've considered all the
2 actinides and as it turns out, plutonium is the dominant
3 dose contributor. So we have used plutonium all by
4 itself and all the isotopes of plutonium in our site
5 suitability accident analysis.

6 With respect to dose guidelines for site
7 acceptability, for Part 100, we have dose guidelines for
8 site suitability for thyroid and whole body; 300 rem
9 thyroid and 25 rem whole body, respectively. For site
10 suitability purposes for the breeder, because we have
11 the possibility of releasing different kinds of
12 activity, we have added other organs and changed
13 somewhat the dose levels that we are using. We have
14 added lung, bone surfaces, red bone marrow and liver,
15 and have made dose equivalents to the lightwater reactor
16 dose guidelines in Part 100.

17 Basically, what we have tried to do is say we
18 do not want the risks from the breeder for design basis
19 accidents to exceed the risks from the lightwater
20 reactor. We have developed criteria for that. We have
21 evaluated the site suitability source term using
22 engineered safety features of the type being proposed
23 for the breeder, and have found that the resulting doses
24 we would get are a small fraction of the guideline.

25 That is brief and to the point. If anybody

1 . would like any details beyond that, I am happy to
2 present them. Yes, sir?

3 MR. SHEWMON: There is appreciable evidence
4 that the source term used for LWRs, there is little
5 physical resemblance to what the fission products are in
6 the gas in such an accident. This can be partly plate
7 out, agglomeration of particulates, conversion of iodine
8 to cesium, a variety of different things. Do we know
9 enough about how fission products are likely to come out
10 of the core or the pressure vessel of an LMFBR to say
11 that there is any comparable sorts of conservatism? Or
12 if we don't, is that largely irrelevant?

13 MR. HULMAN: The question is not irrelevant.
14 I think it is right to the point. Let me point out that
15 the staff has been considering the question of source
16 terms ever since Part 100 was formulated. Recently, we
17 have published two NUREGs on the subject for lightwater
18 reactors, NUREG-0771 and 0772.

19 In those NUREGs we found that there is a
20 possibility that the source term we postulated for site
21 suitability could be conservative for some accident
22 sequences. We have not been able to conclude to date
23 that it is conservative for all possible accident
24 sequences for lightwater reactors.

25 We have tried to consider very briefly the

1 same question with respect to the breeder. My
2 understanding of the staff judgment is the source term
3 we have postulated in terms of its contribution to
4 potential doses is representative of some kinds of
5 beyond design basis accidents and is not as conservative
6 as we might get for other events. It is not a bounding
7 source term for all possible breeder events. That is my
8 understanding of the staff judgment.

9 MR. SHEWMON: Okay. Any other questions? *

10 MR. MARK: You said, I believe, plutonium is
11 the dominant contributor to dose. Does that mean of the
12 heavy elements only plutonium is dominant?

13 MR. HULMAN: Of the actinides, that is
14 correct.

15 MR. MARK: The fission fragments are much
16 larger.

17 MR. SHEWMON: The statement was it was
18 dominant for the actinides, not dominant --

19 MR. MARK: Right. How do you get the curium
20 out of the picture? There is ten times as much activity
21 as plutonium.

22 MR. HULMAN: We have made a computation of the
23 release of all of the actinides, taking them through
24 decay in the containment structures and through the
25 annulus filtration system, out into the environment with

1 the normal atmospheric diffusion and have found that
2 their dose contribution is small with respect to --

3 MR. MARK: I am just unable to detach my
4 thoughts from the fact that there are ten times as many
5 alpha particles per second released by curium as from
6 plutonium. In the end-of-fuel cycle stuff in the fast
7 reactor, I can understand the curium may not be dominant
8 because you might have some reason for saying it is not
9 as volatile or something. I'm asking how you get rid of
10 it.

11 MR. HULMAN: We release it. I would like to
12 ask one of my staff who did the calculation to discuss
13 his consideration of the actinides, and it may shed some
14 light.

15 MR. BELL: What we did was, we ran the case
16 with all the actinides and we ran the case with strictly
17 the plutonium isotopes. What we found was that the
18 plutonium in the critical organs that we are considering
19 at the present time, it contributed 97 percent of the
20 total dose.

21 MR. HULMAN: Larry, I think the question was
22 how much curium did you release?

23 MR. BELL: The same amount as we did for
24 plutonium, 1 percent.

25 MR. MARK: One percent?

1 MR. BELL: One percent.

2 MR. MARK: Then it has ten times the alpha
3 activity, and so it must go somewhere else. Maybe it
4 does not go to the organs, or --

5 MR. BELL: Maybe not the ones we have been told are the
6 critical organs. I don't know. But it's not included
7 in these calculations; it just doesn't show up. It may
8 be that RAB of the --

9 MR. HULMAN: Is it the combination of decay,
10 Larry, and the diffusion conditions that you have
11 assumed that could result in curium not being the major
12 dose contributor?

13 MR. BELL: No, I wouldn't think -- well, it
14 may be decay. I would have to compare the decay
15 scheme--

16 MR. MARK: It's quite good enough for a
17 short-term dose.

18 MR. BELL: For a short-term dose, no, because
19 the filters presumably would act on all the elements the
20 same because we assume that they were particulate, but
21 maybe Walt Pashack will speak to that.

22 MR. MARK: I am just curious as to where it
23 goes.

24 MR. PASHACK: I am Walt Pashack, I am section
25 leader of the Radiological Assessment Branch. The doses

1 we're calculating here are 50-year dose commitments;
2 something that decays very quickly. Although the
3 initial absorbed dose rate by the body is very high, it
4 falls off very quickly.

5 And, of course, the other thing you have to
6 factor into these calculations is the effective
7 half-life within the body. So I don't know what the
8 numbers are specifically, but --

9 MR. MARK: Well, curium -- plutonium lasts
10 forever. It lasts for 30-odd-thousand days.

11 MR. PASHACK: But the body also has removable
12 mechanisms, and I don't know what the difference between
13 them is.

14 MR. HULMAN: Dr. Mark, I don't think that we
15 have given you a satisfactory answer to your question.
16 I propose to provide it to you.

17 MR. MARK: It could be that with your 50-year
18 assumption the curium goes away and the plutonium, after
19 five years, is dominant; for the first five years curium
20 is dominant, and that may be long enough to be bad for
21 the lungs.

22 MR. HULMAN: It very well may be, but I don't
23 believe we've provided you with a satisfactory answer
24 and I propose to give you one separately if that's
25 acceptable.

1 MR. MARK: There are things in the literature
2 where it is called to attention that there is a big dose
3 factor. An article in 1975 in Health Reactor Safety,
4 something like that. Certainly, the big radioactive
5 thing for the first several years has a very small
6 maximum permissible body burden and so on.

7 MR. HULMAN: Yes.

8 MR. MARK: So I would like to be clear on
9 this, because I am just giving some numbers which may
10 not be the important ones.

11 MR. HULMAN: We will provide that information
12 to you.

13 MR. OKRENT: I have a question about a
14 combination of things we have just heard. I just want
15 to understand with regard to contentions 1A, 2, 3B-D,
16 all of which are limited to feasibility of designing
17 CRBR plants to make CDAs sufficiently improbable that
18 they can be excluded from the DBA spectrum, according to
19 the handout from the staff.

20 When you meet with the ASLB, how will you
21 treat this term "sufficiently improbable"? Are you
22 going to have a numerical number, or are you going to
23 wave your hands, or what?

24 MR. MORRIS: This is Bill Morris of the NRC
25 staff. We will not present a numerical value as a

1 discriminator for that. We will base it upon the
2 deterministic criteria and the feasibility of achieving
3 a high reliability for those systems that are supposed
4 to prevent severe accidents.

5 MR. AXTMANN: In the original historical doses
6 proposed for thyroid, whole body for the LWR, most
7 assumed a source term of some kind. Did that involve
8 any chemistry involving water or were these assumed to
9 be all of these -- the iodine and the plutonium -- to be
10 simply airborne?

11 MR. HULMAN: Let me see if I can try and
12 briefly answer your question by saying that the LWR
13 source term history goes back to a footnote in Part 100
14 that refers to a technical information document, 14844,
15 that did consider the chemistry as they understood it at
16 that time.

17 But we wanted to try and envelope the type of
18 activity that could be released. There was a
19 substantial melting of the core.

20 Now, my understanding is they did not define
21 what they meant by a substantial melting of the core.
22 They did not define their considerations of the
23 chemistry, nor the water that would be available in a
24 wet containment. But there were considerations and, in
25 fact, we believe that the iodine that we're using to

1 represent the halogens was a surrogate of those elements
2 whose volatilities were generally similar, and was the
3 basis for selecting iodine at 50 percent.

4 MR. AXTMANN: Well, I am suggesting that
5 simply moving the LWR source term over to the CRBR might
6 violate assumptions on which the original LWR source
7 term was generated in all ignorance of what we seem to
8 be finding out the real source term is.

9 MR. HULMAN: Well, it may very well violate
10 it, but if I also consider what is in NUREG-0771 and
11 0772, which indicate that the present lightwater reactor
12 source term is probably conservative but we don't know
13 how much, and if I consider what Ed Rumble has come up
14 with for release fractions from his analysis of accident
15 sequences for beyond design basis events, I think we
16 still have an analogous source term. It may be
17 conservative; it may not be, but it is analogous.

18 MR. AXTMANN: Well, it might be quite
19 different if the original source term did involve water
20 reactions. It didn't involve cesium, iodide and those
21 sort of things.

22 MR. HULMAN: Yes, and it didn't involve the
23 effects of tellurium and ribidium, that's correct.

24 MR. AXTMANN: I should think that would be
25 worth looking into.

1 MR. SHEWMON: I think my personal feeling is
2 that the water reactor source term, using that source
3 term for water reactors is extremely conservative. On
4 the other hand, if you go back and say look, we have 20
5 percent of these things coming out past sodium, all the
6 noble gases are part of the particulate -- that seems to
7 bound things. You can't really increase iodine much
8 more than a factor of 5, and there's a very good chance
9 that the sodium iodide is semi-stable, at least.

10 MR. AXTMANN: You may be quite right, unless
11 they did take credit for the water atmosphere.

12 MR. SHEWMON: They don't. That was the
13 earlier contention in this 701 and 702, or whatever the
14 NUREGs were that he talked about, that often the water
15 does -- or the cesium iodide would tie it up, that water
16 would wash it down.

17 But there is good evidence that in a lot of
18 accidents, there's a great deal of conservatism in that
19 set of assumptions.

20 MR. AXTMANN: Right. Brand new chemistry was
21 dimly perceived after TMI, but I am just wondering if
22 other chemistry --

23 MR. OKRENT: Could I make a comment? It seems
24 to me there are two kinds of source terms. There is the
25 source term that is used in defining the requirements

1 for the impact on containment leak rate, so forth and so
2 on, and that is what is in 10 CFR Part 100, and that's
3 what I understand was this source term. It is not
4 related to a specific accident scenario, it is not
5 related to what is functioning and what is not
6 functioning and so forth.

7 Then there is -- I don't know what the term
8 conservative means in connection with the source term.
9 It was developed a long time ago with a different kind
10 of reactor situation in mind. Small reactors in large
11 containments, in effect.

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. AXTMANN: That is what I am objecting to.
2 Simply going from the lefthand column to the righthand
3 column.

4 MR. OKRENT: This discussion of conservatism
5 and the TMI accident and so forth, now you have to ask
6 yourself what happens in various accident scenarios if
7 you are going to follow them mechanistically. Then you
8 have to follow the full spectrum, and you treat each
9 event. Well, if you want to follow that route as
10 accurately as you can with the uncertainties and
11 presumably that is related to what is your estimate of
12 the risk from the plant. You are not assuming the
13 containment holds all the time now. If the containment
14 is going to fail, it is going to fail, and some stuff is
15 going to get out. If it holds, it will be a different
16 situation. It is another set of analyses.

17 So, I must say, I would be inclined not to mix
18 this NUREG-0771 one and 0772 with the discussion of the
19 particular source term you are talking about. They need
20 to have a source term in order to meet Part 100. There
21 is a requirement they do a site suitability calculation,
22 and frankly, I am somewhat more interested in the
23 question of what is going to be the containment
24 capability for a spectrum of accidents.

25 MR. SHEWMON: We each have our interests.

1 MR. OKRENT: No. But here you are examining
2 what I have sometimes in writing called a ritual that
3 Part 100 requires.

4 MR. SHEWMON: One other physical chemical
5 fact. When these things come out, they are very likely
6 to come out through a crevice, a floor, a small hole or
7 something, and what gets taken out by aerosoles is very
8 poorly treated these days, and is probably not at all
9 conservatively treated, so that's something else in your
10 back pocket, but we are not smart enough to handle it,
11 so we don't, is my impression of it.

12 MR. HULMAN: I would agree with that.

13 MR. SHEWMON: Are there other questions?

14 MR. HULMAN: One question was raised at the
15 subcommittee meeting on what is the foreign experience
16 with site suitability source terms. I believe the
17 applicant is prepared to answer that one.

18 MR. CLARE: Good morning. I am George Clare.
19 I am going to try to address two questions that were
20 left over from our meeting with the subcommittee two
21 weeks ago. First is a comparison of the Clinch River
22 source term with that used in foreign countries. Second
23 was a somewhat unrelated question relating to the
24 off-site effects of sodium reaction products.

25 (Slide.)

1 MR. CLARE: Very briefly, what I have done is
2 given you a vu-graph that compares the site suitability
3 source term used in the United States for CPBRP with
4 that used in the United Kingdom for the CDFR reactor and
5 in Japan for the Monju reactor. You will note that the
6 source terms that are released to the containment of
7 these other two reactors in their site suitability
8 studies are identical to that used in the United States,
9 with the exception of Japan, where they have decreased
10 the fraction of the halogens that are assumed to be in
11 the containment.

12 I haven't indicated for the U.K. or Japan what
13 might be considered airborne as compared to what might
14 be considered to be plated out in the containment. We
15 just do not know that information at this point in
16 time.. The 50 percent used in the U.K. may be all
17 airborne. There may be some plated out. In Japan, this
18 10 percent number may be all airborne, or may be in some
19 part plated out.

20 For France and Germany, we are unaware of any
21 equivalent of our site suitability source term. We do
22 not believe the French use any major accident,
23 hypothetical or otherwise, source term in their siting
24 studies in any specific sense. In Germany, we know they
25 do deterministic type studies similar to our studies of

1 hypothetical core disruptive accidents. They have
2 applied some determination of acceptability of the risks
3 from those accidents, but that evaluation is not done in
4 terms of a site suitability evaluation the way these
5 site suitability source terms are used in the United
6 States, the U.K., and Japan.

7 Our overall conclusion from this is that the
8 site suitability source term specified for the staff for
9 CRBRF is comparable, favorably comparable to that used
10 in siting foreign LMFBR's.

11 The other subject I want to address is the
12 non-radiological effect of sodium reaction product
13 aerosols. First, to briefly review what are the sodium
14 reaction product aerosols that we are interested in.
15 When sodium burns with oxygen, one gets sodium oxides of
16 various sorts, NaO_2 , Na_2O , various products. Those
17 products can and do in fact combine with water,
18 specifically water vapor and air very quickly, in a
19 matter of seconds, to become sodium hydroxide. The
20 sodium hydroxide can itself react with other elements in
21 the air, other constituents of the air, specifically
22 carbon dioxide, and in a time frame ranging from say a
23 half minute to a few minutes, sodium hydroxide will
24 convert to sodium carbonate, Na_2CO_3 , released in water.

25 Over a much longer period of time, the sodium

1 carbonate can also be converted to sodium bicarbonate,
2 taking again a hydrogen atom up from the water in the
3 air.

4 Now, I want to emphasize that the effects of
5 the sodium reaction product aerosols, radiological or
6 otherwise, have been considered in the design of the
7 plant, specifically in our environmental qualification
8 program and in our control room habitability studies.

9 We are not asking you to review these details
10 today. However, I bring them up here because it is
11 important, and in these considerations we have reached a
12 conclusion that it is necessary, it is prudent to
13 provide aerosol medication features on the plant.
14 Specifically, on our steam generator building where we
15 can have significant quantities of sodium,
16 non-radioactive sodium, in our intermediate heat
17 transport system piping, and the pumps, et cetera,
18 where, if we had a fire, it would leak from that pipe
19 and a subsequent sodium fire, one can release a
20 significant amount of aerosols to the environment.

21 We have specifically provided features,
22 dampers, protectors, appropriate features to minimize
23 the release of those aerosols while still allowing the
24 pressure relief that is necessary to relieve the
25 pressure that can be built up as a result of the sodium.

1 Also, although I failed to note it in writing
2 on the vu-graph, we are considering the non-radiological
3 effects of sodium fires, sodium reaction products in our
4 emergency planning. That was done for FFTF. They have
5 identified in the FFTF emergency procedures, the
6 appropriate points in time at which various actions of
7 the emergency plan would be taken.

8 Now, just to give you a feeling for the
9 effects off-site, what I will call site boundary
10 effects, of a major fire, I have tried to provide on the
11 next vu-graph an outline of a fairly simple calculation
12 that could be done to estimate that.

13 (Slide.)

14 MR. CLARE: First of all, if we assume that a
15 design basis leak in our intermediate heat transport
16 system piping were to take place in the steam generator
17 building, it's a spray fire some 1000 gallons per minute
18 of sodium burning in air, assume that 100 percent of the
19 reaction products from the sodium oxidation would become
20 airborne as sodium oxide, and then of course converting,
21 as I indicated on the earlier vu-graph, and that the
22 mitigation that takes place would only take place to the
23 extent that we have designed our engineered safety
24 feature mitigation system in the plant.

25 We evaluate that using the HAA3 code, which is

1 a well validated code, for the calculation of the
2 depletion of the fallout, the plateout of sodium oxide
3 aerosols. It has been validated against tests at the
4 containment test facility at the Hanford facility. It
5 is a very large facility that shows very good comparison
6 between the experimental evidence in the code.

7 What one finds is that we would release 440
8 pounds of sodium oxides in five minutes, over a period
9 of five minutes. Combine that with site measured
10 meteorology, which gives one a chi over Q of 1×10^{-3}
11 seconds per meter cubed, taking into account the fact
12 that there would be some settling of the aerosol over
13 the roughly half-mile transit from the plant site to the
14 site boundary, the fact that that would take several
15 minutes to take place, we don't know how significant
16 conversion of the sodium hydroxide to sodium carbonate,
17 which is not a great irritant to the human body, one
18 finds that we would have a site boundary concentration
19 for this five-minute period of roughly seven milligrams
20 of sodium hydroxide per cubic meter.

21 Our conclusion then is that the off-site
22 concentration of sodium reaction product aerosols will
23 be low. Seven milligrams per cubic meter is low in the
24 sense that we have known various instances, for example
25 in our experimental facilities, where there have been

1 either intentional or accidental fires of sodium and
2 other liquid metals, and the workers there have been
3 exposed to concentrations as high as 50 to 100
4 milligrams per cubic meter, no effects other than some
5 irritation of the eyes, the nose, and the throat, et
6 cetera. When you do get up around 50 milligrams per
7 cubic meter, the symptoms are such that the workers do
8 want to lay down their tools and get out of the room,
9 but there is certainly no permanent damage of any sort
10 at concentrations as high as 50 milligrams per cubic
11 meter. There have been tests done on animals by
12 Battelle Laboratories, and they find that there is no
13 tissue damage for concentrations as high as roughly 50
14 milligrams per cubic meter.

15 MR. EBERSOLE: Can these materials act as
16 carriers of fission products?

17 MR. CLARE: We assume that whatever fission
18 products might be distributed in sodium in the coolant
19 can be carried by the sodium aerosols either by the
20 aerosols or perhaps even separately, but in the same
21 types of calculations that we do here, and in fact we
22 calculate the off-site doses for all accidents where we
23 could potentially release radioactivity with sodium in
24 pipe leaks and that type of accident.

25 MR. OKRENT: Is the steam generator building

1 seismic Class 1?

2 MR. CLARE: Yes, it is.

3 MR. OKRENT: And the whole secondary line, and
4 the steam generators are seismic Class 1?

5 MR. CLARE: That is correct.

6 MR. SHEWMON: While he is thinking of another
7 question, let me inquire what the project's policy is
8 about having any water lines within containment.

9 MR. CLARE: We do have water lines within
10 containment. We have strict criteria about how we
11 separate those water lines from any cells where sodium
12 is present. The water lines we have are there for
13 equipment decontamination. We have a decontamination
14 facility there. We would like to wash some of the
15 radioactive sodium off of equipment. We also have some
16 water for cooling.

17 MR. SHEWMON: In any of the accidents you are
18 postulating or Mr. Rumble is postulating, the water
19 lines have to be in the top half of the building and the
20 sodium will all run into the bottom half of the
21 building? I am looking more for criteria of that sort.

22 MR. CLARE: We don't have criteria that say
23 that the water lines have to be in the top half or the
24 bottom half. The criteria are along the line that one
25 must have at least three barriers between sodium and

1 water, and there are various subcriteria as to what
2 those barriers can consist of. For example, one
3 typically has two passive barriers and one active
4 barrier.

5 MR. SHEWMON: Well, at a later time I would
6 like to get into just whether, if we're getting into a
7 core melt or containment or something, they would cope
8 with that, which takes a pretty good material. Yet if
9 you start having water and sodium together, you are
10 going to transform the containment problems, as you
11 realize at least as well as I do.

12 MR. CLARE: Yes. We have addressed those
13 things, and we can go over that in the future.

14 MR. OKRENT: If we postulated that somehow a
15 steam generator disintegrated and the building went with
16 it, could you get lethal doses of sodium at the site
17 boundary? I assume there is some quantity of sodium.

18 MR. CLARE: I have never studied what would
19 happen if the steam generator disintegrated and the
20 steam generator building and what effect that would
21 have, so I can't give you a very firm answer to that. I
22 think one of the major conservatisms in our analysis
23 here are assumptions about the spray nature of the fire
24 and the fact that we would release --

25 MR. OKRENT: I just wanted to know whether at

1 the limit there are risks, let's say, of either death or
2 very, very severe injury or not from sodium. You say
3 you haven't studied it?

4 MR. CLARE: We haven't studied the type of
5 accident specifically that you mentioned.

6 MR. OKRENT: You don't need an accident. You
7 only have to postulate a release. I don't know how many
8 milligrams per cubic meters it takes. Presumably it is
9 something much greater than 50, but you haven't told
10 me. Is it 500? Can you reach 500? Is it 5,000? Can
11 you reach 5,000? It is just a benchmark which is of
12 some interest when you are thinking about lower
13 probability events.

14 MR. CLARE: Frankly, there has been so little
15 problem with sodium, sodium fires, et cetera, say, OSHA
16 or any of the typical bodies that deal with chemical
17 hazards haven't specified, haven't come up with any kind
18 of information that would help us define that.

19 MR. OKRENT: Do you have information on the
20 event that occurred in Russia, how much sodium got into
21 the air and how far it went?

22 MR. CLARE: No.

23 MR. RAY: Okay, we'll take a ten-minute break
24 at this point.

25 (Whereupon, a brief recess was taken.)

1 MR. SHEWMON: Gentlemen, as is our wont, we
2 have come up with things that have interested us and
3 stretched out the early part of the agenda. To try to
4 shorten this up, what I propose is that we treat the
5 site suitability or the description of the site very
6 briefly, since it is in the blue book, that we handle
7 the seismology by questions, and that we get the full
8 treatment on the hydrology, since the questions of dams
9 and other such things is a question which has not been
10 settled satisfactorily at the subcommittee meeting.

11 MR. STARK: This is Richard Stark. I was
12 asked to summarize very quickly the findings of the
13 staff on population and site location. I apologize to
14 Henry Piper for trying to do his work for him. I point
15 out that in the document of interest, the site
16 suitability report, NUREG-0786, the population
17 distribution is shown on Page III-I, and I will quote
18 one sentence:

19 "Approximately 4,400 people reside within five
20 miles of the Clinch River site in 1980." I will point
21 out one other thing, that the site itself is located 25
22 miles away from Knoxville, which is, I guess, the
23 closest large city. In addition to that, the document,
24 Chapter 3 of the document describes the population and
25 the distribution, and I will just leave it at that.

1 MR. SHEWMON: How far is it from Oak Ridge
2 Labs?

3 MR. PIPER: It is four and one-half miles.

4 MR. SHEWMON: I guess I look at that as more
5 of a plus, because you have a fair population who have
6 heard of nuclear energy before, and might be of help in
7 an accident. It was in that sense that I was interested.

8 MR. SHEWMON: We are ready now for the
9 seismology and geology. Who is the speaker? An eminent
10 seismologies.

11 MR. KNIGHT: This is Jim Knight from the
12 staff. You had mentioned that we would do this by
13 question. Might I suggest further, particularly after
14 yesterday's session, when we had a similar discussion on
15 Perry, the suggestion was made that perhaps this is a
16 matter suitable to be brought before the Committee in
17 and of itself.

18 Dr. Rockman is here. We are prepared to
19 discuss what we think are the germane items that we
20 could handle in 20 minutes, a discussion fully of the
21 subject. I see eight to fifteen staff members for a day
22 and a half or more to get into this type of thing.

23 MR. SHEWMON: Yes, I think that recurrence
24 time and such things do come into the staff policy and
25 is something we would like to have, but I think it would

1 be best done at a subcommittee meeting instead of trying
2 to have it now. Why don't we just handle this by
3 questions, if we could? At least Dave said he had some
4 questions he could start with.

5 MR. OKRENT: Well, as you are aware, there
6 will be differences regarding the estimates of the
7 probability of SSE exceedence that will probably range
8 somewhere between one in 2,000 and one in 10,000 per
9 year type things. If we accept that this is likely to
10 be the situation, and in fact it is from what I have
11 already seen, how do you propose to assure yourself that
12 the combination of SSE design and design basis and the
13. actual design and the qualification of various things
14 and so forth gives you an adequate degree of protection
15 for this plant, which is not like an LWR in many ways,
16 so you cannot draw fully on LWR experience on margins.

17 MR. KNIGHT: Yes, and the only answer that I
18 can give you on behalf of the staff is that in our
19 review to date, we do not see features of the plant that
20 are, let's call them exquisitely sensitive. We have no
21 structured program at this point that would call for
22 some increase in seismic value, given some trigger
23 level. The presumption, and I feel it is a sound one at
24 this point, is that matters of structures, systems,
25 basic components in the plants, we don't have a

1 situation different from light-water reactors. We have
2 specific design problems, and as the plant design
3 evolves, we may well see something that requires
4 attention and will have to be handled on an ad hoc basis.

5 That is the posture we are in.

6 MR. OKRENT: Well, you see, you are saying you
7 are finding that the site is suitable for a reactor of
8 this type, but I am not sure if you know the seismic
9 characteristics of a reactor of this type, if you know,
10 for example, is there a margin with regard to the lining
11 on the concrete rooms or a margin on the guard vessels
12 or whatever that is sufficiently large so that you have
13 considerable structural capability to take an earthquake
14 of lower probability but a higher degree of shaking than
15 the proposed design basis, or that other things that may
16 be vital to whatever equipment you need to run for a
17 shutdown heat removal given an earthquake, that it will
18 be such that there is the appropriate margin.

19 In fact, I do not even know that you expect to
20 look to see whether there is additional margin. In
21 fact, a member of the staff yesterday, in talking about
22 Perry, I think indicated he did not see any point to
23 looking at an iota beyond the SSE.

24 MR. SHEWMON: What is the question?

25 MR. OKRENT: They are making a finding on a

1 reactor site suitability of a certain type, and I am
2 trying to find out -- they won't give a number, but on
3 the other hand we do have this range of estimates for
4 the SSE which are like one in 2,000, one in 10,000 per
5 year. Are you saying that is a sufficiently good number
6 with regard to a major release? I do not think you are
7 saying that. Even though you will not give a number, I
8 am sure you will say that that number is not a good
9 number. Therefore, you have to have some margin, and
10 yet you can't.--

11 MR. SHEWMON: The margin doesn't have to be
12 the occurrence of the SSE.

13 MR. OKRENT: Exactly, but it is not clear that
14 they have in mind to assure themselves of this margin or
15 whether they in fact know that the reactor of this type
16 is capable of providing the margin. I am not saying
17 that this is undoable, but I haven't heard the staff say
18 they are going to do it.

19 MR. SHEWMON: Jim, you have been over the
20 hoops a couple of times before this committee on would
21 you go back and look more closely at that particular
22 plant and come back and see what has the smallest
23 margin. You do this with certain codes and procedures.
24 To what extent are there comparable codes, and are you
25 sure that at least the applicant has designed to

1 acceptable procedures so that you have a reasonable
2 confidence that they are a comparable margin in the
3 plant we are proposing putting here.

4 MR. KNIGHT: There are two facets to the
5 answer to that question, the first being that yes, we
6 believe that we have a totally analogous system from the
7 standpoint of the codes that are in place, the
8 engineering methodologies that are in place, and as I
9 said earlier, at this juncture we are at a rather
10 advanced concept, and looking at it from the standpoint
11 of very probably a site suitability that there is every
12 reason to believe that we will have the same type
13 margin, the reinforced concrete structures. You have
14 linings very analogous to what you have in fuel pools,
15 the piping systems, and all of the usual type of things.

16 MR. SHEWMON: They are not very thick walled.

17 MR. KNIGHT: I beg your pardon?

18 MR. SHEWMON: The piping systems are not very
19 thick walled in that area.

20 MR. KNIGHT: They are not thick walled, but
21 there are design codes for them that must be adhered to.

22 MR. SIESS: The pressure doesn't dominate the
23 piping load as much as it would for pressure piping.

24 MR. KNIGHT: Absolutely true.

25 MR. SIESS: Would the ratio of seismic stress

1 to the total stress be significantly different?

2 MR. KNIGHT: I would have to believe it would
3 be, yes. But again, I don't believe it is so different
4 that you are thrown into a situation where you have an
5 unknown.

6 MR. SHEWMON: That was the first question. You
7 are dividing your answer into two parts.

8 MR. KNIGHT: Yes. The other is, and I think
9 it is directly related to that, yes, there is a system
10 in place, a recognized system by which you do these
11 things, so that when you are done you know what those
12 margins are. You can find them if you want. You can
13 report them. You can understand them. I feel that
14 there is a tendency to say, well, before the fact, let's
15 significantly increase the seismic input and then go
16 away and be satisfied that we have added lots of
17 margin. I think that that is not really the way to go.
18 If a distinct margin is desired and necessary, it ought
19 to be, first of all, let's see what we have, because I
20 believe the necessary premise for that is that we do
21 have particularly in the major structures to start with
22 very analogous situations, and see what we have, and if
23 there are areas that are exquisitely sensitive, if there
24 are places where the margins are too close for comfort,
25 examine those on that basis, rather than an overall

1 interest.

2 MR. OKRENT: I just wanted the subject
3 discussed briefly to save time, and I think that is the
4 issue that was most relevant.

5 MR. SHEWMON: Are there other seismic and
6 geologic questions?

7 MR. SIESS: Jim, when I looked at the Zion
8 PRA, I got some kind of a feel for the seismic margins.
9 Do we have a PRA for the CRBR that would be comparable?

10 The question is, do you have a PRA that
11 includes the seismic effects for the CRBR.

12 MR. MORRIS: A PRA will be performed.

13 MR. SIESS: With seismic effects?

14 MR. MORRIS: With seismic effects included. I
15 don't know. I cannot state now that it will be a design
16 PRA in that sense, but it will include seismic margin
17 evaluation.

18 MR. SIESS: I guess Dr. Okrent's question
19 could be stated -- I guess the question couldn't be
20 stated, but he is asking, do you expect the results to
21 look like the Zion results. Do you have the same kinds
22 of margins you have in this that you would have had in
23 an LWR, or am I misquoting you?

24 MR. OKRENT: I don't want to endorse the
25 specific Zion results. That is my only reservation.

1 They claim some pretty seismic resistant systems that
2 the staff's consultants have questioned, for example.

3 MR. SIESS: And we all reserve the right not
4 to endorse the CRBR results.

5 MR. SHEWMON: But my impression was that what
6 Jim said, he had every reason to believe from what the
7 codes and procedures involved said that there would be
8 comparable margins.

9 MR. SIESS: That's what he said, and I am
10 saying a PRA with earthquakes in it would give another
11 basis for judging that the margins are comparable in the
12 two types of plants, and it would be a different kind of
13 basis, because it would be systems related rather than
14 stress or code related.

15 MR. SHEWMON: Yes.

16 MR. SIESS: When will you have that PRA? This
17 will be performed by the project?

18 MR. MORRIS: Yes. I believe the PRA is
19 scheduled to be completed somewhere between the issuance
20 of the CP but prior to the final OL issuance.
21 Therefore, it would be possible before granting an
22 operating license to have evaluated this question of the
23 margins for severe earthquakes and to determine what the
24 situation would be at that time.

25 MR. CARBON: Bill, has the applicant committed

1 to do the phase of the PRA that includes the seismic
2 aspect?

3 MR. MORRIS: Yes. We have a letter from the
4 applicant in which he explains the way he will perform
5 the PRA, and the sequence in which that will be
6 performed, and those phases will be performed on the
7 schedule appropriate for the evaluation between the CP
8 and the OL.

9 MR. SHEWMON: Mr. Goeser, do you have any
10 other comments?

11 MR. GOESER: We have indeed provided the
12 plan. We have committed to do the seismic evaluation
13 and the current schedule for completion of it is
14 December of '84.

15 MR. SHEWMON: Thank you.

16 MR. GOESER: That is completion of the entire
17 study.

18 MR. SHEWMON: Okay. Are we ready to go on to
19 hydrology now?

20 MR. OKRENT: I wonder if the staff is ready to
21 provide that answer they were going to take a half an
22 hour or an hour to think about. Do we have a short
23 answer? They said they had modified their position.

24 MR. MORRIS: Bill Morris, NRC staff. I have
25 provided the excerpts from the previous subcommittee

1 meeting, and I think that is what you have got in your
2 hand there.

3 MR. OKRENT: That is the staff position?

4 MR. MORRIS: That is the interim staff
5 position to replace the 24-hour criterion, but I must
6 say that we are still evaluating that position. We are
7 still looking at that.

8 MR. SHEWMON: Okay. Mr. Lee?

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 My agenda says Mr. Lee. This is the guy who
2 stood up when I asked. Is my agenda wrong?

3 MR. LEE: I am Raymond Lee from TVA. I will
4 give a quick review of what went into the determination
5 of the design basis flood level at the CRBR.

6 We looked at two types of events; one, a
7 rainfall flood, and then two, seismic-caused floods.
8 For the sake of time, since the rainfall flood and the
9 rainfall flood we used, -- and since the CRBRP is a
10 nuclear plant, we used the probable maximum flood in
11 determining the rainfall flood elevation -- and since
12 the maximum elevation was 778 at the site, which is 26
13 feet below the controlling event or 27 feet below plant
14 elevation 815, unless there are any questions I won't go
15 into how we determined that.

16 But I would rather go on to the seismic-caused
17 event which produced a controlling elevation.

18 In the seismic-caused flood, we looked at two
19 types of conditions. One is an operational basis
20 earthquake, coincident with a one-half PMF, and a safe
21 shutdown earthquake, SSE, coincident with a 25-year
22 flood. We looked at all dams upstream of the CRBR site,
23 both individually and in groups, to determine the
24 controlling situation.

25 It was found that the controlling situation in

1 both cases was the failure of Norris Dam. The
2 controlling elevation is given by the OBE failure of
3 Norris.

4 MR. SHEWMON: Would you compare the one-half
5 PMF and 25-year flood for me? Could you quantify that
6 somehow?

7 (Slide.)

8 MR. LEE: Yes. The PMP or probable maximum
9 precipitation is the rainfall that produces the probable
10 maximum flood. At the CRBR site, it was a nine-day
11 storm consisting of a three-day main storm amount of
12 17.2 inches, and a three-day antecedent storm, which is
13 40 percent of the three-day main storm, of 6.8 inches,
14 for a total of 24 inches in 9 days in the watershed
15 above Watts Bar Dam.

16 The drainage area above Watts Bar is 17,000
17 plus. So half the PMF would be half that value.

18 MR. SHEWMON: Of rainfall?

19 MR. LEE: Correct. So it is significantly
20 greater than the 25-year flood.

21 MR. SIESS: Half the PMF is what? Is that the
22 standard project flood?

23 MR. LEE: That is comparable to the standard
24 project flood.

25 MR. SIESS: It was just arbitrarily taken as

1 half as being comparable?

2 MR. LEE: We take half because as specified in
3 Reg Guide 1.59, those are the two conditions we have to
4 look at.

5 MR. SIESS: The Reg Guide calls the standard
6 flood one-half the PMF?

7 MR. LEE: Yes.

8 MR. SHEWMON: I do happen to know that the
9 25-year maximum flood is appreciably different than
10 that, but would you tell me what the 25-year flood is in
11 inches?

12 MR. LEE: You can't relate rainfall
13 necessarily to a frequency of flood, but I can say that
14 a 25-year flood would occur on the average of once every
15 25 years, or have a chance of one.

16 MR. SHEWMON: Thank you. I will ask you the
17 question again in a few minutes when you get to working
18 with different units. Go ahead.

19 (Slide.)

20 MR. LEE: Looking at the elevations obtained
21 from the three events, as I said, the PMF is
22 non-controlling. The elevation of the PMF at the site
23 upstream into the site is 777.5, the OBE failure of
24 Norris coincident with the one-half PMF flood at the
25 upstream end of the site elevation is 804.3, and the SSE

1 failure with the 25-year flood is 796.3.

2 Those elevations compare with plant grade
3 elevatio 815.

4 MR. OKRENT: Suppose you did the SEE failure
5 with average flow conditions; how much different would
6 that be?

7 MR. LEE: Not significantly different. It
8 would be somewhat lower due to the fact that your
9 25-year flood has your reservoir levels at a high
10 level. If you use a regular situation it would be lower.

11 MR. OKRENT: So it's primarily a matter of how
12 much water you have in the reservoir and nothing else?

13 MR. LEE: Well, that's the biggest factor,
14 right.

15 MR. OKRENT: Do you have high water in the
16 reservoir for other reasons sometimes, other than
17 because of flood conditions?

18 MR. LEE: No.

19 (Slide.)

20 Okay. To arrive at the controlling elevation,
21 804.3, which is the OBE failure of Norris, we postulated
22 a failure mode, okay? We postulated that blocks 33
23 through 40 in the center of the dam -- that is the tall
24 blocks -- we assumed they would fail, and we assumed
25 they would be deposited downstream of the dam as shown.

1 The analysis that went into determining this
2 mode of failure will be addressed shortly by Tom
3 Abraham. Using this mode, we had a model study made to
4 study the discharge rating, and it didn't agree very
5 well with our analytical solution but we used the lab
6 model to be sure we had the correct discharge from this
7 configuration.

8 MR. CARBON: The OBE corresponds to .125g, is
9 that right?

10 MR. LEE: Yes.

11 MR. CARBON: You are saying here that this is
12 your best estimate of what would happen to Norris Dam?

13 MR. LEE: That is our best judgment of what
14 would happen.

15 MR. CARBON: With that magnitude.

16 MR. LEE: That is correct.

17 MR. SHEWMON: Does TVA have a seismic criteria
18 for the design of their dams?

19 MR. LEE: I will have to defer that question
20 to Mr. Abraham.

21 MR. ABRAHAM: Originally, it was analyzed for
22 one-tenth, an acceleration equivalent to one-tenth of
23 that. We made a re-analysis to measure for this nuclear
24 plant. Let me say quickly that in the total analysis of
25 Norris Dam, TVA does not feel that Norris Dam would fail

1 in this kind of an earthquake.

2 We have done a conservative analysis on the
3 information I will give you later, and we stand by the
4 fact that in assessing all of our dams in which Norris
5 came up, that Norris would not fail under the maximum
6 earthquake that could be expected in the region.

7 However, in the interest of conservatism, in
8 siting this nuclear plant, we took the position that we
9 could not definitely prove it would not. Therefore, we
10 took the most conservative position in postulating the
11 failure. This was originally analyzed for one-tenth g
12 seismic coefficient with no amplification of the base
13 acceleration.

14 MR. SIESS: By that mean, you mean equivalent
15 static?

16 MR. ABRAHAM: Yes.

17 MR. SIESS: And the analysis that leads to
18 that picture is .125g on the same basis?

19 MR. ABRAHAM: That analysis is .09g.

20 MR. SIESS: I thought he said it was the OBE,
21 and I thought somebody asked if the OBE was .125 and the
22 answer was yes.

23 MR. SHEWMON: The OBE is for the nuclear
24 plant, isn't it?

25 MR. LEE: Yes.

1 MR. SIESS: Is the OBE for the dam the same as
2 the OBE for the nuclear plant?

3 MR. LEE: I don't know if we have the OBE for
4 the dam as such.

5 MR. SIESS: Then I don't guess I understand
6 anything. You're not analyzing the dam for the
7 earthquake at Clinch River, at the site; the dam is
8 somewhere else, isn't it?

9 MR. LEE: This postulation was from the
10 analysis made for the CRBR. Isn't that right, T.J.?

11 MR. ABRAHAM: Yes, that is correct.

12 MR. SIESS: The figure is entitled "Analysis
13 for OBE at one-half PMF assumed condition of dam after
14 failure." Now, you can take it word by word, or
15 somebody can tell me what it means.

16 MR. SHEWMON: Let me tell you what I think.
17 What happened was the one-half OBE is defined at the
18 plant, and you assumed that that same earthquake would
19 occur at the dam, and that the dam would fail. Is that
20 correct?

21 MR. HUNT: My name is Joe Hunt, I am with TVA
22 engineering design. Let me clarify this a little bit,
23 if I could. The analysis of Norris Dam for nuclear
24 plants was originally done for Sequoyah and the Buford
25 plant. At that time, the OBE was .09g.

1 MR. SIESS: The OBE for what, the dam or
2 Sequoyah?

3 MR. HUNT: For the dam. We assumed the OBE
4 occurs at the dam. Now, in the interim, of course, the
5 OBE has increased. The failure of the dam would not be
6 influenced by the difference between .09 and .125g.

7 MR. SIESS: That helps a lot.

8 MR. HUNT: The analysis of the dam considered
9 that the 90g was amplified up through the dam, and Tom
10 will get into that in his presentation.

11 MR. OKRENT: Do you have another figure that
12 shows what your assumed failure mode is if you have the
13 SSE?

14 MR. LEE: I don't have a figure but I can tell
15 you what it is. It is the conditional blocks in this
16 link becomes 833 feet instead of the 665 feet.

17 MR. CARBON: Say that again?

18 MR. LEE: This is for the OBE case. In the
19 SEE case we have additional blocks that would fail,
20 increasing the length from 665, as shown for the OBE, to
21 833. We are still with the same debris configuration
22 downstream except it's a longer section of the dam that
23 fails.

24 MR. CARBON: Simply lengthens.

25 MR. LEE: Right.

1 MR. OKRENT: And it doesn't fail to a greater
2 depth. These are upper blocks, if I understand
3 correctly.

4 MR. LEE: You mean it doesn't --

5 MR. OKRENT: In other words, --

6 MR. SIESS: If you look at the cross-section
7 it looks like the whole dam moves out.

8 MR. LEE: It is the whole dam, isn't it, T.J.,
9 the whole dam within that block?

10 MR. ABRAHAM: It is assumed in that picture
11 that the dam overturned in its entirety and laid back in
12 that position.

13 Now, for the SSE, the length will increase
14 because it is not as high as it goes up the abutment,
15 and this improves the stress conditions. Therefore, we
16 assumed for the SSE, since it's a higher earthquake, we
17 took one more step up and took a couple more blocks on
18 each side to increase that 665 length.

19 MR. OKRENT: Okay. So if you had an
20 earthquake beyond the SSE it just would make it somewhat
21 wider, is that what you're saying?

22 MR. ABRAHAM: Yes.

23 MR. CARBON: A question here. I sort of got
24 an implication from what you said that when you went to
25 the SSF you added a couple of blocks on each side. I

1 presume what actually happened was that with the SSE
2 level, that that is your best estimate as to what will
3 happen? You didn't simply arbitrarily take a couple
4 more blocks?

5 MR. ABRAHAM: We didn't make a further
6 analysis. That was the judgment. The foundation
7 doesn't look quite as smooth as the steps in the block,
8 so we merely made a judgment that the SSE is higher
9 stress, so we went up two levels on the estimated block
10 elevation and picked those two blocks as being taken out.

11 MR. CARBON: Does that represent your best
12 judgment, then, as to what would actually happen with
13 the SSE?

14 MR. ABRAHAM: Yes. I want to point out that
15 this kind of thing really doesn't lend itself to exact
16 analyses. There are too many unknowns involved. We
17 have done what we consider a very conservative analysis,
18 and will hand you some information pointing out where I
19 think the analysis is very conservative.

20 To do an exact analysis we feel is not
21 productive and not realistic. We don't think it lends
22 itself to this, so we did a conservative standard
23 stability analysis and arrived at the conclusion of
24 failure. Then from there, we did assume just two more
25 levels going without doing further analysis.

1 MR. EBERSOLE: Could I ask you a question?
2 The residual structure you've got there which has gone
3 down to 665 feet doesn't strike me as being anywhere
4 near as durable as the original one, yet it must be
5 confronted with enormous hydrodynamic forces. How do
6 you know it wasn't cut down lower than that, or swept
7 further than that? What are the force balances that
8 kept it where you've got it?

9 MR. ABRAHAM: The foundation itself. We know
10 what the base of the structure is. Tell me again the
11 rest of the question.

12 MR. EBERSOLE: You said the earthquake was
13 gone; that's the reason it stopped there.

14 MR. ABRAHAM: Oh, you mean the debris?

15 MR. SIESS: What puts those blocks where they
16 are, the earthquake or the water after the earthquake?

17 MR. ABRAHAM: That assumes the blocks
18 overturned, and that is the position of the blocks after
19 overturning.

20 MR. SIESS: And the overturning force is the
21 lateral inertial force from the earthquake plus the
22 water?

23 MR. ABRAHAM: Static plus dynamic loads.

24 MR. EBERSOLE: The water does not move the
25 debris further because of no anchor, et cetera?

1 MR. ABRAHAM: These are matters of judgment.
2 I don't think that anybody can conclusively say where
3 the debris will collect with any type of failure. We
4 don't have experience of this kind. As far as we know,
5 we know of no dam that has ever overturned from seismic
6 activity of this nature. We do have evidence that some
7 have withstood forces much higher than this. And that,
8 again, is one of the listings of the conservative
9 approach we took to it.

10 We have taken the position that this is one
11 logical collection of debris. There may be many others,
12 but we take the position that the obstruction at the
13 river will be approximately the same. I don't think
14 mathematically, that could be calculated, so that is a
15 judgment on the knowledge.

16 MR. SHEWMON: We will hear from him again.
17 Let's get on with it?

18 MR. LEE: I am finished, yes, unless you have
19 other questions.

20 MR. SIESS: Is the last slide somebody else's?

21 MR. LEE: Yes.

22 MR. SHEWMON: Okay. Mr. Abraham, do you want
23 to come up again, then?

24 MR. SIESS: Maybe it would help to know the
25 disciplines of the speakers so that we could ask the

1 right questions to the right people.

2 MR. SHEWMON: Mr. Lee, your responsibility or
3 degree is in -- ?

4 MR. LEE: Hydrology.

5 MR. SIESS: The next one we're going to hear
6 from is what?

7 MR. SHEWMON: I suspect he is a civil
8 engineer, but I don't know.

9 MR. ABRAHAM: I am Tom Abraham and I am a
10 civil engineer. I am a structural engineer, and my
11 experience with TVA has been entirely in the design of
12 hydroelectric structures.

13 MR. LONGENECKER: Mr. Chairman, I repeat
14 again, we have four people from TVA; we have Ray Lee who
15 is a hydrologist, you have Tom who is a civil engineer
16 from the hydrostructural division; we also have
17 available Joe Hunt who is in the geotechnical earthquake
18 engineering staff, and Jim Domer who is Supervisor of
19 BWR Licensing who has been involved in some of the
20 Norris Dam failure calculations.

21 MR. SHEWMON: Do we also have Mr. Piper?

22 MR. LONGENECKER: Yes, we have those four
23 people in those disciplines.

24 MR. SHEWMON: Thank you.

25 (Slide.)

1 MR. ABRAHAM: Again, let me start out by
2 saying that our position with regard to dam safety is
3 that Norris Dam would not fail under these conditions of
4 earthquake. We have made the ultimate conservative
5 assumption because, repeating myself, we cannot totally
6 prove that it would not. So the proven course we took
7 in regard to this is we would postulate a failure of
8 Norris Dam.

9 MR. OKRENT: By "these conditions" you mean
10 OBE 50 percent larger than the SSE? Could you be more
11 specific?

12 MR. ABRAHAM: In dam safety analysis, we --
13 not in regard to nuclear plants, but in regard to dam
14 safety itself, we take two earthquakes. One is the OBE
15 and the other is the MCE, maximum credible earthquake.
16 The maximum credible earthquake is .15g. In our
17 judgment, it will withstand .15g.

18 MR. OKRENT: Okay. So your comment is made in
19 the context of .15g.

20 MR. ABRAHAM: Yes. To give you a little
21 background information, Norris is a gravity dam. It's
22 approximately 1800 feet long. The approximate height is
23 265 feet. The dam is basically a solid concrete mass
24 structure. It has an overflow spillway section, sluices
25 and non-overflow sections on each side of the spillway.

1 The dam was completed in 1936. It was
2 originally designed for an earthquake acceleration of
3 0.1g throughout its height. That means the rock
4 acceleration wasn't amplified in that particular
5 analysis, which is taken constantly throughout the
6 height of the structure.

7 To ensure the safety of its dam, TVA does have
8 a well-developed inspection and maintenance program with
9 grade inspection at intervals to ensure that the dam is
10 in good condition.

11 (Slide.)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Now, when the question of flooding at the
2 plant came up, we took another look and made a new
3 standard stability analysis of the structure. The chief
4 difference between this analysis and the analysis that
5 was made originally was the amplification of the basic
6 acceleration.

7 This is a diagram shown in the spillway
8 section. This is a non-overflow section. You can see
9 from this diagram that actually the acceleration
10 increased from .09 at the rock to as much as .75 g at
11 the top, and .64 g at the non-overflow dam.

12 The results of the analysis are shown here.
13 This is a base stress diagram for the two. Actually the
14 base stress diagram indicated that the resultant forces
15 would stay inside the base but would not overturn. But
16 they were of such high value that we thought it was
17 prudent to assume that it would fail. So that is another
18 bit of conservatism that is in the analysis.

19 The stress was 1200 psi compression on the
20 non-overflow section and 500 plus on the spillway
21 section.

22 MR. OKRENT: How was this dam fixed to the
23 rock, and is that a possible point of failure in an
24 earthquake, in your opinion? I am talking now not about
25 .09 g but .25 g or .35 g or earthquakes beyond your

1 .15 g credible earthquake.

2 MR. ABRAHAM: Sliding is always an important
3 factor to review. This dam was built on competent rock
4 foundation. It was highly treated during its
5 construction to take care of cavities and imperfections
6 within the foundation. This was well keyed in to the
7 foundation and the foundation is rather rugged. So in
8 order to get the sliding, it would be very difficult.
9 It is almost like a keying action into the foundation in
10 this case.

11 MR. OKRENT: So you would guess, if I can put
12 words in your mouth, that this is a much less likely
13 failure mode than overturning?

14 MR. ABRAHAM: We did consider it in that
15 regard and that is the conclusion we arrived at.

16 MR. OKRENT: For the more severe earthquake as
17 well as for the one you analyzed?

18 MR. ABRAHAM: Yes.

19 [Slide.]

20 I thought I would point out some conservatisms
21 in this analysis. This analysis of using an
22 instantaneous picture, if you will, of the dam at some
23 point in which acceleration is maximum, you photograph
24 the dam and apply these forces as a static stability
25 normally referred to as a pseudo-static method of

1 analysis, was used. Actually it does not work that
2 way.

3 This is not a sustained load, it is an
4 oscillating force and load. Consequently, it is not
5 sustained long enough to develop the stresses that I
6 just showed you.

7 The second area of conservatism in the
8 analysis, in amplifying the rock acceleration, we went
9 through actually a simplified dynamic analysis to arrive
10 at the moments and shears in the amplification of the
11 load. Now, if you remember the diagram, these
12 amplifications of all portions of the structure did not
13 occur simultaneously, they occurred at different periods
14 during the earthquake, but we put the maximums all
15 together to arrive at this base acceleration.

16 We assume the concrete had no tensile ability,
17 and we think that we used conservative judgment in
18 assessing the stress analysis after the final stability
19 analysis was made. Some could have assumed that since
20 the resultant forces did not fall outside the base, it
21 could have been assumed to be all right. In fact, some
22 Federal agencies now have that criteria.

23 I mentioned to you that our dam safety
24 assessment presumes that Norris would not fail under as
25 much as .15 g acceleration. I think an important factor

1 here that enters into our judgment on all gravity dams
2 is we do not know of a gravity dam that has failed
3 because of earthquake. We do know of at least one that
4 was subject to an earthquake much higher than the design
5 earthquake here at Norris, a dam in India called Konya
6 dam. It cracked but it did not fail. Its accelerations
7 were at least twice as much as we did here at Norris.

8 Now, to take the analysis a bit further, we
9 took the Konya the dam, we made an analysis with Konya
10 using our conservative approach, our conservative
11 analysis. That indicated that the Konya dam under those
12 conditions would have been in much worse shape than
13 Norris would have been in, but nonetheless it still
14 didn't fail.

15 MR. SIESS: Why is it conservative to assume
16 the spillway gates open?

17 MR. ABRHAM? I don't think it makes a whole
18 lot of difference whether they are open or not.

19 MR. SIESS: If they are open, does the water
20 level go up to 861?

21 MR. ABRAHAM: This condition that was critical
22 was the one-half PMF plus the OBE. At that time the
23 spillgates must be open.

24 MR. SIESS: Would you go back to that previous
25 figure?

1 [Slide]

2 MR. ABRAHAM: The stability?

3 MR. SIESS: Yes. I guess I don't understand
4 why, if the water is at 1036, the hydrodynamic force
5 goes up to 1061.

6 MR. ABRAHAM: This is not the hydrodynamic
7 force. This is the mass of the concrete that appears in
8 between the spillway stress.

9 MR. SIESS: Then the label is wrong, right?
10 That figure is labeled "Hydrodynamic Force."

11 MR. ABRAHAM: Well, you do have some on the
12 pier. Excuse me.

13 MR. SIESS: You said in the --

14 MR. ABRAHAM: A further clarification. Let me
15 clarify that a bit more. This is the design of the mass
16 acceleration. From the crest on up there are piers in
17 between that take this part of the acceleration. Now,
18 the dynamic force of the water resulting from being
19 accelerated into the reservoir itself is this diagram,
20 and then this is the static (indicating).

21 MR. SIESS: Okay. You said under your
22 conservatism that there was not sufficient energy to
23 overturn it. When I look at that slide, it doesn't look
24 to me like there is enough force to overturn it. You
25 have a factor of safety of overturning of 103 on the

1 overturn section? On your assumption, it wouldn't
2 overturn?

3 MR. ABRAHAM: That is correct.

4 MR. SIESS: What would happen if you sheared
5 off the toe?

6 MR. ABRAHAM: We made an analysis of the
7 shears on the planes at the toe in both cases. In those
8 cases the shear was high, and that led us to further
9 assuming that the dam would fail rather than stay there
10 under this analysis. Remember, now, that these blocks
11 were assumed to fail.

12 MR. SIESS: Is that figure on here, vertical
13 plane 8A, 535 psi? Over on the bottom right of the
14 boxes. Is that the shear we are talking about?

15 MR. ABRAHAM: That's correct.

16 MR. SIESS: You assume that you take off the
17 shear and that is how it would overturn?

18 MR. ABRAHAM: Yes. Again, that is a rather
19 conservative assumption. Some of the Federal agencies
20 have a criteria for this type of analysis under these
21 conditions that if the resultant shear falls within the
22 base itself --

23 MR. SIESS: Is that a pure shear?

24 MR. ABRAHAM: Yes, sir.

25 (Slide)

1 I will flash this one back up. This is a
2 presumption of failure at grade level. I think we have
3 covered it in the approach we have taken, unless there
4 are some other questions about it.

5 MR. OKRENT: The forces of the water rushing
6 by, are they insufficient to move debris of this type in
7 whatever form it might be given, that it failed in an
8 earthquake or what?

9 MR. ABRAHAM: My judgment would be that it
10 would be relative to the amount or size of the debris
11 itself. I would judge that if it stayed in blocks as
12 large as this, you would not develop enough force to
13 move it significantly downstream. Of course, you cannot
14 prove that it won't break up into other pieces. We have
15 addressed that and we don't think it is possible to
16 really tell where the debris is. We do feel there will
17 be obstruction in the channel, and perhaps it would be
18 about the same amount of obstruction.

19 Now, we did go a little bit further in making
20 some sensitivity tests, if you will, in which other
21 amounts of debris were taken out. In other words, if
22 the crests were lower or if more of the blocks were
23 totally taken out and we did some flood routing based on
24 that. Raymond might want to address that for a minute.

25 I think the conclusion, Raymond, was that it

1 would still not get over plant grade. Is that so?

2 MR. EBERSOLE: If you brought 970 down foot by
3 foot by foot, at what point would you cover plant grade?

4 MR. ABRAHAM: I don't think we made that
5 analysis, Jess. I think he flashed up that if you
6 evaporated the dam, if you figure on that, if you
7 totally evaporated the dam. Did you give that figure?

8 MR. LEE: Yes. We looked at so-called
9 sensitivity runs. I don't like to call it that, but if
10 you can think of anything better, we will. Where we had
11 problems was that we instantly vanished the entire dam.
12 At the upstream end of the project we have elevation 818
13 at mile 18. At mile 16 downstream of the site,
14 elevation was 811. All other runs gave us elevations
15 lower than plant elevation 815.

16 MR. OKRENT: This is if you instantly removed
17 the dam and there is no obstruction from it?

18 MR. LEE: No debris. It just evaporates.

19 MR. SIESS: I think it would be worth putting
20 up. It was the slide that was handed out to us,
21 gentlemen.

22 MR. SHEMMON: Why don't you tell us what it is?

23 MR. SIESS: It says "Sensitivity Runs,
24 Postulated Failure Mode." It gives an elevation of
25 water to the site for four different assumptions

1 regarding --

2 MR. SHEWMON: It is in the first handout we
3 had on hydrology.

4 MR. SIESS: Yes.

5 Now, on that slide it says OBE conditions with
6 one-half PMF. Would it be any different if it was a
7 PMF? There couldn't be any more water behind the dam,
8 would there?

9 MR. LEE: It would be different if it was a
10 PMF. However, that would be a combination that would be
11 incredible and we don't deal with that.

12 MR. SIESS: Can you explain briefly why the
13 water from the dam is different, whether it came from
14 the PMF or half the PMF?

15 MR. LEE: Okay. The water --

16 MR. SIESS: The downstream?

17 MR. LEE: The elevation at the dam for PMF
18 would be higher than it would for the one-half PMF
19 because your control volumes are higher.

20 MR. SIESS: The elevation behind the dam is at
21 the spillway level.

22 MR. LEE: The elevation was one-half PMF. I
23 believe it was 1036.

24 MR. SIESS: Yes, and that is the spillway
25 level, isn't it?

1 MR. LEE: It is overtop the spillway.

2 MR. SIESS: Oh, I see. It is some couple of
3 feet over the spillway, isn't it.

4 MR. LEE: Yes.

5 MR. SHEWMON: Can we move on on this?

6 MR. SIESS: If the worst case you can think of
7 with the combination of OBE at half the PMF would give
8 you 3 feet above the plant grade at mile 18, what would
9 it give you at the site?

10 MR. LEE: Excuse me?

11 MR. SIESS: The distinction between mile 18
12 and mile 16 as opposed to what it would be at the site.
13 Does that make any difference?

14 MR. PIPER: Dr. Siess, my name is Henry
15 Piper. You are looking at the map of the site on the
16 river where the plant is located. The river mile at
17 which we would take our intake, which is the nearest
18 river mile to the plant there, is river mile 18,. River
19 mile 16 is at our discharge point and would have an
20 elevation of 811. Mile 18 would have an elevation of
21 818. There is a grade there of 7 feet in that space of
22 the river for approximately a couple hours while the
23 peak level of the flood passes the site.

24 Now, on one side it would be 818, on the
25 other, 811.

1 MR. SIESS: What would it be at the plant?

2 MR. PIPER: We didn't make that specific
3 calculation, but you will notice that there is a valley
4 that runs rather at a 45 degree angle of the page to the
5 right there, and that valley is open to the plant grade
6 at 815. So there is not a higher structure than 815
7 between the river at river mile 18 and the plant itself.

8 MR. SIESS: So it would tend to flow down the
9 valley, around the plant, into the river on the other
10 side.

11 MR. PIPER: Yes, because of the gradients
12 there. We may not be able to accomplish that.

13 MR. SIESS: I assume the plant grade was
14 established before these calculations were made?

15 MR. PIPER: No, it wasn't. The plant grade
16 was established based on what we consider to be a very
17 conservative analysis of the combination of floods
18 required in 1.59.

19 MR. SIESS: Thank you.

20 MR. ABRAHAM: I think with respect to that I
21 will make maybe one other comment. This partial failure
22 with accumulation of debris was also done in connection
23 with other dams in studying the Sequoyah and Watts Bar
24 sites, too.

25 MR. SHEWMON: Let me bring up a different

1 question. Is it clear whether -- let's say this
2 question does come up within ten feet of grade. The
3 plant is designed as a matter of course to cope well
4 with that sort of thing?

5 MR. PIPER: I'm not sure I understand your
6 question, Dr. Shewmon.

7 MR. SHEWMON: We are talking about various
8 credible and incredible floods. Not being a civil
9 engineer and structural and all those good things, I
10 struggle along not quite knowing what happens if we do
11 get up to 85 feet.

12 MR. PIPER: 85 is fine. Our plant grade is
13 set at 815. That means that all of the essential
14 buildings are protected against the flood up to a level
15 of 815. Above 815 --

16 MR. SHEWMON: You start worrying about pumps
17 and other things.

18 MR. PIPER: Yes, and auxiliary-type
19 buildings. The water would not intrude into the
20 containment even if the flood got well above 815.

21 MR. SHEWMON: Do we have enough information?

22 MR. SIESS: Would you put this slide back up
23 that shows the chunks of concrete downstream? The
24 calculations made are for essentially overturning of the
25 665-foot width with the debris of the 945 level. Now,

1 that is a considerable lower level than that sketch
2 shows, am I correct?

3 MR. ABRAHAM: Yes.

4 MR. SIESS: That shows 970. That would be a
5 little lower of that. Then you made a calculation with
6 somewhat less width, 370-foot width, with the debris
7 down at the 925 level. That is still lower, right?

8 MR. ABRAHAM: Raymond, I think you will have
9 to answer that.

10 MR. SIESS: It is really the height of the
11 debris, isn't it?

12 MR. ABRAHAM: This was the assessment given to
13 the hydrologist to route the flood. From there he said
14 he didn't like to use the term "sensitivity," but I
15 can't think of a better one right now to look at the
16 debris. He did some changing of this to make it worse.
17 He made these assumptions of first going to a lower
18 level for the crest, assuming rather than it falling in
19 this fashion, it would break up in some fashion, at
20 which this crest is --

21 MR. SIESS: What I don't see on this
22 sensitivity list is what it would be for the case that
23 is shown on that slide. That is, a 665-foot width with
24 the debris at the 970 level.

25 MR. LEE: That is the design basis flood

1 level, elevation 804.3. It is not shown on that slide
2 but it is shown on the --

3 MR. SIESS: 804.3 at mile 18?

4 MR. LEE: And mile 17. That is the design
5 basis flood level as based on this postulated failure.

6 MR. SIESS: 665 by 970. Okay, thank you.

7 MR. CARBON: I want to ask the Staff, are you
8 completely happy with everything that has been said?

9 MR. LEAR: I am George Lear, the Chief of the
10 Hydrologic Engineering Branch.

11 Based upon our earlier review at the beginning
12 of this analysis years ago and also based upon our
13 recent review and analysis by the geotechnical engineers
14 and hydrology engineers and the structural people, the
15 applicant has presented a conservative analysis and we
16 have at this time no further concerns about his
17 approach. We feel it is a logical and acceptable
18 approach at this moment.

19 MR. SIESS: Mr. Chairman, could I ask one more
20 question?

21 MR. SHEWMON: Yes.

22 MR. SIESS: If Norris Dam failed in this
23 manner, and I believe I saw somewhere Watts Bar would
24 also fail and something else, what would be the
25 consequences other than possible damage to CRBR?

1 MR. SHEWMON: Mr. Abraham, do you want to
2 answer that?

3 MR. LEE: What do you mean? What kind of
4 damage?

5 MR. SIESS: To people, or towns.

6 MR. SHEWMON: Would Chattanooga be under water?

7 MR. LEE: It would be catastrophic, yes.

8 MR. SIESS: What would happen to Oak Ridge and
9 some of its plants there that make certain things?

10 MR. LEE: Oak Ridge. I think we have
11 addressed that. Fringes might be inundated but not
12 significantly.

13 MR. EBERSOLE: Your analysis assumed that
14 Watts Bar would fail, but I assume that is making no
15 difference to the CRBR whether it failed or not.

16 MR. LEE: That is correct. It makes no
17 difference to the CRBR.

18 MR. EBERSOLE: Wouldn't there, in fact, be a
19 cascade failure of Watts Bar and then Chicuamagua, et
20 cetera.?

21 MR. LEE: Yes.

22 MR. EBERSOLE: How far down would that go?

23 MR. LEE: We didn't carry the failure of
24 Norris down that far, but in looking at some of our
25 other nuclear plant sitings, Cascades, the other would

1 cascade on down through Gunnersville, failing the earth
2 embankments as it went.

3 MR. EBERSOLE: The earth embankments.

4 MR. SIESS: And hope the Kentucky dam holds.

5 MR. LEE: We think it will.

6 MR. ABRAHAM: I think it is important, though,
7 just to make a comment on that, that we are going
8 independently on our dam safety analysis. We are taking
9 a much more conservative approach on nuclear siting. On
10 our dam safety program we have assessed all of our 40
11 dams, with attention to seismic analysis and so on, and
12 Norris is considered to be safe against normal expected
13 MCE earthquakes.

14 MR. SIESS: What would Knoxville and the City
15 of Oak Ridge see? What about Knoxville? Somebody
16 mentioned Chattanooga, but Knoxville is closer to the
17 site.

18 MR. LEE: Knoxville doesn't have the same
19 problem as Chattanooga because it is higher, on high
20 ground. The waterfront property would probably be wiped
21 out.

22 MR. SIESS: But you wouldn't use the word
23 "catastrophe" for that?

24 MR. LEE: For a PMF flood of that magnitude I
25 would, yes.

1 MR. SHEWMON: Do we need to hear about core
2 melt?

3 MR. STARK: I guess the Applicant can pass out
4 his presentation and you can consider that.

5 MR. SHEWMON: If that is satisfactory, that
6 would be fine. Okay.

7 The question is, I guess, can we write a
8 letter at this meeting. Is there anybody who feels they
9 cannot? If so, would they speak up and identify their
10 concern?

11 [No response.]

12 Apparently we will write a letter at this
13 meeting.

14 MR. SHEWMON: Thank you very much.

15 Why don't we take a couple minute break while
16 they clear the room and then get back.

17

18

19

20 .

21

22

23

24

25

1 MR. SHEWMON: Okay. The next item is disposal
2 of high level wastes. Fire when ready.

3 MR. AXTMANN: In the past 18 months, the ACRS
4 has written three letters on the subject of high level
5 waste and the disposal of same in geologic
6 repositories. The first rather short one in December,
7 1980, expressed the committee's confidence that a
8 1,000-year waste package could be evolved, and the
9 geologic barriers could provide tens of thousands of
10 years of isolation.

11 About a year later, September, 1981, we sent a
12 letter that offered generally favorable comments on the
13 staff's draft of 10 CFR 60, but provided 13 specific
14 comments, including six that have been solicited by the
15 staff. Among the committee's suggestions at that time
16 were the inclusion of the retrievability requirement as
17 a part of the rule rather than as background material,
18 elimination of design and construction criteria from the
19 rule, permitting the licensee to meet an overall safety
20 goal without requiring separate subsystem goals such as
21 the package, the backfill, and so forth, beginning early
22 work on the evaluation and comparison of the various
23 computer models for the reservoir, and relegating the
24 regulation of transuranic waste to a separate document.

25 I will return to these subjects in a moment.

1 A third letter on the subject was issued in March of
2 this year. The Commission requested that the
3 subcommittee offer its advice on the staff's choice
4 between only two contractors who had bid on a contract
5 to verify the longevity of the so-called 1,000 year
6 waste containment package. The subcommittee endorsed
7 the staff's choice with what I recall as neither
8 enthusiasm nor unanimity.

9 The letter itself expressed concerns that the
10 letter we wrote after that endorsement of one of the two
11 contractors, that we expressed concerns that the program
12 was aimed at extraordinarily high standards. In the
13 past six months, the subcommittee has met four times to
14 consider various aspects of the disposal of high level
15 waste. Last December, we considered the domestic and
16 foreign approaches to the overall problem. In January,
17 we met to review the staff's program at that point. In
18 February, we considered the matter of the advice on the
19 verification contract, which I have already mentioned,
20 and earlier this month we considered the latest draft of
21 10 CFR 60, which I think is -- Mike, is this the only
22 packet?

23 MR. BELL: That is the only one that has been
24 made available to the ACRS. The Commission paper, the
25 paper to be transmitted to the Commission, is in the

1 EEO's office, and apparently has not come down yet.

2 MR. AXTMANN: This is marginally different
3 from what you have in your handout, I believe. The
4 handout has the original -- excuse me. The last version
5 has the changes X'd out so you can still see them in the
6 new verbage typed in. It is that subject which is the
7 subject of today's discussion.

8 As a result of that meeting, Dade Moeller
9 drafted a letter which has just been passed out. It is
10 the pink sheet. Absent any questions, I don't know, Mr.
11 Chairman. Do we read the letter now, or do you want to
12 postpone that until tomorrow?

13 MR. SHEWMON: What is your pleasure? Well, we
14 have got some time on the agenda, if that is the way
15 this thing goes. I would just as soon have a first
16 reading, and let's get the reaction that way.

17 (Whereupon, at 12:20 p.m., the Committee went
18 into executive session.)

19

20

21

22

23

24

25

1 AFTERNOON SESSION

2 (2:00 p.m.)

3 MR. RAY: The meeting will please come to
4 order.

5 Paul will be a little bit late getting back.

6 According to the agenda the next item on the
7 program is the decay heat removal systems.

8 It's all yours, Dave.

9 MR. WARD: This afternoon we will hear a
10 report from the staff on their revision to Task Action
11 Plan A-45, which is concerned with requirements to
12 improve the reliability of decay heat removal systems.

13 We have heard over the past year several
14 reports on drafts of the plans. More recently, earlier
15 this year the plan was fairly extensively revised and
16 simplified in some ways. Parts of it were cut out, and
17 you have had two or three months' delay for one reason
18 or another in hearing a report on this revised plan, but
19 we will hear today that the plan has been officially
20 approved within the staff and is issued and the work is
21 beginning on the plan.

22 I don't think there's any particular
23 requirement for us to write a letter to endorse the
24 plan, for example. If we have some problems with it, we
25 might want to write a letter. So at the end of the

1 presentation today I will solicit your opinions on what
2 you think we should do about it. We have not held a
3 subcommittee meeting on this scaled down revised plan.

4 Unless anybody else has any comments, I will
5 turn the meeting over to the staff; and I believe Andy
6 Marchese will do the presentation.

7 (Slide.)

8 MR. MARCHESE: Good afternoon, everyone.

9 For those of you who don't know me, my name is
10 Andrew Marchese, and I am the task manager for ME-45
11 which is the unresolved safety issue entitled, "Shutdown
12 decay heat removal requirements."

13 (Slide.)

14 This is an outline of the topics that I would
15 like to cover today. However, before I start let me
16 just say that I think the most important thing I have to
17 say today is that we finally have gotten the work
18 started on this program after an extensive planning
19 session that has lasted about 15 months; so I am happy
20 to finally be able to come down here and tell you that
21 we've gotten the work started rather than telling you
22 about planning exercises.

23 MR. RAY: What does "start" mean? Who is
24 starting where?

25 MR. MARCHESE: I'm going to get into that.

1 Okay. Some of this now both the subcommittee
2 and the full committee has heard before, but since it's
3 been sometime since we last met, in order to establish
4 some sense of continuity, I want to briefly touch on the
5 overall purpose objective and then get into the
6 background on A-45 and give you an update since last
7 time we met, which I think was last September, and then
8 get into the main elements of the revised plan such that
9 you understand what is in our currently approved plan,
10 and also touch upon what we have taken out of the
11 previous plan and the reasons for that.

12 (Slide.)

13 The overall purpose of A-45 is to evaluate the
14 adequacy of current licensing design requirements to
15 ensure that nuclear power plants do not pose an
16 unacceptable risk due to failure to remove shutdown
17 decay heat. That is a very broadly stated purpose.

18 (Slide.)

19 The overall objects are shown here. First is
20 to develop a comprehensive and consistent set of decay
21 heat removal requirements for both existing and future
22 lightwater reactors.

23 Secondly, we are going to evaluate alternative
24 means of decay heat removal, including diverse dedicated
25 systems, to deal with the broad inspection of transient

1 and accident situations.

2 (Slide.)

3 Now, to go over some of the history of the
4 program, it is shown here. The Commissioners approved
5 this issue as an unresolved safety issue back in
6 December of -- actually that should be 1980. I was
7 assigned shortly thereafter in February to start
8 developing the Task Action Plan.

9 These next couple of items show the documents
10 that were published right after the issue was declared a
11 USI. I think the most important one was the draft Task
12 Action Plan was issued in early May and provided a basis
13 of starting the dialogue with the ACRS subcommittee. So
14 we met in the May to December time frame of 1981 I would
15 say four times with the subcommittee and a couple of
16 times with the full committee. We revised the plan in
17 October based on comments we received both from the
18 subcommittee, and also an internal NRC review was
19 conducted through the May to December time period.

20 This May 22nd we went through a revision of
21 the plan, and I will talk about that in some detail.

22 (Slide.)

23 Okay. Task Action Plan Revision 0 was
24 originally approved by the director of the division of
25 safety technology on October 7, 1981. If you remember,

1 this plan authorized a four-year program with a
2 completion date of October 1985. This program was
3 submitted to the director of NRR, and it was not
4 approved, the main reasons being that there was a
5 feeling that the program was too expensive, taking too
6 long of a period, and that there was work described in
7 the program -- in the plan that industry would be in a
8 better position to take on. And so we basically went
9 back to the drawing boards and considered at least a
10 dozen to 18 different options of the October version of
11 the plan.

12 In about February-March of the 1982 time
13 period we got an agreement on an option that we felt we
14 can go forward with in terms of still meeting our
15 primary goals. So we assessed this program to determine
16 if the primary goals could be realized and with a
17 shorter schedule. We've now come up with a 30-month
18 program that we feel will meet our primary goals. We
19 are now estimating that a draft NUREG report which will
20 contain our proposed recommendations, including any
21 proposed new requirements, along with the supporting
22 technical and cost-benefit basis, will be available by
23 about November of 1984.

24 (Slide.)

25 Continuing with the update in terms of how we

1 achieved a reduced schedule from 48 months down to 30
2 months, the main reasons are stated here. We have
3 deleted most of the work on future plants, although
4 acceptance criteria for decay heat removal systems for
5 future plants will be developed.

6 If you will remember, in the previous plan we
7 were not only going to look at alternative systems for
8 existing plants, but also we were going to look at
9 future plants. I am sure, as you are aware, the
10 alternatives could be considerably different because the
11 problems you have with existing plants from the
12 standpoint of backfitting are considerable, and the
13 choice of system alternatives could be entirely
14 different for existing ones where you're talking about
15 retrofitting versus future. So we did take out the work
16 concerning alternatives for future plants. However,
17 concerning acceptance criteria we are developing a set
18 of criteria that will be applicable to both existing and
19 future plants.

20 Quantitative acceptance criteria, our criteria
21 now will be a range that will stem from both qualitative
22 to quantitative. They are criteria that kind of fall in
23 between.

24 The quantitative criteria now will be based on
25 frequency of core melt due to decay heat removal system

1 failures rather than overall risk. We were originally
2 intending to go forward on an overall risk based
3 approach. We have backed off from that.

4 To simplify things, we feel that the
5 performance of the decay heat removal systems is more
6 tied to core melt frequency. As you know, when you go
7 from core melt frequency to overall risk, uncertainties
8 propagate considerably in terms of having to get into
9 consequence, in terms of whether the containment remains
10 intact or fails, getting into site meteorology and all
11 those things that we're not now going to get into.

12 So our goal, at least the quantitative goal,
13 will be based on core melt frequency due to decay heat
14 removal failures.

15 MR. OKRENT: Excuse me. Does that mean that
16 in setting acceptance criteria for a PWR it won't
17 matter, for example, whether it's an ice condenser or a
18 large dry containment; you'll have the same criteria?

19 MR. MARCHESE: In terms of the criteria for
20 decay heat removal systems that is true.

21 MR. OKRENT: You may want to think about the
22 connotations of the question and answer. I don't want
23 to try to solve the problem here but --

24 MR. RAY: Are the components of the decay heat
25 removal system influencing the degree of failure?

1 MR. MARCHESE: We are trying to avoid having
2 to include containment heat removal systems unless there
3 is an interaction. The systems we will be concentrating
4 on will be dealing with the frequent events, transient,
5 small break LOCA spectrum. We're not going to get into
6 large break LOCA, and we're trying to avoid having to
7 avoid all of the systems where you're talking about
8 getting into containment heat removal aspects. So we
9 have narrowed the program down in that respect.

10 MR. PAY: You really don't know what it will
11 show you until you get into this thing I suspect really.

12 MR. MARCHESE: Yes. I could think of one
13 example like the feed-and-bleed system where there is an
14 interaction with containment. You're dumping heat into
15 the containment, and certainly feed-and-bleed looks like
16 an attractive alternative.

17 MR. EBERSOLE: Well, the design of the
18 containments, however, will reflect the probability of
19 core melt since some of the scenarios first lead to
20 containment failure and then proceed to a core melt
21 after that. Typical is the boiler which has this
22 internal cooling problem since it can't evaporate to
23 atmosphere in the current models.

24 MR. MARCHESE: Well, for the BWR suppression
25 pool cooling we're going to focus on that.

1 MR. EBERSOLE: That's what I really meant.

2 MR. MARCHESE: That's going to receive a
3 considerable amount of attention.

4 MR. OKRENT: One other question. Does your
5 schedule include having obtained from industry the
6 plant-specific evaluations of alternative DHRS's
7 indicated in your third bulletin? In other words, will
8 those have occurred by November '84 when you will have
9 your report, or will they follow your report?

10 MR. MARCHESE: They will follow. We feel it's
11 going to take to about that time period where we are in
12 a position to tell industry which plants are
13 unacceptable and where we know they are improving their
14 decay heat removal systems that will make them
15 acceptable, and we will also know the systems where we
16 feel they are attractive and have a good cost-benefit
17 ratio.

18 I would also add that we will in our program
19 have an industry peer review, which I'll talk about a
20 little more later, in which we intend to invite the
21 industry in to review our interim reports and also get a
22 dialogue going on what they may be doing in this area.

23 MR. OKRENT: The evaluations industry might do
24 on a more plant-specific basis would be after November?

25 MR. MARCHESE: Yes.

1 MR. WARD: Andy, were those criteria against
2 which you plan to publish in the NUREC?

3 MR. EBERSOLE: The GE people have proposed
4 that to cope with this intrinsic weakness in their
5 system that they propose to boil to atmosphere out of
6 the suppression pool which brings the price of minor
7 release of radioactivity for the benefit of avoiding
8 core melt.

9 Will you get that far into extrapolating
10 present designs into future ideas, or are you just going
11 to stop off where they are right now? Are you going to
12 include new concepts?

13 MR. MARCHESE: We will include new concepts if
14 they look attractive for existing plants. We will
15 assess them and rank them based on value impact
16 evaluations.

17 Dennis Barry from Sandia, who is the project
18 manager on A-45, would like to add something.

19 MR. BARRY: With regard to Dave Okrent's
20 comment, we are planning to do plant-specific
21 evaluations relative to assessing the reliability of
22 existing plant decay heat removal systems by applying
23 screening criteria that are based on either
24 probabilistically-based arguments from work that has
25 been done in that area, phenomenological arguments based

1 on things that have been identified with whether the
2 task can perform the decay heat removal function, and
3 with regard to screening criteria.

4 In addition to that, we plan for those plants
5 that seem to have probabilistic-based analyses, we plan
6 to use PRA techniques to do some qualitative assessments
7 of reliability of existing systems in those plants that
8 look like they have some weaknesses.

9 So with regard to this program, we are trying
10 to get a bottom line and make some statement about how
11 plants compare among themselves with regard to the
12 reliability behavior of the systems.

13 In addition, as part of this program we are
14 going to consider how we can change those
15 vulnerabilities with alternative systems, tie them to
16 specific plants, ones that do look like they have
17 problems, and then form the value impact assessment on
18 those specific plants. So we are doing plant-specific
19 work. We are not waiting.

20 I believe what Andy was referring to here on
21 the issue of plant-specific evaluations is that we don't
22 plan to have a bottom line for one and only fixes for
23 plants, but we do feel like we have to look at real
24 plants and the alternative for those plants. It will
25 then be up to industry to evaluate our findings and

1 figure out whether or not they can do it better.

2 . MR. EBERSOLE: Andy, when you look at some of
3 the older plants you will recall that the first
4 regulatory guide -- they used to call it something else
5 years ago -- was on NPSH. It was intended to cope with
6 the fact that there have been plants designed -- at
7 least Browns Ferry was and I suspect there are others --
8 which had the terrible weakness of requiring retention
9 of the atmospheric sufficiently in NPSH to keep the
10 pumps running. If you lost air, you were in trouble.

11 So going back to these old plants I certainly
12 would suggest you look at how many plants are like this
13 and what the severity of that problem is, since I
14 thought it was rather terrible.

15 MR. MARCHESE: The last major point we feel
16 here that has reduced our time in this program, and I
17 think also increased the probability that we will pull
18 it off in 30 months, is that we now have recommended
19 that we have one contractor that will have the overall
20 responsibility for project management, the technical
21 direction and integration, including selection and
22 management of subcontractors.

23 We have made the recommendation, and it has
24 been accepted that Sandia be the lead contractor.
25 Sandia will be responsible for the overall technical

1 lead in the program, and they are going through a
2 subcontractor selection process right now, so they will
3 manage those subcontractors, and we in turn would
4 interface with Sandia all along.

5 (Slide.)

6 Steps that have been achieved to start work on
7 the program, we have received the approval of Mr. Denton
8 March 15th; we've received approval from our senior
9 contract review board which was required because we are
10 talking about expenditures in excess of \$500,000 per
11 year which requires this board's approval. We have
12 implemented a contract with Sandia as the lead lab.
13 They have begun the work, including preparing a detailed
14 action plan of their own. And we have issued Revision 1
15 of TAP A-45 on June 2nd, 1982. Copies have been
16 provided to the ACRS. So the latest version of the plan
17 is a June 2nd plan that we're working to.

18 MR. WARD: Has the Sandia action plan been
19 issued?

20 MR. MARCHESE: It will be issued next week.
21 We have been having extensive discussions with them on
22 it.

23 MR. RAY: Andy, sometime ago in the early
24 stages of the first effort we had the impression that
25 you were having trouble with getting staff management

1 approval to assign resources to the project. What is
2 the status of that?

3 MR. MARCHESE: The status as I know of it --
4 and maybe Carl Neal can elaborate on this -- it looks
5 like it's becoming easier to get internal support. I
6 think from what I hear, Mr. Denton has given his orders
7 to division directors to start supporting USIs, that the
8 case work load is perhaps decreasing and perhaps now we
9 should start devoting more internal research to USI.

10 MR. RAY: So this project is still to be
11 funded?

12 MR. MARCHESE: Well, one of the things I'm
13 doing right now is putting together an internal plan
14 that is assigning branches specific things I would like
15 to have them do along with the schedule of doing that.
16 So we're putting together an internal plan right now.

17 MR. RAY: And you expect a response then?

18 MR. MARCHESE: I expect to have a good
19 internal team supporting me on this program because we
20 do not want technical review branches getting involved
21 at the end when we're publishing reports. They should
22 be involved at the beginning. Helping us with the
23 review of those reports should not be at the end of the
24 program because they are the ones who will have to
25 implement them on the plants.

1 Now, to get into the revised plan --

2 (Slide.)

3 -- This chart shows the main elements of the
4 plan. It is broken down into four major tasks along
5 with supporting subtasks. The first one is we are going
6 to be developing acceptance criteria for assessment of
7 decay heat removal systems. We are going to be
8 developing means for improving decay heat removal
9 systems. We're going to be assessing the adequacy of
10 existing systems against our acceptance criteria. And
11 finally, we will be developing a plan for implementation
12 and actually publishing new requirements, if any, on a
13 technical and cost-benefit basis.

14 This, I think, will show up a little more
15 clearly on the first chart which shows the
16 interrelationship of the tasks in the plan.

17 (Slide.)

18 Very early in the program we are starting out
19 with developing both quantitative and qualitative
20 criteria. The quantitative criteria, as I indicated,
21 will be founded on frequency of core melt due to decay
22 heat removal system failures.

23 What we're planning to do there is to allocate
24 a portion of the overall core melt frequency goal -- for
25 example, the 10⁻⁴ goal that's been suggested, if it

1 finally winds up as being the Commission's goal -- to
2 decay heat removal system failures, and then from that
3 establishing reliability goals on a per demand basis for
4 the different systems that are involved with the decay
5 heat removal function.

6 We will also be developing qualitative
7 criteria for those events which we have termed special
8 emergencies. These are events which are difficult to
9 quantify in a probabilistic sense -- such things as
10 fire, flood, sabotage -- although there have been
11 attempts to quantify anything more.

12 MR. OKRENT: What about seismic?

13 MR. MARCHESE: That will be included.

14 MR. OKRENT: How?

15 MR. MARCHESE: We do not have that fully
16 developed. We are just starting that right now. But we
17 intend to look at the question. If we say we recommend
18 a dedicated system, what should be the seismic design
19 level of that system; should it be beyond the SSE, and
20 what does that gain you; what is the value impact of
21 designing it for a stronger earthquake.

22 MR. OKRENT: How are you going to assess the
23 current capability with regard to decay heat removal and
24 dealing with small, small LOCAs which I understand is in
25 your ballpark?

1 MR. MARCHESE: Right.

2 MR. OKRENT: As you know, the ACES has several
3 specific cases, including some recent one recommended
4 that the staff consider lower probability earthquakes
5 than the SSE and judging the adequacy in this regard.

6 Now, do you expect to tackle this problem head
7 on and come up with an assessment of what the current
8 status is of possible alternatives, or just what will
9 you do if you are not going to tackle that option?

10 MR. MARCHESE: I don't believe -- Dennis can
11 correct me -- I don't believe we're going to tackle that
12 one head on, but I do think in terms of the seismic
13 design criteria we will be looking at the question of
14 whether or not our alternative systems, if we recommend
15 them, should be designed to an earthquake level greater
16 than the SSE, what the value impact of doing that is.

17 Do you agree with that?

18 MR. BARRY: First of all, I understand there's
19 another program that is ongoing to look at spectrums of
20 earthquakes beyond the SSE, is that correct, Andy?

21 MR. MARCHESE: Yes.

22 MR. BARRY: I don't know what the name of that
23 program is.

24 MR. MARCHESE: There's one called the Seismic
25 Structural Margins Review Program which we are going to

1 be interfacing with that group to see what they come up
2 with. I think we are going to be looking at, you know,
3 what is the sensitivity of different component seismic
4 design in terms of changes in risk and what the
5 cost-benefit is of changing that. I think that's one of
6 the things they're looking at.

7 MR. WARD: Does their program have a schedule
8 which is compatible with your program using what they
9 develop?

10 MR. MARCHESE: That program when I last talked
11 to them was like on a five-year time frame.

12 MR. OKRENT: Are you talking about the SSMRP
13 program? Don't bet on that one answering your specific
14 question. I don't think you will find that specific
15 question is a part of their program plan, assuming they
16 meet their program plan. I do not know how you will
17 evaluate the benefits of some possible new system with
18 regard to augmented seismic capability if you don't know
19 what the existing capability is.

20 MR. MARCHESE: They have these fragility
21 analyses going on which I'm sure you're familiar with.

22 MR. OKRENT: I'm familiar with them, yes.

23 MR. BARRY: We have been somewhat reluctant to
24 -- one of the aims of this program is not to be generic
25 in nature. We are trying to come up with some

1 assessment on as many plans as we can. Our goal is all
2 plans concerning the reliability of decay heat removal.

3 One of the many ways that decay heat removal
4 systems can be vulnerable is seismic. Seismic is one
5 part of that. We feel that we cannot go into the level
6 of detail developing fragility curves and determine the
7 seismic signatures of every site and responses of the
8 buildings that would come into play with the fragility
9 curves of the individual components for all the sites.

10 The approach that we are planning to take is
11 to draw upon the existing regulatory requirements that
12 reflect the current state-of-the-art kind of
13 requirements for seismic design. We plan to draw from
14 those requirements what we consider to be the essence of
15 the requirements, what is necessary to meet current SSE
16 requirements, not going beyond SSE. In a probabilistic
17 way we are not planning to do that.

18 We also plan to draw on the efforts that have
19 been made in the Zion and Indian Point studies where an
20 attempt has been made to quantify the contribution to
21 core melt. We plan to cull from that those
22 characteristics of the systems that contributed most to
23 those core melt frequencies as a result of an
24 earthquake. With that information we then plan to
25 screen other plants and to look at the characteristics

1 we feel is an indication that they would have seismic
2 weaknesses; but we are not planning to try to quantify
3 those seismic contributions to the core melt at all
4 plants. I think that is beyond the scope of our effort.

5 Where those plants seem to have seismic
6 weaknesses we will look at whether they meet the current
7 guidelines for seismic events, again not going beyond
8 the current guidelines.

9 The reason for us doing that is we feel we
10 could for any number of special emergencies call upon
11 this program to reassess the adequacy of the current
12 guidelines for those emergencies. We can do it for
13 fire, we can do it for sabotage, earthquakes, floods,
14 hurricanes, what have you. I think an individual
15 assessment of any one of those could be a program in
16 itself.

17 MR. OKRENT: Well, I am not trying to talk you
18 into doing anything at the moment. I am trying to
19 ascertain what it is you will do and why it is
20 acceptable, if it is, and whether it will meet your own
21 stated goals.

22 Now, this vu-graph talks about assessing
23 adequacy of decay heat removal systems in specific
24 plants on a probabilistic basis. Those are not my
25 words; those are your words. I don't see how you can

1 assess the adequacy from the seismic point of view if
2 all you do is look at was it designed to meet the SSE or
3 not and so forth.

4 MR. BARRY: I agree with you, and that is why
5 we are planning to draw upon the two attempts that have
6 been made to put probabilities on the contribution to
7 core melt from seismic events; but both of those efforts
8 were in themselves extensive efforts. We feel we cannot
9 do that on all plants obviously.

10 We instead are going to -- we feel those
11 contributions to core melt, whether they be
12 probabilistically assessed or deterministically
13 assessed, those contributions can be assigned to
14 particular plant weaknesses or characteristics such as a
15 nonseismically designed structure or a nonseismically
16 designed system.

17 But with regard to looking at SSEs or
18 earthquakes that go beyond the SSE with a certain
19 probability and assessing whether or not the
20 probabilities of the systems change with the existing
21 earthquake threat, we are not planning to do that. So
22 the probabilistic assessment that you are talking about
23 here, as I believe Andy has indicated, will be limited
24 to those transient and LOCA events that have been
25 traditionally quantified probabilistically. In

1 addition, we plan to include up to what the
2 state-of-the-art has tried to do with regard to things
3 like fire and earthquake and hurricane where there has
4 been some attempt to do that probabilistically.

5 But the probablistic assessments we're talking
6 about here are to actually take on the order of a dozen
7 safety analyses that have been done and modify them in a
8 way that reflects the particular features of plants that
9 we don't find to be weak, and to then reassess plants
10 using a current state of the art risk assessment. Where
11 those risk assessments have not probabilistically
12 handled seismic events and other special emergency
13 events, we are not planning to go off and do a
14 site-specific analysis.

15 MR. OKRENT: Well, I think there is reason to
16 be concerned that by the time you get to the stated end
17 of this study, which is November 1984, that seismic risk
18 studies are somewhat more common than they are now, and
19 I don't know if they will be more believable. That is a
20 separate issue. Put if you are not at least having a
21 considerable amount of thinking and effort, going in
22 this direction may present a problem.

23 Fires, if I understand correctly, have been
24 looked at for many of the existing plants as part of the
25 ongoing reviews, and in some cases people have proposed

1 alternate ways of accomplishing shutdown heat removal
2 because that was simpler than changing the design with
3 regard to mixed cables, et cetera. So you may there
4 have some basis for examining the situation on a large
5 number of plants. I just don't know how many.

6 MR. BARRY: The fire studies were not
7 quantitative in terms of our probabilistic risk
8 assessment. They were descriptive.

9 MR. OKRENT: That is true. Of course, again
10 we now have a couple of fire risk estimates, also quite
11 uncertain, maybe even more uncertainty. But there will
12 be more of these that have been done by November '84.

13 So for those reasons, in the first place it
14 seems to me you may have an incomplete basis on which to
15 judge the adequacy of existing systems or the benefit or
16 whatever, and also because of the fact that by then what
17 looks now to be keeping up with the Joneses may not be
18 keeping up with the Joneses any more. I think you may
19 want to dwell on this aspect.

20

21

22

23

24

25

1 Let me give you one example that seems to me
2 may warrant some thought. When we ourselves tried to
3 look at specific reactors, casually, briefly, you know,
4 an hour or two in discussion, it seems that there are
5 some aspects of the plant where they have analyzed the
6 structures and so forth and assessed the margins, but
7 there are some aspects of the plants where are they can
8 say is we have qualified it for the SSE, we don't know
9 what it will take.

10 You can go to somebody's subjective estimate
11 of the fragilities, but I am sure you can get other
12 multiple estimates of fragility that would vary a lot.

13 MR. MARCHESE: Okay, Dr. Okrent. I think we
14 will reflect on your comment and check on the present
15 status of a number of programs that are kind of touching
16 on the seismic issue and see if we can come up with
17 better answer to your question.

18 MR. WARD: If there are indeed developments in
19 the area that Dave is suggesting, between now and time
20 for publishing the NUREG is there any particular problem
21 in factoring those into the criteria you have
22 established?

23 MR. MARCHESE: I think that is on a time scale
24 that is consistent.

25 MR. WARD: I guess I find it hard to believe

1 that the state of the art is going to be all that
2 advanced in the next two years, but you were cautioning
3 him to try to keep up with it as they are developed over
4 the next two years?

5 MR. OKRENT: Yes. I am certainly not advising
6 him to take those numbers and put them into their
7 calculations. I think they have to have enough
8 sophistication to be able to use what is being developed
9 as a minimum.

10 MR. MARCHESE: Along with developing criteria,
11 which is going to be done very early in the program, we
12 are going to start of with these tasks here
13 (indicating), which are aimed at developing improved
14 means of decay heat removal.

15 This task is divided up into three subtasks.
16 One concentrates on the phenomenological aspect, the
17 second are the engineering aspects, and the third are
18 the operational aspects. The phenomenological aspects
19 will take a good look at all of the thermal hydraulics
20 tests, information that is coming out of LOFT and
21 Semiscale, in which they are looking at modes of heat
22 transfer that involve natural convection and refluxing.

23 We are going to review that to see to what
24 extent could we extrapolate that information to
25 full-size systems for a range of plant configurations.

1 We feel that there is a lot to be learned there. We
2 think if we can count on some of these modes of heat
3 transfer, it would simplify the alternative means of
4 decay heat removal considerably.

5 For example, it would lessen the need to have
6 a large power supply to the alternative system. We will
7 also be doing calculations using existing tools, such
8 modes of heat removal as feed and bleed, which has been
9 discussed quite extensively. This will also be done as
10 part of this 2.1. The 2.2 concentrates on engineering
11 aspects of alternative means of decay heat removal. We
12 will be looking at a number of alternatives that have
13 been described in the plan, and also doing the
14 associated value impact associated with those
15 alternatives.

16 The third item concentrates on the operational
17 aspects. There is a rather substantial effort going on
18 developing emergency operator guidelines, that is,
19 developing the means for using decay heat removal
20 systems in atypical ways, and we will be doing the
21 procedures there to see if we can count on these in
22 terms of improved means of removing decay heat.

23 This item will also have thermal hydraulic
24 relationships, and the time for operator action is a
25 critical parameter that needs to be looked at. How long

1 does the operator have to take action? What is the
2 probability of the operator erring in taking corrective
3 action?

4 MR. EBERSOLE: Although it has been around for
5 many years, it has suddenly come into the limelight and
6 is being worked on intensively. The PTS problem. When
7 you say feed and bleed anymore, you better say feed and
8 bleed at reduced pressures and perhaps with a few other
9 words, too.

10 MR. MARCHESE: There is an interface we have
11 established with the people doing the pressurized
12 thermal shock issue. That program, fortunately, is
13 advanced more than ours and on schedule. They impose
14 some system restraints.

15 MR. EBERSOLE: Maybe bigger valves.

16 MR. MARCHESE: Right. So we are working
17 closely with them.

18 Now, when we get down into this area, what we
19 are doing here is we are assessing plants against the
20 quantitative criteria and against the criteria for
21 special emergencies. That is these two blocks. In this
22 block here we are trying to group plants to minimize the
23 number of plants that we have to look at.

24 We are hoping that we can group plants, that
25 is, those plants that can have a PRA for an IREP study

1 performed on them. We are hoping to group all those
2 other plants under those what we call parent plant. A
3 parent plant is one that would have an IREP study
4 performed and looking at other plants in terms of how
5 their system configurations compare with a group of
6 plants.

7 It is questionable how successful that will be
8 because, as I think I have talked about before, there is
9 considerable variability in decay heat removal systems
10 frpm plant to plant, even with the same vendors. We are
11 finding substantial variations. We have four, three and
12 two-loop plants. We have some of the older plants where
13 they use recirc configurations.

14 So to the extent we will be successful in
15 doing that will be questionable. Eventually we would
16 like to screen all the plants we look at against those
17 criteria.

18 And then finally at this stage we will be in a
19 position, having done the value impact assessment on a
20 range of alternatives, we will be in a position to rank
21 alternatives to ensure that they have a favorable value
22 impact. We will know which plants do not meet our
23 criteria. We will know that applying one or more of our
24 criteria that would meet our specifications, and we
25 would basically spell out the requirements along with

1 knowing which plants are in a bad position with respect
2 to decay heat removal.

3 MR. OKRENT: Is there a task or a subtask
4 which involves ascertaining the decay heat removal
5 system requirements for other countries that are using
6 LWRs?

7 MR. MARCHESE: Good question.

8 [Slide]

9 We have included in this program, because this
10 was also a comment that was in the ACRS letter, at the
11 end of the sentence, back about last fall, in which the
12 Staff as part of this program should take a hard look at
13 the systems in certain countries that have gone to
14 greater lengths, at least I believe, in their systems
15 they employ for decay heat removal.

16 [Slide]

17 We intend to do that with the mechanism we are
18 discussing right now. We intend to solicit information
19 first from a number of countries. We are fairly
20 familiar with the hardware that is being used. It is
21 the basis behind the design decisions that we would like
22 to get more of. We are intending to solicit that kind
23 of information from those countries, get back and then
24 arrange for visits to those countries to look at them in
25 detail.

1 We are also planning on setting up an
2 international seminar where we would invite a number of
3 countries to publish papers and host a seminar in which
4 we would publish the papers on this subject of decay
5 heat removal. So that is what we are toying around with
6 right now.

7 This shows the overall schedule for the
8 program on each of the main subtasks of the program. I
9 might add these were open areas here. This is where we
10 had started work last year and then it stopped because
11 we ran out of money after the program was not approved.
12 That period represents the internal effort that we went
13 through in terms of reconsidering a number of options
14 that resulted in the revised program that I have just
15 described.

16 We have started on developing the criteria.
17 That work has started. We have some limited work that
18 is going on grouping the plants. In about a month or
19 two we are expecting to publish a report on the grouping
20 effort.

21 The other work will get started a little later
22 on because we needed to have some time for Sandia to get
23 the subcontract work started, and the work will be
24 starting a little later on. But there will be a number
25 of interim reports that will be published on this

1 program and we intend to provide those to the committee
2 for your review and comment as well as eliciting
3 comments from the Staff.

4 The Technical Review Branch. As I mentioned,
5 we hope to get a team lined up to look at those internal
6 reports, and also Sandia is going to be setting up what
7 we call an industry peer review group. That is a group
8 that will have representatives from the vendors, A&Es
9 and utilities that have expertise in this area. They
10 will come in and we can talk about the pros and cons as
11 well as solicit their views.

12 I do feel that there are probably some efforts
13 going on in industry that are not being widely
14 publicized. I have had a lot of discussions with
15 different people and I get the feeling that the
16 utilities are thinking about this. We have also
17 discussed this plan with EPRI, trying to get them
18 involved in it. In fact, I might just talk about that
19 a minute.

20 [Slide)

21 This was a major comment, I think, we got from
22 the full committee, to encourage industry to get
23 involved. We don't want to go down a three or four year
24 program and develop requirements that industry was
25 screaming about. We are trying to get them involved in

1 the beginning.

2 So we have encouraged industry to get involved
3 in A-45. We have asked them to consider a number of
4 options. Setting up a parallel program in this area
5 probably would be ideal, or perhaps doing specific parts
6 of the Action Plan. This one here was a task we had
7 deleted from the previous plan which had gone into a
8 specific plant and looked at a specific alternative
9 system for that plant. I think industry can do a better
10 job in that area than we can. At the minimum we see
11 setting up an industry peer review group.

12 In terms of priority for development of
13 conceptual designs for improved decay heat removal
14 systems for a specific plant, this will depend on a core
15 melt frequency due to that plant and on the
16 effectiveness of improvement of decay heat removal
17 systems as a means of reducing that frequency and/or
18 capability for handling special emergency situations.

19 So this was discussed with EPRI and they are
20 thinking about it. Whether or not they take a lead is
21 questionable.

22 We also presented this plan to an industry
23 seminar that was hosted by NUS in which there were many
24 utilities, vendors, and even foreign representatives
25 there.

1 The point I am trying to make is a lot of
2 people are aware of this plan, they know we are working
3 on it, and I am sure they are not going to sit back
4 while it goes on.

5 There are a number of backup slides in your
6 package. I guess I will leave it up to you to what
7 extent you want to look at it.

8 David, did you want me to cover anything?

9 MR. WARD: Well, we have ten more minutes.

10 MR. OKRENT: Can I ask a question?

11 MR. WARD: Yes.

12 MR. SHEWMON: The Chairman will take five if
13 you run out of anything else to do.

14 MR. OKRENT: If you start using these various
15 existing PRAs, one of the things that arises, what are
16 the stated uncertainties of the PRAs? Then there is a
17 next question: Does one agree with the stated
18 uncertainties of the PRAs or is there some other
19 assessment of them? And then there is a follow-on
20 question: How do I come up with decisions in view of
21 the assessment of the uncertainties, whatever it is?

22 Now, that is not an easy subject. Anybody
23 working in the area will be, in a sense, breaking
24 ground, but if you don't deal with it at all or deal
25 with it superficially, instead of breaking ground it may

1 be the way people bury you.

2 I was wondering if you have some kind of
3 approach or is it an identified task or just what?

4 MR. MARCHESE: You may want to briefly
5 describe the approach you are going to take in putting
6 the system logic on the computer. I think that may help.

7 MR. BERRY: I agree. Among the uncertainties
8 are regarding completeness and accuracy. There are
9 different numbers that have been used in different
10 PRAs. There are different levels of completeness that
11 have been done in different PRAs. Accident sequences
12 have evolved, some of which appear to be important.

13 What we plan to do is use completed work not
14 so much off the shelf but instead to draw upon that
15 completed work to define criteria for systems in the
16 power plants for different accident events, and use that
17 existing work to define the components that are called
18 upon to meet the accident situations.

19 We plan to use this information to define the
20 logic models for how the complete PRAs can be
21 represented in a consistent format and to put all the
22 logic models and the level treatment for PRAs on the
23 same level of detail. in some cases at the expense of
24 eliminating some more detail in other elaborate PRAs and
25 adding accident sequences to things that we think today

1 do not reflect the state of the art understanding.

2 We then plan to quantify the PRAs to identify
3 what is in the currently adopted data base for frequency
4 of failure of equipment and operator actions. By doing
5 it this way, we will have, we feel, probably a
6 consistent uncertainty that will apply across the spread
7 of PRAs we are talking about. This will apply also in
8 plants we apply to these reference PRAs for further
9 analysis.

10 We are not planning, at least at this stage,
11 to use the numbers that come out of these things at face
12 value, but instead as a bases of ranking and screening
13 plants to identify ones that are worse and those that
14 don't look so bad.

15 I would think that in this program it would be
16 a logical approach in that we cannot again go off and
17 assess how much precision or lack of accuracy we have
18 with each plant that we are evaluating. Our approach is
19 to try to identify the good ones and the bad ones. For
20 the bad ones, we plan to look at alternative ways of
21 improving those plants.

22 There will be uncertainties associated with
23 the way we do our assessment, but we believe that at
24 that stage it would be up to the particular industry
25 representative utility to either attack or not attack

1 what our decisions are. And one way of attacking them,
2 of course, is to draw on uncertainties you may have to
3 attack them.

4 But otherwise, except perhaps some sensitivity
5 analyses along the lines of looking at uncertainties fo
6 other accident sequences, we are not planning to do a
7 whole lot of numbers with the range of uncertainties.
8 We will have a tool to screen them out.

9 MR. OKRENT: Well, I certainly wouldn't
10 recommend a whole lot of number punching, but I suppose
11 what you are planning to do is put these PRAs on a
12 similar basis. That wouldn't necessarily make them all
13 right or all wrong. In fact, there can still be
14 differences because there will be a set of assumptions
15 on human error that you put in and it will affect two
16 different plants in a certain way. It may not be
17 alike. It may be just what happens within the human
18 failure handbook or whatever the thing is called.

19 Now, what you are proposing to do is useful,
20 but it is sort of not directly related to the question,
21 but I will leave it for you to reflect on. I think the
22 NRC needs to begin trying to address the uncertainties
23 and not just do sensitivity studies, that is something
24 quite different, and to try to decide how they are going
25 to incorporate this uncertain state of knowledge into

1 decision making.

2 There are some things you can do
3 qualitatively, but you are inevitably going to be partly
4 on a quantitative basis if you ever talk about
5 cost-benefit decision-making.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. WARD: Andy, did you want to say something
2 about this?

3 MR. KNIEL: One way of alleviating the
4 uncertainty was in the formulation of the criteria of
5 ⁻⁴ 10 , say, for core meltdown or severe core damage,
6 and to say that in that criteria there is quite a
7 substantial fraction to cover the uncertainties. For
8 example, we can't allow 30 percent of that total simply
9 to cover that uncertainty and then allocate the
10 remaining 70 percent. Those systems that can be
11 quantified without too much uncertainty, where you are
12 dealing only with random errors, and the human operator
13 errors, and then to allow a further component to cover
14 the area where you are pretty uncertain. That is to
15 say, what we call the special circumstances for external
16 hazards, so that is an area where we know we can't
17 quantify it, but be conscious of the fact that it
18 contributes to the overall probability of core meltdown,
19 and therefore has got to be allowed for in any
20 decision-making process.

21 When you look at it this way, that part is
22 where we hope to do very much with the probabilistic
23 risk assessment. It will be less than one-third of the
24 total target. So that we would be able to have quite a
25 substantial error, I think, in that quantification. In

1 fact, two or three, without being grossly over in the
2 overall target of the analysis.

3 MR. WARD: Did you want to comment?

4 MR. OKRENT: It is a possible approach for
5 some people who will say a factor of ten is as good as,
6 you know, sort of in that case, you have a problem, but
7 I suspect that we have a question.

8 MR. WARD: Andy, on the plan to involve
9 industry, you mentioned three options, or you showed
10 three options, but what sort of schedule are you on to
11 go with one or another of those options? How are you
12 going to influence industry? What do you expect in the
13 way of cooperation from EPRI and other parts of the
14 industry?

15 MR. MARCHESE: I really can't speak to them at
16 this point in time. At least right now I don't have
17 any --

18 MR. RAY: Andy, have you contacted them? Are
19 they responsive?

20 MR. MARHESE: Yes. I have talked to them.
21 Actually, I made a trip out there to discuss this with
22 them at some length. They said they would consider it.
23 They couldn't make any commitments. I guess they felt
24 they were in kind of a precarious situation as being
25 between the utilities and the licensing people. They

1 typically do not like to get in between.

2 I have talked to the AIF and the other
3 industry people, and really have not gotten any
4 commitments. So I think we will utilize them in the
5 sense of establishing a peer review, but in terms of
6 them actually committing to do anything, we don't have
7 those commitments.

8 MR. RAY: Don't be too optimistic.

9 MR. MARCHESE: We won't.

10 MR. WARD: Is your idea to try to get them to
11 to part of the A45, or to do work broader, beyond the
12 newly defined A45? Part of the reason for cutting down
13 the task was that your management thought that some of
14 the things would rightfully be done by the industry.

15 MR. MARCHESE: We are too plant-specific.

16 MR. WARD: How are you going to get those
17 things done by industry?

18 MR. MARCHESE: Hopefully, we will be in a
19 position at the end of the program to tell them to direc
20 them to do it, because we don't have the basis. Right
21 now it is kind of a negotiating kind of thing.

22 MR. WARD: So the industry involvement of that
23 type you see as requiring them to evaluate their systems
24 against the criteria that you promulgate in two years?

25 MR. MARCHESE: Right. But what I mentioned, I

1 would like to see them get involved earlier on. To what
2 extent they will do that is questionable.

3 MR. BERRY: Our plan is, since we have had
4 difficulty in getting somebody else to carry the ball
5 for industry involvement, our plan is to establish what
6 you might say, consultant agreements or support
7 agreements, in a structural form with people in the
8 industry to which we would pass reports at different
9 milestones within the program to comment how we are
10 doing and to give us suggestions on what we can do
11 better. This was done in other work by Sandia in the
12 sabotage program where a peer review group was
13 established. About 50 members were involved. They
14 involved very senior people from utilities and others.

15 I have had some people call me to get involved
16 in such a group. In many cases, some people in the
17 industry want to be in on the ground floor of what is
18 being done.

19 MR. WARD: This is a little bit of an aside,
20 but to give an example of the procedure that was
21 followed in the sabotage program worries me a little
22 bit, because as I recall the meeting we had in March out
23 there at Sandia, we had a presentation for the
24 laboratory people on the sabotag program, and then we
25 had presentations from two of the major vendors on how

1 their advanced designs would deal with the question of
2 sabotage, and neither of those presentations paid any
3 attention as far as I can tell to the work that Sandia
4 had done.

5 MR. BERRY: Well, there is no way of assuring
6 that the industry representatives will talk among
7 themselves. We are just hoping that we can have some
8 other minds that might be sensitive to concerns we are
9 not concerned about to be interfacing with us in this
10 program. Whether or not the industry people then take
11 that insight back and use it is something we really
12 cannot guarantee. We can guarantee that we will factor
13 their comments and concerns into our evaluations.

14 MR. RAY: Dave, can we wind it up? Because we
15 are digging into Chet's time, and we have a wall at the
16 end of the day that we should not go beyond.

17 MR. WARD: Thank you, Andy. Are there any
18 other comments from the Committee members, or is there
19 any point of view that there is something in particular
20 we should be advising the Committee or the staff on with
21 regard to this task action plan? Should we write a
22 letter saying something?

23 (No response.)

24 MR. WARD: Okay. Thank you, Andy.

25 (Whereupon, at 3:10 p.m., the Committee

1 recessed, to go into executive session.)

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

In the matter of: ACRS/267th General Meeting

Date of Proceeding: July 9, 1982

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Jane N. Beach

Official Reporter (Typed)

Jane N. Beach

Official Reporter (Signature)

CONTENTIONS RELATED TO SITE SUITABILITY REPORT

<u>CONTENTION NO.</u>	<u>SUBJECT</u>
1(A)*	INCLUSION OF CDAs IN DBA
2*	SPECTRUM AND, HENCE, IN SITE
3(B)-(D)*	SUITABILITY SOURCE TERM
5(A)**	ADEQUACY OF CLINCH RIVER SITE METEOROLOGY AND POPULATION DENSITY.
5(B)	LONG-TERM EVACUATION OF NEARBY FACILITIES
11(D)(1)	10 CFR 100.11 ORGAN DOSE EQUIVALENT LIMITS

* LIMITED TO FEASIBILITY OF DESIGNING CRBR PLANT TO
MAKE CDAs SUFFICIENTLY IMPROBABLE THAT THEY CAN BE
EXCLUDED FROM DBA SPECTRUM

** CONTENTION MORE RELATED TO NEPA ALTERNATIVE SITE REVIEW

72

Natural Resources Defense Council, Inc.

1725 I STREET, N.W.
SUITE 600
WASHINGTON, D.C. 20006
202 223-8210

RECEIVED

JUL 7 PM 4 54

New York Office
122 EAST 42ND STREET
NEW YORK, N.Y. 10168
212 949-0049

Western Office
25 KEARNY STREET
SAN FRANCISCO, CALIF. 94108
415 631-6561

July 7, 1982

Dr. Paul Shewmon, Chairman
Advisory Committee on Reactor Safeguards
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Dr. Shewmon:

I understand that the full Advisory Committee on Reactor Safeguards (ACRS) is meeting tomorrow, July 8, 1982, to consider the suitability of the proposed site for the Clinch River Breeder Reactor (CRBR). I also am aware that the ACRS Subcommittee on CRBR has held several meetings this year* to discuss the CRBR licensing approach, core disruptive accidents, and the suitability of the proposed site. I have attended these meetings when possible and have reviewed the transcripts of each meeting.

As you may be aware, the Natural Resources Defense Council, Inc. (NRDC), is a principal intervenor in the CRBR licensing proceedings. Several of NRDC's contentions concern the suitability of the CRBR site and other safety issues under review by the ACRS Subcommittee on CRBR.

I am writing you to express my dismay over the inadequacy of the review to date of the CRBR licensing approach, CRBR design, and the proposed site by the ACRS Subcommittee. First, during eight meetings, the Subcommittee has invited only the Applicants and the NRC Staff to present their respective views on the CRBR safety and site issues. The Subcommittee has ignored completely the Intervenor's in this matter. Not a single member of the Subcommittee has directly sought, even informally, the views of the Intervenor's experts regarding CRBR safety and site suitability issues, even though the Subcommittee is aware of at least some of Intervenor's'

*/ Feb. 2-3; March 30-31; May 4-5; May 24-25.

New England Office: 17 ERIE DRIVE • NATICK, MA. 01760 • 617 655-2656
Public Lands Institute: 1720 RACE STREET • DENVER, CO. 80206 • 303 377-9740

Dr. Paul Shewmon
July 7, 1982
Page Two

contentions in this case (Transcripts of ACRS CRBR Subcommittee meeting, March 31, 1982, pp. 123-124). Intervenors are in sharp disagreement with both the Staff and the the Applicants on several key issues under review by the ACRS, and the ACRS should be fully aware of all points of controversy before making a decision.

Second, it has become obvious that neither the Staff nor the Applicants are being completely candid with the ACRS CRBR Subcommittee. Neither party has informed the Subcommittee of the severe limitations that have been placed, at their request, upon the scope of the safety and site suitability reviews during the LWA-1 proceedings. I suggest that the Subcommittee and full ACRS review the transcript of the Atomic Safety and Licensing Board Prehearing Conference of April 5-6, 1982, and the depositions of the Staff and Applicants taken by NRDC in June 1982.* You will find the presentations made by the Applicants and Staff to the ACRS strikingly dissimilar to those made to the Licensing Board and the Intervenors.

A third impropriety concerns Dr. William E. Kastenberg, a consultant to the ACRS CRBR Subcommittee. Under contract to the Department of Energy, one of the Applicants in this licensing proceeding, Dr. Kastenberg prepared a report entitled "Anticipated Transients Without Scram for Light Water Reactors: Implications for Liquid Metal Breeder Reactors" (co-authored with Kenneth H. Solomon), RAND Note N-1188-DOE, July 1979. In this report, Dr. Kastenberg draws conclusions about the adequacy of the CRBR design which also bear directly on the suitability of the CRBR site. As a prior consultant to DOE on matters directly related to the CRBR, Dr. Kastenberg should not now be serving as an ACRS consultant on those same issues. I do not know Dr. Kastenberg and make no allegations concerning objectivity; yet I believe he should withdraw from the ACRS CRBR Subcommittee immediately to avoid any appearance of bias or impropriety.

Fourth, at the March 31, 1982, Subcommittee meeting, Dr. Carson Mark, an ACRS member whose opinions I respect but do not necessarily agree with, stated (Transcript, p. 124):

... it will be hilarious if the intervenors bring this up -- is [sic] the possibility of interrupting operations at K25, which they obviously would like to interrupt anyway. To raise that contention will really be great fun.


* / Staff - May 6, 1982; Applicants - June 16, 21, 1982.

Dr. Paul Shewmon
July 7, 1982
Page Three

Had the ACRS shown Intervenors the courtesy of inviting our views on our contentions, I might be inclined to dismiss this statement as a little joke in bad taste but of no consequence. The fact that the ACRS continues to thumb its nose at Intervenors while making these remarks reflects a more serious problem; namely, that the ACRS displays a lack of independence and detachment necessary to function as an impartial reviewer of the CRBR.

I would be pleased to hear that you are taking steps to rectify this situation.

Sincerely,

A handwritten signature in black ink, appearing to read 'TBC', with a long horizontal flourish extending to the right.

Thomas B. Cochran, Ph.D.

APPENDIX I

ADMITTED AND RENUMBERED CONTENTIONS

1. The envelope of DBAs should include the CDA.
 - a) Neither Applicants nor Staff have demonstrated through reliable data that the probability of anticipated transients without scram or other CDA initiators is sufficiently low to enable CDAs to be excluded from the envelope of DBAs.
 - b) Neither Applicants nor Staff have established that Applicants' "reliability program" even if implemented is capable of eliminating CDAs as DBAs.
 - (1) The methodology described in the PSAR places reliance upon fault tree and event tree analysis. Applicants have not established that it is possible to obtain sufficient failure mode data pertinent to CRBR systems to validly employ these techniques in predicting the probability of CDAs.
 - (2) Applicants' projected data base to be used in the reliability program is inadequate. Applicants have not established that the projected data base encompasses all credible failure modes and human elements.
 - (3) Even if all of the data described in Applicants' projected data base is obtained, Applicants have not established that CDAs have a sufficiently low

probability that they may be excluded from the CRBR design bases.

(4) Applicants have not established that the test program used for their reliability program will be completed prior to Applicants' projected date for completion of construction of the CRBR.

2. The analyses of CDAs and their consequences by Applicants and Staff are inadequate for purposes of licensing the CRBR, performing the NEPA cost/benefit analysis, or demonstrating that the radiological source term for CRBRP would result in potential hazards not exceeded by those from any accident considered credible, as required by 10 CFR §100.1¹(a), fn. 1.
 - a) The radiological source term analysis used in CRBRP site suitability should be derived through a mechanistic analysis. Neither Applicants nor Staff have based the radiological source term on such an analysis.
 - b) The radiological source term analysis should be based on the assumption that CDAs (failure to scram with substantial core disruption) are credible accidents within the DBA envelope, should place an upper bound on the explosive potential of a CDA, and should then derive a conservative estimate of the fission product release from such an accident. Neither Applicants nor Staff have performed such an analysis.

- c) The radiological source term analysis has not adequately considered either the release of fission products and core materials, e.g. halogens, iodine and plutonium, or the environmental conditions in the reactor containment building created by the release of substantial quantities of sodium. Neither Applicants nor Staff have established the maximum credible sodium release following a CDA or included the environmental conditions caused by such a sodium release as part of the radiological source term pathway analysis.
- d) Neither Applicants nor Staff have demonstrated that the design of the containment is adequate to reduce calculated offsite doses to an acceptable level.
- e) As set forth in Contention 8(d), neither Applicants nor Staff have adequately calculated the guideline values for radiation doses from postulated CRBRP releases.
- f) Applicants have not established that the computer models (including computer codes) referenced in Applicants' CDA safety analysis reports, including the PSAR, and referenced in the Staff CDA safety analyses are valid. The models and computer codes

used in the PSAR and the Staff safety analyses of CDAs and their consequences have not been adequately documented, verified or validated by comparison with applicable experimental data. Applicants' and Staff's safety analyses do not establish that the models accurately represent the physical phenomena and principles which control the response of CRBR to CDAs.

- g) Neither Applicants nor Staff have established that the input data and assumptions for the computer models and codes are adequately documented or verified.
 - h) Since neither Applicants nor Staff have established that the models, computer codes, input data and assumptions are adequately documented, verified and validated, they have also been unable to establish the energetics of a CDA and thus have also not established the adequacy of the containment of the source term for post accident radiological analysis.
3. Neither Applicants nor Staff have given sufficient attention to CRBR accidents other than the DBAs for the following reasons:

- a) Neither Applicants nor Staff have done an adequate, comprehensive analysis comparable to the Reactor Safety Study ("Rasmussen Report") that could identify other CRBR accident possibilities of greater frequency or consequence than the accident scenarios analyzed by Applicants and Staff.
 - b) Neither Applicants' nor Staff's analyses of potential accident initiators, sequences, and events are sufficiently comprehensive to assure that analysis of the DBAs will envelop the entire spectrum of credible accident initiators, sequences, and events.
 - c) Accidents associated with core meltthrough following loss of core geometry and sodium-concrete interactions have not been adequately analyzed.
 - d) Neither Applicants nor Staff have adequately identified and analyzed the ways in which human error can initiate, exacerbate, or interfere with the mitigation of CRBR accidents.
4. Neither Applicants nor Staff adequately analyze the health and safety consequences of acts of sabotage, terrorism or theft directed against the CRBR or supporting facilities nor do they adequately analyze the programs to prevent such acts or disadvantages of any measures to be used to prevent such acts.

- a) Small quantities of plutonium can be converted into a nuclear bomb or plutonium dispersion device which if used could cause widespread death and destruction.
 - b) Plutonium in an easily usable form will be available in substantial quantities at the CRBR and at supporting fuel cycle facilities.
 - c) Analyses conducted by the Federal Government of the potential threat from terrorists, saboteurs and thieves demonstrate several credible scenarios which could result in plutonium diversion or releases of radiation (both purposeful and accidental) and against which no adequate safeguards have been proposed by Applicants or Staff.
 - d) Acts of sabotage or terrorism could be the initiating cause for CDAs or other severe CRBR accidents and the probability of such acts occurring has not been analyzed in predicting the probability of a CDA.
5. Neither Applicants nor Staff have established that the site selected for the CRBR provides adequate protection for public health and safety, the environment, national security, and national energy supplies; and an alternative site would be preferable for the following reasons:
- a) The site meteorology and population density are less favorable than most sites used for LWRs.

- (1) The wind speed and inversion conditions at the Clinch River site are less favorable than most sites used for light-water reactors.
 - (2) The population density of the CRBR site is less favorable than that of several alternative sites.
 - (3) Alternative sites with more favorable meteorology and population characteristics have not been adequately identified and analyzed by Applicants and Staff. The analysis of alternative sites in the ER and the Staff Site Suitability Report gave insufficient weight to the meteorological and population disadvantages of the Clinch River site and did not attempt to identify a site or sites with more favorable characteristics.
- b) Since the gaseous diffusion plant, other proposed energy fuel cycle facilities, the Y-12 plant and the Oak Ridge National Laboratory are in close proximity to the site an accident at the CRBR could result in the long term evacuation of those facilities. Long term evacuation of those facilities would result in unacceptable risks to the national security and the national energy supply.

6. The ER and FES do not include an adequate analysis of the environmental impact of the fuel cycle associated with the CRBR for the following reasons:
 - a) The ER and FES estimate the environmental impacts of the fuel cycle based upon a scale-down of analyses presented in the LMFBR Program Environmental Statement and Supplement for a model LMFBR and fuel cycle. The analyses of the environmental impacts of the model LMFBR and fuel cycle in the LMFBR Program Statement and Supplement are based upon a series of faulty assumptions.
 - b) The impacts of the actual fuel cycle associated with CRBR will differ from the model LMFBR and fuel cycle analyzed in the LMFBR Program Environmental Statement and Supplement. The analysis of fuel cycle impacts must be done for the particular circumstances applicable to the CRBR. The analyses of fuel cycle impacts in the ER and FES are inadequate since:
 - (1) The impact of reprocessing of spent fuel and plutonium separation required for the CRBR is not included or is inadequately assessed;

- (2) The impact of transportation of plutonium required for the CRBR is not included, or is inadequately assessed;
- (3) The impact of disposal of wastes from the CRBR spent fuel is not included, or is inadequately assessed;
- (4) The impact of an act of sabotage, terrorism or theft directed against the plutonium in the CRBR fuel cycle, including the plant, is not included or is inadequately assessed, nor is the impact of various measures intended to be used to prevent sabotage, theft or diversion.

7. Neither Applicants nor Staff have adequately analyzed the alternatives to the CRBR for the following reasons:

a) Neither Applicants nor Staff have adequately demonstrated that the CRBR as now planned will achieve the objectives established for it in the LMFBR Program Impact Statement and Supplement.

- (1) It has not been established how the CRBR will achieve the objectives there listed in a timely fashion.
- (2) In order to do this it must be shown that the specific design of the CRBR, particularly core design and engineering safety features, is sufficiently similar to a practical commercial size LMFBR that building and operating the CRBR will

demonstrate anything relevant with respect to an economic, reliable and licensable LMFBR.

- (3) The CRBR is not reasonably likely to demonstrate the reliability, maintainability, economic feasibility, technical performance, environmental acceptability or safety of a relevant commercial LMFBR central station electric plant.
- b) No adequate analysis has been made by Applicants or Staff to determine whether the informational requirements of the LMFBR program or of a demonstration-scale facility might be substantially better satisfied by alternative design features such as are embodied in certain foreign breeder reactors.
- c) Alternative sites with more favorable environmental and safety features were not analyzed adequately and insufficient weight was given to environmental and safety values in site selection.
 - (1) Alternatives which were inadequately analyzed include Hanford Reservation, Idaho Reservation (INEL), Nevada Test Site, the TVA Hartsville and Yellow Creek sites, co-location with an LMFBR fuel reprocessing plant (e.g., the Development Reprocessing Plant), an LMFBR fuel fabricating plant, and underground sites.

8. The unavoidable adverse environmental effects associated with the decommissioning of the CRBR have not been adequately analyzed, and the costs (both internalized economic costs and external social costs) associated with the decommissioned CRBR are not adequately assessed in the NEPA benefit-cost balancing of the CRBR.

- a) There is no analysis of decommissioning in the Applicants' Environmental Report;
- b) Environmental Impact Statements (EIS) related to LWRs prepared by NRC have been inadequate due in part to recently discovered omissions (see below), and the FES for the CRBR is no different;
- c) A recent report "Decommissioning Nuclear Reactors" by S. Harwood; May, K.; Resnikoff, M.; Schlenger, B.; and James, P. (New York Public Interest Research Group (N.Y. PIRG), unpublished, January, 1976) indicates that (with the exception of the Elk River reactor) the isolation period following decommissioning of power reactors has been based on the time required for Co-60 to decay to safe levels. Harwood, et al. (p. 2) believe the previous analyses are in error because they have underestimated the significance of radionuclide, Ni-59. The time period for Ni-59 to decay to safe levels is estimated by Harwood, et al. (p. 2) for LWR to be at least 1.5 million years. The economic and societal implications of this 1.5 million year decay period are at present unknown.

- d) Petitioner believes the NRC must systematically analyze all neutron activation products that may be produced in the proposed CRBR to determine the potential isolation period, following decommissioning, and then provide a comprehensive analysis of the costs (both economic and societal) of decommissioning.
9. Neither Applicants nor Staff have demonstrated that Applicants' plans for coping with emergencies are adequate to meet NRC requirements.
- a) The PSAR contains insufficient information regarding Applicants' ability to identify the seriousness and potential scope of radiological consequences of emergency situations within and outside the site boundary, including capabilities for dose projection using real-time meteorological information and for dispatch of radiological monitoring teams within the Emergency Planning Zones.
 - b) Applicants and Staff have failed to account properly for local emergency response needs and capabilities in establishing boundaries for the plume exposure pathway and ingestion pathway EPZs for the CRBR.

- c) The PSAR contains insufficient analysis of the time required to evacuate various sectors and distances within the plume exposure pathway EPZ for transient and permanent populations, nor does it note major impediments to the evacuation or taking of protective actions.
- d) The PSAR contains insufficient information to ensure the compatibility of proposed emergency plans for both onsite areas and the EPZs, with facility design features, site layout, and site location.
- e) The PSAR contains insufficient information concerning the procedures by which protective actions will be carried out, including authorization, notification, and instruction procedures for evacuations.
- f) Applicants' proposed emergency plans fail to take into account the special measures necessary to cope with a CDA, including the need for increased protective, evacuation and monitoring measures, reduced response time and special protective action levels.
- g) Applicants and Staff have failed to provide adequate assurance that the proposed emergency plans will meet the requirements and standards of 10 CFR §50.47(b).

10. Neither Applicants nor Staff have demonstrated that the facility will be provided with systems necessary to establish and maintain safe cold shutdown and maintain containment integrity that are capable of performing their functions during and after being exposed to the environmental conditions
 - a) associated with postulated accidents, as required by General Design Criterion 4, 10 CFR Part 50, Appendix A; or
 - b) created by sodium fires or the burning (or local detonation) of hydrogen.

11. The health and safety consequences to the public and plant employees which may occur if the CRBR merely complies with current NRC standards for radiation protection of the public health and safety have not been adequately analyzed by Applicants or Staff.
 - a) Neither Applicants nor Staff have shown that exposures to the public and plant employees will be as low as practicable (reasonably achievable).
 - b) Neither Applicants nor Staff have adequately assessed the genetic effects from radiation exposure including genetic effects to the general population from plant employee exposure.

- c) Neither Applicants nor Staff have adequately assessed the induction of cancer from the exposure of plant employees and the public.
- d) Guideline values for permissible organ doses used by Applicants and Staff have not been shown to have a valid basis.
 - (1) The approach utilized by Applicants and Staff in establishing 10 CFR §100.11 organ dose equivalent limits corresponding to a whole body dose of 25 rems is inappropriate because it fails to consider important organs, e.g., the liver, and because it fails to consider new knowledge, e.g., recommendations of the ICRP in Reports 26 and 30.
 - (2) Neither Applicants nor Staff have given adequate consideration to the plutonium "hot particle" hypothesis advanced by Arthur R. Tamplin and Thomas B. Cochran, or to the Karl Z. Morgan hypothesis described in "Suggested Reduction of Permissible Exposure to Plutonium and Other Transuranium Elements," Journal of American Industrial Hygiene (August 1975).

CRBR PLANT SITE SUITABILITY REVIEW

- o LWA-1s
- o PROPOSED SITE PREPARATION ACTIVITIES
- o APPROACH TO SITE SUITABILITY REVIEW
- o SITE SUITABILITY REPORT

Cecil Thomas
T2

LWA-1s

- o ISSUANCE GOVERNED BY 10 CFR 50.10(e)
- o AUTHORIZES CONDUCT OF NON-SAFETY-RELATED SITE PREPARATION ACTIVITIES
- o REQUIRES COMPLETION OF ENVIRONMENTAL AND SITE SUITABILITY REVIEWS AND PUBLIC HEARINGS THEREON
- o ACTIVITIES UNDERTAKEN ENTIRELY AT RISK OF APPLICANTS
- o ISSUANCE HAS NO BEARING ON ISSUANCE OF CONSTRUCTION PERMIT
- o ISSUANCE REQUIRES FINDING THAT
"...BASED UPON THE AVAILABLE INFORMATION AND REVIEW TO DATE, THERE IS REASONABLE ASSURANCE THAT THE PROPOSED SITE IS A SUITABLE LOCATION FOR A REACTOR OF THE GENERAL SIZE AND TYPE PROPOSED FROM THE STANDPOINT OF RADIOLOGICAL HEALTH AND SAFETY CONSIDERATIONS..." (10 CFR 50.10 (e)(2))
- o 27 ISSUED SINCE ESTABLISHED IN 1974

PROPOSED SITE PREPARATION ACTIVITIES


- o GENERAL SITE CLEARING AND GRADING
AREAS FOR ACCESS ROADS AND RAILROADS, TEMPORARY
CONSTRUCTION FACILITIES, PARKING LOT, MAIN PLANT,
COOLING TOWERS, SWITCHYARDS, STORAGE AREAS, ON-
SITE QUARRY, RUNOFF TREATMENT PONDS, CONCRETE
BATCHING AND MIXING PLANT AND BARGE UNLOADING
FACILITY.
- o EXCAVATION
ACCESS ROADS AND RAILROADS, CONCRETE BATCHING
AND MIXING PLANT, PARKING LOT, MAIN PLANT, COOLING
TOWERS, SWITCHYARDS, STORAGE AREAS, TEMPORARY CON-
STRUCTION FACILITIES AND BUILDINGS, RUNOFF TREATMENT
PONDS AND QUARRY OPERATIONS.
- o INSTALLATION OF TEMPORARY CONSTRUCTION FACILITIES
TEMPORARY ONSITE ROADS, CONSTRUCTION PARKING AREAS,
RAILROADS AND RAILROAD SPURS, CONTRACTOR WORK AND
STORAGE AREAS, CONSTRUCTION UTILITIES, CONCRETE
BATCHING AND MIXING PLANT, ONSITE QUARRY AND
CRUSHING FACILITY SEWAGE TREATMENT PLANT AND
CRAFT TOILET FACILITY, FIRE PROTECTION SYSTEM,

RUNOFF TREATMENT PONDS, STORM DRAINAGE SYSTEM,
BARGE UNLOADING SYSTEM AND CONSTRUCTION BUILDINGS.

o OTHER ACTIVITIES

PERMANENT ACCESS ROAD, RAILROAD SPUR, CONSTRUCTION
PARKING AREA, TEMPORARY ROADS, CONTRACTOR WORK
AND STORAGE AREAS, CONSTRUCTION UTILITIES,
PERMANENT MAIN SURVEY CONTROL LINES AND BENCHMARKS
AND QUARRY AND STOCKPILE AREAS.

APPROACH TO SITE SUITABILITY REVIEW



- STEP 1: DEFINE CHARACTERISTICS OF FACILITY OF GENERAL SIZE AND TYPE PROPOSED RELEVANT TO SITE SUITABILITY.
- STEP 2: DETERMINE CHARACTERISTICS OF PROPOSED SITE.
- STEP 3: ASSESS COMPATIBILITY OF SITE AND FACILITY CHARACTERISTICS.

SITE SUITABILITY REPORT

- o NUREG-0786 (UPDATES MARCH 1977 REPORT)
- o DOCUMENTS RESULTS OF STAFF'S EVALUATION OF SUITABILITY OF CLINCH RIVER SITE FOR FACILITY OF GENERAL SIZE AND TYPE AS PROPOSED CRBR PLANT.
- o CONCLUDES THAT BASED ON AVAILABLE INFORMATION AND REVIEW TO DATE, THERE IS REASONABLE ASSURANCE THAT THE CLINCH RIVER SITE IS A SUITABLE LOCATION FOR A FACILITY OF THE GENERAL SIZE AND TYPE AS THE PROPOSED CRBR PLANT FROM THE STANDPOINT OF RADIOLOGICAL HEALTH AND SAFETY CONSIDERATIONS.

BASIS FOR STAFF'S BELIEF THAT CRBR RISK
WILL BE COMPATIBLE TO LWR RISK

- o CRBR WILL MEET ALL APPLICABLE LWR REGULATORY CRITERIA AND ADDITIONAL SPECIAL CRITERIA APPROPRIATE TO LMFBRs.
- o CONSEQUENCES OF DBAs AND SSST WILL BE WITHIN 10 CFR 100 GUIDELINES.
- o DESIGN MEASURES TO MAKE SEVERE ACCIDENTS (CDAs) VERY IMPROBABLE.
- o DESIGN MEASURES TO ACCOMMODATE SEVERE ACCIDENTS (CDAs).
- o PRELIMINARY EVALUATION OF ACCIDENT RISKS.
- o PERFORMANCE OF PRA TO CONFIRM THAT CRBR MEETS SAFETY GOAL.

Morris

T3

RISK COMPARABILITY
OF
CRBRP DESIGN
WITH LWR'S

SIMILAR SOURCES AND CAUSES

- RISK DOMINANT ACCIDENT SEQUENCES INVOLVE CORE
- CORE INVENTORIES ARE COMPARABLE PER MW
(PLUTONIUM LARGER IN CRBRP)
- HEAT GENERATION VS HEAT REMOVAL IMBALANCE FOR FUEL
DAMAGE TO OCCUR

SIMILAR ACCIDENT TYPES

- INTERNAL PLANT FAILURES
- EXTERNAL FORCES
- SABOTAGE

Rumble
T4

CORE DISRUPTION

INTERNAL PLANT FAILURE

LOCA

FLOW BLOCKAGE

LOHS

FAILED FUEL PROPAGATION

TRANSIENTS

PRIMARY COOLANT SYSTEM RESPONSE TO CORE DISRUPTION

MECHANICAL FAILURES - HEAD RELEASE

THERMAL FAILURES - RELEASE TO REACTOR CAVITY

CONTAINMENT RESPONSE

- CONTAINMENT ENVIRONMENTAL FACTORS AFFECTING FISSION PRODUCT BEHAVIOR AND EQUIPMENT OPERATION

PRESSURE

TEMPERATURE

AIRBORNE MATERIALS

- CONTAINMENT FAILURE MODES

FAILURE TO ISOLATE

EARLY FILTERED VENTING

OVERPRESSURE FAILURE

PROMPT FAILURES

LOSS OF ALL OFF-SITE ELECTRIC POWER AT CRBRP

HEAT TRANSPORT SYSTEMS

- STEAM GENERATOR AUXILIARY HEAT REMOVAL SYSTEM
STEAM DUMPING (SHORT TERM)
PROTECTED AIR-COOLED CONDENSERS
- DIRECT HEAT REMOVAL SYSTEM

ELECTRICAL POWER

- TURBINE BYPASS SYSTEM
- DIESEL GENERATORS
- BATTERY POWER (SEVERAL HOURS)

CDA SEQUENCE CLASSES FOR SCOPING CRBR RISKS
FROM INTERNAL INITIATORS

INITIATION

PRIMARY SYSTEM
FAILURE

CONTAINMENT
FAILURE

GENERIC CORE
DISRUPTION

SMALL OR LARGE
HEAD RELEASE
&
THERMAL FAILURE

NONE

GENERIC CORE
DISRUPTION

SMALL OR LARGE
HEAD RELEASE
&
THERMAL FAILURE

OVERPRESSURE

GENERIC CORE
DISRUPTION

SMALL HEAD
RELEASE
&
THERMAL FAILURE

CONTAINMENT
ISOLATION

GENERIC CORE
DISRUPTION

LARGE HEAD RELEASE
&
THERMAL FAILURE

CONTAINMENT
ISOLATION

A SCOPING COMPARISON OF SEVERE ACCIDENT
RISKS DUE TO CRBRP WITH COMPARABLE SIZE
LWRs AT CRBRP SITE

- . USED CRAC CODE TO PERFORM THE CALCULATIONS TO GAIN A PERSPECTIVE OF RELATIVE RISKS OF CRBRP AND LWRs.
- . THE CRBRP ACCIDENT SEQUENCES, PROBABILITIES, AND RELEASE FRACTIONS WERE BASED ON SCOPING ESTIMATES DESCRIBED TO YOU BY ED RUMBLE.
- . THE BWR AND THE PWR ACCIDENT SEQUENCES, PROBABILITIES, AND RELEASE FRACTIONS WERE THE SAME AS USED IN OUR ACCIDENT EVALUATIONS FOR ENVIRONMENTAL STATEMENTS. (RSS REBASE-LINE)
- . THE CORE INVENTORIES CORRESPONDED TO THE POWER LEVEL OF 1121 MWt. (INCLUDING THE CONSIDERATION OF THE DIFFERENCES IN CRBRP AND LWR CORES).
- . FOR THIS COMPARISON WE USED THE CRBRP SITE CHARACTERISTICS (METEOROLOGY, POPULATION DISTRIBUTION, ETC.)

CONCLUSIONS OF THE COMPARISON

- . BASED ON THE PRELIMINARY SCOPING ANALYSIS THE STAFF FINDS THAT THE CRBRP RISKS WILL NOT EXCEED THE RISKS FROM COMPARABLE LWRs.
- . FURTHER WORK ON A FULL PRA IS IN PROGRESS AND WILL ESTABLISH BETTER ESTIMATES OF PROBABILITIES AND RELEASES AS DISCUSSED BY ED RUMBLE.

CRBR DOSE GUIDELINES

	LWR*		CRBR**	
	CP STAGE DOSE (REM)	OL STAGE DOSE (REM)	CP STAGE DOSE (REM)	OL STAGE DOSE (REM)
THYROID	150	300	150	300
WHOLE BODY	20	25	20	25
BONE SURFACE	-	-	150	300
RED BONE MARROW	-	-	37.5	75
LUNG	-	-	37.5	75
LIVER	-	-	75	150

ADDITIONAL GUIDELINES

Mortality risk equivalent whole body dose from any postulated design basis accident (on a calculated dose basis) should be no greater than the mortality risk equivalent whole body dose value of 10 CFR Part 100 for an LWR (i.e., 34 rem whole body risk equivalent at the O.L. stage, and 24.5 rem whole body risk equivalent at the CP stage).

*BASIS: 10 CFR PART 100

**BASIS: SAME AS LWR FOR THYROID AND WHOLE BODY. THE LUNG AND BONE DOSES ARE BASED ON THE CRITICAL ORGAN CONCEPT.

Site Suitability Source Term Release from Core[†]

<u>RADIOACTIVE SPECIES</u>	<u>LWR* SOURCE TERM</u>	<u>CRBR** SOURCE TERM</u>
NOBLE GASES	100%	100%
HALOGENS	50%	50%
SOLIDS	1%	1%
PLUTONIUM	-	1%

* BASIS: TID 14844 NON-MECHANISTIC SOURCE TERM (i.e., SEQUENCE OF EVENTS NOT TAKEN INTO ACCOUNT).

** BASIS: SAME BASIS AS FOR LWR SOURCE TERM WITH INCLUSION OF PLUTONIUM

† FISSION PRODUCTS ARE ASSUMED TO BE RELEASED FROM THE CORE TO THE PRIMARY CONTAINMENT. THE ASSUMPTION IS THAT THE SOURCE TERM FISSION PRODUCTS ARE INSTANTANEOUSLY RELEASED TO AND UNIFORMLY DISTRIBUTED THROUGHOUT THE PRIMARY CONTAINMENT AND AVAILABLE FOR RELEASE TO THE ENVIRONMENT (EXCEPT IN THE CASE OF THE IODINES IT IS ASSUMED THAT ONE-HALF OF THE IODINES RELEASED ARE INSTANTANEOUSLY PLATED OUT AND THE REMAINDER IS UNIFORMLY DISTRIBUTED THROUGHOUT THE PRIMARY CONTAINMENT AND AVAILABLE FOR RELEASE TO THE ENVIRONMENT).

SITE SUITABILITY SOURCE TERM ASSUMPTIONS AND DOSE RESULTS

Power Level		1121 Mwt
Core Fraction Released to Containment:		
Noble Gases		100%
Iodines		50%
Solid Fission Products		1%
Plutonium		1%
Primary Containment Free Volume		$3.7 \times 10^6 \text{ ft}^3$
Primary Containment Leak Rate		0.1%/day
Bypass Fraction		0.001%/day
Annulus Filtration System Filter Efficiencies:		
Particulate Iodine, Solids and Plutonium		99%
Elemental and Organic Iodine		95%
Annulus Filtration System Flow Rates, cfm:		
Exhaust		3000
Recirculation		11000
Aerosol Fallout Coefficients in Containment, hr ¹		
0-2 hours		.0853
2-8 hours		.0659
8-24 hours		.0571
Minimum Exclusion Area Boundary Distance		670 meters
Low Population Zone		4023 meters
Atmospheric Dispersion Parameters (5% meteorology), sec/m ³		
0-2 hours at exclusion area boundary		1.22×10^{-3}
0-8 hours at LPZ		1.2×10^{-4}
8-24 hours at LPZ		8.4×10^{-5}
24-96 hours at LPZ		3.9×10^{-5}
96-720 hours at LPZ		1.4×10^{-5}
Dose Consequences, rem		
	Exclusion Area	Low Population Zone
Thyroid	12	7
Whole Body	0.6	0.3
Lung	0.4	0.4
Bone Surface	10	9
Red Bone Marrow	2.4	2.1
Liver	1.1	1.0
Mortality Risk Equivalent Whole Body	1.7	1.1

EVENTS ANALYZED IN
DESIGN BASIS FLOOD DETERMINATION

PROBABLE MAXIMUM FLOOD

SEISMIC FAILURE

OBE CONCURRENT WITH $\frac{1}{2}$ PMF

SSE CONCURRENT WITH 25-YEAR FLOOD

Lee
T7

PROBABLE MAXIMUM PRECIPITATION

RAINFALL DEPTH (FOR A PARTICULAR SIZE BASIN)
THAT APPROACHES THE UPPER LIMIT THAT THE PRESENT
CLIMATE CAN PRODUCE.

PMP - CRBR

9 DAY STORM

*3-DAY ANTECEDENT STORM -	6.8 INCHES
*3-DAY DRY PERIOD -	0
*3-DAY MAIN STORM -	17.2 INCHES
*TOTAL	<u>24.0 INCHES</u>

*AVERAGE ON WATERSHED ABOVE WATTS BAR

FLOOD ELEVATIONS

PLANT GRADE ELEVATION = 815

<u>EVENT</u>	<u>CRBR ELEVATION</u>	
	<u>MILE 16</u>	<u>MILE 18</u>
PMF	776.0	777.5
OBE FAILURE WITH $\frac{1}{2}$ PMF	798.2	804.3
SSE FAILURE WITH 25-YR. FLOOD	790.5	796.3




Figure 2.4-30 Norris Dam - Analysis for OBE & One Half PMF-Assumed Condition of Dam After Failure

SENSITIVITY RUNS

<u>POSTULATED FAILURE MODE</u>	<u>CRBR</u> <u>ELEVATION</u>	
	<u>MILE 16</u>	<u>MILE 18</u>
OBE CONDITIONS WITH $\frac{1}{2}$ PMF		
INSTANT VANISHMENT OF ENTIRE DAM (NO DEBRIS)	811.0	818.0
VANISHMENT OF THREE BLOCKS (38-40) TO GROUND LEVEL	802.2	808.4
OVERTURNING OF BLOCKS 33-44 (665-FOOT WIDTH) WITH 945 DEBRIS LEVEL	802.6	808.9
OVERTURNING OF BLOCKS 37-43 (370-FOOT WIDTH) WITH 925 DEBRIS LEVEL	805.3	811.9

CRBRP SITE SUITABILITY

BRIEFING FOR:


ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)

SITE DESCRIPTION


PRESENTED BY:

HENRY B. PIPER
PUBLIC SAFETY
CRBRP PROJECT OFFICE

JULY 9, 1982




TL



8

Figure 2.1-1 LOCATION OF CLINCH RIVER SITE IN RELATION TO COUNTIES AND STATE



10

Figure 2.2-4 URBAN AREAS WITHIN 10 MILES OF THE CRBRP SITE.



Figure 2.1-5 TOPOGRAPHY OF THE CRBRP SITE




Figure 2.2-10 INDUSTRIAL PLANTS WITHIN 10-MILE RADIUS OF THE CRBRP SITE.

1980 RESIDENT POPULATION DISTRIBUTION

0 TO 10 MILES FROM THE CRBRP SITE

<u>Direction</u>	<u>Distance (miles)</u>						<u>10-mile Total</u>
	<u>0 to 1</u>	<u>1 to 2</u>	<u>2 to 3</u>	<u>3 to 4</u>	<u>4 to 5</u>	<u>5 to 10</u>	
N	0	0	0	0	0	2,000	2,000
NNE	0	0	0	0	0	4,400	4,400
NE	0	0	0	0	0	4,500	4,500
ENE	10	10	0	0	0	3,900	3,920
E	20	30	50	10	20	4,300	4,430
ESE	20	30	50	140	120	2,300	2,660
SE	0	20	50	140	110	7,200	7,520
SSE	0	30	40	90	320	2,000	2,480
S	0	50	50	120	160	1,100	1,480
SSW	10	30	50	80	90	800	1,060
SW	20	80	80	110	140	700	1,130
WSW	20	70	80	140	340	2,800	3,450
W	0	130	100	110	500	4,400	5,240
WNW	10	80	170	10	60	4,400	4,730
NW	30	30	0	10	40	1,700	1,810
NNW	10	0	0	0	120	1,100	1,230
Total	150	590	720	960	2,020	47,600	52,040
Cumulative Total	150	740	1,460	2,420	4,440	52,040	

1980 RESIDENT POPULATION DISTRIBUTION

10 TO 50 MILES FROM THE CRBRP SITE*

Direction	Distance (miles)					50-mile Total
	10 to 20	20 to 30	30 to 40	40 to 50		
10-mile Total						
N	4,700	2,200	6,400	7,000	22,300	
NNE	9,100	6,300	17,500	10,300	47,600	
NE	22,100	10,900	6,200	5,100	48,800	
ENE	22,100	100,900	41,800	12,800	181,520	
E	34,400	102,600	34,600	21,300	197,330	
ESE	9,600	43,100	7,000	4,800	67,160	
SE	5,300	6,300	3,700	2,300	25,120	
SSE	5,200	2,400	4,100	6,500	20,680	
S	5,600	7,200	6,200	5,500	25,980	
SSW	3,300	11,200	22,800	9,900	48,260	
SW	2,200	3,600	6,000	10,500	23,430	
WSW	3,400	5,000	6,500	7,200	25,550	
W	12,300	2,600	11,100	4,800	36,040	
WNW	7,800	3,100	5,500	4,500	25,630	
NW	2,400	2,100	3,900	7,900	18,110	
NNW	3,800	1,700	5,600	5,000	17,330	
Total	153,300	311,200	188,900	125,400	830,840	
Cumulative Total	205,340	516,540	705,440	830,840		




Figure 2.1-6


COMPARATIVE POPULATION DISTRIBUTION SURROUNDING NUCLEAR PLANT SITES

Amend. 15
Apr. 1976

CRBRP SITE SUITABILITY

BRIEFING FOR:

**ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)**



**SITE SUITABILITY SOURCE TERMS
AND NON-RADIOLOGICAL EFFECTS
OF SODIUM REACTION PRODUCTS
AEROSOLS**

PRESENTED BY:

GEORGE H. CLARE

**LICENSING MANAGER, CRBRP PROJECT
WESTINGHOUSE**

ADVANCED REACTORS DIVISION

JULY 9, 1982

*Clare
T5*

THE CRBRP SITE SUITABILITY SOURCE TERM IS COMPARABLE TO THAT USED FOR SITING FOREIGN LMFBRs

PERCENT RELEASED FROM PRIMARY COOLANT BOUNDARY

	CRBRP (USA)	CDFR (UK)	MONJU (JAPAN)
• NOBLE GASES	100	100	100
• HALOGENS (AIRBORNE)	50 (25)	50	10
• SOLIDS	1	1	1
• FUEL	1	1	1

NO EQUIVALENT TO THE SSST IS KNOWN TO BE USED IN FRANCE OR GERMANY (FRG).

THE NON-RADIOLOGICAL EFFECTS OF SODIUM REACTION PRODUCT AEROSOLS HAVE BEEN CONSIDERED

- $\text{Na} + \text{O}_2 \rightarrow \text{NaO}_x$
 $\text{NaO}_x + \text{H}_2\text{O} \rightarrow \text{NaOH} (+ \text{O}_2)$
 $\text{NaOH} + \text{CO}_2 \rightarrow \text{Na}_2\text{CO}_3 (+ \text{H}_2\text{O})$
- EFFECTS ON SAFETY RELATED EQUIPMENT ARE ADDRESSED
 - ENVIRONMENTAL QUALIFICATION
 - CONTROL ROOM
 - AEROSOL MITIGATION FEATURES

**ANY OFFSITE CONCENTRATION OF SODIUM
REACTION PRODUCT AEROSOLS
WILL BE LOW**

ASSUME:

- STEAM GENERATOR BUILDING DESIGN BASIS LEAK
- 100% OF SPRAY REACTION PRODUCTS AIRBORNE
- ONLY ESF MITIGATION IS EFFECTIVE

EVALUATION:

- DEPLETION IN THE SGB; HAA-3 (440 LB/5 MIN)
- 50% METEOROLOGY; 1×10^{-3} SEC/m³
- DEPLETION DURING TRANSPORT; 1/100

RESULTS: 7 MILLIGRAMS (NaOH) PER CUBIC METER

CRBRP SITE SUITABILITY


BRIEFING FOR:

ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS (ACRS)

HYDROLOGY

- PROBABLE MAXIMUM FLOOD R. LEE, TVA
- IMPACT OF NORRIS DAM SITE T. J. ABRAHAM,
TVA
- EFFECT OF CORE MELT
ON GROUNDWATER H. B. PIPER,
CRBRP/PO

JULY 9, 1982



T8

LIQUID PATHWAYS EVALUATION

RADIOLOGICAL CONSEQUENCES ASSOCIATED WITH RELEASE OF RADIOACTIVE MATERIAL TO THE GROUNDWATER FOLLOWING AN HCDA HAVE BEEN EVALUATED IN:

- CRBRP-3, VOLUME 2, "HYPOTHETICAL CORE DISRUPTIVE ACCIDENT CONSIDERATIONS IN CRBRP; ASSESSMENT OF THERMAL MARGIN BEYOND THE DESIGN BASE"
- ER QUESTION/RESPONSE E240.2R

ANALYSIS OF MELTED-FUEL-MASS LEACH

CRBRP LIQUID PATHWAY ANALYSES SIMILAR TO WASH-1400, WITH THE FOLLOWING EXCEPTIONS:

- CRBRP SITE SPECIFIC FLOW SYSTEM DATA WAS USED
- NO WATER WAS ASSUMED TO BE AVAILABLE FROM THE REACTOR CONTAINMENT VESSEL TO ADD TO GROUNDWATER AT MELT-THROUGH

COMPARISON OF CALCULATED GROUNDWATER EFFLUENT CONCENTRATIONS FOR MOST SIGNIFICANT ISOTOPES AT ENTRANCE TO CLINCH RIVER

NUCLIDE	CRBRP		LWR		MPC (10 CFR 20)
	CONCENT. ($\mu\text{ci/cc}$)	TIME OF PEAK (YRS)	CONCENT. ($\mu\text{ci/cc}$)	TIME OF PEAK (YRS)	
• Sr-90	3.6×10^{-9}	336	7.1×10^{-4}	5.9	3×10^{-7}
• Tc-99	6.8×10^{-8}	45	3.6×10^{-6}	.9	2×10^{-4}
• Pu-239	7.1×10^{-7}	3580	8.0×10^{-7}	535	5×10^{-6}

CRBRP/NRC LIQUID PATHWAY GENERIC STUDY (NUREG-0440) COMPARISON

- CRBRP CONTAINED RADIONUCLIDE SOURCE SIGNIFICANTLY LESS THAN SOURCE USED IN NUREG-0440
 - GENERALLY 2 TO 40 TIMES LESS
- SITE SPECIFIC PARAMETERS ARE SIMILAR.
 - NUREG-0440 USED CLINCH-TENNESSEE-OHIO-MISSISSIPPI RIVER SYSTEM

RADIONUCLIDE SOURCE TERM COMPARISON

ISOTOPE	NUREG-0440 LWR CORE INVENTORY (Ci)	CRBRP CORE INVENTORY END OF CYCLE (Ci)	RATIO <u>NUREG VALUE</u> <u>CRBRP VALUE</u>
• ^3H	5.9×10^4	2.34×10^4	3
• ^{89}Sr	9.2×10^7	1.60×10^7	6
• ^{90}Sr	6.1×10^6	6.79×10^5	9
• ^{90}Y	6.4×10^6	7.11×10^5	9
• ^{91}Y	1.2×10^8	2.04×10^7	6
• ^{95}Nb	1.7×10^8	3.48×10^7	5
• ^{103}Ru	1.4×10^8	5.26×10^7	3
• $^{103\text{m}}\text{Rh}$	1.4×10^8	5.26×10^7	3
• ^{105}Rh	6.7×10^7	3.85×10^7	2
• ^{106}Rh	7.6×10^7	1.96×10^7	4
• ^{106}Ru	5.1×10^7	1.96×10^7	3
• $^{110\text{m}}\text{Ag}$	3.5×10^5	4.33×10^4	8

RADIONUCLIDE SOURCE TERM COMPARISON

ISOTOPE	NUREG-0440 LWR CORE INVENTORY (Ci)	CRBRP CORE INVENTORY END OF CYCLE (Ci)	RATIO <u>NUREG VALUE</u> CRBR VALUE
• ^{111m}Ag	4.3×10^6	2.57×10^6	2
• ^{113m}Cd	1.0×10^3	1.91×10^3	1/2
• ^{115m}Cd	6.2×10^4	3.55×10^4	2
• ^{115}Cd	8.8×10^5	5.46×10^5	2
• ^{123}Sn	9.4×10^5	3.62×10^5	3
• ^{125}Sn	1.5×10^6	7.58×10^5	2
• ^{125}Sb	7.4×10^5	3.96×10^5	2
• ^{125m}Te	2.5×10^5	7.88×10^4	3
• ^{127}Sb	8.3×10^6	3.76×10^6	2
• ^{127m}Te	1.6×10^6	5.40×10^5	3
• ^{127}Te	8.1×10^6	3.69×10^6	2
• ^{129m}Te	6.6×10^6	2.65×10^6	2
• ^{129}Te	3.9×10^7	9.71×10^6	4

RADIONUCLIDE SOURCE TERM COMPARISON

ISOTOPE	NUREG-0440 LWR CORE INVENTORY (Ci)	CRBRP CORE INVENTORY END OF CYCLE (Ci)	RATIO <u>NUREG VALUE</u> CRBR VALUE
• ^{129}I	2.9	6.7×10^{-1}	4
• ^{131}I	1.0×10^8	3.00×10^7	3
• ^{132}Te	1.4×10^8	4.00×10^7	4
• ^{133}I	1.9×10^8	5.15×10^7	4
• ^{134}Cs	2.1×10^7	6.60×10^5	32
• ^{136}Cs	5.8×10^6	2.65×10^6	2
• ^{137}Cs	8.6×10^6	1.70×10^6	5
• ^{140}Ba	1.8×10^8	4.19×10^7	4
• ^{140}La	1.8×10^8	4.22×10^7	4
• ^{141}Ce	1.7×10^8	4.29×10^7	4
• ^{144}Ce	1.1×10^8	2.02×10^7	5
• ^{144}Pr	1.1×10^8	2.02×10^7	5
• ^{238}Pu	2.5×10^5	3.29×10^5	4/5
• ^{239}Np	2.1×10^9	9.48×10^8	2

SITE SPECIFIC PARAMETER COMPARISON

PARAMETER	CRBRP SITE SPECIFIC VALUE	NUREG 0440 VALUE
• LENGTH IN FEET FROM CORE BASEMAT MELT POINT TO RIVER.	1600	1500
• AVERAGE SOIL POROSITY	.3	.2
• PERMEABILITY (FLOW VELOCITY)	2000 FT/YR	2446 FT/YR

CONCLUSION

RADIOLOGICAL CONSEQUENCES ASSOCIATED WITH RELEASE OF RADIOACTIVE MATERIAL TO THE GROUNDWATER FOLLOWING A HCDA ARE:

- LESS THAN THOSE HYPOTHESIZED FOR AN LWR IN NUREG-0440 AND WASH-1400
- COMPARABLE TO 10 CFR 20 EFFLUENT RELEASE LIMITS FOR ROUTINE RELEASES

NORRIS BACKGROUND INFORMATION

GRAVITY DAM APPROXIMATELY 1800 FEET WITH A MAXIMUM HEIGHT OF 265 FEET.



THE DAM IS A SOLID CONCRETE MASS CONCRETE STRUCTURE WITH AN OVERFLOW SPILLWAY, SLUICES AND NONOVERFLOW SECTIONS ON EACH SIDE.

THE DAM WAS COMPLETED IN 1936.

NORRIS DAM WAS ORIGINALLY DESIGNED FOR AN EARTHQUAKE ACCELERATION OF 0.1g THROUGHOUT ITS HEIGHT.



TO ENSURE THE SAFETY OF ITS DAM TVA HAS A WELL DEVELOPED INSPECTION AND MAINTENANCE PROGRAM.

Abraham
T7



TYPICAL SPILLWAY SECTION

TYPICAL NON-OVERFLOW SECTION



*SHEAR S, THAT IS REQ'D FOR Q=1 IS CALCULATED FROM SHEAR-FRICTION FORMULA
 $Q = \frac{\Sigma H}{0.65 \Sigma V + SA}$ A IS ASSUMED TO BE ENTIRE AREA


NOTES: 1. VERTICAL ACCELERATION OF NON-OVERFLOW AND SPILLWAY AT BASE ASSUMED TO BE 0.09g. BY DYNAMIC ANALYSIS, AMPLIFICATION OF ACCELERATION ABOVE THE BASE WAS DETERMINED TO BE 0.14g AT THE TOP FOR THE NON-OVERFLOW SECTION AND 0.14g AT THE TOP FOR THE SPILLWAY

2. HORIZONTAL ACCELERATION OF NON-OVERFLOW AND SPILLWAY AT BASE ASSUMED TO BE 0.09g. BY DYNAMIC ANALYSIS, AMPLIFICATION OF ACCELERATION ABOVE THE BASE WAS DETERMINED TO BE 0.64g AT THE TOP FOR THE NON-OVERFLOW SECTION AND 0.75g AT THE TOP FOR THE SPILLWAY.


3. SPILLWAY GATES ASSUMED OPEN FOR THIS ANALYSIS.

ΣV	ΣH	$\frac{\Sigma H}{\Sigma V}$	AVG SHEAR FOR Q=1	S REQD FOR Q=1	MAX FS	$\frac{\Sigma MR}{\Sigma NO}$	VERT. SHEAR ON PLANE A-A
112,616K	143,567K	1.28	850PSI (ENT. BASE)	490PSI*	566 PSI	1.25	247PSI
2101K	276K	1.33	850PSI (ENT. BASE)	490PSI*	1220 PSI	1.03	535PSI



Figure 2.4-29. Norris Dam-Spillway & Non-Overflow Results of Analysis for OBE + 1/2 PMP



TYPICAL SPILLWAY SECTION



TYPICAL NON-OVERFLOW SECTION



NOTES: 1. VERTICAL ACCELERATION OF NON-OVERFLOW AND SPILLWAY AT BASE ASSUMED TO BE 0.06g. BY DYNAMIC ANALYSIS, AMPLIFICATION OF ACCELERATION ABOVE THE BASE WAS DETERMINED TO BE 0.14g AT THE TOP FOR THE NON-OVERFLOW SECTION AND 0.14g AT THE TOP FOR THE SPILLWAY.

2. HORIZONTAL ACCELERATION OF NON-OVERFLOW AND SPILLWAY AT BASE ASSUMED TO BE 0.09g. BY DYNAMIC ANALYSIS, AMPLIFICATION OF ACCELERATION ABOVE THE BASE WAS DETERMINED TO BE 0.64g AT THE TOP FOR THE NON-OVERFLOW SECTION AND 0.75g AT THE TOP FOR THE SPILLWAY.

3. SPILLWAY GATES ASSUMED OPEN FOR THIS ANALYSIS.

*SHEAR, S, THAT IS REQ'D FOR Q = 1 IS CALCULATED FROM SHEAR-FRICTION FORMULA

$$Q = \frac{0.65 \sum V + SA}{\sum H} \cdot A \text{ IS ASSUMED TO BE ENTIRE AREA}$$

**SHEAR S REQ'D FOR Q = 1 CONSIDERING PORTION OF BASE IN COMPRESSION (NO TENSION) INSTEAD OF ENTIRE AREA.

$\sum V$	$\sum H$	$\frac{\sum H}{\sum V}$	AVG S REQ'D FOR Q=1	MAX FS	$\frac{\sum MR}{\sum MO}$	VERT. SHEAR ON PLANE A-A
112 516K	143 587K	1.28	85psi (177) (BASE) (psi)	566 psi	1.75	247psi

$\sum V$	$\sum H$	$\frac{\sum H}{\sum V}$	AVG S REQ'D FOR Q=1	MAX FS	$\frac{\sum MR}{\sum MO}$	VERT. SHEAR ON PLANE A-A
2101K	2786K	1.33	85psi (415) (BASE) (psi)	1220 psi	1.03	535psi

Figure 2.4-29. Norris Dam-Spillway & Non-Overflow Results of Analysis for OBE + 1/2 PMF

CONSERVATISM IN THE SEISMIC ANALYSIS

1. THE CONSERVATIVE PSEUDO STATIC METHOD OF STABILITY ANALYSIS WAS USED. THIS ASSUMES A SUSTAINED RATHER THAN OSCILLATING FORCE.
2. THE AMPLIFICATION OF THE BASE ACCELERATION WAS TAKEN AS THE MAXIMUM FOR ALL PARTS OF STRUCTURE ALTHOUGH THEY ALL DO NOT OCCUR SIMULTANEOUSLY ONLY.
3. THE CONCRETE WAS ASSUMED INCAPABLE OF TAKING ANY TENSION.
4. ALTHOUGH THE DAM WAS ASSUMED TO OVERTURN THERE IS INSUFFICIENT ENERGY GENERATED OVER THE SHORT DURATION OF THE LOAD TO OVERTURN THE STRUCTURE.
5. CONSERVATIVE JUDGEMENT WAS USED IN ASSESSMENT OF FAILURE RECOGNIZING NUCLEAR PLANT SITING.
6. TVA'S ASSESSMENT OF NORRIS REGARDING ITS SAFETY PROGRAM IS THAT NORRIS CAN SAFELY WITHSTAND THE MAXIMUM CREDITABLE EARTHQUAKE.
7. OTHER GRAVITY DAMS HAVE BEEN SUBJECTED TO MUCH HIGHER EARTHQUAKE ACCELERATIONS AND HAVE NOT FAILED. FOR EXAMPLE, KONYA DAM IN INDIA. TVA MADE AN ANALYSIS OF KONYA USING THE PSEUDO-STATIC METHOD. RESULTS INDICATED THE DAM TO BE STRESSED MUCH WORSE THAN NORRIS.

NRC STAFF STATUS REPORT
ON UNRESOLVED SAFETY ISSUE (UBI), TASK A-45
"SHUTDOWN DECAY HEAT REMOVAL REQUIREMENTS"

FOR THE
267TH ACRS MEETING
JULY 9, 1982

ANDREW R. MARCHESE
TASK MANAGER FOR A-45
GENERIC ISSUES BRANCH
DIVISION OF SAFETY TECHNOLOGY, NRR
PHONE: 49-24712

T10

710

PRESENTATION OUTLINE

- PURPOSE
- OBJECTIVE
- BACKGROUND ON TASK A-45
- UPDATE ON TASK A-45
- MAIN ELEMENTS OF TASK ACTION PLAN A-45

PURPOSE

- THE OVERALL PURPOSE OF TASK A-45 IS TO EVALUATE THE ADEQUACY OF CURRENT LICENSING DESIGN REQUIREMENTS TO ENSURE THAT NUCLEAR POWER PLANTS DO NOT POSE UNACCEPTABLE RISK DUE TO FAILURE TO REMOVE SHUTDOWN DECAY HEAT

OBJECTIVES

- TO DEVELOP A COMPREHENSIVE AND CONSISTENT SET OF DECAY HEAT REMOVAL (DHR) SYSTEM REQUIREMENTS FOR EXISTING AND FUTURE LWRs.
- TO EVALUATE ALTERNATIVE MEANS OF DHR AND OF DIVERSE "DEDICATED" SYSTEMS TO DEAL WITH A BROADER SPECTRUM OF TRANSIENT AND ACCIDENT SITUATIONS

BACKGROUND

- COMMISSIONERS APPROVED SDHR REQUIREMENTS AS AN USI (REF., MEMO, S. J. CHILK TO W. J. DIRCKS, SECY-80-325, DATED DECEMBER 24, 1980)
- TASK MANAGER ASSIGNED TO TASK A-45 ON FEBRUARY 17, 1981
- NUREG-0705 (MARCH 1981), "IDENTIFICATION OF NEW USIs RELATING TO NUCLEAR POWER PLANTS - SPECIAL REPORT TO CONGRESS, "PROVIDED AN EXPANDED DISCUSSION OF TASK A-45
- MEMORANDUM, A. R. MARCHESE TO T. E. MURLEY, "ACTIVITIES RELATED TO TASK A-45, "DATED APRIL 8, 1981
- DRAFT TASK ACTION PLAN (TAP) FOR TASK A-45 ISSUED ON MAY 22, 1981
- REVISION 0 OF TAP A-45 (APPROVED BY DSF DIRECTOR) ISSUED ON OCTOBER 7, 1981
- REVISION 1 OF TAP A-45 ISSUED ON JUNE 2, 1982

UPDATE ON TASK A-45 SINCE ACRS FULL COMMITTEE MEETING OF SEPTEMBER 10, 1981

- A TASK ACTION PLAN (REV. 0) FOR USI A-45 WAS ORIGINALLY APPROVED BY DIRECTOR, DST, ON OCTOBER 7, 1981
- THIS PLAN, WHICH AUTHORIZED A FOUR-YEAR PROGRAM WITH A COMPLETION DATE OF OCTOBER 1985, WAS NOT APPROVED BY DIRECTOR, NRR
- WE HAVE REASSESSED THIS PROGRAM TO DETERMINE IF THE PRIMARY GOALS COULD BE REALIZED ON A SHORTER SCHEDULE
- WE HAVE NOW DETERMINED THAT OUR PRIMARY OBJECTIVES CAN BE OBTAINED WITH A 30 MONTH PROGRAM
- WE ESTIMATE THAT A DRAFT NUREG REPORT CONTAINING OUR PROPOSED RECOMMENDATIONS INCLUDING ANY PROPOSED NEW REQUIREMENTS, ALONG WITH THE SUPPORTING TECHNICAL AND COST/BENEFIT BASIS, WILL BE AVAILABLE BY NOVEMBER 1984

UPDATE (CONT.)

● REDUCED SCHEDULE OBTAINED BY:

- DELETING MOST OF WORK ON FUTURE PLANTS, ALTHOUGH ACCEPTANCE CRITERIA FOR DHRS FOR FUTURE PLANTS WILL BE DEVELOPED
- QUANTITATIVE ACCEPTANCE CRITERIA WILL BE BASED ON FREQUENCY OF CORE MELT DUE TO DHRS FAILURES RATHER THAN OVERALL RISK
- RELYING MORE ON INDUSTRY TO PERFORM MORE PLANT-SPECIFIC EVALUATIONS OF ALTERNATIVE DHRS WHERE THE STAFF CAN SHOW SIGNIFICANT IMPROVEMENTS IN SAFETY
- HAVING ONE CONTRACTOR WITH OVERALL RESPONSIBILITY FOR PROJECT MANAGEMENT, TECHNICAL DIRECTION AND INTEGRATION, INCLUDING SELECTION AND MANAGEMENT OF SUBCONTRACTORS

UPDATE (CONT.)

● STEPS ACHIEVED TO START WORK ON PROGRAM:

- RECEIVED APPROVAL BY DIRECTOR, NRR ON MARCH 15, 1982
- RECEIVED APPROVAL BY SENIOR CONTRACT REVIEW BOARD ON APRIL 9, 1982
- IMPLEMENTED A CONTRACT ON MAY 3, 1982 WITH SANDIA AS THE LEAD LAB. TO BEGIN WORK & PREPARE A DETAILED PROPOSAL.
- ISSUED REVIEW 1 OF TAP A-45 ON JUNE 2, 1982 THAT IS CONSISTENT WITH THE ABOVE

MAIN ELEMENTS OF A-45 TASK ACTION PLAN-REVISION 1

- DEVELOP ACCEPTANCE CRITERIA FOR ASSESSMENT OF DHRs
 - DEVELOP QUANTITATIVE CRITERIA FOR EXISTING PLANTS
 - DEVELOP QUANTITATIVE CRITERIA FOR FUTURE PLANTS
 - DEVELOP QUALITATIVE CRITERIA FOR "SPECIAL EMERGENCIES"
- DEVELOP MEANS FOR IMPROVEMENT OF DHRs
 - PHENOMENOLOGICAL STUDIES
 - CONCEPTUAL DESIGN STUDIES
 - OPERATIONAL ASPECTS OF ALTERNATIVE DHR SYSTEMS
- ASSESS ADEQUACY OF DHRs IN EXISTING LWRs
 - ASSESS ADEQUACY OF DHRs IN SELECTED EXISTING PLANTS ON PROBABILISTIC BASIS
 - ASSESS ADEQUACY OF DHRs IN EXISTING PLANTS ON DETERMINISTIC BASIS
 - GROUP OTHER EXISTING PLANTS FOR ASSESSMENT OF ADEQUACY OF DHRs
- DEVELOP PLAN FOR IMPLEMENTING NEW REQUIREMENTS (E.G., PREPARE NUREG, REG. GUIDE)





Figure 1. Inter-Relation of Sub-Tasks in Task Action Plan A-45

Figure B-1
 DETAILED SCHEDULE FOR TASK A-45
 "SHUTDOWN DECAY HEAT REMOVAL REQUIREMENTS"



BACK - UP
SLIDES

DEFINITIONS USED IN TASK ACTION PLANT A-45

- REFLOOD PHASE (REP): THE INITIAL PHASE OF A SEVERE LOCA, WHEN THE OBJECTIVE IS TO REFLOOD THE REACTOR
- SHUTDOWN DECAY HEAT REMOVAL (SDHR) PHASE: THE TRANSITION FROM REACTOR TRIP TO "HOT SHUTDOWN," EXCLUDING THE INITIAL REFLOODING PHASE IN A SEVERE LOCA
- RESIDUAL HEAT REMOVAL (RHR) PHASE: THE TRANSITION FROM "HOT SHUTDOWN" TO "COLD SHUTDOWN" AND MAINTAINING COLD SHUTDOWN CONDITIONS
- DECAY HEAT REMOVAL (DHR) PHASE: SDHR AND RHR PHASES COMBINED

DEFINITION OF DECAY HEAT REMOVAL SYSTEM

IN THE CONTEXT OF TASK A-45, DHR SYSTEM IS DEFINED AS THOSE COMPONENTS AND SYSTEMS REQUIRED TO MAINTAIN PRIMARY AND/OR SECONDARY COOLANT INVENTORY CONTROL AND TO TRANSFER HEAT FROM THE REACTOR COOLANT SYSTEM AND CONTAINMENT BUILDING TO AN ULTIMATE HEAT SINK FOLLOWING SHUTDOWN OF THE REACTOR FOR NORMAL EVENTS, OFF-NORMAL TRANSIENT EVENTS (E.G., LOSS OF OFFSITE POWER, LOSS OF MAIN FEED-WATER) AND SMALL LOCAs (I.E., 1/2" TO 2"). DHR SYSTEM DOES NOT ENCOMPASS THOSE EMERGENCY CORE COOLING COMPONENTS AND SYSTEMS REQUIRED ONLY TO MAINTAIN COOLANT INVENTORY AND DISSIPATE HEAT DURING THE FIRST 10 MINUTES FOLLOWING MEDIUM OR LARGE LOCAs.

MAIN ELEMENTS OF A-45 TASK ACTION PLAN (Oct '81)

- DEVELOP INTERIM ACCEPTANCE CRITERIA FOR ASSESSMENT OF DHRS
 - EXISTING PLANTS
 - FUTURE PLANTS
 - DEVELOPMENT OF INTERIM QUALITATIVE CRITERIA FOR "SPECIAL EMERGENCIES"

- DEVELOP MEANS FOR IMPROVEMENT OF SDHRS
 - PHENOMENOLOGICAL STUDIES
 - (1) REVIEW OF CURRENT THERMAL-HYDRAULICS RESEARCH RELEVANT TO SDHRS
 - (2) ON-GOING REVIEW OF THERMAL-HYDRAULICS RESEARCH
 - CONCEPTUAL DESIGN STUDIES (GENERIC)
 - OPERATIONAL ASPECTS OF ALTERNATIVE SDHR SYSTEMS


- ASSESS ADEQUACY OF DHRS IN EXISTING AND FUTURE LWRs
 - CATEGORIZE PLANTS AS "EXISTING" OR "FUTURE"
 - ASSESS ADEQUACY OF DHRS IN SELECTED EXISTING PLANTS ON RISK BASIS
 - GROUP OTHER EXISTING PLANTS FOR ASSESSMENT OF ADEQUACY OF DHRS
 - ASSESS ADEQUACY OF DHRS IN SELECTED FUTURE PLANTS
 - ASSESS ADEQUACY OF DHRS IN EXISTING PLANTS ON DETERMINISTIC BASIS

- DEVELOP AND COST IMPROVED DHRS IN SELECTED PLANTS
 - SELECTED EXISTING PLANTS
 - SELECTED FUTURE PLANTS


- RECONSIDER ADEQUACY OF ACCEPTANCE CRITERIA FOR DHRS
 - REVIEW INTERIM DHRS ACCEPTANCE CRITERIA AND TECHNICAL REQUIREMENTS, REVISE IF NECESSARY

- DEVELOP PLAN FOR IMPLEMENTING NEW REQUIREMENTS (E.G., PREPARE NUREG, REG. GUIDE)

Figure 1. Inter-Relation of Sub-Tasks in Task Action Plan A-45 - (Oct. 1982)



Legend:



X - Identifies Sub-Task Number

MAIN ELEMENTS OF A-45 TASK ACTION PLAN (Feb-82)

● DEVELOP ~~INTERIM~~ ACCEPTANCE CRITERIA FOR ASSESSMENT OF DHRs

- EXISTING PLANTS
- FUTURE PLANTS
- DEVELOPMENT OF ~~INTERIM~~ QUALITATIVE CRITERIA FOR "SPECIAL EMERGENCIES"

● DEVELOP MEANS FOR IMPROVEMENT OF SDHRs

- PHENOMENOLOGICAL STUDIES
 - (1) REVIEW OF CURRENT THERMAL-HYDRAULICS RESEARCH RELEVANT TO SDHRs
 - (2) ON-GOING REVIEW OF THERMAL-HYDRAULICS RESEARCH
- CONCEPTUAL DESIGN STUDIES (GENERIC)
- OPERATIONAL ASPECTS OF ALTERNATIVE SDHR SYSTEMS

● ASSESS ADEQUACY OF DHRs IN EXISTING ~~AND FUTURE~~ LWRs

- ~~- CATEGORIZE PLANTS AS "EXISTING" OR "FUTURE"~~
- ASSESS ADEQUACY OF DHRs IN SELECTED EXISTING PLANTS ~~ON RISK BASIS~~
- GROUP OTHER EXISTING PLANTS FOR ASSESSMENT OF ADEQUACY OF DHRs
- ~~- ASSESS ADEQUACY OF DHRs IN SELECTED FUTURE PLANTS~~
- ASSESS ADEQUACY OF DHRs IN EXISTING PLANTS ON DETERMINISTIC BASIS

~~● DEVELOP AND COST IMPROVED DHRs IN SELECTED PLANTS~~

- ~~SELECTED EXISTING PLANTS~~
- ~~SELECTED FUTURE PLANTS~~

● ~~RECONSIDER ADEQUACY OF ACCEPTANCE CRITERIA FOR DHRs~~

- ~~- REVIEW INTERIM DHRs ACCEPTANCE CRITERIA AND TECHNICAL REQUIREMENTS,~~
- ~~REVISE IF NECESSARY~~

● DEVELOP PLAN FOR IMPLEMENTING NEW REQUIREMENTS (E.G., PREPARE NUREG, REG. GUIDE)

DISCUSSION WITH EPRI ON INDUSTRY INVOLVEMENT IN TASK A-45

- ENCOURAGE INDUSTRY COOPERATION AND INVOLVEMENT IN TASK A-45
- OPTIONS TO CONSIDER:
 - INDUSTRY SETS UP ITS OWN PARALLEL PROGRAM, OR
 - INDUSTRY DOES SPECIFIC PARTS OF A-45 ACTION PLAN (E.G., SUB-TASK 4 ON PLANT-SPECIFIC DESIGN OF ALTERNATIVE DHRS)
 - INDUSTRY PEER REVIEW GROUP FOR TASK A-45 MILESTONE REPORTS
- PRIORITY FOR DEVELOPMENT OF CONCEPTUAL DESIGNS FOR IMPROVED DHRS FOR A SPECIFIC PLANT WILL DEPEND ON:
 1. CORE MELT FREQUENCY DUE TO THAT PLANT AND ON THE EFFECTIVENESS OF IMPROVEMENT OF DHRS AS A MEANS OF REDUCING THAT FREQUENCY, AND/OR
 2. CAPABILITY FOR HANDLING "SPECIAL EMERGENCY" SITUATIONS