

ATTACHMENT 3 TO TXX-94044
AFFECTED TECHNICAL SPECIFICATION PAGES
(NUREG-1468) REVISED BY ALL APPROVED
LICENSE AMENDMENTS

INDEX

ADMINISTRATIVE CONTROLS

<u>SECTION</u>	<u>PAGE</u>
6.5.3 TECHNICAL REVIEW AND CONTROLS.....	6-11
6.6 REPORTABLE EVENT ACTION.....	6-13
6.7 SAFETY LIMIT VIOLATION.....	6-13
6.8 PROCEDURES AND PROGRAMS.....	6-13
6.9 REPORTING REQUIREMENTS.....	6-17
6.9.1 ROUTINE REPORTS.....	6-17
Startup Report.....	6-17
Annual Reports.....	6-18
Annual Radiological Environmental Operating Report.....	6-19
Semiannual Radioactive Effluent Release Report.....	6-19
Monthly Operating Reports.....	6-19
Core Operating Limits Report.....	6-20
6.9.2 SPECIAL REPORTS.....	6-22
6.10 RECORD RETENTION.....	6-22
6.11 RADIATION PROTECTION PROGRAM.....	6-23
6.12 HIGH RADIATION AREA.....	6-23
6.13 PROCESS CONTROL PROGRAM (PCP).....	6-25
6.14 OFFSITE DOSE CALCULATION MANUAL (ODCM).....	6-25

DEFINITIONS

MEMBER(S) OF THE PUBLIC

1.18 MEMBER(S) OF THE PUBLIC shall include all persons who are not occupationally associated with the plant. This category does not include employees of the licensee, its contractors, or vendors. Also excluded from this category are persons who enter the site to service equipment or to make deliveries. This category does include persons who use portions of the site for recreational, occupational, or other purposes not associated with the plant.

OFFSITE DOSE CALCULATION MANUAL

1.19 The OFFSITE DOSE CALCULATION MANUAL (ODCM) shall contain the methodology and parameters used in the calculation of offsite doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring Alarm/Trip Setpoints, and in the conduct of the Environmental Radiological Monitoring Program. The ODCM shall also contain (1) the Radioactive Effluent Controls and Radiological Environmental Monitoring Programs required by Section 6.8.3 and (2) descriptions of the information that should be included in the Annual Radiological Environmental Operating and Semi-annual Radioactive Effluent Release Reports required by Specifications 6.9.1.3 and 6.9.1.4.

OPERABLE - OPERABILITY

1.20 A system, subsystem, train, component or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified function(s), and when all necessary attendant instrumentation, controls, electrical power, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its function(s) are also capable of performing their related support function(s).

OPERATIONAL MODE - MODE

1.21 An OPERATIONAL MODE (i.e., MODE) shall correspond to any one inclusive combination of core reactivity condition, power level, and average reactor coolant temperature specified in Table 1.2.

PHYSICS TESTS

1.22 PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation: (1) described in Chapter 14.0 of the FSAR, (2) authorized under the provisions of 10 CFR 50.59, or (3) otherwise approved by the Commission.

PRESSURE BOUNDARY LEAKAGE

1.23 PRESSURE BOUNDARY LEAKAGE shall be leakage (except steam generator tube leakage) through a nonisolable fault in a Reactor Coolant System component body, pipe wall, or vessel wall.

RADIOACTIVE EFFLUENTS

3/4.11.1 LIQUID EFFLUENTS

LIQUID HOLDUP TANKS*

LIMITING CONDITION FOR OPERATION

3.11.1 The quantity of radioactive material contained in each unprotected outdoor tank shall be limited to less than or equal to 10 Curies, excluding tritium and dissolved or entrained noble gases.

APPLICABILITY: At all times.

ACTION:

- a. With the quantity of radioactive material in any unprotected outdoor tank exceeding the above limit, immediately suspend all additions of radioactive material to the tank, within 48 hours reduce the tank contents to within the limit, and describe the events leading to this condition in the next Semiannual Radioactive Effluent Release Report, pursuant to Specification 6.9.1.4.
- b. The provisions of Specifications 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.11.1 The quantity of radioactive material contained in each of the unprotected outdoor tanks shall be determined to be within the above limit by analyzing a representative sample of the tank's contents at least once per 7 days when radioactive materials are being added to the tank.

*Tanks included in this specification are those unprotected outdoor tanks that are not surrounded by liners, dikes, or walls capable of holding the tank contents and that do not have tank overflows and surrounding area drains connected to the Liquid Radwaste Treatment System.

RADIOACTIVE EFFLUENTS

GAS STORAGE TANKS

LIMITING CONDITION FOR OPERATION

3.11.2.2 The quantity of radioactivity contained in each gas storage tank shall be limited to less than or equal to 200,000 Curies of noble gases (considered as Xe-133 equivalent).

APPLICABILITY: At all times.

ACTION: (Units 1 and 2)

- a. With the quantity of radioactive material in any gas storage tank exceeding the above limit, immediately suspend all additions of radioactive material to the tank, within 48 hours reduce the tank contents to within the limit, and describe the events leading to this condition in the next ~~Semi~~⁷Annual Radioactive Effluent Release Report, pursuant to Specification 6.9.1.4.
- b. The provisions of Specifications 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.11.2.2 The quantity of radioactive material contained in each gas storage tank shall be determined to be within the above limit at least once per 92 days when radioactive materials are being added to the tank.

ADMINISTRATIVE CONTROLS

ANNUAL REPORTS (Continued)

- b. The results of specific activity analyses in which the primary coolant exceeded the limits of Specification 3.4.7. The following information shall be included: (1) Reactor power history starting 48 hours prior to the first sample in which the limit was exceeded (in graphic and tabular format); (2) Results of the last isotopic analysis for radioiodine performed prior to exceeding the limit, results of analysis while limit was exceeded and results of one analysis after the radioiodine activity was reduced to less than limit. Each result should include date and time of sampling and the radioiodine concentrations; (3) Clean-up flow history starting 48 hours prior to the first sample in which the limit was exceeded; (4) Graph of the I-131 concentration ($\mu\text{Ci/gm}$) and one other radioiodine isotope concentration ($\mu\text{Ci/gm}$) as a function of time for the duration of the specific activity above the steady-state level; and (5) The time duration when the specific activity of the primary coolant exceeded the radioiodine limit.

ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT*

6.9.1.3 The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted before May 1 of each year. The report shall include summaries, interpretations, and analysis of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in (1) the ODCM, and (2) Sections IV.B.2, IV.B.3, and IV.C of Appendix I to 10 CFR 50.

SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT**

prior to May 1

6.9.1.4 The Semiannual Radioactive Effluent Release Report covering the operation of the unit during the previous 6 months of operation shall be submitted within 60 days after January 1 and July 1 of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be (1) consistent with the objectives outlined in the ODCM and PCP and (2) in conformance with 10 CFR 50.36a and Section IV.B.1 of Appendix I to 10 CFR 50.

year

MONTHLY OPERATING REPORTS

6.9.1.5 Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the PORVs or safety valves,

*A single submittal may be made for a multiple unit station.

**A single submittal may be made for a multi-unit station. The submittal should combine those sections that are common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit.

ADMINISTRATIVE CONTROLS

6.13 PROCESS CONTROL PROGRAM (PCP)

Changes to the PCP:

- a. Shall be documented and records of reviews performed shall be retained as required by Specification 6.10.30. This documentation shall contain:
 - 1) Sufficient information to support the change together with the appropriate analyses or evaluations justifying the change(s) and
 - 2) A determination that the change will maintain the overall conformance of the solidified waste product to existing requirements of Federal, State, or other applicable regulations.
- b. Shall become effective after review and acceptance by the SORC and the approval of the Vice President, Nuclear Operations.

6.14 OFFSITE DOSE CALCULATION MANUAL (ODCM)

Changes to the ODCM:

- a. Shall be documented and records of reviews performed shall be retained as required by Specification 6.10.30. This documentation shall contain:
 - 1) Sufficient information to support the change together with the appropriate analyses or evaluations justifying the change(s) and
 - 2) A determination that the change will maintain the level of radioactive effluent control required by 10 CFR 20.106, 40 CFR 190, 10 CFR 50.36a, and Appendix I to 10 CFR 50 and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations.
- b. Shall become effective after review and acceptance by the SORC and the approval of the Vice President, Nuclear Operations.
- c. Shall be submitted to the Commission in the form of a complete, ~~legible~~ copy of the entire ODCM as a part of or concurrent with the ~~Semi-annual~~ Radioactive Effluent Release Report for the period of the report in which any change to the ODCM was made. Each change shall be identified by markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (e.g., month/year) the change was implemented.