

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | IN | J | S | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ | 5  
9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE JO 57 CAT 58

CON'T  
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 7 | 2 | 7 | 0 | 5 | 2 | 6 | 8 | 1 | 8 | 0 | 6 | 2 | 4 | 8 | 1 | 9  
7 8 60 61 DOCKET NUMBER 66 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
0 2 | While performing Surveillance Procedure SP(O)4.6.1.3 on the 100' Containment Air Lock,

0 3 | it was determined that the leak rate exceeded the limit of 0.05 La at the design

0 4 | pressure of 47.0 psig as required by Technical Specification 3.6.1.3b. Action

0 5 | Statement 3.6.1.3 was entered at 0530 hours.

0 6 | \_\_\_\_\_

0 7 | \_\_\_\_\_

0 8 | \_\_\_\_\_

0 9 | SYSTEM CODE: S A (11) CAUSE CODE: E (12) CAUSE SUBCODE: X (13) COMPONENT CODE: P E N E T R (14) COMP SUBCODE: A (15) VALVE SUBCODE: Z (16)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

(17) LER NO REPORT NUMBER: 8 1 (21) EVENT YEAR: 8 1 (22) SEQUENTIAL REPORT NO.: 0 5 7 (23) OCCURRENCE CODE: 0 3 (24) REPORT TYPE: L (25) REVISION NC: 0 (26)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKE'N: B (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0 0 0 0 (22) ATTACHMENT SUBMITTED: Y (23) NPRD-4 FORM SUB.: N (24) PRIME COMP. SUPPLIER: L (25) COMPONENT MANUFACTURER: C 3 1 0 (26)  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
1 0 | The outer door was not properly aligned, and therefore would not maintain pressure.

1 1 | The outer door was centered and tested satisfactorily. Action Statement 3.6.1.3 was

1 2 | terminated at 2006 hours.

1 3 | \_\_\_\_\_

1 4 | \_\_\_\_\_

1 5 | FACILITY STATUS: D (28) % POWER: 0 0 0 (29) OTHER STATUS: N/A (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: Surveillance Test (32)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 6 | ACTIVITY CONTENT RELEASED: Z (33) Z (34) AMOUNT OF ACTIVITY: N/A (35) LOCATION OF RELEASE: N/A (36)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7 | PERSONNEL EXPOSURES NUMBER: 0 0 0 (37) TYPE: Z (38) DESCRIPTION: N/A (39)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 8 | PERSONNEL INJURIES NUMBER: 0 0 0 (40) DESCRIPTION: N/A (41)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z (42) DESCRIPTION: N/A (43)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 0 | PUBLICITY ISSUED: N (44) DESCRIPTION: 8209020082 810624 PDR ADOCK 05000272 S PDR (45) NRC USE ONLY  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER: J. J. Espey PHONE: 609-935-0998