

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NOS. 50-327 AND 50-328

TENNESSEE VALLEY AUTHORITY

NOTICE OF ISSUANCE OF AMENDMENTS

FACILITY OPERATING LICENSE NOS. DPR-77 AND DPR-79

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 14 to Facility Operating License No. DPR-77 and Amendment No. 5 to Facility Operating License DPR-79, issued to Tennessee Valley Authority (licensee) for the Sequoyah Plant, Units 1 and 2 (the facilities) located in Hamilton County, Tennessee.

The amendments were authorized by telephone on June 18, 1982, and were confirmed by letter on June 23, 1982. The amendments authorize, for a period of 30 days, changes in the requirement that containment sump level instrumentation be operable for automatic switchover from Refueling Water Storage Tank to containment sump and accident monitoring. These amendments were issued on an expedited basis to permit both Sequoyah units to remain at 100 percent power.

The application for the amendments complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendments. Prior public notice of these amendments was not required since the amendments do not involve a significant hazards consideration.

The Commission has determined that the issuance of these amendments will not result in any significant environmental impact and that pursuant to 10 CFR 51.5(d)(4) environmental impact statements, or negative declarations and environmental impact

~~appraisals need not be prepared in connection with issuance of these amendments.~~

OFFICE	.....	.....	.....	.....	.....	.....
SURNAME	....	B208030029	B20707	.....	.....	.....
		PDR	ADOCK	05000327	.....	.....
DATE	....	P	PDR	.....	.....	.....

For further details with respect to this action, see (1) Tennessee Valley Authority letter dated June 18, 1982, (2) Amendment No. 14 to Facility Operating License No. DPR-77 with Appendix A Technical Specification page changes; (3) Amendment No. 5 to Facility Operating License No. DPR-79 with Appendix A Technical Specification page changes; and (4) the Commission's related Safety Evaluation.

All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, N.W., Washington, D. C., and the Chattanooga Hamilton County Bicentennial Library, 1001 Broad Street, Chattanooga, Tennessee 37402. A copy of Amendment No. 14 and Amendment No. 5 may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 7<sup>th</sup> day of July 1982.

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor G. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing

*no to family only*

OFFICE	LA:DL:AB #4	DL:LB #4	OELD	DL:LB #4	AD:DL	
SURNAME	MDuncan/hmc	Chahle	<i>Chahle</i>	Adensam	R. T. ESCO	
DATE	6/28/82	6/28/82	6/28/82	7/1/82	7/1/82	

July 7, 1982

AMENDMENT NO. 14 TO FACILITY OPERATING LICENSE DPR-77 - SEQUOYAH UNIT 1  
AMENDMENT NO. 5 TO FACILITY OPERATING LICENSE DPR-79 - SEQUOYAH UNIT 2

DISTRIBUTION w/enclosures:

Dr-~~cket~~ No. 50-369  
LB #4 r/f  
R. Birkel  
M. Duncan  
I&E  
OELD  
E. Adensam  
R. Hartfield, MPA  
R. Diggs, ADM  
D. Eisenhut/R. Purple  
J. Souder  
T. Barnhart (4)

bcc w/enclosures:

NRC PDR  
Local PDR  
NSIC  
TERA  
A. Rosenthal, ASLAB  
ASLBP  
ACRS (16)  
W. Jones (10)