

August 6, 1982

DMB 016

DISTRIBUTION
Docket File

Docket No. 50-312

Mr. J. J. Mattimoe
Assistant General Manager and
Chief Engineer
Sacramento Municipal Utility
District
6201 S Street
P. O. Box 15830
Sacramento, California 95813

NRC PDR
L PDR
ORB#4 Rdg
DEisenhut
OELD
AEOD
IE-2
ACRS-10
TBarnhart-4
LSchneider
OGC
OPA
DBrinkman
RDiggs
ASLAB
MPadovan
RIngram
Gray File+4

Dear Mr. Mattimoe:

SUBJECT: AMENDMENT NO. 38 TO THE RANCHO SECO TECHNICAL SPECIFICATIONS -
SURVEILLANCE TESTING

The Commission has issued the enclosed Amendment No. 38 to Facility Operating License No. DPR-54 for the Rancho Seco Nuclear Generating Station. The amendment consists of changes to the Technical Specifications (TSs) in response to your May 24, 1982 letter. Based upon our review, we have modified the TSs as agreed to by members of your staff.

This amendment temporarily changes the TS Section 1.2.8 definition of refueling interval from 18 months to 24 months for specified surveillance requirements. Upon startup from the next refueling outage, this temporary definition will expire. Additionally, this amendment changes TS Section 4.6.3 to permit diesel generator overhaul to be delayed until the next refueling outage.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

ORIGINAL SIGNED BY

Mark L. Padovan, Project Manager
Operating Reactors Branch #4
Division of Licensing

Enclosures:

- 1. Amendment No. 38
- 2. Safety Evaluation
- 3. Notice

cc w/enclosures:

See next page

OFFICER	See next page	ORB#4:DL	ORB#4:DL	CORB#4:DL	AP:OR:DL	OELD
SURNAM	8209020211 820806 PDR ADOCK 05000312 P PDR	ram	MPadovan;cf	JStolz	GKainas	RBlack
DATE		/82	8/6/82	8/6/82	8/6/82	8/6/82