

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | F | L | S | L | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

CON'T
0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 3 | 5 | 7 | 0 | 7 | 2 | 5 | 8 | 2 | 3 | 0 | 8 | 2 | 4 | 8 | 2 | 9
7 8 9 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | During normal full power operation, Channel "MA" Containment Isolation
0 3 | Signal (CIS) Radiation Monitor failed low. The "MA" CIS Radiation
0 4 | Monitor Channel was declared inoperable in accordance with TS 3.3.2.1.
0 5 | The MA Channel was repaired, functionally tested and restored to
0 6 | operable status within the time limits specified. The other three
0 7 | channels remained operable throughout the event, so the health and
0 8 | safety of the public were not affected.

0 9 | S | D | 11 | E | 12 | G | 13 | I | N | S | T | R | U | 14 | X | 15 | Z | 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
17 | LER/RO REPORT NUMBER | 8 | 2 | 21 22 | 0 | 3 | 0 | 24 26 | 0 | 3 | 28 29 | L | 30 | 0 | 32
18 | ACTION TAKEN | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 37 40 | N | 23 | N | 24 | A | 25 | X | 9 | 9 | 9 | 25
13 34 35 36 37 38 39 40 41 42 43 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | The "MA" CIS Radiation Monitor Channel failed due to a failed "Action-Pak"
1 1 | Model 4300-159 V/I converter. Specific cause for the converter failure
1 2 | was not determined. Immediate corrective action was to replace the
1 3 | Action-Pak converter. No further action was required.

1 4 | _____
1 5 | E | 3 | 0 | 9 | 9 | 29 | NA | 30 | R | 31 | Operator Observation | 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 8 | 0 | 0 | 0 | 40 | NA | 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
1 9 | Z | 42 | NA | 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
2 0 | N | 44 | NA | 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER Paul Pace PHONE (305) 552-3654