

Appendix

NOTICE OF VIOLATION

Consumers Power Company

Docket No. 50-155

As a result of the inspection conducted on June 12 through July 30, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

Technical Specification Section 6.8.1 states: "Written procedures shall be established,...for all...systems...and safety actions defined in the Big Rock Point Quality List."

Contrary to the above, the licensee failed to provide written procedures to control reactor coolant system level on June 16th and 17th, 1982.

This is a Severity Level V violation (Supplement I.E.).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

\_\_\_\_\_  
Dated

\_\_\_\_\_  
R. C. Knop, Chief  
Projects Branch 1

8209020239 820817  
PDR ADOCK 05000155  
Q PDR